

STATE OF SOUTH DAKOTA SUMMARY REPORT

2025 Building Codes Review



Board of Technical Professions
Rapid City, South Dakota

As Prepared By:

Model Building Code Workgroup of the Board of Technical Professions

October 2025

Table of Contents

Table of Contents	Page 2
Introduction	Page 3
Workgroup Members	Page 4
Workgroup Meeting Schedule	Page 4
Significant Changes from the 2021 International Building Code To the 2024 International Building Code	Pages 5 – 13
Significant Changes from the 2021 International Energy Conservation Code To the 2024 International Energy Conservation Code	Pages 14 – 22
Significant Changes from the 2021 International Property Maintenance Code To the 2024 International Property Maintenance Code	Pages 23
Significant Changes from the 2021 International Residential Code To the 2024 International Residential Code	Pages 24 – 28
Executive Summary	Page 29
Bibliography	Page 29
Appendix A	International Code Council Significant Changes To the 2024 International Building Code
Appendix B	International Code Council Significant Changes To the 2024 International Energy Conservation Code
Appendix C	International Code Council Significant Changes To the 2024 International Residential Code
Appendix D	National Association of Home Builders Estimated Costs of 2024 IRC Code Changes

Introduction

This report has been prepared for the people of the great State of South Dakota and is intended to be a guide to updating relevant codes that may be adopted by communities. The information contained in this report has been reviewed and prepared by a workgroup as established by the South Dakota Board of Technical Professions pursuant to SDCL 11-10-13. The statute tasked the workgroup with the following:

Beginning in the year 2024, and every three years thereafter, the Board of Technical Professions created under § 36-18A-14 shall convene a workgroup to review the latest edition of the model national codes referenced in this chapter. The workgroup shall consist of two local building code officials, one person engaged in the business of constructing multi-family housing, one person engaged in the business of constructing single-family housing, one person engaged in the business of constructing commercial buildings, one licensed architect, and one licensed professional engineer. The workgroup shall identify any significant revisions to the current edition of each model code and evaluate the impact of the revisions on the quality, safety, and cost of construction in the state. The workgroup may recommend amendments to this chapter, including updates to the current edition of any model code referenced in this chapter and alternatives and exceptions to such codes. The workgroup shall report its findings and recommendations to the Board of Technical Professions within six months from the date of the workgroup's first meeting, and the Board shall publish the report on its website. The workgroup shall dissolve and cease to exist upon the completion of its report to the Board.

The specific codes referenced in Title 11, Chapter 10 are:

- 11-10-5 2021 Edition of the International Building Code
- 11-10-7 2009 Edition of the International Energy Conservation Code
- 11-10-11 2021 Edition of the International Property Maintenance Code
- 11-10-12 2021 Edition of the International Residential Code

Workgroup Direction:

1. Identify any significant revisions to the current edition of each model code.
2. Evaluate the impact of the revisions on the quality, safety, and cost of construction in the state
 - a. The value of cost implications is completely dependent upon the individual projects and their various levels of complexity. The intent of this review is to advise on the cost implications, not to assess the actual value. For reference, the entire changes report as published by the International Code Council is included in Appendix C.
 - b. Appendix D includes a Home Builders Association publication that does provide some cost guidance per specific types of residential structures.
3. Recommend amendments, including updates to the current edition of any model code referenced in this chapter (11) and alternatives and exceptions to such codes.
4. The Workgroup will report findings and recommendations to the SDBoTP.

2024 Workgroup Members:

Two Local Building Code Officials

Mr. Neil King
Sioux Falls Building Official
Sioux Falls, SD

Mr. Trent Mohr
Deadwood Building Official

Multi-Family Housing

Single Family Housing

Mr. Andy Pulford
Lloyd Companies Construction

Mr. Joel Ingle
C-Lemme Companies, LLC

Commercial Buildings

Architect

Mr. Neal Schlottman, PE
SECO Construction (retired)

Mr. Jeffrey Nelson, AIA NCARB
Falls Architecture Studio, LLC

Engineer

Department of Labor and Regulation

Mr. Rob Maher, PE
Structural Engineering Associates, Inc.

Ms. Jodi Aumer
Director of Professional Licensing

The workgroup established a monthly meeting schedule to review appropriate information as related to each of the referenced codes. Sessions have been scheduled as follows:

First meeting of the Workgroup:

April 9, 2025

Subsequent meetings:

May 14, 2025

June 11, 2025

July 9, 2025

August 13, 2025

September 24, 2025

October 8, 2025

The information presented in this report will be presented in the order in which it is referenced in Title 11, Chapter 10.

2021 Edition of the International Building Code

Updated to

2024 Edition of the International Building Code

Every three years, the International Conference of Building Officials provides revisions and updates to the previous code publication year. The information below is items within the code that, in the eyes of the committee, have cost implications with regard to revisions from the 2021 International Building Code to the 2024 International Building Code.

The value of cost implications is completely dependent upon the individual projects and their various levels of complexity. It is the intent of this review only to advise that there are cost implications and not the actual value. For reference, the entire changes report as published by the International Code Council is included in Appendix A.

Code Section	Code Change	Explanation	Cost Implications
423.4.2	Location	Established a maximum travel distance to a storm shelter. This only pertains to critical operation buildings or campuses. Increase cost may occur depending on the distances. This may require multiple storm shelters depending on circumstances. A cost of construction to critical emergency operation buildings, by requiring more than one storm shelter on larger campuses.	YES
		Reasoning Statement - Due to the time-sensitive nature of the potential hazard, the distance individuals must travel to reach a protected space must be limited.	

Code Section	Code Change	Explanation	Cost Implications
903.2.2.2	Laboratories involving testing, research, and development	This was added in this code cycle because these types of areas may have an increased risk of fire. This will increase construction costs. The code points out when testing research and development of lithium-ion or lithium-metal batteries is being conducted in a Type B occupancy.	YES
		Reasoning Statement - To effectively address the risk of fire resulting from thermal runaway in lithium-ion or lithium-metal batteries, early detection, a mitigation strategy, and suppression measures are essential. This proposal specifically focuses on the suppression component of that response framework.	

Code Section	Code Change	Explanation	Cost Implications
903.2.4	Sprinkler Requirements for a Group F-11, research and development	<p>This was added this code cycle because these types of areas may have an increased risk of fire.</p> <p>This will increase construction costs. The code points out when testing research and development of lithium-ion or lithium-metal batteries is being conducted in a Type B occupancy.</p>	YES
		Reasoning Statement - To effectively address the risk of fire resulting from thermal runaway in lithium-ion or lithium-metal batteries, early detection, a mitigation strategy, and suppression measures are essential. This proposal specifically focuses on the suppression component of that response framework.	

Code Section	Code Change	Explanation	Cost Implications
907.5.2.1.3	Audible alarms	<p>Group I-1 are now added to the occupancies that require 520-Hz low-frequency alarms.</p> <p>Cost will increase in new construction as the new alarms are more expensive. ICC estimates \$57 per sleeping room if an emergency voice alarm communication (EVAC) system is not required and \$107 in the units required to have an EVAC.</p>	YES
		Reasoning Statement - This Proposal seeks to enhance the ability of residents in and I-1 Occupancies to be awakened by the fire alarm system or smoke alarm by requiring the 520 Hz low-frequency audible alarm signal. It is needed because residents in I-1 Occupancies do not rely on trained staff to wake them, and they are able to self-evacuate the building (e.g., assisted living facilities, halfway houses, group homes).	

Code Section	Code Change	Explanation	Cost Implications
917.2	Mass Notification System	<p>This is a new section that requires an analysis for mass notification risk for Group E occupancies with an occupant load greater than 500.</p> <p>This is an additional cost for the analysis and the possible addition of the notification system. This change is to address injuries in schools resulting from a range of emergencies, including active shooter incidents.</p>	YES
		<p>Reasoning Statement – This proposal is intended to reduce injuries and fatalities in newly constructed schools by addressing a wide range of emergencies, including fires, human-caused incidents (both accidental and intentional), hazardous situations, accidents, and natural disasters. This proposal is necessary to enhance public life safety in Group E occupancies from all emergencies, but most importantly from a significant increase in human-caused incidents in recent years.</p>	

Code Section	Code Change	Explanation	Cost Implications
1023.7, 1023.7.1 and 1023.7.2	Interior Exit Stairway, Exterior Walls, and Roof Assemblies	<p>This is a code modification with new sections added to address situations where non-rated walls are adjacent to non-rated roof assemblies.</p> <p>This requires rating of roof assemblies and openings next to interior exit stairways with unrated exterior walls.</p>	YES
		<p>Reasoning Statement - This code change is needed to address designs where non-rated exterior walls of an interior exit stairway or ramp are adjacent to non-rated roof assemblies, which may also have unprotected openings within 10 feet of the exterior walls of the stairway or ramp. In the attached illustration, the unrated glazed exterior wall of the interior exit stairway is directly adjacent to an unprotected skylight in the roof of a lobby below. The designer agreed to protect the stairway's exterior wall for 10 feet above the skylight, although the current code does not require this protection. This proposal provides more comprehensive protection for one of the most important egress elements in Chapter 10, interior exit stairways and ramps.</p>	

Code Section	Code Change	Explanation	Cost Implications
1110.4, 1110.4.1, 1110.4.2, 1110.4.3 and 1110.4.4	Adult Changing Stations	<p>These sections were added during this code cycle. It is now required to provide an adult changing station in certain occupancies, outlining the requirements of the room, travel distance, and prohibited locations.</p> <p>This will require either adding an extra toilet room or creating larger rooms to accommodate the station.</p>	YES
		<p>Reasoning Statement - An adult changing station contains a changing table large enough to accommodate an adult-sized person located in proximity to sanitary facilities, such as lavatories and trash disposal. Without such facilities, severely disabled people who cannot use toilets because of their disability suffer from severe isolation because they and their caregivers must return home to be changed. This lack of access has a profound impact not only on the person with a disability but also on their caregivers, who are often their immediate family members. Normal activities outside the home, such as shopping, entertainment, and travel, must be curtailed because of a lack of safe and sanitary places to change. On occasion, caregivers report they have no option other than to change the adults for whom they care on restroom floors. Aside from the obvious sanitation concerns, which are far from minimal, this practice raises serious questions about how we as a community afford people with significant disabilities a measure of human dignity and protect their right to privacy.</p>	

Code Section	Code Change	Explanation	Cost Implications
1110.14, 1110.14.1, 1110.14.2 and 1110.14.3	Seating and Standing Spaces at Dining Surfaces and Work Surfaces	<p>This section was revised to simplify the code by reducing potential confusion. There were two sections of the code prior to this, one for assembly areas and one for dining areas.</p> <p>This will result in increased costs due to the additional space required to meet enhanced accessibility standards.</p>	YES
		<p>Reasoning Statement - This proposal cross-references the main section for tables in this section, as they both require 5% of seating to be accessible; dispersion within the space; and location on levels served by accessible routes. The requirements for dispersion in 1014.1 are slightly more specific regarding the dispersion of accessible tables “among similar elements” in the facility. This proposal contains two major parts: first, Section 1110.14 would apply the scoping to both fixed and movable tables that are provided for the consumption of food or drink. New Section 1110.14.2 would ensure that seating at an appropriate height for persons who are semi-ambulatory is provided in addition to the wheelchair spaces.</p>	

Code Section	Code Change	Explanation	Cost Implications
1404.15.2	Installation over foam plastic insulating sheathing	<p>This coordinates the IBC with provisions in the IRC.</p> <p>Foam sheathing may be applied directly to studs when alternative wall bracing methods are used in place of traditional structural wood panels (such as plywood or OSB). However, this approach requires vinyl siding materials to meet higher performance standards, necessitating the use of more costly materials.</p>	YES
		<p>Reasoning Statement - This proposal coordinates the IBC with provisions already in the IRC (Section R703.11.2) and in ASTM D3679 for the specification of vinyl siding. For buildings meeting criteria for Type V construction (where vinyl siding is permissible in the IBC), this proposal provides needed wind load pressure rating requirements for vinyl siding installed on walls that also use foam sheathing as continuous insulation for energy code compliance</p>	

Code Section	Code Change	Explanation	Cost Implications
1511.9 and subsections	Raised-deck systems installed over a roof assembly	<p>This is a new section of the code to provide specific design and installation guidance for raised-deck systems.</p> <p>This requirement is essentially a noncombustible fire-blocking provision on the edge of raised deck systems to prevent fire from entering from the perimeter.</p>	YES
		<p>Reasoning Statement - Currently, the IBC does not have any specific provisions for the design and installation of raised-deck systems. These provisions should be a subsection to Section 1511 because these systems are a roof structure over a roof assembly. A definition of "raised deck systems" is needed to ensure the correct application of new requirements for these systems. Fundamentally, the concerns were to clarify necessary roof drainage and roof structure support, while not adversely impacting fire safety.</p>	

Code Section	Code Change	Explanation	Cost Implications
1603.1.4	Wind and Tornado Design Data	<p>Design requirements have been updated to incorporate additional considerations for buildings located in areas prone to tornadoes.</p> <p>Recent code changes require designers to consider additional factors when constructing buildings in tornado-prone areas. These updates will increase construction costs for Type III and IV buildings, which typically include critical infrastructure, emergency management facilities, hospitals, and large assembly spaces (300+ occupants). The intent is not to design for the rare, high-damage tornado events that often make headlines, but rather to address the more frequent, lower-intensity tornadoes. While less dramatic, these smaller storms contribute to greater cumulative damage over time</p>	YES
		<p>Reasoning Statement - Tornado hazards have not previously been considered in the design of conventional buildings, even though tornadoes and tornadic storms cause more fatalities than hurricanes and earthquakes combined (NIST 2014) and more catastrophe insured losses than hurricanes and tropical storms combined (Insurance Information Institute 2021). This gap is addressed for the first time in ASCE 7-22, which now includes requirements for tornado loads. The tornado hazard maps and load methodology are based on a decade of research and development led by the National Institute of Standards and Technology (NIST), in collaboration with ASCE, following the record 2011 tornado season (1,691 tornadoes causing 553 fatalities). ASCE 7-22 requirements for tornado loads apply to Risk Category III and IV buildings and other structures sited in the tornado-prone region, which is approximately equal to the area of the U.S. east of the Continental Divide.</p>	

Code Section	Code Change	Explanation	Cost Implications
1604.5	Risk Category	<p>All Group I-2 and most Group I-3 occupancies have now been relocated to a Risk Category IV.</p> <p>This will apply higher standards to group I-2 (ex., Hospitals) and group I-3 (Jail and detention centers)</p>	YES
		<p>Reasoning Statement - The code change addresses the intent of the IBC as well as ASCE 7, whereby the codes will provide more protection for buildings with a high concentration of occupants and certain large buildings that, in total, have 5,000 or more occupants. ASCE 7 intends to improve protection for “Buildings and other structures, the failure of which could pose a substantial risk to human life”.</p>	

Code Section	Code Change	Explanation	Cost Implications
Section 1608	Snow Loads	<p>This section was completely revised to address the changes made in ASCE-7-22 Minimum Design Loads and Associated Criteria for Buildings. Previous editions used data for snowfall from 1952 to 1992, and this new document is based on 30 years of additional snow load data</p> <p>Snow accumulation data has changed in areas across the state. The code has now become address point specific when dealing with snow loads in the IBC. The factor is found using the ASCE-7 hazard tool</p>	YES
		<p>Reasoning Statement - This proposal is complementary to the proposed changes for metal building systems in Chapter 22. Metal building systems are generally highly optimized structures heavily dependent on bracing components to work per the design intent. The bracing components often consist of materials that aren't considered to be "structural steel," and therefore, inspection of the completed installation of those critical components is often overlooked.</p>	

Code Section	Code Change	Explanation	Cost Implications
1705.2.6	Metal Building Systems	<p>This is a new section that requires special inspections for a metal building system.</p> <p>This provision will require the hiring of a special inspector when constructing a pre-engineered metal building system. It is a periodic inspection, meaning they don't have to be on site watching the actual install, but will be required to review certain areas that may be covered up as construction progresses. The inspection will most likely be a spot check and inspection of each connection and component.</p>	YES
		<p>Reasoning Statement - This proposal is complementary to the proposed changes for metal building systems in Chapter 22. Metal building systems are generally highly optimized structures that are heavily dependent on bracing components to work per the design intent. The bracing components often consist of materials that aren't considered to be "structural steel," and therefore inspection of the completed installation of those critical components are often overlooked.</p>	

Code Section	Code Change	Explanation	Cost Implications
1809.14	Grade Beams	<p>This is a new section to add the same grade beam provisions contained in the Deep Foundation Section.</p> <p>This will increase the cost of construction, if the geotechnical report (which is required now) shows the soils aren't capable of support, grade beams now have design criteria for design.</p>	YES
		Reasoning Statement - The code change proposal will not, in general, increase or decrease the overall cost of construction. These provisions provide alternatives and options for the designer to select the most economical approach. The designer may choose between ductile detailing (hoops and ties) or, perhaps, detail a larger foundation or more longitudinal reinforcement. For grade beams in deep foundations, this proposal limits the use of the exception to certain soil conditions, which may have a slight cost impact.	

Code Section	Code Change	Explanation	Cost Implications
2308.2.7	Hillside light-frame construction	<p>This is added to provide correlation between the IBC and the IRC, along with a modification made by ASCE/SEI 7-22.</p> <p>This will increase the number of buildings requiring engineering for building on moderately steep to very steep sites.</p>	YES
		Reasoning Statement - This proposal provides a correlation between the prescriptive provisions of IBC Section 2308 and the provisions of IRC Section R301.2.2.6 Item 8, added in the 2021 IRC, with the intent of improving the seismic performance of wood-light-frame hillside buildings. A related modification has been made in ASCE/SEI 7-22 to provide additional guidance to engineers designing wood light-frame hillside buildings.	

Code Section	Code Change	Explanation	Cost Implications
2308.11.4 and Table 2308.11.4	Wind Uplift	<p>This was added to update the roof-to-wall connection loads to comply with the IBC-referenced standard ASCE 7-16. A new exception was added to allow the truss-to-wall connection to be designed using either the loads on the truss design drawings or the construction documents.</p> <p>This will be a cost increase in areas with higher basic wind speeds, and the previous charts were incorrect.</p>	YES
		<p>Reasoning Statement - The reason for this code change is to update the roof-to-wall connection loads to comply with the IBC-referenced wind design standard, ASCE 7-16. The current loads are based on an older version of ASCE 7 that uses outdated terminology (V-ASD). ASD wind loads have not been used since ASCE 7-10. The wind uplift loads need to be updated to the Ultimate Wind Speeds (now Basic Design Wind Speeds) used in ASCE 7-16 (and ASCE 7-22). That way, the wind speeds will match the required Basic Design Wind speeds of Figures 1609.3(1) through 1609.3(12).</p>	

Code Section	Code Change	Explanation	Cost Implications
2406.1	Human Impact Loads	<p>This is to clarify that all panes of glazing in a multi-pane glass assembly shall be safety glazing, not just the outer panes.</p> <p>An example of a cost increase is a window close to a shower, only the interior pane is required to be safety-glazed; with this provision, both the interior and exterior pane in a double-hung window are now required.</p>	YES
		<p>Reasoning Statement – In recent months, the glass industry has received reports of multi-pane glass assemblies imported from outside the United States, where the outermost panes are marked as safety glazing, but the center pane(s) in these multi-pane assemblies are annealed glass, which breaks dangerously when broken by human impact. Nothing in either safety glazing standard, specifically CPSC 16 CFR 1201 and ANSI Z97.1, prohibits this since they establish acceptance criteria ONLY for individual glass panes, not for multi-panel glass assemblies. Accordingly, the adoption of this proposal is critical to ensure that multi-pane glass assemblies installed in hazardous locations are safe in the event of human impact and to ensure potentially dangerous annealed panes of glass are not intermingled with safety glazing in multi-pane glass assemblies.</p>	

2009 Edition of the International Energy Conservation Code
Updated to
2024 Edition of the International Energy Conservation Code

Industry standards and practices have moved toward high-level energy efficiency and the health and quality of our indoor environment since the early 2000s. Energy efficiency standards and practices are primarily related to equipment and product manufacturers transitioning their available product lines toward high-end energy efficiency and Energy Star-rated systems.

Regardless of which year or version of the IECC is chosen for compliance, the industry standards of practice and equipment are already largely compliant with the most recent versions of the IECC codes.

For this reason, we recommend continuing on a voluntary compliance basis with the 2009 IECC code to avoid significant cost increases due to increased mandatory design, testing, and compliance enforcement measures that would be included by updating to the 2024 Edition of the IECC.

For the purpose of this report, the sections referenced below relate to changes from the 2021 IECC and are a small part of the entire list of changes to the 2024 Edition of the International Energy Conservation Code. For reference, the entire changes report as published by the International Code Council is included in Appendix B.

Page 4 Added Section Code Compliance Agency - This creates a new jurisdictional department for implementation, administration, and enforcement of the IECC

Referenced Section	Cost Implications
SECTION C103 CODE COMPLIANCE AGENCY C103.1 Creation of enforcement agency. The [INSERT NAME OF DEPARTMENT] is hereby created, and the official in charge thereof shall be known as the authority having jurisdiction (AHJ). The function of the agency shall be the implementation, administration, and enforcement of the provisions of this code. C103.2 Appointment. The AHJ shall be appointed by the chief appointing authority of the jurisdiction. C103.3 Deputies. In accordance with the prescribed procedures of this jurisdiction and with the concurrence of the appointing authority, the AHJ shall have the authority to appoint a deputy AHJ, other related technical officers, inspectors, and other employees. Such employees shall have powers as delegated by the AHJ.	YES

Referenced Section	Cost Implications
<p>SECTION C105</p> <p>CONSTRUCTION DOCUMENTS</p> <p>C105.1 The code official is authorized to require necessary construction documents to be prepared by a registered design professional.</p>	<p>YES</p>
<p>C105.2 Electronic media documents are permitted to be submitted where approved by the code official. Construction documents shall be of sufficient clarity to "indicate the location, nature, and extent of the work proposed, and show in sufficient detail pertinent data and features of the building systems and equipment as herein governed. Details shall include, but are not limited to, the following as applicable:</p> <ol style="list-style-type: none"> 1. Energy compliance path. 2. Insulation materials and their R-values. 3. Fenestration U-factors and solar heat gain coefficients (SHGC). 4. Area-weighted U-factor and solar heat gain coefficient (SHGC) calculations. 5. Air barrier and air sealing details, including the location of the air barrier." 6. Thermal bridges as identified in Section C402.6. 7. Mechanical system design criteria. 8. Mechanical and service water-heating systems and equipment types, sizes, and efficiencies. 9. Economizer description. 10. Equipment and system controls. 11. Fan motor horsepower (hp) and controls. 12. Duct sealing, duct and pipe insulation, and location. 13. Lighting fixture schedule with wattage and control narrative. 14. Location of daylight zones on floor plans. 15. Location of pathways for routing of raceways or cable from the on-site renewable energy system to the electrical distribution equipment. 16. Air barrier and air sealing details, including the location of the air barrier. Location reserved for inverters metering equipment and energy storage systems (ESS), and a pathway reserved for routing of raceways or conduit from the renewable energy system to the point of interconnection with the electrical service and the ESS. 17. Location and layout of a designated area for ESS. 18. Rated energy capacity and rated power capacity of the installed or planned ESS. 	<p>YES</p>

Referenced Section	Cost Implications
C106.3 Valuation of work. The applicant for a permit shall provide an estimated value of the work for which the permit is being issued at the time of application. Such estimated valuations shall include the total value of the work, including materials and labor. Where, in the opinion of the code official, the valuation is underestimated, the permit shall be denied unless the applicant can show detailed estimates acceptable to the code official. The final valuation shall be approved by the code official.	YES

Referenced Section	Cost Implications
<p>C402.6.1.1 Air barrier design and documentation requirements. Design of the continuous air barrier shall be documented as follows:</p> <ol style="list-style-type: none"> 1. Components comprising the continuous air barrier and their position within each building thermal envelope assembly shall be identified. 2. Joints, interconnections, and penetrations of the continuous air barrier components shall be detailed. 3. The continuity of the air barrier building element assemblies that enclose conditioned space or provide a boundary between conditioned space and unconditioned space shall be identified. 4. Documentation of the continuous air barrier shall detail methods of sealing the air barrier, such as wrapping, caulking, gasketing, taping, or other approved methods at the following locations: <ol style="list-style-type: none"> 4.1. Joints around fenestration and door frames. 4.2. Joints between walls and floors; between walls at building corners; between walls and roofs, including parapets and copings; where above-grade walls meet foundations; and at similar intersections. 4.3. Penetrations or attachments through the continuous air barrier. 4.4. Building assemblies used as ducts or plenums. 4.5. Changes in continuous air barrier materials and assemblies. 5. Identify where testing will or will not be performed in accordance with Section C402.6.2. Where testing will not be performed, a plan for field inspections required by Section C402.6.2.3 shall be provided that includes the following: <ol style="list-style-type: none"> 5.1. A schedule for periodic inspection. 5.2. The continuous air barrier scope of work. 5.3. A list of critical inspection items. 5.4. Inspection documentation requirements. 5.5. Provisions for corrective actions where needed. 	YES

Page 70 Balconies and floor decks. It notes that they shall not penetrate the building's thermal envelope.

Referenced Section	Cost Implications
C402.7.1 Balconies and floor decks. Balconies and concrete floor decks shall not penetrate the building's thermal envelope. Such assemblies shall be separately supported or shall be supported by structural attachments or elements that minimize thermal bridging through the building's thermal envelope.	YES

Page 71 Structural Beams and columns shall be covered with not less than R5 insulation for not less than 2' beyond the interior or exterior surface of an insulation component within the building thermal envelope.

Referenced Section	Cost Implications
C402.7.3 Structural beams and columns. Structural steel and concrete beams and columns that project through the building thermal envelope shall be covered with not less than R-5 insulation for not less than two feet (610 mm) beyond the interior or exterior surface of an insulation component within the building thermal envelope.	YES

Pages 75 – 149 *References 2022 ASHRAE 90.1.*

Currently, South Dakota has not adopted ASHRAE 90.1. The 2009 IECC references the 2007 version of ASHRAE 90.1.

Page 180 This measure requires installation of efficient dehumidification technology, which may increase the initial equipment cost but saves operational energy and maintenance costs; it is a cost-effective code requirement.

Referenced Section	Cost Implications
C403.15 Dehumidification in spaces for plant growth and maintenance. Equipment that dehumidifies indoor grow and greenhouse spaces shall be one or more of the following: <ol style="list-style-type: none">1. Dehumidifiers tested in accordance with the test procedure listed in DOE 10 CFR 430 and DOE 10 CFR 430, Subpart B, Appendix X or X1.2. An integrated HVAC system with on-site heat recovery designed to fulfill not less than 75 percent of the annual energy for dehumidification reheat.3. A chilled water system with on-site heat recovery designed to fulfill not less than 75 percent of the annual energy for dehumidification reheat.4. A solid or liquid desiccant dehumidification system for system designs that require a dewpoint of not more than 50°F (10°C).	YES

Page 192 The code is revised to require circulation pumps with thermostatic flow balancing valves and ECM motors. This increases construction costs but saves operating energy costs. The code change increases the stringency but is a cost-effective change.

Referenced Section	Cost Implications
C404.6.1 Circulation systems. Heated-water circulation systems shall be provided with a circulation pump. Gravity and thermo-syphon circulation systems shall be prohibited. The system return pipe shall be a dedicated return pipe. Controls must be configured to automatically shut off the pump when the circulation loop reaches the desired water temperature and there is no demand for hot water. Where a circulation pump serves multiple risers or piping zones, controls shall include self-actuating thermostatic balancing valves or another means of flow control to automatically balance the flow rate through each riser or piping zone.	YES

Page 194 This amendment adds four new space types to an existing space list requiring occupancy sensor lighting controls: a computer room, a data center, a medical supply room in a health care facility, a laundry/washer area, and a telemedicine room in a health care facility. This change may increase the construction cost by expanding the occupancy sensor requirements to new space types, but it is a cost-effective measure. Replaces the text “warehouse” with “warehouse storage areas” for clarity.

Referenced Section	Cost Implications
C405.2.1 Occupant sensor controls. Occupant sensor controls shall be installed to control lights in the following space types: <ol style="list-style-type: none"> 1. Classrooms/lecture/training rooms. 2. Computer room , data center. 3. Conference/meeting/multipurpose rooms. 4. Copy/print rooms. 5. Lounges/breakrooms. 6. Medical supply room in a health care facility. 7. Enclosed offices. 	YES

Requires sleeping and dwelling units to be provided with lighting controls and switched receptacles, instead of occupancy sensor-based lighting and receptacle controls. This change simplifies the requirements for dwelling and sleeping units. This decreases the stringency.

Adds new subsection C405.2.10.1.

Requires a switched receptacle and occupant sensor lighting controls. Automatic shutoff is not required where captive key override controls all lighting and switched receptacles in units with five or fewer permanently installed lights and switched receptacles.

Adds new subsection C405.2.10.2.

Requires bathroom lighting to be controlled by an occupant sensor that automatically turns off the lights within 20 minutes of the space being unoccupied. Additionally, a manual control must be installed at the entrance of each unit to turn off all lighting and switched receptacles, except for those in bathrooms and kitchens.

Referenced Section	Cost Implications
<p>C405.2.10 Sleeping unit and dwelling unit lighting and switched receptacle controls. Sleeping units and dwelling units shall be provided with lighting controls and switched receptacles as specified in Sections C405.2.10.1 and C405.2.10.2.</p> <p>C405.2.10.1 Sleeping units and dwelling units in hotels, motels, and vacation timeshare properties. Sleeping units and dwelling units in hotels, motels, and vacation timeshare properties shall be provided with the following:</p> <ol style="list-style-type: none"> 1. Not less than two 125V, 15- and 20-amp switched receptacles in each room, except for bathrooms, kitchens, foyers, hallways, and closets. 2. Lighting controls that automatically turn off all lighting and switched receptacles within 20 minutes after all occupants have left the unit. <p>Exception: Automatic shutoff is not required where captive key override controls all lighting and switched receptacles in units with five or fewer permanently installed lights and switched receptacles.</p> <p>C405.2.10.2 Sleeping units in congregate living facilities. Sleeping units in congregate living facilities shall be provided with the following controls:</p> <ol style="list-style-type: none"> 1. Lighting in bathrooms shall be controlled by an occupant sensor control that automatically turns off lights within 20 minutes after all occupants have left the space. 2. Each unit shall have a manual control by the entrance that turns off all lighting and switched receptacles in the unit, except for lighting in bathrooms and kitchens. The manual control shall be marked to indicate its function. 	<p>YES</p>

Page 218 It adds a new Section C405.9 by moving the provision from Section C405.1 and aligns the requirement with the ASHRAE Standard 90.4 for computer rooms. This change will increase the stringency of computer room requirements and hence the construction cost.

Referenced Section	Cost Implications
<p>C405.9 Data centers and computer rooms. Electrical equipment in data centers and computer rooms shall comply with this section.</p> <p>C405.9.1 Data centers. Transformers, uninterruptible power supplies, motors, and electrical power processing equipment in data centers shall comply with Section 8 of ASHRAE 90.4 in addition to this code.</p> <p>C405.9.2 Computer rooms. Uninterruptible power supplies in computer rooms shall comply with the requirements in Tables 8.5 and 8.6 of ASHRAE 90.4 in addition to this code.</p>	YES

Page 226 Adds a new Section C405.16. This change slightly increases stringency and the construction cost, but is cost-effective.

Term "may increase the stringency but is cost-effective" is used in many areas throughout the 2024 IECC.

Page 307 Renames the section title by adding the text “and receptacle.” Now, this section includes a functional testing requirement for receptacle controls. It slightly increases construction costs due to additional code verification efforts.

Revised Section C408.3.1.2 time-switch control requirements to include receptacle controls. It slightly increases construction costs due to additional code verification efforts.

Referenced Section	Cost Implications
<p>C408.3 Functional testing of lighting and receptacle controls. Automatic lighting and receptacle controls required by this code shall comply with this section.</p> <p>C408.3.1 Functional testing. Prior to passing final inspection, the registered design professional or approved agency shall provide evidence that the lighting control systems have been tested to ensure that control hardware and software are calibrated, adjusted, programmed, and in proper working condition in accordance with the construction documents and manufacturer’s instructions. Functional testing shall be in accordance with Sections C408.3.1.1 through C408.3.1.3 for the applicable control type.</p> <p>C408.3.1.2 Time-switch controls. Where time-switch controls are provided, Items 1 through 5 shall be performed for all time-switch controls. For projects with more than seven spaces where lighting or receptacles are controlled by time-switch controls, not less than 10 percent of spaces, and in no case fewer than one space, shall be tested according to Items 6 and 7 unless the code official or registered design professional requires a higher percentage to be tested. Where 30 percent or more of the tested spaces fail any of the requirements in Items 6 and 7, all remaining spaces shall be tested.</p>	YES

<ol style="list-style-type: none"> 1. Confirm the time-switch control is programmed with accurate weekday, weekend, and holiday schedules. 2. Provide documentation to the owner of time-switch controls programming, including weekday, weekend, holiday schedules, and set-up and preference program settings. 3. Verify the correct time and date in the time switch. 4. Verify that any battery backup is installed and energized. 5. Verify that the override time limit is set to not more than 2 hours. 6. Simulate occupied condition. Verify and document the following: <ol style="list-style-type: none"> 6.1. All lights can be turned on and off by their respective area control switch. 6.2. The switch only operates lighting in the enclosed space in which the switch is located. 6.3. Receptacles in the space controlled by the time-switch controls turn on. 7. Simulate an unoccupied condition. Verify and document the following: <ol style="list-style-type: none"> 7.1. Nonexempt lighting turns off. 7.2. Manual override switch allows only the lights and receptacles controlled by the time-switch controls in the enclosed space where the override switch is located to turn on controlled lighting and receptacles for more than 2 hours. 7.3. Receptacles controlled by the time-switch controls turn off. 8. Additional testing as specified by the registered design professional. 	
--	--

Page 308 *Adds new Section C408.3.1.4.* Lighting control verification requirement for High-end trim.
Adds new Section C408.3.1.5. This section is used with additional efficiency credits. It may slightly increase construction costs due to the additional verification and testing requirements.
Adds new Section C408.3.1.6. This section is used with additional efficiency credits. It may slightly increase construction costs due to the additional verification and testing requirements.

Referenced Section	Cost Implications
<p>C408.3.1.4 High-end trim controls. Where lighting controls are configured for high-end trim, verify the following:</p> <ol style="list-style-type: none"> 1. High-end trim maximum level has been set. 2. The calibration adjustment equipment is located for ready access only by authorized personnel. 3. Lighting controls with ready access for users cannot increase the lighting power above the maximum level established by the high-end trim controls. <p>C408.3.1.5 High-end trim lighting control verification for L02 Additional Efficiency Credit. For the qualifying spaces associated with the project receiving the additional efficiency credits in Section C406.2.5.2, the following shall be documented while daylight responsive controls are not reducing lighting power:</p> <ol style="list-style-type: none"> 1. The maximum setting for power or light output for each control group of general lighting luminaires. 2. The high-end trim setting for power or light output for each control group of general lighting luminaires. 3. For projects with seven or fewer claimed qualifying spaces, the reduction in light output or reduction in power due to high-end trim shall be tested in all spaces and shown to reduce the general lighting power or light output to not greater than 85 percent of full power or light output. For projects with more than seven claimed qualifying spaces, the reduction in light output or reduction in power due to high-end 	<p>YES</p>

<p>trim shall be tested in not less than 10 percent of spaces, and not less than seven spaces, and be shown to reduce general lighting power or light output to not greater than 85 percent of full power or light output. Where more than 30 percent of the tested spaces fail, the remaining qualifying spaces shall be tested.</p> <ol style="list-style-type: none"> 4. Summarize the reduction in general lighting power or light output resulting from the high-end trim setting for each qualifying space and the floor area of each qualifying space. 5. Summarize the fraction of total floor area for spaces where high-end trim reduces general lighting power or light output to not greater than 85 percent of full power or light output. <p>C408.3.1.6 Demand responsive lighting controls G01. For spaces associated with the project receiving renewable and load management credits in Section C406.3.2, the following procedures shall be performed:</p> <ol style="list-style-type: none"> 1. Confirm the maximum set point upon receipt of the demand response signal has been established for each space. 2. For projects with seven or fewer spaces with controls, each space shall be tested. 3. For projects with more than seven spaces with controls, testing shall be done for each unique space type. Where multiple spaces of each space type exist, not less than 10 percent of each space type, and in no case fewer than one space, shall be tested unless the code official requires a higher percentage to be tested. Where 30 percent or more of the tested controls fail in a space type, all remaining identical space types shall be tested. 4. For demand-responsive controls to be tested, verify the following: <ol style="list-style-type: none"> 4.1. Where high-end trim controls are used, the high-end trim shall be set before testing. 4.2. Turn off all non-general lighting in the space. 4.3. Set general lighting to its maximum illumination level. Where high-end trim is set, this will be the maximum illumination level at the high-end trim set point. 4.4. An illumination measurement shall be taken in an area of the space that is not controlled by daylight-responsive controlled lighting. If there are no areas without daylight-responsive controls, the daylight-responsive controls shall be overridden from reducing the lighting level during the test. 4.5. Measure and document the maximum illumination level of the space. 5. Simulate a demand response signal and measure the illumination level at the same location as for the measurement in Section C408.3.1.6, Item 4.5. Verify the illumination level has been reduced to not greater than 80 percent of the maximum illumination level documented in Section C408.3.1.6, Item 4.5. 6. Simulate the end of a demand event by turning off the demand response signal; confirm controls automatically return to their normal operational settings at the end of the demand response event. 	
--	--

2024 Edition of the International Property Maintenance Code

The 2024 Edition of the International Property Maintenance Code does not have any significant revisions on quality, safety and cost of construction.

2021 Edition of the International Residential Code

Updated to

2024 Edition of the International Residential Code

Every three years, the International Conference of Building Officials provides revisions and updates to the previous code publication year. The information listed below are items within the code that, in the eyes of the committee, have cost implications with regard to revisions from the 2021 International Residential Code to the 2024 International Residential Code.

The value of cost implications is dependent upon the individual projects and their various levels of complexity. It is the intent of this review only to advise that there are cost implications, and it is not the actual value. For reference, the entire changes report as published by the International Code Council is included in Appendix C. Appendix D includes a Home Builders Association publication that provides some cost guidance per specific types of residential structures.

Code Section	Code Change	Explanation	Cost Implications
Figure R301.2(3)	Allowable Stress Design Ground Snow Loads	<p>This section was completely revised to address the changes made in ASCE-7-22 Minimum Design Loads and Associated Criteria for Buildings. Previous editions used data for snowfall from 1952 to 1992, and this new document is based on 30 years of additional snow load data.</p> <p>This is not a blanket increase. A more address-specific approach is used to determine snow loads now than the previous broader map. As an example, Sioux Falls will see an increase by going from 40 to 55 lbs., while Pierre stays the same, having no effect.</p>	YES
		<p>Reasoning Statement - The previous editions of ASCE 7 included mapped values for ground snow load, pg, (GSL) based on a statistical analysis using National Weather Service snowfall data from 1952 to 1992. This map was first included in the 1992 edition of ASCE 7 and was updated with additional information for the 1995 edition. It has remained essentially as it was in 1995 for each subsequent edition through 2016. Additionally, at the time that map was generated, the authors (researchers at the Cold Regions Research and Engineering Laboratory [CRREL] of the US Army Corps of Engineers) marked as Case Study or 'CS' several significant regions, encompassing large parts of eighteen states, where the statistical analysis had not been completed or the data were insufficient to perform the analysis. The CS regions place a significant burden on structural engineers to perform snow load hazard analyses yet offer minimal guidance on how to conduct these studies.</p>	

Code Section	Code Change	Explanation	Cost Implications
R302.3.5	Vertically stacked duplexes	<p>Non-sprinklered units will require smoke-tight construction and interlocking smoke alarms between the units.</p> <p>This will result in an increased cost of construction. Vertically stacked duplexes are at a higher risk of life safety in a fire event. Thus, a higher</p>	YES

		standard of construction has been applied to these types of buildings.	
		Reasoning Statement - Section 302.3.5 has been added to recognize that stacked duplexes are inherently more hazardous than side-by-side duplexes, particularly with respect to the upper unit due to the tendency of smoke and flames to spread vertically, which increases the risk of charging the upper unit with smoke and cutting off the means of egress and the means of escape if/when fire vents through exterior doors or windows. Providing a smoke separation, in addition to the current requirement for a fire-rated separation, will delay smoke transmission to the upper unit. The proposed text related to the construction of the smoke separation is derived from the IBC definition of "smoke partition," which establishes the performance requirement "...is constructed to limit the transfer of smoke".	

Code Section	Code Change	Explanation	Cost Implications
R330.4	Energy Storage Systems Locations	<p>This fills in the gaps for opening requirements in the envelope of fire-resistant walls.</p> <p>The cost increase is due to requirements now being applied to ESS systems installed in the home. Previously, these were rare, and now that they are becoming more common, the code needs to address the hazard they pose in a home.</p>	YES
		Reasoning Statement - The energy storage system presents a fire hazard to the occupants of the dwelling. The code already requires a fire protective envelope around ESS, but the code has left holes in this envelope, including penetrations and the door. To reduce the chance of fire spread and allow its occupants an ample amount of time to evacuate the building, the envelope must be sealed. This can easily be done by requiring a fire-rated door or equivalent to seal any penetrations.	

Code Section	Code Change	Explanation	Cost Implications
R502.11 and subsections	Floor Framing Supporting Guards	<p>This section was added to address the installation of guards and their attachments to the floor system.</p> <p>Increased requirements for Guard post floor framing supports. Also, not allowing I-joists or engineered trusses to be a part of the direct support. (This was supported by the truss manufacturing industry).</p>	YES
		Reasoning Statement - By recommendation of the manufacturers of I-	

		joists and trusses and consensus of the entire task group, this proposal prohibits the use of I-joists and trusses as edge framing members supporting guards except where the effects of the guard loads are specifically considered in the design of the edge member. This is based upon the limited embedment of fasteners in the thickness of the joist and truss materials, open areas/voids, and surfaces where fasteners cannot be used that would weaken the component or connections between the truss/I-joist components.	
--	--	--	--

Code Section	Code Change	Explanation	Cost Implications
R507.2.4	Flashing	<p>This adds language that self-adhered membranes shall comply with FGIA 711.</p> <p>If using a self-adhered membrane as flashing, it needs to be manufactured to the FGIA standard. This is a rise in the cost of the material used.</p>	YES
		Reasoning Statement - Self-adhering membrane flashing is becoming more common. These new requirements align with what is required for self-adhering membrane flashings that have been commonly used for window installation for many years.	

Code Section	Code Change	Explanation	Cost Implications
R507.9.1.5, R507.9.1.6, R507.9.1.7 and R507.9.1.8	Ledger Flashing, Water-Resistive Barrier, Existing Walls, and Exterior Wall Coverings	<p>A deck ledger to a house band joist depends on materials that are free from decay. It is critical to ensure the band joist of the house floor system does not decay. The IRC has long required deck ledgers to be flashed to prevent the entry of water. However, there was no guidance. This attempts to provide more details on how to be flashed correctly. If using a self-adhered membrane as flashing, it needs to be manufactured to the FGIA standard. This is a rise in the cost of the material used.</p> <p>There will be an increase in material and labor costs. Considering this change is directly related to decks, the cost may be minimal as most decks are not large in size.</p>	YES
		<p>Reasoning Statement - The primary goals of this proposal are:</p> <ol style="list-style-type: none"> 1. Support the variety of flashing methods currently in use. 2. Recognize the different ledger fastening methods in Section 507: Fastened in contact with the sheathing/water-resistive barrier and fastened with 1/2-inch of stacked washer spacing the ledger off the sheathing/water-resistive barrier. 3. Recognize the different cladding materials and types of installations (drainage plane, back-vented) 4. Recognize the higher risk of cutting into an existing water-resistant barrier for a deck attachment. 5. Recognize that many houses do not have a water-resistant barrier. 6. Protect the house framing when cladding is replaced with a deck ledger. 	

Code Section	Code Change	Explanation	Cost Implications
R602.10.6	Construction of Methods ABW, PFH, PFG, CSW-PF, and BV-WSP	<p>This section was modified to remove confusion by users on where to locate the edge of a single portal frame.</p> <p>With the added note: Headers shall not extend over more than one opening. Cost will increase if multiple openings are close enough together so that one header could span multiple openings. By requiring extra studs for the additional king studs that would be required, this will add additional costs including the labor associated with the work.</p>	YES
		<p>Reasoning Statement - There has been ongoing confusion regarding how to determine the edge of a single portal frame when applying braced wall panel spacing rules under R602.10.2.2. Specifically, users disagree on whether spacing should be measured from the vertical sheathed portal at one end or from the end of the header. Given that the entire length of the header transfers shear loads from the top plate, and the spacing rules intend to prevent excessive load accumulation in the top plate, it is reasonable to interpret the edge of the portal as the end of the header.</p>	

Code Section	Code Change	Explanation	Cost Implications
Section R704	Exterior Soffits and Fascia	<p>This adds language on the installation for fascia.</p> <p>Add additional types of soffits to the list, which could require more blocking if installed on soffits wider than 24 inches.</p>	YES
		<p>Reasoning Statement - Over the past few cycles, the treatment of exterior wall coverings and soffits has become separated and addressed in different sections of the code. R704 is now an entire section of the code dedicated to soffit and now fascia. The construction methods for these parts of the exterior of the structure are unique, and prior to the last few cycles, were not addressed at all. This has been a noticeable area in need of requirements based on wind performance failures due to a lack of direction. With this change in definitions and changes in other areas of the code, it will help builders, installers, and building officials better understand how R704 applies and how R703 applies. These definitions create a clearer understanding of the application.</p>	

Code Section	Code Change	Explanation	Cost Implications
Chapter 11	Energy Efficiency	<p>With each code cycle, energy performance requirements continue to increase—driven in part by advancements in technology and improvements in building materials.</p> <p>Codified law 11-10-7 states the 2009 IECC as a voluntary standard.</p> <p>For this reason, we recommend continuing on a voluntary compliance basis with the 2009 IECC code to avoid significant cost increases due to increased mandatory design, testing, and compliance enforcement measures that would be included by updating to the 2024 Edition of the IECC.</p>	YES

Executive Summary

Each of the codes listed under Title 11, Chapter 10, is continually reviewed and updated by the International Code Council. Their review is meant to keep codes current and relevant as times change across the globe. The review completed by this Workgroup is specific in its content to show how these codes affect the great State of South Dakota and its communities. If this document can be a guide to communities and their understanding and potential adoption of various codes, we have been successful.

The Workgroup has followed changes and updates in this code family in 2023 and 2024 and concluded with this report in 2025. We, the Workgroup, are proud to be part of the process in which South Dakota strives to protect the health, safety, and welfare of our residents and communities.

Bibliography:

2024 Significant Changes to the International Building Code

Version: March 2025

Published by the International Code Council

2024 Significant Changes to the International Building Code

Published by the International Code Council

2024 Significant Changes to the International Property Maintenance Code

Published by OSA Property Management

November 17, 2024

2024 Significant Changes to the International Residential Code

Version: January 2025

Published by the International Code Council

Appendix A

Green Text indicates possible increase in cost of construction Red Text indicates a reduction in construction cost. Blue text indicates no cost change, a clarification was made to the section

Significant Changes to the 2024 IBC

Code Section	Code Change	Explanation	Cost	Reasoning Statement - these statements are excerpts from the proponent of the change as submitted to ICC
Section 104	Duties and Powers of Building Official	It now gives four methods for determination of compliance. -- Listed Compliance; Technical assistance; Alternate materials, design & methods; Modifications Fences not over 7 feet in height were previously exempted and still are except for when the fence is used as a barrier for a swimming pool, now a permit is required for this fence.	\$0	
105.2	Work Exempt from Permit	Definitions is a very needed section of the code as it is critical that everyone is talking about the same thing. An example is the definition of Exterior Wall Assembly and High-Rise Buildings have become more specific.	\$0	
Section 202	Definitions	Some additional items were added to the laundry list on the different occupancies. This code cycle the term lithium-ion and lithium metal batteries were added to the laundry list in more than one place in order to keep these occupancies from being called a hazardous occupancy.	\$0	
Chapter 3	Occupancy Classification and Use	A whole new table was added to clarification for items that could have been considered as hazardous.	\$0 & potential	
307.1.1	Occupancy Exemptions	This gives more options for unlocking the doors to the individual floors	\$0	
403.5.3	Stairway Door Operation	The added exception is for hospitals that specifies a fire barrier is not required between the atrium and adjoining spaces for up to 3 stories, provided the design of the smoke control are accounted for it.	\$0	
404.6	Enclosure of Atriums	This clarifies that in a care suite the paths leading to the exit doors is required to only be a minimum of 36 inches wide, not the width required in I-2 corridors which is 96 inches for bed movement.	\$0	
407.4.4.4	Circulation paths within a Care Suite	Puzzle rooms are now allowed to comply with the egress requirements of Chapter 10 versus the specialty requirements for special amusement areas.	\$0 & potential decrease	Simply gives the owner some more options, could potentially decrease cost if owner can design the puzzle room around a compliant egress system
411.1	Special Amusement Areas	This section has been changed in its entirety to make fires and cleanups.	\$0	
411.3	Detection and Alarm Systems			This change coordinates the requirements for flammable gas with the change in definition to "flammable gas." The change in definition results in two categories of flammable gas, Category 1A and Category 1B. The existing requirements in the code are based on Category 1A flammable gases. As a result, new requirements had to be developed to regulate Category 1B flammable gases. It should be noted that there is a distinction between Category 1B flammable gas based on the burning velocity. The research on this code change is based on a burning velocity of 3.9 in/s (10 cm/s) or less. Higher burning velocity Category 1B flammable gases are not commercially available, hence there is no means of evaluating their performance. The changes to the table for the higher allowable quantities are for the Category 1B low burning velocity flammable gases. There is no change to the Category 1B high burning velocity flammable gases.
414.2.5.4	Flammable Gas	Flammable gases are now divided into two categories 1A & 1B. This allows a greater quantity of product for a Category 1B.	\$0 & potential decrease	By modifying the maximum quantities for category 1B flammable gases. Cost will decrease by not requiring separate fire areas to store the same amount of material.
423.4.1	Design Occupant Capacity	This section now will allow the AHJ to use actual numbers for determining the occupant load versus the design occupant load.	\$0 & potential	
423.4.2	Location	Established a maximum travel distance to a storm shelter. This only pertains to critical operation buildings or campuses	Increase cost	A cost of construction to critical emergency operation buildings, by requiring more than one storm shelter on larger campuses
503.1.4.1	Enclosures over Occupiable Roof Areas	In a High-rise building the elements surrounding the occupiable roof is now not limited to 48 inches in height.	\$0	This is a modification to give the building official guidance when reviewing buildings to determine if it should be viewed as a roof or another story for firefighter access
506.3.3.1	Frontage Increase	An additional line was added to clarify how to achieve the existing table.	\$0 as these buildings are already sprinkled	This is a clarification to reduce confusion from Chapter 9 which already required sprinkler in 1 occupancies through-out
509.1	Incidental uses	This table changed to make sprinklers mandatory in Group I-2 (hospitals) in laundry rooms, waste & linen collection rooms, storage rooms over 50 sq. ft., maintenance shops and rooms in jails & hospitals that are padded.	\$0	
510.2	Occupant load above the pedestal	This code cycle it eliminated the limit of 300 occupants above the pedestal separation.	\$0	Recent exploration of the science for tall wood buildings resulted in three new types of construction in the 2021 IBC. One of the major differences in the three construction types is the amount of mass timber wall and ceiling area that may be exposed. Accordingly, when the tall wood building fire research program was being developed, a determination was made regarding how much ceiling area, wall area and combinations of ceiling and wall areas could be left exposed during those tests. Fire performance characteristics of mass timber materials available at the time, coupled with limitations in the test lab's physical equipment (exhaust hood and exhaust duct connector) restricted the amount of exposed mass timber material, leading to a conservative test protocol which, for ceilings, became 20 percent of the floor area for buildings of Type IV-B construction. A more recent test series, utilizing code-compliant CLT qualified under ANSI/APA PRG 320 2019: Standard for Performance-Rated Cross-Laminated Timber, has justified an expansion of that allowance to 100 percent of the floor area.
602.4.2	Type IV-B Construction	The allowable amount of exposed mass timber went from 20% to 100% on the ceilings after more research has been done. This allows more of the mass timber to be shown and not hidden by gypsum board.	decrease the cost of construction	Reduces the cost of construction, due to removing the requirement to cover a minimum
603.1	Combustible Material in Types I and II Construction	Another exception was added for combustible materials in Non-combustible buildings. It now allows the vapor retarder that is required in our climate zone to be of combustible materials	\$0 & potential decrease	
704.2 & 704.3	Protection of the primary structural frame	The current language was confusing, this cleaned up these two sections leading to more consistent interpretations.	\$0	Technically this change does not effect cost. With the clarification of the requirement, I feel this is actually a decrease the cost of construction, with the way it may have been interpreted by a jurisdiction
705.6	Continuity of fire-resistive exterior walls	This is a new section that gives clarity to the continuity requirements for an exterior wall.	\$0	
705.7.1	Floor Assemblies in Type III Construction	This is a new section clarifying that the floor assembly may contribute to the fire resistivity of the exterior wall.	\$0	
706.1.2	Fire Walls	This is a new section that allows another option on how to construct a fire wall by using NFPA 221	\$0	This is a decrease in construction cost. The double wall and cumulative fire resistance allowances in the NFPA allows for simple less intrusive alternatives in many remodel scenarios
707.6	Fire Barrier Walls Enclose	This change adds 3 more exceptions for limiting the openings in a fire barrier wall.	\$0	
707.8	Joints in Fire Resistive Walls	This gives clarification of joint protection on two fire resistive walls meeting each other.	\$0	
708.4.1	Fire Partition Walls Enclose Elevator Lobbies	This is a new section clarifying elevator lobby protection requirements	\$0	
710.4	Smoke Partitions	This section now states that a lay-in ceiling is now "capable of limiting the transfer of smoke" provided the ceiling tiles weigh a minimum of 1 pound per square foot and the HVAC system is fully ducted.	\$0	
712.1.3.2	Automatic Shutters	This puts the required items in bullet format with some editorial changes	\$0	
713.13.4	Chute Discharge Room	This change allows the opening protection to have the same rating in the tables rather than requiring a 2-hour rated opening	\$0	
713.14	Elevator, Dumbwaiter and other Hoistways	This change is meant to bring about consistent terminology for elevator protection	\$0	
714.5.1	Through Penetrations of Horizontal Assemblies	This new exception clarifies that opening protection is not required within parking garage ramps	\$0	
714.5.1.2	Through-Penetration Firestop System	This new exception provides consistency with other parts of the IBC	decrease the cost of construction	This will reduce the cost of construction through labor and material in that it removes the "T" rated on some types of through penetrations. The T rating is a temperature rise. Eliminating it removes the requirement to fill the void with insulation prior to installing a fire stopping material
715.2.1 & 715.2.2	Installation of fire-resistant joint systems	This was a wording clarification where the paragraphs were separated from one paragraph into two paragraphs to clean up the language	\$0	
715.4 & 715.5	Exterior Curtain Walls	This adds 3 exceptions for curtain wall joint intersections	decrease the cost of construction	Although the code change proposal says this is a cost decrease I feel it is more a clarification of the requirement and that many jurisdictions were already not requiring a fire stop system at the areas the new exceptions are addressing
715.6	Fire Barrier/nonfire-resistance-rated roof assembly	This provided details on how to protect voids at the intersection of a fire barrier and the underside of a nonfire resistance-rated roof assembly. This section is moved to a better place to find in the code.	\$0	
7107.2.4 & 717.2.4.1	Mechanical, Electrical & Plumbing Controls	This section was added to clarify that control wires are not allowed to be installed through the fire and/or smoke damper rendering them inoperable	\$0 or possibly more if the wires were making the damper inoperable	
903.2	Where Sprinklers are Required	This added a sentence that says a sprinkler system is not required in energy storage systems where not required by Section 1207 of the IFC	\$0	
903.2.2.2	Laboratories involving testing, research and development	This was added this code cycle because these types of areas may have an increased risk of fire	Will increase the cost of construction	This will increase the cost of construction. As it calls out when testing research and development of lithium-ion or lithium metal batteries is being conducted in a type B occupancy
903.2.4	Sprinkler Requirements for a Group F-1	Two items were added this code cycle. A Sprinkler system is now required for the manufacturing of Lithium Ion batteries or manufacturing vehicles with lithium ion batteries	Will increase the cost of construction	Again this will increase cost by specifically calling out lithium type batteries in a facility of any size
903.3.1.2	NFPA-13R sprinkler systems	This changed the maximum height for using a NFPA-13R from 30 feet to 45 feet in height for a Group R-2 Occupancy	\$0 & potential	Sprinklers are required due to the R occupancy this will allow the use of a 13R up to 45' in height on top of a full 13 system
907.2.1	Fire Alarms in Group A occupancies	Two new exceptions were added this code cycle to eliminate the requirement for an emergency voice/alarm communications in a Group A-5 outdoor stadium	\$0 & potential decrease	This could potentially decrease cost, these exceptions existed in the NFPA standard and may have been overlooked by design professionals since there was no mention in the IBC or IFC
907.2.11.3	Smoke alarms near cooking appliances	This code section now aligns with the current version of NFPA-72 where it states smoke alarms shall be installed a minimum of 10 feet from a cooking appliance	\$0	

907.5.2.1.3	Audible alarms	Group I-1 are now added to the occupancies that require 520-Hz low frequency alarms	Will increase the cost of construction	Cost will increase in ne construction as the new alarms are more expensive. ICC estimates \$57 per sleeping room if a emergency voice alarm communication(EVAC) system is not required and \$107 in the units required to have an EVAC	This Proposal seeks to enhance the ability of residents in and I-1 Occupancies to awakened by the fire alarm system or smoke alarm by requiring the 520-Hz low frequency audible alarm signal. It is needed because residents in I-1 Occupancies do not rely on trained staff to wake them and they are able to self-evacuate the building (I-1 occupancies example's; assisted living facilities, halfway houses, Group Homes...)
912.5	Fire Department Signage	Currently the signage requirements are in the IFPA-14, now the verbiage is in the IFC and the IBC	\$0		
915	Carbon Monoxide Detection	This section has been completely reformatted to help clarify requirements	\$0		
917.2	Mass Notification System	This is a new section that requires an analysis for mass notification risk for Group E occupancies with an occupant load greater than 500.	Will increase the cost of construction	This is an additional cost for the analysis then possible addition of the notification system. This is to address injuries in schools from not only fires but also any other type of emergency such as an active shooter event	This proposal seeks to reduce the number of injuries and fatalities in new schools from all types of emergencies including but not limited to fire, human-caused events (accidental and intentional), other dangerous situations, accidents, and natural disasters. This proposal is needed to enhance public life safety in Group E occupancies from all emergencies, but most importantly from a significant increase in human-caused incidents in recent years.
Chapter 10	Means of Egress	Throughout this chapter occupable roof was added for clarification. An example would be currently it says one story and now it will say one story and an occupable roof. This is being done to clarify that an occupable roof is not an extra story	\$0		
1003.3.1	Headroom on Doors	This clarifies that door closers and other equipment are allowed to be 78 inches in height, and not the full 80 inches of the door casing	\$0 & potential		
1006.2.2.2	Retiroation machinery room egressing	This clarifies the egressing requirements for a retroiteration machinery room	\$0		
1008.2	Means of Egress Illumination	An additional exception was added clarifying that self service storage units 400 sq. ft. or less and accessed directly from the exterior do not need egress illumination	\$0		
1008.3	Means of Egress Illumination required by an emergency electrical system	This change simplified by stating exactly where an emergency electrical system shall be required.	\$0		
1009.2.2	Accessible Means of Egress Doors	This clarifies which doors in an accessible means of egress are required to have maneuvering clearances	\$0		
1010.1.1	Size of Doors	Two exceptions were removed because of redundancy/conflict with previous code additions and it now sends one over to the IFC for the minimum clear opening required to access a shower.	\$0		
1010.2.3	Hardware Height	This section was reformatted for the first exception and then added an exception where it matches the requirements of the ISPS	\$0	ISPCS - Intemation Swimming Pool and Spa Code	
1010.2.4	Locks and Latches	This adds 4 definitions to different types of locks and it details where each is allowed to be used taking away the confusion and many different interpretations	\$0		
1010.2.6	Stairway Doors	Changes were made in this section to match the provisions to high-rise buildings to allow the stairway exit door to be locked from the side opposite the egress side by three different methods	\$0		
1010.2.9	Monitored or recorded egress, and access control systems	This sections was adjusted for clarification for what is required on the egress side of the doors when there is controlled egress.	\$0		
1010.2.14	Elevator Lobby Exit Access Doors	This is a new section that has addressed a situation where many jurisdictions are making amendments to the code. This eliminates the need for an elevator lobby to have direct access to an exit and allows the egress path to go through a tenant space provided 8 requirements are met	This could increase or decrease the cost of construction	cost could increase or decrease upon how a municipality was previously interpreting this section. The new language simply makes it less interpretive	
1011.5.5.1	Nosing projection size	The nosing limitation of 1 1/4 inches is no longer applicable when solid risers are not required and the new exception will allow tread depth to be extended beneath adjacent tread without any limitation on extension.	\$0		
1013.2	Low-Level Exit Signs in Group R-1	This removes the requirement for low-level exit signs when the building is equipped with an automatic sprinkler system throughout	Will decrease the cost of construction	Hotels currently require a floor level exit sign,this requirement has been removed for hotels with a sprinkler system	
1013.5.1	Photoluminescent Exit Signs	This is a new section that clarifies that it goes back to the manufacturer's installation instruction on how much light is needed to charge said sign	\$0		
1014.3	Lateral Location of Handrails	This is a new section that details how far from the walking surface the handrails may be located.	\$0		
1014.7 & 1014.8	Handrail Extensions and Clearance	This provided clarification on handrail extensions and added two new exceptions for clearance	\$0		
1015.2	Where Guards are Required	Provisions were added for guards around occupiable roofs	\$0		
1015.3	Guard Height	The minimum guard height is now allowed to be 36 inches in height in Group R-2 and R-3 occupancies under certain conditions	\$0		
1015.8	Window Opening	This clarifies the window opening protection requirements. This gives two different criteria for windows above 75 feet in height above grade and those less than that.	\$0		
1016.2	Egress Through Intervening Spaces	This change is editorial in nature by eliminating an exception to an exception for Group H occupancies	\$0		
1017.2.3	Group H-5 Egress	This new section allows for an increase of travel distance for a Group H-5 (semiconductor facility) occupancy provided 4 criteria are met	\$0		
1019.3	Exit Stairways for other than Groups I-2 & I-3	This clarifies two story openings as there was inconsistent interpretation of this code section	\$0		
1020.2.1	Elevator Hoistway Protection	This change clarifies the fire resistance rating requirement for an elevator door	\$0		
1023.7, 1023.7.1 & 1023.7.2	Interior Exit Stairway Exterior Walls and Roof Assemblies	This is a code modification and new sections that were needed to address situations where nonrated walls are adjacent to nonrated roof assemblies.	Will increase the cost of construction	requires rating of roof assemblies and opening next to interior exit stairways with rated exterior walls. See picture on Sheet 2	This code change is needed to address designs where nonrated exterior walls of an interior exit stairway or ramp are adjacent to nonrated roof assemblies which may also have unprotected openings within 10 feet of the exterior walls of the stairway or ramp. As you can see in the attached illustration, the unrated glazed exterior wall of the interior exit stairway is directly adjacent to an unprotected skylight in the roof of a lobby below. The designer agreed to protect the exterior wall of the stairway for 10 feet above the skylight but currently there is no language in the code to require it. This proposal provides more comprehensive protection for one of the most important egress elements in Chapter 10, interior exit stairways and ramps.
1029.3	Egress Courts Construction & Openings	This adds another exception to requiring fire resistivities in an egress court path to the public way.	decrease the cost of construction	adds another exception for designers to avoid having to rated walls on an egress court	
1030.8	Common Path of Egress Travel	This addresses requirements in a different section of the code to make the intentions of the code clear	\$0		
1030.9.5	Dead-end Aisles	This change allows a longer dead end in smaller occupant load numbers and matches the typical 50 person criteria for two exits.	\$0		
1103.2.11	Accessibility in Residential Group R-1 or R-3	This added the Group R-3 criteria as this can include transient facilities with 10 or fewer occupants.	\$0		
1104.5	Accessible Route Location	The rewording of this proposal was for clarification only	\$0		
1105.1.1	Power-operated doors at Public Entrances	This is intended to clarify how the power-operated door requirement is acollid	\$0		
1106.3	Parking for Groups R-2, R-3 & R-4's	This is to clarify the required number of parking spaces based on the occupancy	\$0		
1106.3.1	Parking located beneath a building	This section was relocated however states the same thing, when parking is located beneath a building accessible parking is required also	\$0		
1107.2	Electrical Vehicle Charging Stations	An exception was added stating that when EV charging stations for buses, trucks and law enforcement vehicles accessible parking stalls are not required	\$0		
1108.6.1.1	Accessible units in Group R-1	Two exceptions were added, one permitting more options where the units contain showers and not bathtubs and second allows transfer showers to be substituted for a minimum number of roll-in showers.	\$0		
1108.6.2.2.1	Type A Unit Bathrooms	This gives the option to put in a shower instead of a bathtub in a Type A unit realizing that for some people bathtubs are difficult to maneuver in.	\$0		
1108.6.3	Group R-3 Bathrooms	This section works in conjunction with the changes in Section 1103.2.11. This gives clarification on the number of Accessible and Type B units	\$0		
1108.6.3.2	General Exception for Type A & B units	This is a clarification on the required number of Type A & B units	\$0		
1108.7	Sinks	This is a clarification on the required number of Type A & B units	\$0		
1110.3		This exception now allow the designer to use the 5 percent option if desired	\$0		An adult changing station contains a changing table large enough to accommodate an adult-sized person that is located in proximity to sanitary facilities, such as lavatories and trash disposal. Without such facilities, severely disabled people who cannot use toilets because of their disability suffer from severe isolation because they and their caregivers must return home to be changed. This lack of access has a profound impact not only on the person with a disability, but on their caregivers who are often their immediate family members. Normal activities outside the home such as shopping, entertainment, and travel must be curtailed because of a lack of safe and sanitary places to change. On occasion, caregivers report they have no option other than to change the adults for whom they care on restroom floor. Aside from the obvious sanitation concerns which is far from minimal, this practice raises serious questions about how we as a community afford people with significant disabilities a measure of human dignity and protect their right to privacy.
1110.4, 1110.4.1, 1110.4.2, 1110.4.3 & 1110.4.4	Adult Changing Stations	These sections were added this code cycle. It is now required to provide an adult changing station in certain occupancies. It gives the requirements of the room, travel distance and prohibited locations.	Will increase the cost of construction	This will either require an extra toilet room to be added or creating larger rooms to accommodate the station	
1110.5	Kitchen Sinks	An exception was added to clarify that not all sinks in a kitchen have to be accessible.	\$0	one could argue this is an increase since the laundries are specifically called out now in the IBC but the ICC A117.1-2017 operable parts of all equipment are required to comply. It just now specifies called out in the IBC	
1110.6, 1110.6.1 & 1110.6.2	Laundry Equipment	This proposal moves the scoping from Appendix E to Chapter 11. This affects only public laundries.	\$0 & potential increase		
1110.14, 1110.14.1, 1110.14.2 & 1110.14.3	Seating & Standing Spaces at Dining Surfaces and Work Surfaces	This section was revised to simplify the code by reducing potential confusion. There were two sections of the code prior to this, one for assembly areas and one for dining areas	Will increase the cost of construction	This will increase cost due to more space being required to accommodate for the addition accessibility requirements to be met	This proposal simply cross references the main section for tables in this section as they both require 5% of seating to be accessible, dispersion within the space, and location on levels served by accessible routes. The requirements for dispersion in 11014.1 is slightly more specific regarding dispersion of accessible tables "among similar elements" in the facility. This proposal contains two major parts: first, Section 1110.14 would apply the scoping to both fixed and movable tables that are provided for the consumption of food or drink. New Section 1110.14.2 would ensure that seating that is at an appropriate height for persons who are semi-ambulatory is provided in addition to the wheelchair spaces.
1111.4.14	Swimming Pools, Wading Pools, Cold Baths, Hot Tubs and Spas	The first exception was changed to provide more clarification for the accessible route to a catch pool	\$0 & potential		
1112.6	Signage Designations	This section was relocated from Appendix E. It says Where provided signs shall be visual characters, raised characters and braille.	\$0		
1201.1	Interior Environment Scope	Additional items that are in this chapter are added: enhanced classroom acoustics, interior space dimensions, access to unoccupied spaces, toilet & bathroom requirements and UV germicidal irradiation systems	\$0		
1202.3 & Table 1202.3	Insulation for Condensation Control	This section was changed from a minimum R-Value to where not the required R-value is stated but that a percentage of the required insulation must be air-impermeable insulation for condensation control is required in unvented attic and unvented enclosed rafter assemblies.	\$0	This is addressing unvented attics and crawls spaces when builders go above minimum R values for insulation. A percentage of air permeable insulation must now be included to address condensation issues	
1208.3	Dwelling Unit Size	This new section requires a minimum of 190 sq. ft. of habitable space in a dwelling unit	\$0	previously this language was only in the efficiency dwelling unit section the language was just added here for consistency in the code	

1211	UV Germicidal Irradiation Systems	This is a new section added that simply states where provided it must listed and labeled and installed properly	Will increase the cost of appliance	not an increase in the cost of construction since these are a choice of the designer, but the cost of the appliance will increase	
1402	Exterior Walls Performance Requirements	There are many changes in this section to inform one on what section of the code certain types of coverings are to go to.	\$0		
1402.7	Exterior Wall Veneers Manufactured using Combustible Adhesives	This is a new section that is specific to exterior wall veneers composed of a metal core and facings that are both noncombustible and are laminated to the core using a combustible laminating adhesive.	\$0		
1402.8	Vertical & Lateral flame propagation compliance methods	This give 3 compliance methods for those walls tested in accordance with NFPA-285.	\$0		
1403.2	Water-resistive Barrier	This section was changed to match what is in the IRC and to add another option for a water-resistive barrier	\$0		
1404.3	Vapor Retarders	Several revisions have been made to the sections involving vapor retarders to have consistency with IRC and IECC.	\$0		
1404.15.2	Installation over foam plastic insulating sheathing	This coordinates the IBC with provisions that are in the IRC.	Will increase the cost of construction	since foam sheathing can be directly applied to studs if an alternative wall bracing is used in lieu of the traditional use of structural wood panels(SWP-plywood or OSB). The use of vinyl siding materials will need to be manufactured to higher performance requirements. Making the use of more expensive material mandatory.	This proposal coordinates the IBC with provisions already in the IRC (Section R703.11.2) and in ASTM D3679 for specification of vinyl siding For buildings meeting criteria for Type V construction (where vinyl siding is permissible in the IBC), this proposal provides needed wind load pressure rating requirements for vinyl siding installed on walls that also use foam sheathing as continuous insulation for energy code compliance
Section 1409 Section 1411 Section 1412	Insulated Metal Panel BIPV systems Soffits and Fascias	This is a new section for a product called Insulated Metal Panels (IMP) This is a new section for Building Integrated Photovoltaic Systems (BIPV) This section is a code change to improve the wind performance of soffits and fascia by adding structural design requirements and compliant installation options.	\$0 \$0 \$0		
1502.3	Roof Drainage Scuppers	The scupper requirements have been removed from the IBC as they are in the IPC	\$0	This could be seen as a cost increase, really all it does is reiterate the requirement to follow the manufactures recommendations SD this is under the scope of the UPC	
1504.8	Wind Resistance of Aggregate-surfaced roofs	This is a clarification on the minimum height of a parapet when an aggregate surface roof is used to keep said aggregate from blowing off of the roof	\$0		
1507.1.1	Underlayment	This change will align the IBC roof underlayment requirements with high wind regions with the IRC.	\$0	clears things up and adds some options	
1507.8.1 & 1507.9.1	Deck Requirements	This is clarification on the deck requirements for a wood shingle & shake coverings	\$0		
1511.2.4	Type of Construction for Penthouses	This is a clarification that the exterior walls and roof construction shall be the same as what is required for the type of construction of the building.	\$0 & potential	This change lessens the requirements for fire resistance construction for penthouses	
1511.7.6, 1511.7.6.1 & 1511.7.6.2	Lightning Protection Systems	This is a new section that clarifies that Lightning Protection Systems must be installed in accordance with the roofing component manufacturer's installation instructions	\$0		
151.9 & subsections	Raised-deck systems installed over a roof assembly	This is a new section of the code to give specific design and installation for raised-deck systems.	Will increase the cost of construction	this requirement essential is a non combustible fire blocking provision on the edge of these raised deck systems preventing fire from entering from the perimeter	Currently the IBC does not have any specific provisions for the design and installation of raised-deck systems. These provisions should be a subsection to Section 1511 because these systems are a roof structure over a roof assembly. A definition of "raised deck systems" is needed to ensure correct application of new requirements for these systems. Fundamentally, the concerns were to clarify necessary roof drainage and roof structure support, while not adversely impacting fire safety.
1603.1.4	Wind & Tornado Design Data	Items were changed that now must take in more factors for design that are in a tornado area	Will increase the cost of construction	This will increase the cost of construction to type III and IV Building. These are generally our building that are critical to infrastructure and emergency management. While also including hospitals and buildings with large assembly areas (300+). The intent is not to evaluate buildings to sustain the large high damaged tornado. This new loading is addressing the smaller tornado. While the large tornado cause alot of damage at one time and make the news feeds, they actually cause less damage in dollars amounts year to year compared to smaller less news worthy storms do in an accumulative evaluation.	Tornado hazards have not previously been considered in the design of conventional buildings, despite the fact that tornadoes and tornadic storms cause more fatalities than hurricanes and earthquakes combined (NIST 2014) and more catastrophe insured losses than hurricanes and tropical storms combined (Insurance Information Institute 2021). This gap is addressed for the first time in ASCE 7-22, which now includes requirements for tornado loads. The tornado hazard maps and load methodology are based on a decade of research and development led by the National Institute of Standards and Technology (NIST), in collaboration with ASCE, following the record 2011 tornado season (1,691 tornadoes causing 553 fatalities). ASCE 7-22 requirements for tornado loads apply to Risk Category III and IV buildings and other structures sited in the tornado-prone region, which is approximately equal to the area of the U.S. east of the Continental Divide.
1604.5	Risk Category	All Group I-2 and most Group I-3 occupancies have now been relocated to a Risk Category IV	Will increase the cost of construction	This will apply higher standards to group I-2 (ex. Hospitals) and group 3 (Jail and detention centers)	The code change addresses the intent of the IBC as well as ASCE 7 whereby the codes are interested in providing more protection for buildings with a high concentration of occupants and certain large buildings that in total have 5,000 or more occupants. ASCE 7 intends to improve protection for "Buildings and other structures, the failure of which could pose a substantial risk to human life"
1604.5.2 1607.3.1 & 1607.3.2 1607.6 & 1607.6.1 1607.13.2	Photovoltaic (PV) Panel Systems Partial Loading of Floors and Roofs Helpads & Concentrated Loads Alternative Uniform Live Load Reduction	This is a new section that give guidance on what risk category should be assigned to PV systems, whether mounted on the ground, roof or just elevated. These are two new sections that state that Uniform floor and roof live loads applied to selected spans are permitted to be reduced. This section was rewritten to provide uniform and consistent requirements for helpads This section was changed so it is more in line with the 2022 edition of ASCE/SEI 7 which is a document used by structural engineers	\$0 \$0 \$0 \$0	this brings the IBC up to date with the same provisions as the ASCE/SEI 7 minimum design loads	
Section 1608	Snow Loads	This section was completed revised to address the changes made in ASCE-7-22 Minimum Design Loads and Associated Criteria for Buildings. Previous editions used data for snowfall from 1952 to 1992 and this new document is based on 30 years of additional snow load data	May increase the cost of construction	Snow accumulation data has changed, some area its more some less The code has now become adding, not just dealing with snow loads in the IBC. The factor is found using the ASCE-7 hazard tool	The previous editions of ASCE 7 included mapped values for ground snow load, pg. (GSL) based on a statistical analysis using National Weather Service snowfall data from 1952 to 1992. This map was first included in the 1992 edition of ASCE 7 and was updated with additional information for the 1995 edition. It has remained essentially as it was in 1995 for each subsequent edition through 2016. Additionally, at the time that map was generated, the authors (researchers at the Cold Regions Research and Engineering Laboratory [CRREL] of the US Army Corps of Engineers) marked as Case Study or 'CS' several significant regions, encompassing large parts of eighteen states, where the statistical analysis had not been completed or the data were insufficient to perform the analysis. The CS regions place significant burden on structural engineers to do snow load hazard analysis, and very little guidance has been provided as to how to conduct such studies
Section 1609 1609.5 1609.6.3 & 1609.6.3.1	Wind Loads Tornado Loads Rigid Tile	The notes for the figures have changed to match what is in ASCE-7 Risk category III & IV buildings located in the tornado-prone regions shall be designed in accordance with Chapter 32 of ASCE 7. This section was changed so it is more in line with the 2022 edition of ASCE/SEI 7 which is a document used by structural engineers	\$0 Will increase the cost of construction \$0	See Comment for 1603.1.4	
Section 1611 Section 1613	Rain Loads Earthquake Loads	This section was changed so it is more in line with the 2022 edition of ASCE/SEI 7 which is a document used by structural engineers Seismic Design Category maps were inserted into the code to be more consistent with ASCE/SEI 7-22	\$0 \$0		
1705.2.6	Metal Building Systems	This is a new section that requires special inspections for a metal building system	Will increase the cost of construction	This provision will require the hiring of a special inspector when constructing a pre-engineered metal building system. It is a periodic inspection meaning they don't have to be on site watching the actual install and when scheduled the inspection will most likely be a spot check an inspection of each connection and component	This proposal is complimentary to the proposed changes for metal building systems in Chapter 22. Metal building systems are generally highly optimized structures that are heavily dependent on bracing components to work per the design intent. The bracing components often consist of materials that aren't considered to be "structural steel," and therefore inspection of the completed installation of those critical components are often overlooked.
1705.3	Concrete Special Inspections	Continuous special inspection on welding of reinforcing bar in concrete construction and has been coordinated with ACI 318.	Will decrease the cost of construction	This actually decreases the cost, by breaking out the table more it removes the requirement of a continuous inspection on 2 of the 5 required inspections. This will have a modest decrease in the construction of precast panels	
1807.2.5 & sub sections	Guards for Retaining Walls	Guards are now specified if they are required to be installed on top of retaining walls, more clarification than anything else	\$0	This does not add anything additional requirements than what's required for guards in Chapter 10	
1809.14	Grade Beams	This is a new section to add the same grade beam provisions contained in the Deep Foundation Section	Will increase the cost of construction	Will increase the cost of construction, if the geotechnical report (which is required now) shows the soils aren't capable of support. Grade beams now have design criteria for design	The code change proposal will not, in general, increase or decrease the overall cost of construction. These provisions provide alternatives and options for the designer to select the most economical approach to choose between ductile detailing (beams and ties) or, perhaps, detail a larger foundation or more longitudinal reinforcement. For grade beams in deep foundations, this proposal limits the use of the exception to certain soil conditions which may have a slight cost impact.
1901.2.1	Structural concrete with GFRP reinforcement	This adds a new referenced standard	\$0	Code Development Committees implied no change in cost of construction. From conversations I've had with contractors they say GFRP reinforcement is a big labor savings due to its ease of working with over traditional metal bar	
Section 1905 Section 1907	Seismic Requirements Slabs-On-Ground	This section is being reformatted to be in align with ACI 318-19 This section is reformatted with a new name "slabs-on-ground from just minimum slab provisions	\$0 \$0		
Section 2201 2303.2.1 2303.2.6 and subsections 2304.10.1	Steel Alternate Fire Testing Design Values Fire Protection of connections	This whole section was reformatted to provide better flow, usability and clarification of steel provisions This section was added to provide a new standard specifically for fire-retardant-treated wood. This section is revised to clarify that design values for fire-retardant-treated wood products are subject to all the adjustments for untreated wood products This revises the title and description to avoid using the term fire-resistance rating as it applies to connections	\$0 \$0 \$0 \$0		
2305.1.2	Permanent Load Duration	This is revised to use "wood shear walls" and "wood diaphragms" instead of "wood-frame" shear walls and diaphragms in both wood-frame and cross-laminated timber shear walls.	\$0		
2306.1.3 & 2306.1.4	Preservative-treated & fire-retardant-treated wood allowable stresses	These two types of woods are separated into their own section now because they are handled differently	\$0		
2308.2.7	Hillside light-frame construction	This is added to provide correlation between the IBC and the IRC along with a modification made by ASCE/SEI 7-22	Will increase the cost of construction	This will increase the number of buildings requiring engineering for building on moderate/ steep to very steep sites	This proposal provides correlation between the prescriptive provisions of IBC Section 2308 and the provisions of IRC Section R301.2.2.6 Item 8, added in the 2021 IRC with the intent of improving the seismic performance of wood-light-frame hillside buildings. A related modification has been made in ASCE/SEI 7-22 to provide additional guidance to engineers designing wood light-frame hillside buildings.
2308.3, 2308.4 & 2308.6 & subsections	limitations of conventional light-frame construction cutting, notching & boring of dimensional wood framing	This code change is to emphasize the limitations on story height for conventional construction this takes the language from the other I-codes and puts it in the IBC	\$0 \$0	This is a realignment of the chapter	

2308.11.4 & Table 2308.11.4	Wind Uplift	This was added to update the roof to wall connection loads to comply with the IBC referenced standard ASCE 7-16. A new exception was added to allow the truss to wall connection to be designed using either the loads on the truss design drawings or the construction documents	Will increase the cost of construction	This is going to be a cost increase in areas with higher basic wind speed and the previous charts were wrong.	The reason for this code change is to update the roof to wall connection loads to comply with the IBC referenced wind design standard, ASCE 7-16. The current loads are based on a very old version of ASCE 7. That can be seen by the use of the term V-assd. ASD wind loads have not been used since ASCE 7-10. The wind uplift loads need to be updated to the Ultimate Wind Speeds (now just called Basic Design Wind Speeds) used in ASCE 7-16 (and ASCE 7-22). That way the windspeeds will match the required Basic Design Windspeeds of Figures 1609.3(1) through 1609.3(12).
2405.3 & subsections	Screening	This section was reformatted to correct and inaccurate reference and did their best to make the language clearer	\$0		
2406.1	Human Impact Loads	This is a clarification that all panes of glazing in a multi-pane glass assembly shall be safety glazing, not just the outer panes.	Will increase the cost of construction	An example of cost increase a window close to a shower, only the interior pane is required to be safety glazed, with this provision both interior and exterior pane in a double hung ae now required.	In recent months, the glass industry has received reports of multi-pane glass assemblies imported from outside the United States where the outermost panes are marked as safety glazing, but center pane(s) in these multi-pane assemblies, are annealed glass which breaks dangerously when broken by human impact. Nothing in either safety glazing standard - namely CPSC-16 CFR 1201 and ANSI Z97.1 - prohibits this since they establish acceptance criteria ONLY for individual glass panes, not for multi-paneled glass assemblies. Accordingly, the adoption of this proposal is critical to ensure that multi-pane glass assemblies installed in hazardous locations are safe in the event of human impact and to ensure that potentially dangerous annealed panes of glass are not intermingled with safety glazing in multi-pane glass assemblies.
2406.4.3	Glazing in Windows	The term or adjacent walking surface was added in an attempt to fix the existing format to make things more clear. And also removed" 25' above any grade roof or walking surface" for the exterior of the building reduced to 6'	Will decrease the cost of construction	This is a clarification and will reduce the cost if the 25' on the exterior was actually being enforced	
2603.1.2	Insulating Sheathing	This section and table were added to reference applicable standards that govern material characteristics	\$0		
2603.4.1.4	Exterior walls, one story buildings	This introduces a new definition of Insulated metal panels (IMPs) specifically designed and used for wall and roof application of the building assembly.	\$0		
2603.4.1.15	Separately controlled climate structures	This section requires foam plastic to be covered by a metal facing with the foam up to a maximum of 4 inches and more than that it must be protected by a thermal barrier	\$0		
Section 2703	Lightning Protection Systems	This new section gives guidance on lightning protection systems where provided.	\$0	The standards are already used in the installation of these systems, they are just now being brought into the code	
2902.1 & Table 2902.1	Minimum Number of Fixtures	Additional and more detailed occupancies are given for fixture counts	\$0		
2902.1.2	Fixtures in single-user toilet facilities and bathing rooms	This gives more explanation when calculating the number of fixtures required	\$0		
2902.3.6	Door Locking	There is now the availability to lock a multi-user toilet room provided 3 conditions are met.	\$0		
3001.2	Elevator Emergency Communication Systems	The two way communication includes both visual and audible means of communicating. It now references ASME A17.1 for the technical provisions	\$0		
3006.3	Elevator Hoistway Door Protection	A smoke-protective curtain assembly is now an allowable way to protect the Hoistway doors.	\$0		
Section 3009	Private Residence Elevators	A new section for private residence elevators has been added	\$0		
3103.1.1	Extended Period of Service Time for Temporary Structures	This gives specifics for temporary structures extending their service for up to 1 year	\$0		
Section 3302	Owner's Responsibility for Fire Protection	This is a new section detailing what the owners responsibility is during all phases of construction, repair, alteration or demolition work	\$0		

Appendix B

Code Changes to the 2024 International Energy Conservation Code (IECC) – Commercial Provisions

Mod Number	Summary - Text of Mod																		
CE#1	Clarifies how the commercial energy code applies.																		
Related mod: CED1-2- 22	<div>C101.2 Scope. This code applies to commercial buildings and the buildings' sites and associated systems and equipment the design and construction of buildings not covered by the scope of the IECC—Residential Provisions.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	ALC	D	D/C				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
	X																		
Action	AS	ALC	D	D/C															
			X																
CE#2	A new clarification subsection states that appendices are not applicable unless adopted.																		
Related mod: CED1-2- 22	<div>C101.2.1 Appendices. Provisions in the appendices shall not apply unless specifically adopted</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	ALC	D	D/C				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
	X																		
Action	AS	ALC	D	D/C															
			X																
CE#3	Provides expanded clarification on the intent of this code.																		
Related mod: CED1-1- 22	<div>C101.3 Intent. This code shall regulate the design and construction of buildings for the effective use and conservation of energy over the useful life of each building. This code is intended to provide flexibility to permit the use of innovative approaches and techniques to achieve this objective. This code is not intended to abridge safety, health or environmental requirements contained in other applicable codes or ordinances. The IECC—Commercial Provisions provide market-driven, enforceable requirements for the design and construction of commercial buildings, providing minimum efficiency requirements for buildings that result in the maximum level of energy efficiency that is safe, technologically feasible, and life-cycle cost effective, considering economic feasibility, including potential costs and savings for consumers and building owners, and return on investment. Additionally, the code provides jurisdictions with supplemental requirements, including ASHRAE 90.1, and optional requirements that lead to achievement of zero energy buildings, presently, and through glidepaths that achieve zero energy buildings by 2030 and on additional timelines sought by governments, and achievement of additional policy goals as identified by the Energy and Carbon Advisory Council and approved by the Board of Directors. Requirements contained in the code will include, but not be limited to, prescriptive- and performance-based pathways. The code International Code Council and others. The code will aim to simplify code requirements to facilitate the code's use and compliance rate. The code is updated on a 3-year cycle with each subsequent edition providing increased energy savings over the prior edition. This code is intended to provide flexibility to permit the use of innovative approaches and techniques to achieve this intent. This code is not intended to abridge safety, health or environmental requirements contained in other applicable codes or ordinances.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	ALC	D	D/C				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
	X																		
Action	AS	ALC	D	D/C															
			X																
CE#4	Renumbers sub-section C101.5.1 to C101.4.1. Creates new Section C102. Created by moving an existing Section.																		
Related Mod: CED1-1- 22	<div>C101.5C101.4 Compliance. Residential buildings shall meet the provisions of IECC—Residential Provisions. Commercial buildings shall meet the provisions of IECC—Commercial Provisions.</div> <div>C101.5.1C101.4.1 Compliance materials. The code official shall be permitted to approve specific computer software, worksheets, compliance manuals and other similar materials that meet the intent of this code:</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	ALC	D	D/C				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
	X																		
Action	AS	ALC	D	D/C															
			X																
CE#5	Moves and Renumbers Section C101.4. Renames C102.5 to Partial Invalidity																		
Related Mod:	<div>SECTION C102 APPLICABILITY</div> <div>C101.4C102.1 Applicability. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern.</div> <div>C101.4.1C102.1.1 Mixed residential and commercial buildings. Where a building includes both residential building and commercial building portions, each portion shall be separately considered and meet the applicable provisions of IECC—Commercial Provisions or IECC—Residential Provisions.</div> <div>C108.3C102.2 Other laws. The provisions of this code shall not be deemed to nullify any provisions of local, state or federal law.</div> <div>C108.2C102.3 Applications of references. References to chapter or section numbers, or to provisions not specifically identified by number, shall be construed to refer to such chapter, section or provision of this code.</div> <div>C108.1C102.4 Referenced codes and standards. The codes and standards referenced in this code shall be those listed in Chapter 6, and such codes and standards shall be considered as part of the requirements of this code to the prescribed extent of each such reference and as further regulated in Sections C102.4.1 and C102.4.2.</div> <div>C108.1.1C102.4.1 Conflicts. Where conflicts occur between provisions of this code and referenced codes and standards, the provisions of this code shall apply.</div> <div>C108.1.2C102.4.2 Provisions in referenced codes and standards. Where the extent of the reference to a referenced code or standard includes subject matter that is within the scope of this code, the provisions of this code, as applicable, shall take precedence over the provisions in the referenced code or standard.</div> <div>C107.1C102.5 General Partial Invalidity. If a portion of this code is held to be illegal or void, such a decision shall not affect the validity of the remainder of this code.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				X	Action	AS	ALC	D	D/C				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
			X																
Action	AS	ALC	D	D/C															
			X																
The original text of mod is not consistent with that of the 2023 FBC – EC.																			

The original text of mod is not consistent with that of the 2023 FBC – EC.

CE#6	Created new Section C103. And New Sub sections C103.1 through C103.3																		
Related Mod: CED1-3- 22	<div>SECTION C103</div> <div>CODE COMPLIANCE AGENCY</div> <div><p>C103.1 Creation of enforcement agency. The [INSERT NAME OF DEPARTMENT] is hereby created and the official in charge thereof shall be known as the authority having jurisdiction (AHJ). The function of the agency shall be the implementation, administration and enforcement of the provisions of this code.</p><p>C103.2 Appointment. The AHJ shall be appointed by the chief appointing authority of the jurisdiction.</p><p>C103.3 Deputies. In accordance with the prescribed procedures of this jurisdiction and with the concurrence of the appointing authority, the AHJ shall have the authority to appoint a deputy AHJ, other related technical officers, inspectors and other employees. Such employees shall have powers as delegated by the AHJ.</p></div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>IS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>			Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AL/EC	IS				x
Staff Classification	Correlates Directly	Energy Standard	Over lap																
	x																		
Action	AS	AL/EC	IS																
			x																
CE#7	Renumbers Section C102. Renumbers C104.1.1.																		
Related Mod: CED1-3- 22	<div>SECTION C102C104</div> <div>ALTERNATIVE MATERIALS, DESIGN AND METHODS OF CONSTRUCTION AND EQUIPMENT</div> <div><p>102.1C104.1 General.—The provisions of this code are not intended to prevent the installation—of any material or to prohibit any design or method of construction not specifically prescribed by—this code, provided that any such alternative has been—<i>approved</i>—.The <i>code official</i>—shall have—t he authority to approve an alternative material, design or method of construction upon the written application of the <i>owner</i>— or the owner's authorized agent.—The <i>code official</i>—shall first find that the proposed design is satisfactory and complies with the intent of the provisions of this code, and—that the material, method or work offered is, for the purpose intended, not less than the equivalent—of that prescribed in this code in quality, strength, effectiveness,—<i>fire resistance</i>—, durability, energy conservation and safety. The <i>code official</i>—shall respond to the applicant, in writing, stating the reason s why the alternative was <i>approved</i>— or was not <i>approved</i>—.</p><p>C102.1.1C104.1.1 Above code programs. The <i>code official</i>— or other authority having jurisdiction shall be permitted to deem a national, s tate or local energy efficiency program as exceeding the energy efficiency required by this code. Buildings—<i>approved</i>— in writing by such— an energy efficiency program shall be considered to be in compliance with this code. The requirements identified in Table C407.2 Table C 407.2(1) shall be met.</p></div> <div><p>The original text of mod is not consistent with that of the 2023 FBC – EC.</p></div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>IS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>			Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				x	Action	AS	AL/EC	IS				x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			x																
Action	AS	AL/EC	IS																
			x																
CE#8	Renumbers C103																		
Related Mod: CED1-2- 22	<div>SECTION C103C105</div> <div>CONSTRUCTION DOCUMENTS</div> <div><p>C103.1C105.1 General.—<i>Construction documents</i>— and other supporting data shall be submitted—in one or more sets, or in a digital format where allowed by the b y uilding <i>code official</i>—, with each application for a permit. The <i>construction documents</i>— shall be prepared b a <i>registered design professional</i>— where required by the sta n tutes of the jurisdiction in which the project is to be constructed. Where special conditions exist, the <i>code official</i> is authorized to require necessary <i>construction documents</i> to be prepared by a <i>registered desig professional</i>.</p></div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>IS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>			Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AL/EC	IS				x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	AL/EC	IS																
			x																
CE#9	Renumbers sub-section C103.2. Added four new construction document requirement items to the existing lists: • Thermal bridges as identified in Section C402.6.																		
	<ul style="list-style-type: none">• Location reserved for inverters, metering equipment, and energy storage systems (ESS), and a pathway reserved for routing raceways or conduits from the renewable energy system to the point of interconnection with the electrical service and the ESS.• The location of pathways for routing raceways or cable from the on-site renewable energy system to the electrical distribution equipment.• Location and layout of a designated area for ESS.• Rated energy capacity and rated power capacity of the installed or panned ESS.																		
Related Mod: CED1-2- 22, CECP1-2- 21, CEDP1-4- 21, CEPI- 7-21	<div><p>C103.2C105.2 Information on construction documents.—<i>Construction—documents—</i> shall— be drawn to scale on suitable material: Electronic media documents are permitted to be submitted where <i>approved</i> by the <i>code official</i> . <i>Construction documents</i> shall be of sufficient clarity to indicate the location, nature and extent of the work proposed, and show in sufficient detail pertinent data and features of the <i>building</i> , systems and equipment as herein governed. Details shall include, but are not limited to, the following as applicable:</p><ol style="list-style-type: none">1. Energy compliance path.2. Insulation materials and their <i>R</i> -values.3. Fenestration <i>U</i>-factors and solar heat gain coefficients (SHGC).4. Area-weighted <i>U</i>-factor and solar heat gain coefficient (SHGC) calculations.5. <i>Air barrier</i> and air sealing details, including the location of the <i>air barrier</i> .6. <i>Thermal bridges</i> as identified in Section C402.6.6-7- Mechanical system design criteria.6-8- Mechanical and service water heating systems and equipment types, sizes and efficiencies.7-9- Economizer description.8-10- Equipment and system controls.9-11- Fan motor horsepower (hp) and controls.10-12- Duct sealing, duct and pipe insulation and location.11-13- Lighting fixture schedule with wattage and control narrative.12-14- Location of daylight zones on floor plans.15. Location of pathways for routing of raceways or cable from the on-site renewable energy system to the electrical distribution equipment.13-16- Air barrier and air sealing details, including the location of the air barrier.Location reserved for inverters, metering equipment and energy storage systems (ESS), and a pathway reserved for routing of raceways or conduit from the renewable energy system to the point of interconnection with the electrical service and the ESS.17. Location and layout of a designated area for ESS.18. Rated energy capacity and rated power capacity of the installed or planned ESS.</div> <div><p>C103.2.1C105.2.1 Building thermal envelope depiction. The <i>building thermal envelope</i> shall be represented on the construction drawings.</p></div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>IS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>			Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AL/EC	IS				x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	AL/EC	IS																
			x																

CE#10	Renumbers C103.3 through C103.5		
Related Mod: CE20-29-23	<p>C103.3C105.3 Examination of documents. C103.3.1C105.3.1 Approval of construction documents</p> <p>C103.3.2C105.3.2 Previous approvals.</p> <p>C103.3.3C105.3.3 Phased approval</p> <p>C103.4C105.4 Amended construction documents C103.5C105.5 Retention of construction documents:</p>		
CE#11	<p>Renumbers Section C103.6 and sub-sections C103.6.1, C103.6.2, and C103.6.3.</p> <p>Adds a new planning requirement for annual energy use data gathering and disclosure as specified per the energy monitoring section C405.13.</p>		
Related Mod: CE20-29-23	<p>C103.6C105.6 Building documentation and closeout submittal requirements. The construction documents shall specify that the documents described in this section be provided to the building owner or owner's authorized agent within 90 days of the date of receipt of the certificate of occupancy.</p> <p>C103.6.1C105.6.1 Record documents. Construction documents shall be updated to convey a record of the completed work. Such updates shall include mechanical, electrical and control drawings that indicate all changes to size, type and location of components, equipment and assemblies.</p> <p>C103.6.2C105.6.2 Compliance documentation. Energy code compliance documentation and supporting calculations shall be delivered in one document to the building owner as part of the project record documents or manuals, or as a standalone document. This document shall include the specific energy code edition utilized for compliance determination for each system, documentation demonstrating compliance with Section C303.4.3 for each fenestration product installed, and the interior lighting power compliance path, building area or space-by-space, used to calculate the lighting power allowance.</p> <p>For projects complying with Item 2 of Section C401.2, the documentation shall include:</p> <ol style="list-style-type: none"> 1. The envelope insulation compliance path. 2. All compliance calculations including those required by Sections C402.1.4, C403.8.1, C405.3 and C405.5. 3. A plan for annual energy use data gathering and disclosure as specified in Section C405.13. <p>For projects complying with Section C407, the documentation shall include that required by Sections C407.3.1 and C407.3.2.</p> <p>C103.6.3C105.6.3 Systems operation control.</p> <p>The original text of mod is not consistent with that of the 2023 FBC – EC.</p>		
CE#12	Renumbers Section C104. Renumbers C104.1-C104.5		
Related Mod: CEPI-8-21-PI	<p>SECTION E104C106 FEES</p> <p>C104.1C106.1 Fees. A permit shall not be issued until the fees prescribed in Section C106.2 by law have been paid, nor shall an amendment to a permit be released until the additional fee, if any, has been paid.</p> <p>C104.2C106.2 Schedule of permit fees. A fee for each permit shall be paid as required, in accordance with the schedule as established by the applicable governing authority.</p> <p>C106.3 Valuation of work. The applicant for a permit shall provide an estimated value of the work for which the permit is being issued at the time of application. Such estimated valuations shall include the total value of the work, including materials and labor. Where, in the opinion of the code official, the valuation is underestimated, the permit shall be denied unless the applicant can show detailed estimates acceptable to the code official. The final valuation shall be approved by the code official.</p> <p>C104.3C106.4 Work commencing before permit issuance. Any person who commences any work before obtaining the necessary permits shall be subject to an additional fee established by the code official that shall be in addition to the required permit fees.</p> <p>C104.4C106.5 Related fees. The payment of the fee for the construction, alteration, removal or demolition of work done in connection to or concurrently with the work or activity authorized by a permit shall not relieve the applicant or holder of the permit from the payment of other fees that are prescribed by law.</p> <p>C104.5C106.6 Refunds. The code official is authorized to establish a refund policy.</p> <p>The original text of mod is not consistent with that of the 2023 FBC – EC.</p>		
CE#13	Renumbers C105. Renumbers C105.1, C105.2, C105.2.1 through C105.2.6.		
Related Mod: CED1-5-22, CED1-87-22, CED1-92-22, CEPI-7-21	<p>SECTION E107C112 VALIDITY</p> <p>SECTION C105C107 INSPECTIONS</p> <p>C105.1C107.1 General. C105.2C107.2 Required inspections:</p> <p>C105.2.1C107.2.1 Footing and foundation insulation. Inspections shall verify the footing and foundation insulation R-value, location, thickness, depth of burial and protection of insulation as required by the code, approved plans and specifications.</p> <p>C105.2.2C107.2.2 Thermal building thermal envelope. Inspections shall verify the correct type of insulation, R-values, location of insulation, thermal bridge mitigation, fenestration, U-factor, SHGC and VT, and that air leakage controls are properly installed, as required by the code, approved plans and specifications.</p> <p>C105.2.3C107.2.3 Plumbing system. Inspections shall verify the type of insulation, R-values, protection required, controls and heat traps as required by the code, approved plans and specifications.</p> <p>C105.2.4C107.2.4 Mechanical system. Inspections shall verify the installed HVAC equipment for the correct type and size, controls, insulation, R-values, system and damper air leakage, minimum fan efficiency, energy recovery and economizer as required by the code, approved plans and specifications.</p> <p>C105.2.5C107.2.5 Electrical system. Inspections shall verify lighting system controls, components and meters as required by the code, approved plans and specifications. Where an ESS area is required, inspections shall verify space availability and pathways to electrical services.</p> <p>C105.2.6C107.2.6 Final inspection. The final inspection shall include verification of the installation and proper operation of all required building controls, and documentation verifying activities associated with required building commissioning have been conducted in accordance with Section C408</p>		
	<p>The original text of mod is not consistent with that of the 2023 FBC – EC.</p>		

CE#14	Renumbers C105.3 through C105.6																
Related Mod: CED1-5- 22, CED1-87- 22, CED1-92- 22, CEPI-7-21	<div>C105.3C107.3 Reinspection</div> <div>C105.4C107.4 Approved inspection agencies. C105.5C107.5 Inspection requests.</div> <div>C105.6C107.6 Reinspection and testing.</div> <div>The original text of mod is not consistent with that of the 2023 FBC – EC.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>MS/C</td><td>D</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				x	Action	AS	MS/C	D				x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
			x														
Action	AS	MS/C	D														
			x														
CE#15	Deletes C108. Renumbers and renamed Section C106. Renumbers C108.1, C108.2																
Related Mod:	<div>SECTION C108C109 REFERENCED STANDARDS</div> <div>SECTION C106C108 NOTICE OF APPROVAL</div> <div>C106.1C108.1 Approval. After the prescribed tests and inspections indicate that the work complies in all respects with this code, a notice of approval shall be issued by the code official .</div> <div>C106.2C108.2 Revocation:</div> <div>The original text of mod is not consistent with that of the 2023 FBC – EC.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>MS/C</td><td>D</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap				x	Action	AS	MS/C	D				x
Staff Classification	Correlates Directly	Energy Standard	Over lap														
			x														
Action	AS	MS/C	D														
			x														
CE#16	Renumbers and renamed Section C110. Adds new Section C109.4. The code official must take action per the board's decision.																
Related Mod: CED1-6- 22, CEC2D-4-23 Part I,	<div>SECTION C110C109 BOARD MEANS OF APPEALS</div> <div>C110.1C109.1 General. In order to hear and decide appeals of orders, decisions or determinations made by the code official relative to the application and interpretation of this code, there shall be and is hereby created a board of appeals. The code official shall be an ex officio member of said board but shall not have a vote on any matter before the board. The board of appeals shall be appointed by the governing body authority and shall hold office at its pleasure. The board shall adopt rules of procedure for conducting its business, and shall render all decisions and findings in writing to the appellant with a duplicate copy to the code official .</div> <div>C110.2C109.2 Limitations on authority. An application for appeal shall be based on a claim that the true intent of this code or the rules legally adopted thereunder have been incorrectly interpreted; the provisions of this code do not fully apply or an equally good or better form of construction is proposed. The board shall not have authority to waive requirements of this code.</div> <div>C110.3C109.3 Qualifications. The board of appeals shall consist of members who are qualified by experience and training on matters pertaining to the provisions of this code and are not employees of the jurisdiction.</div> <div>C109.4 Administration. The code official shall take action in accordance with the decisions of the board.</div> <div>The original text of mod is not consistent with that of the 2023 FBC – EC.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>MS/C</td><td>D</td></tr><tr><td></td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap					Action	AS	MS/C	D				
Staff Classification	Correlates Directly	Energy Standard	Over lap														
Action	AS	MS/C	D														
CE#17	Renumbers Section C109. Renumbers Sections C109.1 through C109.4.																
Related Mod:	<div>SECTION C109C110 STOP WORK ORDER</div> <div>C109.1C110.1 Authority. Where the code official finds any work regulated by this code being performed in a manner contrary to the provisions of this code or in a dangerous or unsafe manner, the code official is authorized to issue a stop work order.</div> <div>C109.2C110.2 Issuance. The stop work order shall be in writing and shall be given to the owner of the property; the owner's authorized agent or the person performing the work. Upon issuance of a stop work order, the cited work shall immediately cease. The stop work order shall state the reason for the order and the conditions under which the cited work is authorized to resume.</div> <div>C109.3C110.3 Emergencies. Where an emergency exists, the code official shall not be required to give a written notice prior to stopping the work.</div> <div>C109.4C110.4 Failure to comply. Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to fines established by the AHJ.</div> <div>The original text of mod is not consistent with that of the 2023 FBC – EC.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>MS/C</td><td>D</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				x	Action	AS	MS/C	D				x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
			x														
Action	AS	MS/C	D														
			x														
CE#18	Renames "Air Curtain" and edits the definition.																
Related Mod: CEPI-72- 21	<div>AIR CURTAIN. A device, installed at the building entrance, that generates and discharges a laminar air stream intended to prevent the infiltration of external, unconditioned air into the conditioned spaces, or the loss of interior, conditioned air to the outside.</div> <div>AIR CURTAIN UNIT. A device installed at the building entrance that generates and discharges a laminar airstream intended to prevent the infiltration of external, unconditioned air into the conditioned spaces or the loss of interior, conditioned air to the outside.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>MS/C</td><td>D</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				x	Action	AS	MS/C	D				x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
			x														
Action	AS	MS/C	D														
			x														
CE#19	Adds new definition																
Related Mod: CEPI-32- 21	<div>AIR LEAKAGE. The uncontrolled airflow through the building thermal envelope caused by pressure differences across the building thermal envelope. Air leakage can be inward (infiltration) or outward (exfiltration) through the building thermal envelope .</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>MS/C</td><td>D</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				x	Action	AS	MS/C	D				x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
			x														
Action	AS	MS/C	D														
			x														
CE#20	Adds new definition																

Related Mod: CEPI- 225-21	APPROVED SOURCE. An independent person, firm or corporation approved by the code official, who is competent and experienced in the application of engineering principles to materials, methods or systems analyses.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D															
		X	D/EC															
CE#21	Adds new definition																	
Related Mod: CEPI-83- 21	BEST EFFICIENCY POINT (BEP). The pump hydraulic power operating point (consisting of both flow and head conditions) that results in the maximum efficiency.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D															
		X	D/EC															
CE#22	Corrects error in text																	
Related Mod:	BIOGAS. A mixture of hydrocarbons that is a gas at 60°F (15.5°C) and 1 atmosphere of pressure that is produced through the anaerobic digestion of organic matter.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table> <p>The original text of mod is not consistent with that of the 2023 FBC – EC.</p>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
			X															
Action	AS	AS/EC	D															
		X	D/EC															
CE#23	Deletes Biomass. Adds new definition																	
Related Mod: CEPI-12- 21 Part I	BIOMASS. Nonfossilized and biodegradable organic material originating from plants, animals and/or microorganisms, including products, by-products, residues and waste from agriculture, forestry and related industries as well as the nonfossilized and biodegradable organic fractions of industrial and municipal wastes, including gases and liquids recovered from the decomposition of nonfossilized and biodegradable organic material. BIOMASS WASTE. Organic nonfossil material of biological origin that is a byproduct or a discarded product. Biomass waste includes municipal solid waste from biogenic sources; landfill gas; sludge waste; agricultural crop byproducts; straw; and other biomass solids, liquids and biogases, but excludes wood and wood-derived fuels (including black liquor), biofuel feedstock, biodiesel and fuel ethanol.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table> <p>The original text of mod is not consistent with that of the 2023 FBC – EC.</p>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
			X															
Action	AS	AS/EC	D															
		X	D/EC															
CE#24	Adds new definition																	
Related Mod: CECP1-4- 21	CHI-FACTOR (χ-FACTOR). The heat loss factor for a single thermal bridge characterized as a point element of a building thermal envelope (Btu/h × °F) [W/k].	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D															
		X	D/EC															
CE#25	Adds new definition																	
Related Mod: CEPI-83- 21	CLEAN WATER PUMP. A device that is designed for use in pumping water with a maximum nonabsorbent free solid content of 0.016 lb/ft³ (0.256 kg/m³) and with a maximum dissolved solid content of 3.1 lb/ft³ (49.66 kg/m³), provided that the total gas content of the water does not exceed the saturation volume, and disregarding any additives necessary to prevent the water from freezing at a minimum of 14°F (-10°C).	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D															
		X	D/EC															
CE#26	Adds new definition																	
Related Mod: RED1- 360-22	COMMON AREAS. All conditioned spaces within Group R occupancy buildings that are not dwelling units or sleeping units .	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D															
		X	D/EC															
CE#27	Adds new definition																	
Related Mod: CECP1-5- 21, CECP1-2- 21	COMMUNITY RENEWABLE ENERGY FACILITY. A facility that produces energy harvested from renewable energy resources and is qualified as a community energy facility under applicable jurisdictional statutes and rules.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D															
		X	D/EC															
CE#28	Adds new definition																	
Related Mod: CEC2D- 3-23	CONGREGATE LIVING FACILITIES. A building or part thereof that contains sleeping units where residents share bathroom or kitchen facilities, or both.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	D/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D															
		X	D/EC															
CE#29	Adds new definition																	
Related Mod:	CONSTRUCTION DOCUMENTS. Written, graphic and pictorial documents prepared or assembled for describing the design, location and physical characteristics of the elements of a project necessary for obtaining a building permit.																	

CEPI- 225- 21		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td>D/IC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D		X		D/IC				
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					
Action	AS	AS/IC	D																			
	X		D/IC																			
CE#30	Adds new definition																					
Related Mod: CEPI-14- 21	<p>DEDICATED OUTDOOR AIR SYSTEM (DOAS). A ventilation system that supplies 100 percent outdoor air primarily for the purpose of <i>ventilation</i> and that is a separate system from the <i>zone</i> space-conditioningsystem.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>D/IC</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/IC	D				D/IC			X	
Staff Classification	Correlates Directly	Energy Standard	Over lap																			
	X																					
Action	AS	AS/IC	D																			
			D/IC																			
		X																				
CE#31	Adds new definition																					
Related Mod: CEPI-84- 21	<p>DEHUMIDIFIER. A self-contained, electrically operated and mechanically enclosed product with the sole purpose of dehumidifying the space consisting of the following:</p> <ol style="list-style-type: none">1. A refrigerated surface (evaporator) that condenses moisture from the atmosphere.2. A refrigerating system, including an electric motor.3. An air-circulating fan.4. A means for collecting or disposing of the condensate. <p>A dehumidifier does not include a portable air conditioner, room air conditioner or packaged terminal air conditioner.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>D/IC</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D				D/IC			X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					
Action	AS	AS/IC	D																			
			D/IC																			
		X																				
CE#32	Adds new definition																					
Related Mod: CEPI-9- 21	<p>DEMAND CONTROL KITCHEN VENTILATION (DCKV). A system that provides <i>automatic</i> , continuous control over exhaust hood and makeup air fan speed in response to temperature, optical or infrared (IR) sensors that monitor cooking activity or through direct communication with cooking appliances.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td>D/IC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D		X		D/IC				
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					
Action	AS	AS/IC	D																			
	X		D/IC																			
CE#33	Adds new definition																					
Related Mod: CEPI-9- 21	<p>DEMAND RESPONSE SIGNAL. A signal that indicates a price or a request to modify electricity consumption for a limited time period.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>D/IC</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D				D/IC			X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					
Action	AS	AS/IC	D																			
			D/IC																			
		X																				
CE#34	Adds new definition																					
Related Mod: CEPI-99- 21	<p>DEMAND RESPONSIVE CONTROL. A control capable of receiving and automatically responding to a <i>demand response signal</i> .</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td>D/IC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D		X		D/IC				
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					
Action	AS	AS/IC	D																			
	X		D/IC																			
CE#35	Adds new definition																					
Related Mod: CEPI-84- 21	<p>DESSICANT DEHUMIDIFICATION SYSTEM. A mechanical dehumidification technology that uses a solid or liquid material to remove moisture from the air.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>D/IC</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D				D/IC			X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					
Action	AS	AS/IC	D																			
			D/IC																			
		X																				
CE#36	Adds new definition																					
Related Mod: CEPI-14- 21	<p>DX-DEDICATED OUTDOOR AIR SYSTEM UNIT (DX-DOAS UNIT). A type of air-cooled, water-cooled or water source factory-assembled product that dehumidifies 100 percent outdoor air to a low dew point and includes reheat that is capable of controlling the supply dry-bulb temperature of the dehumidified air to the designated supply air temperature. It may precondition outdoor air with an <i>energy recovery ventilation system</i> .</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td>D/IC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D		X		D/IC				
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					
Action	AS	AS/IC	D																			
	X		D/IC																			
CE#37	Adds new definition																					
Related Mod: CEPI- 121-22	<p>EAST-ORIENTED. Facing within 45 degrees of true east to the south and within less than 22.5 degrees of true east to the north in the northern hemisphere or facing within 45 degrees of true east to the north and within less than 22.5 degrees of true east to the south in the southern hemisphere.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td>D/IC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/IC	D		X		D/IC				
Staff Classification	Correlates Directly	Energy Standard	Over lap																			
	X																					
Action	AS	AS/IC	D																			
	X		D/IC																			
CE#38	Modified an existing definition.																					
Related Mod: CE2D-4- 23	<p>EMITTANCE. The ratio of the radiant heat flux emitted by a specimen measured on a scale from 0 to 1, where a value of 1 indicates perfect release of thermal radiation.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td>D/IC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/IC	D		X		D/IC				
Staff Classification	Correlates Directly	Energy Standard	Over lap																			
	X																					
Action	AS	AS/IC	D																			
	X		D/IC																			
CE#39	Adds new definition																					
Related Mod: CEPI- 112-21	<p>ENERGY RECOVERY, SERIES. A three-step process in which the first step is to remove energy from a single airstream without the use of mechanical cooling. In the second step, the airstream is mechanically cooled for the purpose of dehumidification. In the third step, the energy removed in the first step is reintroduced to the airstream.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X														
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																			
	X																					

[illegible]

Related Mod: CEPI- 119-21		FAN SYSTEM, SINGLE-CABINET. A fan system that supplies air to a space and recirculates the air, wherein a single cabinet houses a single fan, a single fan array , a single set of fans operating in parallel or fans or fan arrays in series.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
	X																		
CE#51	Adds new definition																		
Related Mod: CEPI- 119-21		FAN SYSTEM, TRANSFER. A fan system that exclusively moves air from one occupied space to another.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
	X																		
CE#52	Adds new definition																		
Related Mod: CEPI- 119-21		FAN SYSTEM AIRFLOW. The sum of the airflow of all fans with fan electrical input power greater than 1 kW at fan system design conditions , excluding the airflow that passes through downstream fans with fan electrical input	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
	X																		
CE#53	Modified an existing definition for clarity.																		
Related Mod: CECPI-4- 21		F-F ACTOR. The perimeter heat loss factor per unit perimeter length of for-slab-on-grade floors $(\text{Btu/h} \times \text{ft} \times \text{T}) / (\text{W}/(\text{m} \times \text{K}))$.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D				X
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
			X																
CE#54	Adds new definition																		
Related Mod: CECPI-2- 21		FINANCIAL RENEWABLE ENERGY POWER PURCHASE AGREEMENT. A financial arrangement between a renewable electricity generator and a purchaser wherein the purchaser pays or guarantees a price to the generator for the project's renewable generation. Also known as a "financial power purchase agreement" and "virtual power purchase agreement."	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
		X																	
CE#55	Adds new definition																		
Related Mod: CED1- 208-22		GREEN RETAIL TARIFF. An electricity-rate structure qualified under applicable statutes or rules contracted by an electricity service provider to the building project owner to provide electricity generated with 100 percent renewable energy resources without the purchase of unbundled renewable energy certificates (RFEs).	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D			X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
		X																	
CE#56	Modified an existing definition.																		
Related Mod: CEPI- 185-21		GREENHOUSE. A structure or a thermally isolated area of a building that maintains a specialized sunlit environment with a skylight roof ratio of 50 percent or more above the growing area exclusively used for, and essential to, the cultivation, protection or maintenance of plants. Greenhouses are those that are erected for a period of 180 days or more	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
	X																		
CE#57	Adds new definition																		
Related Mod: CE2D-5- 23		HIGH-CAPACITY GAS-FIRED WATER HEATER. Gas-fired instantaneous water heaters with a rated input greater than 200,000 Btu/h (58.6 kW) and not less than 4,000 Btu/h per gallon (310 W per liter) of stored water. Also, gas-fired storage water heaters with a rated input both greater than 105,000 Btu/h (30.8 kW) and less than 4,000 Btu/h per gallon (310 W per liter) of stored water.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D				X/EC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
			X/EC																
CE#58	Adds new definition																		
Related Mod: CEPI- 185-21		HORTICULTURAL LIGHTING. Electric lighting used for horticultural production, cultivation or maintenance	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
	X																		
CE#59	Adds new definition																		
Related Mod: CEPI- 102-21		HUMIDISTATIC CONTROLS. Automatic controls used to maintain humidity at a setpoint.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>D/EC X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D				D/EC X
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/EC	D																
			D/EC X																
CE#60	Adds new definition																		

Related Mod: CEPI-76- 21	<div>HVAC TOTAL SYSTEM PERFORMANCE RATIO (HVAC TSPR). The ratio of the sum of a building's annual heating and cooling load in thousands of Btu's to the sum of annual site energy consumption of the building HVAC systems in Btu.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	D	D/C				X					
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						
Action	AS	AS/EC	D	D/C																			
			X																				
CE#61	Adds new definition																						
Related Mod: CEPI-84- 21	<div>INDOOR GROW. A space, other than a <i>greenhouse</i> , used exclusively for and essential to horticultural production, cultivation or maintenance.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td>X</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	D	D/C		X							
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						
Action	AS	AS/EC	D	D/C																			
	X																						
CE#62	Adds new definition																						
Related Mod: CEPI-84- 21	<div>INTEGRATED HVAC SYSTEM. An HVAC system designed to handle both sensible and latent heat removal. <i>Integrated HVAC systems</i> include, but are not limited to, HVAC systems with a sensible heat ratio of 0.65 or less and the capability of providing cooling, dedicated outdoor air systems, single-package air conditioners with at least one refrigerant circuit providing hot gas reheat, and <i>dehumidifiers</i> modified to allow external heat rejection</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	D	D/C				X					
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						
Action	AS	AS/EC	D	D/C																			
			X																				
CE#63	Modified an existing definition.																						
Related Mod: CEPI- 124-21	<div>LARGE-DIAMETER CEILING FAN. A ceiling fan that is greater than <i>or equal to 84 1/2 inches (2.15 m) 24-in (613.4 mm) in diameter. These fans are sometimes referred to as High-Volume, Low-Speed (HVLS) fans.</i></div> <div>This code change is already part of the 2023 FBC – EC.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td></td><td>Notified</td><td></td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap			Notified				X		Action	AS	AS/EC	D	D/C				X	
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
		Notified																					
		X																					
Action	AS	AS/EC	D	D/C																			
			X																				
CE#64	Renamed an existing definition "Low-Sloped Roof."																						
Related Mod: CECD1- 11-22	<div>LOW-SLOPED ROOF.LOW SLOPE. A roof having a slope less than 2 units vertical in 12 units horizontal (17-percent slope) <i>as applied to roofs.</i></div> <div>This code change is already part of the 2023 FBC – EC.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap					Action	AS	AS/EC	D	D/C				X					
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
Action	AS	AS/EC	D	D/C																			
			X																				
CE#65	Adds new definition																						
Related Mod: CEPI- 121-22	<div>NORTH-ORIENTED. Facing within 67.5 degrees of true north in the northern hemisphere or facing within 67.5 degrees of true south in the southern hemisphere.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td>X</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	D	D/C		X							
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						
Action	AS	AS/EC	D	D/C																			
	X																						
CE#66	Adds new definition																						
Related Mod: CEPI- 108-21	<div>OCCUPIED-STANDBY MODE. Mode of operation when an HVAC zone is scheduled to be occupied and an occupant sensor indicates no occupants are within the zone .</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td>X</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	D	D/C		X							
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						
Action	AS	AS/EC	D	D/C																			
	X																						
CE#67	Adds new definition																						
Related Mod:	<div>OWNER. Any person, agent, operator, entity, firm or corporation having any legal or equitable interest in the property; or recorded in the official records of the state, county or municipality as holding an interest or title to the property; or otherwise having possession or control of the property, including the guardian of the estate of any such person, and the executor or administrator of the estate of such person if ordered to take possession of real property by a court.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	D	D/C				X					
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						
Action	AS	AS/EC	D	D/C																			
			X																				
CE#68	Adds new definition																						
Related Mod: CECD1- 23-22	<div>PARKING AREA, EXTERIOR. Parking spaces, drive aisles and ramps that are not located within a <i>building</i> , or that are located on a roof.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td>Notified</td><td></td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X	Notified				X		Action	AS	AS/EC	D	D/C				X	
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X	Notified																					
		X																					
Action	AS	AS/EC	D	D/C																			
			X																				
CE#69	Adds new definition																						
Related Mod: CECD1- 23-22	<div>PARKING AREA, INTERIOR. Parking spaces, drive aisles and ramps located within a <i>building</i> .</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/C</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	D	D/C				X					
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						
Action	AS	AS/EC	D	D/C																			
			X																				
CE#70	Adds new definition																						
Related Mod: CECP1-6- 21	<div>PARKING GARAGE SECTION. A part of an enclosed parking garage that is separated from all other parts of the garage by full-height solid walls or operable openings that are intended to remain closed during normal operation and where vehicles cannot pass to other parts of the garage. A parking garage can have one or more <i>parking garage sections</i> , and <i>parking garage sections</i> can include multiple floors.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X																
Staff Classification	Correlates Directly	Energy Standard	Over lap																				
	X																						

--	--

Related Mod: CED1-91- 22	<table><tr><td rowspan="2">FRA ME TYP</td><td colspan="2">WINDOW AND GLASS DOOR</td><td colspan="2">SKYLIGHT</td></tr><tr><td>Single</td><td>Double</td><td>Single</td><td>Double</td></tr><tr><td>Metal</td><td>1.20</td><td>0.80</td><td>2.00</td><td>1.30</td></tr><tr><td>Metal with thermal break</td><td>1.10</td><td>0.65</td><td>1.90</td><td>1.10</td></tr><tr><td>Nonmetal or metal clad</td><td>0.95</td><td>0.55</td><td>1.75</td><td>1.05</td></tr><tr><td>Glazed Glass block</td><td colspan="4">0.60</td></tr></table> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>IS</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	FRA ME TYP	WINDOW AND GLASS DOOR		SKYLIGHT		Single	Double	Single	Double	Metal	1.20	0.80	2.00	1.30	Metal with thermal break	1.10	0.65	1.90	1.10	Nonmetal or metal clad	0.95	0.55	1.75	1.05	Glazed Glass block	0.60				Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	IS		x		
FRA ME TYP	WINDOW AND GLASS DOOR		SKYLIGHT																																											
	Single	Double	Single	Double																																										
Metal	1.20	0.80	2.00	1.30																																										
Metal with thermal break	1.10	0.65	1.90	1.10																																										
Nonmetal or metal clad	0.95	0.55	1.75	1.05																																										
Glazed Glass block	0.60																																													
Staff Classification	Correlates Directly	Energy Standard	Over lap																																											
	x																																													
Action	AS	AS/EC	IS																																											
	x																																													
CE#98	<p>Modified prescriptive compliance requirements for Dwelling Units and Sleeping Units. Dwelling and Sleeping Units in Group R-2 buildings that meet the requirements of Section R406 are considered to be in comply with this chapter.</p> <p>In item #2, the phrase "Total Building Performance" was replaced with "Simulated Building Performance" per the new definition created for the latter.</p> <p>C401.2 Application. Commercial buildings shall comply with Section C401.2.1 or C401.2.2.</p> <p>C401.2.1 International Energy Conservation Code. Commercial buildings shall comply with one of the following:</p> <ol style="list-style-type: none">Prescriptive Compliance. The Prescriptive Compliance option requires compliance with Sections C402 through C406 and Section C408. Dwelling units and sleeping units in Group R-2 buildingsTotal Simulated Building Performance. The Total Simulated Building Performance option requires compliance with Section C407. <p>without systems serving multiple units shall be deemed to be in compliance with this chapter, provided that they comply with Section R406.</p> <p>Exception: Additions , alterations , repairs and changes of occupancy to existing buildings complying with Chapter 5.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>IS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap				x	Action	AS	AS/EC	IS				x																													
Staff Classification	Correlates Directly	Energy Standard	Over lap																																											
			x																																											
Action	AS	AS/EC	IS																																											
			x																																											
CE#99	<p>Renamed the section C401.3 title "Thermal envelope certificate." Made similar editorial changes in the body of this sub-section for clarity.</p>																																													
Related Mod: CED1-92- 22, CED1-94- 22, CED1-95- 22	<p>C401.3 Building thermal envelope certificate. A permanent <i>building thermal envelope</i> certificate shall be completed by an approved party. Such certificate shall be posted on a wall in the space where the space conditioning equipment is located, a utility room or other approved location. If located on an electrical panel, the certificate shall not cover or obstruct the visibility of the circuit directory label, service disconnect label or other required labels. A copy of the certificate shall also be included in the construction files for the project. The certificate shall include the following:</p> <ol style="list-style-type: none">R-values of insulation installed in or on ceilings, roofs, walls, foundations and slabs, basement walls, crawl space walls and floors and ducts outside conditioned spaces .U-factors and solar heat gain coefficients (SHGC) of fenestrations.Results from any building thermal envelope air leakage testing performed on the building . <p>Where there is more than one value for any component of the building thermal envelope, the certificate shall indicate the area-weighted average value where available. If the area-weighted average is not available, the certificate shall list each value that applies to 10 percent or more of the total component area.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td></td><td>Amended</td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>IS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap			Amended	x	Action	AS	AS/EC	IS				x																													
Staff Classification	Correlates Directly	Energy Standard	Over lap																																											
		Amended	x																																											
Action	AS	AS/EC	IS																																											
			x																																											
CE#100	<p>Renames the Section C402 Building Envelope Requirements.</p>																																													
Related Mod: CED1-92- 22, CED1-94- 22, CED1-95- 22	<p>SECTION C402 BUILDING THERMAL ENVELOPE REQUIREMENTS</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td>Amended</td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>IS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x	Amended		Action	AS	AS/EC	IS				x																													
Staff Classification	Correlates Directly	Energy Standard	Over lap																																											
	x	Amended																																												
Action	AS	AS/EC	IS																																											
			x																																											
CE#101	<p>Revises the section for clarification and adds new requirements.</p> <p>Revises item #1. Edits requirements for clarity and adds new thermal envelope requirements per section C402.1.2.1.8 when mechanical equipment envelope penetration area exceeds 1%.</p> <p>Adds new item #2. Exterior wall solar reflectance and thermal emittance must comply with Section C402.3.</p> <p>Edits item #3 and adds new requirements. Fenestration in the building thermal envelope assemblies must comply with Section C402.5. Building and building thermal envelope must comply with Item 2 of Section C401.2.1, C401.2.2, or C402.1.4 if the vertical fenestration area or skylight exceeds Section C402.5 requirements.</p> <p>Edits item #4 or #5 for clarity (duplicate items).</p>																																													
	<p>#4/#5. Air leakage of the building thermal envelope must comply with Section C402.6. Created new bullet items #6 and #7 from the existing code language.</p> <p>#6. Thermal bridges in above-grade walls must comply with Section C402.7.</p> <p>#7. Walk-in coolers, walk-in freezers, refrigerated warehouse coolers, and refrigerated warehouse freezers must comply with Section C403.12. Some of the changes may increase the code stringency but are cost-effective.</p>																																													
Related	<p>Section C401.2.1 shall comply with the following:</p>																																													

Mod: CEPI-29-21, CEPI-28-21, CEPI-4-21, CEPI-27-21, CEPI-32-21, CEPI-31-21, CED1-92-22, CED1-94-22	<p>1. The opaque portions of the <i>building thermal envelope</i> shall comply with the specific insulation requirements of Section C402.2 and the thermal requirements of Section C402.1.2, the fr- value-based method of C402.1.3; the <i>U</i>-, <i>C</i>- and <i>F</i>-factor-based method of Section C402.1.2; or the component performance alternative of C402.1.4. Where the total area of through penetrations of mechanical equipment is greater than 1 percent of the opaque above-grade wall area, the building thermal envelope shall comply with Section C402.1.2.1.8.</p> <p>2. Wall solar reflectance and thermal emittance shall comply with Section C402.3.</p> <p>2. 3. Roof solar reflectance and thermal emittance shall comply with Section C402.4.</p> <p>3-4- Fenestration in the building thermal envelope assemblies shall comply with Section C402.5. Where buildings have a vertical fenestration area or skylight area greater than that allowed in Section C402.5, the building and building thermal envelope shall comply with Item 2 of Section C401.2.1, C401.2.2 or C402.1.4.</p> <p>4- Air leakage of building thermal envelope assemblies shall comply with Section C402.6.</p> <p>5- Air leakage of the building thermal envelope shall comply with Section C402.6.</p> <p>6- Thermal bridges in above-grade walls shall comply with Section C402.7.</p> <p>7- Walk-in coolers, walk-in freezers, refrigerated warehouse coolers and refrigerated warehouse freezers shall comply with Section C403.12.</p> <p>Alternatively, where buildings have a vertical fenestration area or skylight area exceeding that allowed in Section C402.5, the building and <i>building thermal envelope</i> shall comply with Item 2 of Section C401.2.1 or Section C401.2.2.</p> <p>Walk-in coolers, walk-in freezers, refrigerated warehouse coolers and refrigerated warehouse freezers shall comply with Section C403.12.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D / D/C</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap					Action	AS	AS/EC	D / D/C				
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
Action	AS	AS/EC	D / D/C															
CE#102	Moves the two requirements to a new sub-section C402.1.1.1 to create the low energy building specifications. Adds new sub-section C402.1.1.1. Renumbers an existing section and made editorial changes. Renumbers Section C402.1.2, made editorial changes, and increased the heating capacity threshold to 20 kBtu/h from 17 kBtu/h.																	
Related Mod: CEPI-34- 21, CED1-92- 22, CEPI-34-21, CED1-99- 22	<p>C402.1.1 Low-energy buildings and greenhouses. The following low-energy buildings, or portions thereof separated from the remainder of the building by <i>building thermal envelope</i> assemblies complying with this section, shall be exempt from the <i>building thermal envelope</i> provisions of Section C402.</p> <p>1- Those with a peak design rate of energy usage less than 3.4 Btu/h × ft² (10.7 W/m²) or 4.0 watt per square foot (10.7 W/m²) of floor area for space conditioning purposes.</p> <p>2- Those that do not contain conditioned space:</p> <p>C402.1.1.1 Low-energy buildings. Buildings that comply with either of the following:</p> <p>1. Those with a peak design rate of energy usage less than 3.4 Btu/h × ft² (10.7 W/m²) or 1.0 watt per square foot (10.7 W/m²) of floor area for space conditioning purposes.</p> <p>2. Those that do not contain conditioned space.</p> <p>C402.1.1.1-C402.1.1.2 Greenhouses. Greenhouse structures or areas that are mechanically heated or cooled and that comply with all of the following shall be exempt from the <i>building thermal envelope</i> requirements of this code:</p> <p>1. Exterior opaque envelope assemblies comply with Sections C402.2 and C402.5.5.</p> <p>Exception: Low energy greenhouses that comply with Section C402.1.1.</p> <p>2. Interior partition <i>building thermal envelope</i> assemblies that separate the greenhouse from conditioned space comply with Sections C402.2, C402.5.3 and C402.5.5.</p> <p>3. Fenestration assemblies that comply with the <i>building thermal envelope</i> requirements in Table C402.1.1.2. The <i>U</i>-factor for a roof shall be for the roof assembly or a roof that includes the assembly and an internal curtain system.</p> <p>Exception: Unconditioned greenhouses.</p> <p>C402.1.2-C402.1.1.3 Equipment buildings. Buildings that comply with the following shall be exempt from the <i>building thermal envelope</i> provisions of this code:</p> <p>1. Are separate buildings with floor area not more than 1,200 square feet (111 m²).</p> <p>2. Are intended to house electric equipment with installed equipment power totaling not less than 7 watts per square foot (75 W/m²) and not intended for human occupancy.</p> <p>3. Have a heating system capacity not greater than 137,200 Btu/h (56 kW) and a heating thermostat setpoint that is restricted to not more than 50°F (10°C).</p> <p>4. Have an average wall and roof <i>U</i>-factor less than 0.200 in Climate Zones 1 through 5 and less than 0.120 in Climate Zones 6 through 8.</p> <p>5. Comply with the roof solar reflectance and thermal emittance provisions for Climate Zone 1.</p>																	
	FSEC – Anticipated energy impact on FBC-EC – Decrease	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D / D/C</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D / D/C		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D / D/C															
	X																	
CE#103	Renumbers an existing table C402.1.1.1 and renamed the table header.																	
Related Mod: CEPI-34- 21	TABLE C402.1.1.1-1 TABLE C402.1.1.2 FENESTRATION BUILDING THERMAL ENVELOPE MAXIMUM REQUIREMENTS	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D / D/C</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D / D/C		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D / D/C															
	X																	
CE#104	Renumbers section C402.1.4 and made editorial changes for clarity.																	
Related Mod: CEPI-27- 21, CEPI-28-21, CED1-94- 22	<p>C402.1.4-C402.1.2 Assembly U-factor, C-factor or F-factor-based method. <i>Building thermal envelope</i> opaque assemblies shall meet the requirements of Sections C402.2 and C402.5 based on the climate zone specified in Chapter 3. <i>Building thermal envelope</i> opaque assemblies intended to comply on an assembly U-, C- or F-factor basis shall have a U-, C- or F-factor not greater than that specified in Table C402.1.2. Commercial buildings or portions of commercial buildings enclosing Group A occupancies shall use the U-, C- or F-</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D / D/C</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D / D/C		X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	D / D/C															
	X																	
CE#105	Renumbers Table C402.1.4. Deleted footnote text "ci = Continuous Insulation, NR = No Requirement, LS = Liner System."																	

CEPI-28-21, CED1-92-22, CED1-100-22	<p>TABLE C402.1.4 TABLE C402.1.2 OPAQUE THERMAL ENVELOPE ASSEMBLY MAXIMUM REQUIREMENTS, U-FACTOR METHOD^{a, b} For SI: 1 pound per square foot = 4.88 kg/m²; 1 pound per cubic foot = 16 kg/m³. ei = Continuous Insulation; NR = No Requirement; LS = Linear System.</p>
-------------------------------------	--

		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AL/NC</td><td>D</td><td>D/NC</td></tr><tr><td></td><td>X</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AL/NC	D	D/NC		X			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																	
	X																			
Action	AS	AL/NC	D	D/NC																
	X																			
CE#106	<p>Renumbers Section C402.1.4.1, renamed the section title and revised the opaque assembly provisions. This is a re-organized new section.</p> <p>U-factors, C-factors, and F-factors of assemblies and calculation procedures from ASHRAE 90.1 Appendix A can be a compliance alternative, provided they meet the criteria of table C402.1.2.</p> <p>U-factors of opaque assemblies determined by testing in accordance with ASTM C1363 can be a The R-value of continuous insulation must be permitted to be added to or subtracted from the original tested design, and airspaces used for assembly evaluations must comply with Section C402.2.7.</p>																			
Related Mod: CEPI-27- 21, CEPI-41-21, CED1-103-22	<p>C402.1.4.1 C402.1.2.1 Roof/ceiling assembly. Methods of determining U-, C- and F-factors. The maximum roof/ceiling assembly U-factor shall not exceed that specified in Table C402.1.2 based on construction materials used in the roof/ceiling assembly. Where assemblies—U-factors—C-factors—and—calculation—procedures—are established in ANSI/ASHRAE/IES 90.1 Appendix A for opaque assemblies, such opaque assemblies shall be a compliance alternative provided they meet the criteria of Table C402.1.2 and the construction, excluding cladding system on walls, complies with the applicable construction details from ANSI/ASHRAE/IES 90.1 Appendix A. Where U-factors have been established by testing in accordance with ASTM C1363, such opaque assemblies shall be a compliance alternative provided they meet the criteria of Table C402.1.4. The R-value of continuous insulation shall be permitted to be added to or subtracted from the original tested design. Airspaces used for assembly evaluations must comply with Section C402.2.7.</p> <p>C402.1.4.1.1 C402.1.2.1.1 Tapered, above-deck insulation based on thickness. Where used as a component of a maximum roof/ceiling assembly U-factor calculation, the tapered roof insulation R-value contribution to that calculation shall use the average thickness in inches (mm) along with the material R-value per inch (per mm) solely for U-factor compliance as prescribed in Section C402.1.2. For tapered, above-deck roof insulation, area-weighted U-factors of non-uniform insulation thickness shall be determined by an approved method.</p> <p>Exception: The area-weighted U-factor shall be permitted to be determined by using the inverse of the average R-value determined in accordance with the exception to Section C402.1.3.2.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AL/NC</td><td>D</td><td>D/NC</td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AL/NC	D	D/NC					
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																	
	X																			
Action	AS	AL/NC	D	D/NC																
CE#107	<p>Renumbers Section C402.1.4.1.2.</p> <p>Adds new subsection C402.1.2.1.3. In determining compliance with Table C402.1.2, the U-factor of concrete masonry units with integral insulation shall be permitted to be used.</p> <p>Adds new subsection C402.1.2.1.4. Assembly complying with Section C402.1.3.4 must be permitted to comply with the required maximum U-factors for mass walls and mass floors in accordance with Table C402.1.2.</p>																			
Related Mods: CEPI-41- 21, CED1- 103-22, CEPI-27- 21, CED1- 100-21	<p>C402.1.4.1.2 C402.1.2.1.2 Suspended ceilings. Insulation installed on suspended ceilings having removable ceiling tiles shall not be considered part of the assembly U-factor of the roof/ceiling construction.</p> <p>C402.1.2.1.3 Concrete masonry units, integral insulation. In determining compliance with Table C402.1.2, the U-factor of concrete masonry units with integral insulation shall be permitted to be used.</p> <p>C402.1.2.1.4 Mass walls and floors. Compliance with required maximum U-factors for mass walls and mass floors in accordance with Table C402.1.2 shall be permitted for assemblies complying with Section C402.1.3.4.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AL/NC</td><td>D</td><td>D/NC</td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AL/NC	D	D/NC					
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																	
	X																			
Action	AS	AL/NC	D	D/NC																
CE#108	<p>Adds new subsection C402.1.2.1.5. Where above-grade walls include more than one assembly type or penetration of the opaque wall area, an approved method can determine the area-weighted U-factor of the above-grade wall.</p>																			
Related Mods: CED1- 107-22	<p>C402.1.2.1.5 Area-weighted averaging of above-grade wall U-factors. Where above-grade walls include more than one assembly type or a penetration of the opaque wall area, the area-weighted U-factor of the above-grade wall is permitted to be determined by an approved method.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AL/NC</td><td>D</td><td>D/NC</td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AL/NC	D	D/NC					
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																	
	X																			
Action	AS	AL/NC	D	D/NC																
CE#109	<p>Renumbers Section C402.1.4.2, renames title and revises the provision of how it is applied depending on cavity insulation, frame spacing, and shape of frames</p>																			

Related Mods:

C402.1.4.2-C402.1.2.1.6 Thermal resistance of cold-formed steel walls. Cold-formed steel assemblies. U-factors of walls with cold-formed steel studs shall be permitted to be determined in accordance with Equation 4-1:
(Equation 4-1)
where:
 R_{se} = The cumulative R-value of the wall components along the path of heat transfer, excluding the cavity insulation and steel studs.
 R_e = The effective R-value of the cavity insulation with steel studs as specified in Table C402.1.2.1.6.
U-factors for building thermal envelopes containing cold-formed steel-framed ceilings and walls shall be permitted to be determined in accordance with AISI S250 as modified herein.
1. Where the steel-framed wall contains no cavity insulation, and uses continuous insulation to satisfy the U-factor maximum, the steel-framed wall member spacing is permitted to be installed at any on-center spacing.
2. Where the steel-framed wall contains framing at 24 inches (610 mm) on center with a 23 percent framing factor or framing at 16 inches (406 mm) on center with a 25 percent framing factor, the next lower framing member spacing input values shall be used when calculating using AISI S250.
3. Where the steel-framed wall contains less than 23 percent framing factors, the AISI S250 shall be used without any modifications.
4. Where the steel-framed wall contains other than standard C-shape framing members, the AISI S250 calculation option for other than standard C-shape framing is permitted to be used.

Staff Classification	Correlates Directly	Energy Standard Needed	Spec. App.
	x		

Action	AS	ADG	DS	DRG
		x		

CE#110

Adds new subsection C402.1.2.1.7.
This section clarifies and improves the consistency of thermal performance specification for spandrel panels. No change in code stringency.
Adds new subsection C402.1.2.1.8. The changes requires to use an approved u-factor for the equipment or a default u-factor of 0.5 for the envelope impacted. This change increases the code stringency but is a cost-effective measure.

Related Mods:

CEPI-44- 21

C402.1.2.1.7 Spandrel panels. U-factors of opaque assemblies within fenestration framing systems shall be determined in accordance with the default values in Table C402.1.2.1.7, ASTM C1363 or ANSI/NFRC 100.

Staff Classification	Correlates Directly	Energy Standard Needed	Spec. App.
	x		

Action	AS	ADG	DS	DRG
		x		

CE#111

Adds new subsection C402.1.2.1.8. The changes requires to use an approved u-factor for the equipment or a default u-factor of 0.5 for the envelope impacted. This change increases the code stringency but is a cost-effective measure.

Related Mods:

CEPI-29- 21,
CED1- 106-22,
CED1- 108-22

C402.1.2.1.8 Mechanical equipment penetrations. Where the total area of through penetrations of mechanical equipment is greater than 1 percent of the opaque above-grade wall area, such area shall be calculated as a separate wall assembly, in accordance with either Section C402.1.2.1.5 or Section C402.1.4 using a published and approved U-factor for that equipment or a default U-factor of 0.5.

FSEC – Anticipated energy impact on FBC-EC – Decrease

Staff Classification	Correlates Directly	Energy Standard Needed	Spec. App.
	x		

Action	AS	ADG	DS	DRG
		x		

CE#112

Adds new table C402.1.2.1.7.

Related Mod:

CEPI-44- 21,
CED1- 110-22

TABLE C402.1.2.1.7
EFFECTIVE U-FACTORS FOR SPANDREL PANELS:
RATED R-VALUE OF INSULATION BETWEEN

FRAMING MEMBERS	R-4	R-7	R-10	R-15	R-20	R-25	R-30
Frame Type	Spandrel Panel			Default U-Factor			
Single glass pane, stone, or metal panel	0.285	0.259	0.247	0.236	0.230	0.226	0.224
Aluminum without thermal break, low-e coatings	Double glazing with no			0.273	0.254	0.244	0.234
Triple glazing or double glazing with low-e glass	0.263	0.249	0.241	0.233	0.228	0.225	0.223
Single glass pane, stone, or metal panel	0.243	0.212	0.197	0.184	0.176	0.172	0.169
Aluminum with thermal break, low-e coatings	Double glazing with no			0.228	0.205	0.193	0.182
Triple glazing or double glazing with low-e glass	0.217	0.199	0.189	0.180	0.174	0.170	0.167
Single glass pane, stone, or metal panel	0.217	0.180	0.161	0.145	0.136	0.130	0.126
Structural glazing, low-e coatings	Double glazing with no			0.199	0.172	0.157	0.143
Triple glazing or double glazing with low-e glass	0.186	0.165	0.152	0.140	0.133	0.128	0.125
Single glass pane, stone, or metal panel	0.160	0.108	0.082	0.058	0.045	0.037	0.031
No framing or insulation is	Double glazing with no			0.147	0.102	0.078	0.056
Triple glazing or double glazing with low-e glass	0.139	0.098	0.076	0.055	0.043	0.035	0.030

Extrapolation

a. Outside of the table shall not be permitted. Assemblies with distance between framing less than 30 inches, or not included in the default table, shall have a U-factor determined by testing in compliance with ASTM C1363 or modeling in compliance with ANSI/NFRC 100. Spandrel panel assemblies in the table do not include metal backpans. For designs with metal backpans, multiply the U-factor by 1.2.

b. This frame type shall be used for systems that do not contain a nonmetallic element separating the metal exposed to the exterior from the metal exposed to the interior condition.

c. This frame type shall be used for systems where a nonmetallic element separates the metal exposed to the exterior from the metal that is exposed to the interior condition.

d. This frame type shall be used for systems that have no exposed mullion on the exterior.

e. This frame type shall be used for systems where there is no framing or the insulation is continuous and uninterrupted between framing.

[illegible]

	<p>Having a maximum thermal conductivity of 0.44 Btu-in/h-ft²-°F.</p> <p>d. Where heated slabs are below grade, below-grade walls shall comply with the exterior insulation <i>R</i>-value requirements for heated slabs, above-grade mass walls.</p> <p>e. "Mass floors" shall be in accordance with Section C402.1.3.4.</p> <p>f. "Mass walls" shall be in accordance with Section C402.1.3.4.</p> <p>g. The first value is for perimeter insulation and the second value is for full, under-slab insulation. Perimeter insulation and full-slab insulation components shall be installed in accordance with Section C402.2.4. <u>is not required to extend below the bottom of the slab.</u></p>																							
	<p>h. The first value is cavity insulation; the second value is continuous insulation. Therefore, "R-0 + R-120" means R-12 continuous insulation and no cavity insulation; "R-13 + R-3.80" means R-13 cavity insulation and R-3.8 continuous insulation; "R-20" means R-20 cavity insulation and no continuous insulation R-13, R-20 and R-27 cavity insulation, as used in this table, apply to a nominal 4-inch, 6-inch and 8-inch-deep wood or cold-formed steel stud cavity, respectively.</p> <p>i. Where the required <i>R</i>-value in Table C402.1.3 is met by using continuous insulation such that cavity insulation is not required, the <i>R</i>-value is applicable to any wall framing spacing.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td></td><td>x</td><td></td><td>x</td></tr><tr><th>Action</th><th>AS</th><th>ALC</th><th>D</th><th>D/C</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap						x		x	Action	AS	ALC	D	D/C				x		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																					
	x		x																					
Action	AS	ALC	D	D/C																				
			x																					
CE#115	Adds new Section C402.1.3.1. Adds new Section C402.1.3.2.																							
Related Mod:	<p>C402.1.3.1 <i>R</i>-value of multi-layered insulation components. Where cavity insulation is installed in multiple layers, the cavity insulation <i>R</i>-values shall be summed to determine compliance with the cavity insulation <i>R</i>-value requirements. Where continuous insulation is installed in multiple layers, the continuous insulation <i>R</i>-values shall be summed to determine compliance with the continuous insulation <i>R</i>-value requirements. Cavity insulation <i>R</i>-values shall not be used to determine compliance with the continuous insulation <i>R</i>-value requirements in Table C402.1.3.</p> <p>C402.1.3.2 Area-weighted averaging of <i>R</i>-values. Area-weighted averaging shall not be permitted for <i>R</i>-value compliance.</p> <p>Exception: For tapered above-deck roof insulation, compliance with the <i>R</i>-values required in Table C402.1.3 shall be permitted to be demonstrated by multiplying the rated <i>R</i>-value per inch of the insulation material by the average thickness of the roof insulation. The average thickness of the roof insulation shall equal the total volume of the roof insulation divided by the area of the roof.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>ALC</th><th>D</th><th>D/C</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap						x			Action	AS	ALC	D	D/C				x		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																					
	x																							
Action	AS	ALC	D	D/C																				
			x																					
CE#116	Renumbers Section C402.2.1.3.																							
Related Mod: CEPI-41- 21	<p>C402.2.1.3 C402.1.3.3 Suspended ceilings-insulation installed on suspended ceilings having removable ceiling tiles shall not be considered part of the minimum thermal resistance (<i>R</i>-value) of roof insulation in roof/ceiling construction-</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td></td><td>x</td><td></td><td>x</td></tr><tr><th>Action</th><th>AS</th><th>ALC</th><th>D</th><th>D/C</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap						x		x	Action	AS	ALC	D	D/C				x		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																					
	x		x																					
Action	AS	ALC	D	D/C																				
			x																					
CE#117	Adds new Section C402.1.3.4. Section C402.1.2.1.4 references this section.																							
Related Mod: CEPI-27- 21, CED1- 100-21	<p>C402.1.3.4 Mass walls and mass floors. Compliance with required maximum <i>U</i>-factors for mass walls and mass floors in accordance with Table C402.1.2 and minimum <i>R</i>-values for insulation components applied to mass walls and mass floors in accordance with Table C402.1.3 shall be permitted for assemblies complying with the following:</p> <ol style="list-style-type: none">Where used as a component of the <i>building thermal envelope</i>, mass walls shall comply with one of the following:<ol style="list-style-type: none">1. Weigh not less than 35 pounds per square foot (171 kg/m²) of wall surface area.2. Weigh not less than 25 pounds per square foot (122 kg/m²) of wall surface area where the material weight is not more than 120 pounds per cubic foot (pcf) (1922 kg/m³).3. Have a heat capacity exceeding 7 Btu/ft² × °F (144 kJ/m² × K).4. Have a heat capacity exceeding 5 Btu/ft² × °F (103 kJ/m² × K) where the material weight is not more than 120 pcf (1922 kg/m³).Where used as a component of the <i>building thermal envelope</i>, the minimum weight of mass floors shall comply with one of the following:<ol style="list-style-type: none">1. Thirty-five pounds per square foot (171 kg/m²) of floor surface area.2. Twenty-five pounds per square foot (122 kg/m²) of floor surface area where the material weight is not more than 120 pcf (1922 kg/m³). <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>ALC</th><th>D</th><th>D/C</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap						x			Action	AS	ALC	D	D/C				x		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																					
	x																							
Action	AS	ALC	D	D/C																				
			x																					
CE#118	Renumbers Section C402.1.5, renames the section title, updates the referenced sections, and updates the compliance equation to account for thermal bridges.																							
Related Mod: CECP1-4- 21, CED1-92- 22, CED1-94- 22	<p>C402.1.5 C402.1.4 Component performance alternative method—Building thermal envelope values and fenestration areas determined in accordance with Equation 4-2 Equation 4-1 shall be an alternative to compliance with the <i>U</i>, <i>r</i>, <i>F</i>, <i>psi</i>, <i>chi</i>, and <i>C</i> factors in Tables C402.1.2, C402.1.2.1.7, C402.1.4 and C402.5 and the maximum allowable fenestration areas in Section C402.5.1. Fenestration shall meet the applicable SHGC requirements of Section C402.5.3.</p> <p>where: (Equation 4-2)</p> <p>A = Sum of the (UA-Dif) values for each distinct assembly type of the building thermal envelope, other than slabs on-grade and below-grade walls;</p> <p>UA-Dif = UA-Proposed — UA-Table;</p> <p>UA-Proposed = Proposed-U-value × Area;</p> <p>UA-Table = (U-factor from Table C402.1.3, C402.1.2 or C402.5) × Area;</p> <p>B = Sum of the (FL-Dif) values for each distinct slab-on-grade perimeter condition of the building thermal envelope;</p> <p>FL-Dif = FL-Proposed — FL-Table;</p> <p>FL-Proposed = Proposed-F-value × Perimeter-length.</p>																							

	<p>FL-Table = (f-factor specified in Table C402.1.2) × Perimeter length.</p> <p>C = Sum of the (CA Dif) values for each distinct below-grade wall assembly type of the building thermal envelope.</p> <p>CA Dif = CA Proposed — CA Table.</p> <p>CA Proposed = Proposed C-value × Area.</p> <p>CA Table = (Maximum allowable C-factor specified in Table C402.1.2) × Area.</p> <p>Where the proposed vertical glazing area is less than or equal to the maximum vertical glazing area allowed by Section C402.5.1, the value of D (Excess Vertical Glazing Value) shall be zero. Otherwise:</p> <p>$D = (DA \times UV) - (DA \times U \text{ Wall})$, but not less than zero. DA = (Proposed Vertical Glazing Area) — (Vertical Glazing Area allowed by Section C402.5.1). UA Wall = Sum of the (UA Proposed) values for each opaque assembly of the exterior wall.</p> <p>U Wall = Area-weighted average U-value of all above-grade wall assemblies. UAV = Sum of the (UA Proposed) values for each vertical glazing assembly. UV = UAV/total vertical glazing area.</p> <p>Where the proposed skylight area is less than or equal to the skylight area allowed by Section C402.5.1, the value of E (Excess Skylight Value) shall be zero. Otherwise: $E = (EA \times US) - (EA \times U \text{ Roof})$, but not less than zero.</p> <p>EA = (Proposed Skylight Area) — (Allowable Skylight Area as specified in Section C402.5.1). U-Roof = Area-weighted average U-value of all roof assemblies.</p> <p>UAS = Sum of the (UA Proposed) values for each skylight assembly. US = UAS/total skylight area.</p> <p>Equation 4-1</p> <p>where:</p> <p>A_P = Sum of the (area × U-factor) for each proposed building thermal envelope assembly, other than slab-on-grade or below-grade wall assemblies.</p> <p>B_P = Sum of the (length × F-factor) for each proposed slab-on-grade condition.</p> <p>C_P = Sum of the (area × C-factor) for each proposed below-grade wall assembly.</p> <p>T_P = Sum of the (ψLP) and (χNP) values for thermal bridges caused by materials with a thermal conductivity less than or equal to 3.0 Btu × in/h × ft² × °F shall be assigned as zero. For buildings or structures located in Climate Zones 0 through 3, the value of T_P shall be assigned as zero.</p> <p>ψLP = Psi-factor × length of the thermal bridge elements in the proposed building thermal envelope.</p> <p>χNP = Chi-factor × number of the thermal bridge point elements other than fasteners, ties or brackets in the proposed building thermal envelope.</p> <p>A_T = Sum of the (area × U-factor permitted by Tables C402.1.2 and C402.5) for each proposed building thermal envelope assembly, other than slab-on-grade or below-grade wall assemblies.</p> <p>B_T = Sum of the (length × F-factor permitted by Table C402.1.2 for each proposed slab-on-grade condition.</p> <p>C_T = Sum of the (area × C-factor permitted by Table C402.1.2) for each proposed below-grade wall assembly.</p> <p>T_T = Sum of the (ψLT) and (χNT) values for each type of thermal bridge condition in the proposed building thermal envelope.</p> <p>$A_P + B_P + C_P + T_P \leq A_T + B_T + C_T + T_T - V_F - V_S$, Section C402.7 in the proposed building. For the purposes of this section, the (ψLP) and (χNP) values for thermal bridges caused by materials with a thermal conductivity less than or equal to 3.0 Btu × in/h × ft² × °F shall be assigned as zero. For buildings or structures located in Climate Zones 0 through 3, the value of T_P shall be assigned as zero.</p> <p>ψLT = (Psi-factor specified as “compliant” in Table C402.1.4) × length of the thermal bridge elements in the proposed building thermal envelope.</p> <p>χNT = (Chi-factor specified as “compliant” in Table C402.1.4) × number of the thermal bridge point elements other than fasteners, ties or brackets in the proposed building thermal envelope.</p> <p>P_F = Maximum vertical fenestration area allowable by Section C402.5.1, C402.5.1.1 or C402.5.1.2.</p> <p>Q_F = Proposed vertical fenestration area.</p> <p>$R_F = Q_F - P_F$, but not less than zero (excess vertical fenestration area).</p> <p>S_F = Area-weighted average U-factor permitted by Table C402.5 of all vertical fenestration assemblies.</p> <p>T_F = Area-weighted average U-factor permitted by Table C402.1.2 of all exterior opaque wall assemblies.</p> <p>$U_F = T_F - T_P$ (excess U-factor for excess vertical fenestration area). $V_F = R_F \times U_F$ (excess U × A due to excess vertical fenestration area). P_S = Maximum skylight area allowable by Section C402.1.2.</p> <p>Q_S = Actual skylight area.</p> <p>$R_S = Q_S - P_S$, but not less than zero (excess skylight area).</p> <p>S_S = Area-weighted average U-factor permitted by Table C402.5 of all skylights.</p> <p>T_S = Area-weighted average U-factor permitted by Table C402.1.2 of all opaque roof assemblies.</p> <p>$U_S = S_S - T_S$ (excess U-factor for excess skylight area).</p> <p>$V_S = R_S \times U_S$ (excess U × A due to excess skylight area).</p> <p>A proposed psi- or chi-factor for each thermal bridge shall comply with one of the following, as applicable:</p> <ol style="list-style-type: none">Where the proposed mitigation of a thermal bridge is compliant with the requirements of Section C402.7, the “compliant” values in Table C402.1.4 shall be used for the proposed psi- or chi-factors.Where a thermal bridge is not mitigated in a manner at least equivalent to Section C402.7, the “noncompliant” values in Table C402.1.4 shall be used for the proposed psi- or chi-factors.Where the proposed mitigation of a thermal bridge provides a psi- or chi-factor less than the “compliant” values in Table C402.1.4, the proposed psi- or chi-factor shall be determined by thermal analysis, testing or other approved sources. <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Overlap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Overlap					Action	AS	AL/EC	EC																																				
Staff Classification	Correlates Directly	Energy Standard	Overlap																																														
Action	AS	AL/EC	EC																																														
CE#119	Adds new table C402.1.4. This change is consistent with the thermal performance of products currently in the market.																																																
Related Mod:	TABLE C402.1.4 PSI- and CHI-FACTORS TO DETERMINE THERMAL BRIDGES FOR THE COMPONENT PERFORMANCE METHOD																																																
CECPI-4- 21, CED1- 138-22	<table><tr><th rowspan="2"></th><th>THERMAL BRIDGE PER SECTION C402.7</th><th>THERMAL BRIDGE COMPLIANT WITH SECTION C402.7</th><th colspan="2">THERMAL BRIDGE NONCOMPLIANT WITH SECTION C402.7</th></tr><tr><th></th><th>Psi-Factor (Btu/h × ft × °F)</th><th>Chi-Factor (Btu/h × °F)</th><th>Psi-Factor (Btu/h × ft × °F)</th><th>Chi-Factor (Btu/h × °F)</th></tr><tr><td>C402.7.1 Balconies and floor decks</td><td>0.2</td><td>N/A</td><td>0.5</td><td>N/A</td></tr><tr><td>C402.7.2 Cladding supports</td><td>0.2</td><td>N/A</td><td>0.3</td><td>N/A</td></tr><tr><td>C402.7.3 Structural beams and columns</td><td>N/A</td><td>1.0 carbon steel 0.3 concrete</td><td>N/A</td><td>2.0 carbon steel 1.0 concrete</td></tr><tr><td>C402.7.4 Vertical fenestration</td><td>0.15</td><td>N/A</td><td>0.3</td><td>N/A</td></tr><tr><td>C402.7.5 Parapets</td><td>0.2</td><td>N/A</td><td>0.4</td><td>N/A</td></tr></table> <p>For SI: 1 W/m × K = 0.578 Btu/h × ft × °F, 1 W/K = 1.9 Btu/h × °F. N/A = Not Applicable.</p>		THERMAL BRIDGE PER SECTION C402.7	THERMAL BRIDGE COMPLIANT WITH SECTION C402.7	THERMAL BRIDGE NONCOMPLIANT WITH SECTION C402.7			Psi-Factor (Btu/h × ft × °F)	Chi-Factor (Btu/h × °F)	Psi-Factor (Btu/h × ft × °F)	Chi-Factor (Btu/h × °F)	C402.7.1 Balconies and floor decks	0.2	N/A	0.5	N/A	C402.7.2 Cladding supports	0.2	N/A	0.3	N/A	C402.7.3 Structural beams and columns	N/A	1.0 carbon steel 0.3 concrete	N/A	2.0 carbon steel 1.0 concrete	C402.7.4 Vertical fenestration	0.15	N/A	0.3	N/A	C402.7.5 Parapets	0.2	N/A	0.4	N/A	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap					Action	AS	AL/EC	EC
	THERMAL BRIDGE PER SECTION C402.7		THERMAL BRIDGE COMPLIANT WITH SECTION C402.7	THERMAL BRIDGE NONCOMPLIANT WITH SECTION C402.7																																													
		Psi-Factor (Btu/h × ft × °F)	Chi-Factor (Btu/h × °F)	Psi-Factor (Btu/h × ft × °F)	Chi-Factor (Btu/h × °F)																																												
C402.7.1 Balconies and floor decks	0.2	N/A	0.5	N/A																																													
C402.7.2 Cladding supports	0.2	N/A	0.3	N/A																																													
C402.7.3 Structural beams and columns	N/A	1.0 carbon steel 0.3 concrete	N/A	2.0 carbon steel 1.0 concrete																																													
C402.7.4 Vertical fenestration	0.15	N/A	0.3	N/A																																													
C402.7.5 Parapets	0.2	N/A	0.4	N/A																																													
Staff Classification	Correlates Directly	Energy Standard	Over lap																																														
Action	AS	AL/EC	EC																																														
CE#120	Renumbers Section C402.5.5. Made editorial changes.																																																

Related Mod: CECPI-3- 21	<p>C402.5.5-C402.1.5 Rooms-containing-fuel-burning-appliances. In Climate Zones 3 through 8, where combustion air is supplied through openings in an exterior wall to a room or space containing a space-conditioning fuel-burning appliance, one of the following shall apply:</p> <ol style="list-style-type: none">1. The room or space containing the appliance shall be located outside of the <i>building thermal envelope</i>.2. The room or space containing the appliance shall be enclosed and isolated from <i>conditioned spaces</i> inside the <i>building thermal envelope</i>. Such rooms shall comply with all of the following: <ol style="list-style-type: none">2.1. The walls, floors and ceilings that separate the enclosed room or space from <i>conditioned spaces</i> shall be insulated to be not less than equivalent to the insulation requirement of <i>below-grade walls</i> as specified in Table C402.1.3 or Table C402.1.2.2.2. The walls, floors and ceilings that separate the enclosed room or space from <i>conditioned spaces</i> shall be sealed in accordance with Section C402.6.1.2.2.3. The doors into the enclosed room or space shall be fully gasketed.																
	<p>2.4. Piping serving as part of a heating or cooling system</p> <p>Water lines and ducts in the enclosed room or space shall be insulated in accordance with Section C403. Service water piping shall be insulated in accordance with Section C404.</p> <p>2.5. Where an air duct supplying combustion air to the enclosed room or space passes through <i>conditioned space</i>, the duct shall be insulated to an <i>R-value</i> of not less than R-8.</p> <p>Exception: Fireplaces and stoves complying with Sections 901 through 905 of the <i>International Mechanical Code</i>, and Section 2111.14 of the <i>International Building Code</i>.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Modified</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>DI</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AL/EC	DI				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap														
Action	AS	AL/EC	DI														
CE#121	<p>Renames Section C402.2 title, makes editorial change and updates the referenced sections. Deletes Section C402.2.1.1. Renumbers Section C402.2.1.4 and edits the provision. Adds new Section C402.2.1.3. This new section clarifies the minimum thickness requirements of tapered insulation.</p>																
Related Mod: CEPI-27- 21	<p>C402.2 Specific</p> <p>building thermal envelope insulation and installation requirements. Insulation in <i>building thermal envelope</i> opaque assemblies shall be installed in accordance with Section C403.2 and Sections C402.2.1 through C402.2.7, or an approved design and Table C402.1.3.</p> <p>C402.2.1 Roof-ceiling construction assembly. The minimum thermal resistance (<i>R-value</i>) of the insulating material installed either between the roof framing or continuously on the roof assembly shall be as specified in Table C402.1.3, based on construction materials used in the roof assembly. Insulation materials in the roof-ceiling construction shall be installed between the roof or ceiling framing, continuously below the ceiling framing, continuously above, below, or within the roof deck or in any approved combination thereof. Insulation installed above the roof deck shall comply with Sections C402.2.1.1 through C402.2.1.3.</p> <p>C402.2.1.1 Tapered, above-deck insulation based on thickness. Where used as a component of a roof/ceiling assembly <i>R-value</i> calculation, the sloped-roof insulation <i>R-value</i> contribution to that calculation shall use the average thickness in inches (mm) along with the material <i>R-value</i> per inch (per mm) solely for <i>R-value</i> compliance as prescribed in Section 402.1.3.</p> <p>C402.2.1.4 C402.2.1.4 Joints staggered. Continuous, above-deck insulation board located above the roof deck shall be installed in not less than two layers and the edge joints between each layer of insulation shall be staggered, except where insulation tapers to the roof deck at a gutter edge, roof drain or scupper.</p> <p>C402.2.1.2 Minimum thickness, lowest point. The minimum thickness of above-deck roof insulation at its lowest point, gutter edge, roof drain or scupper, shall be not less than 1 inch (25 mm).</p>																
	<p>C402.2.1.5 C402.2.1.2 Skylight curbs. Skylight curbs shall be insulated to the level of roofs with the above-deck roof insulation entirely above the deck or R-5, whichever is less.</p> <p>Exception: Unit skylight curbs included as a component of a skylight listed and labeled in accordance with NFRC 100 shall not be required to be insulated.</p> <p>C402.2.1.3 Minimum thickness of tapered insulation. The thickness of tapered above-deck roof insulation at its lowest point, gutter edge, roof drain or scupper, shall be not less than 1 inch (25 mm).</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Modified</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>DI</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AL/EC	DI				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap														
Action	AS	AL/EC	DI														
CE#122	<p>Revises the provision to include insulation installation requirements and removes the reference to the minimum efficiency level requirement tables.</p>																
Related Mod: C402.2.2 Above-grade walls	<p>C402.2.2 Above-grade walls. The minimum thermal resistance (<i>R-value</i>) of materials installed between floor framing, be integral to the floor assembly, in the wall cavity between framing members and continuously on the walls shall be as specified in Table C402.1.3, based on framing type and construction materials used in the wall assembly. The <i>R-value</i> of integral insulation installed in concrete masonry units shall not be used in determining compliance with Table C402.1.3 except as otherwise noted in the table. In determining compliance with Table C402.1.2, the use of the <i>U-factor</i> of concrete masonry units with integral insulation shall be permitted.</p> <p>"Mass walls" where used as a component in the thermal envelope of a building shall comply with one of the following:</p> <ol style="list-style-type: none">1. Weigh not less than 35 pounds per square foot (171 kg/m²) of wall surface area;2. Weigh not less than 25 pounds per square foot (122 kg/m²) of wall surface area where the material weight is not more than 120 pcf (1900 kg/m³);3. Have a heat capacity exceeding 7 Btu/ft²•°F (144 kJ/m²•°K);4. Have a heat capacity exceeding 5 Btu/ft²•°F (103 kJ/m²•°K), where the material weight is not more than 120 pcf (1900 kg/m³). <p>Above-grade wall insulation materials shall be installed between the wall framing, be integral to the wall assembly, be continuous on the wall assembly, or be any combination of these insulation methods. Where continuous insulation is layered on the exterior side of a wall assembly, the joints shall be staggered.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Modified</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>DI</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AL/EC	DI				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap														
Action	AS	AL/EC	DI														
CE#123	<p>Renames the section title, revises the provision, and removes the minimum requirement table references.</p>																

Related Mod: CEPI-27- 21	<p>C402.2.3 Floors over outdoor air or unconditioned space. The thermal properties (component <i>R</i>-values or assembly <i>U</i>- or <i>G</i>-factors) of floor assemblies over outdoor air or unconditioned space shall be as specified in Table C402.1.3 or C402.1.2 based on the construction materials used in the floor assembly. Floor framing cavity insulation or structural slab insulation shall be installed to maintain permanent contact with the underside of the subfloor decking or structural slabs.</p> <p>"Mass floors" where used as a component of the thermal envelope of a building shall provide one of the following weights: Floor insulation shall be installed between floor framing, be integral to the floor assembly, be continuous on the floor assembly, or be any combination of these insulation methods. Where continuous insulation is layered on the exterior side of a floor assembly, the joints shall be staggered. Floor framing cavity insulation or structural slab insulation shall be installed to maintain permanent contact with the underside of the subfloor decking or structural slabs.</p> <p>1. 35 pounds per square foot (171 kg/m²) of floor surface area.</p> <p>2. 25 pounds per square foot (122 kg/m²) of floor surface area where the material weight is not more than 120 pounds per cubic foot (1923 kg/m³).</p> <p>Exceptions:</p> <p>1. The floor framing cavity insulation or structural slab insulation shall be permitted to be installed in contact with the top side of sheathing or continuous insulation installed on the bottom side of floor assemblies where combined with insulation that meets or exceeds the minimum R-value in Table C402.1.3 for "Metal framed" or "Wood framed and other" values for "Walls, above grade" and extends from the bottom to the top of all perimeter floor framing or floor assembly members. Floor framing or structural slab members at the perimeter of the floor assembly shall be insulated vertically for their full depth with insulation equivalent to that required for the above-grade wall construction.</p> <p>2. Insulation applied to the underside of concrete floor slabs shall be permitted an airspace of not more than 1 inch (25 mm) where it turns up and is in contact with the underside of the floor under walls associated with the building thermal envelope.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AS/EC	D				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap															
Action	AS	AS/EC	D															
CE#124	Revises the provision and combines the subsection C402.2.4.1.																	
Related Mod: CEPI-27- 21	<p>C402.2.4 Slabs-on-grade. The minimum thermal resistance (<i>R</i>-value) of the insulation for unheated or heated slab-on-grade floors designed in accordance with the <i>R</i>-value method of Section C402.1.3 shall be as specified in Table C402.1.3. Where installed, the perimeter insulation for slab-on-grade shall be placed on the outside of the foundation or on the inside of the foundation wall. For installations complying with Table C402.1.3, the perimeter insulation shall extend downward from the top of the slab for the minimum distance shown in the table or to the top of the footing, whichever is less, or downward to not less than the bottom of the slab and then horizontally to the interior or exterior for the total distance shown in the table. Where installed, full slab insulation shall be continuous under the entire area of the slab-on-grade floor, except at structural column locations and service penetrations. Insulation required at the heated slab perimeter shall not be required to extend below the bottom of the heated slab and shall be continuous with the full slab insulation.</p> <p>Exception: Where the slab-on-grade floor is greater than 24 inches (610 mm) below the finished exterior grade, perimeter insulation is not required.</p> <p>402.2.4.1 Insulation installation. Where installed, the perimeter insulation shall be placed on the outside of the foundation or on the inside of the foundation wall. The perimeter insulation shall extend downward from the top of the slab for the minimum distance shown in the table or to the top of the footing, whichever is less, or downward to not less than the bottom of the slab and then horizontally to the interior or exterior for the total distance shown in the table. Insulation extending away from the building shall be protected by pavement or by not less than 10 inches (254 mm) of soil. Where installed, full slab insulation shall be continuous under the entire area of the slab-on-grade floor, except at structural column locations and service penetrations. Insulation required at the heated slab perimeter shall not be required to extend below the bottom of the heated slab and shall be continuous with the full slab insulation.</p> <p>Exception: Where the slab-on-grade floor is greater than 24 inches (61 mm) below the finished exterior grade, perimeter insulation is not required.</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AS/EC	D				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap															
Action	AS	AS/EC	D															
CE#125	Revises the provision of section C402.2.5.																	
Related Mod: CEPI-27- 21	<p>C402.2.5 Below-grade walls. The <i>G</i>-factor for the below-grade exterior walls shall be in accordance with Table C402.1.2. The <i>R</i>-value of the insulating material installed continuously within or on the below-grade exterior walls of the building envelope shall be in accordance with Table C402.1.3. The <i>G</i>-factor or <i>R</i>-value required Below-grade wall insulation shall be installed between framing members, be integral to the wall assembly, be continuous on the wall assembly, or be any combination of these insulation methods. For installations complying with Section C401.2.1, insulation shall extend to a depth of not less than 10 feet (3048 mm) below the outside finished ground level or to the level of the lowest floor of the conditioned space enclosed by the building.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AS/EC	D				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap															
Action	AS	AS/EC	D															
CE#126	Deletes an exception.																	
Related Mod: CEPI-27- 21	<p>C402.2.6 Insulation of radiant heating systems. Radiant heating system panels, and their associated components that are installed in interior or exterior assemblies, shall be insulated to an <i>R</i>-value of not less than <i>R</i>-3.5 on all surfaces not facing the space being heated. Radiant heating system panels that are installed in the building thermal envelope shall be separated from the exterior of the building or unconditioned or exempt spaces by not less than the <i>R</i>-value of insulation installed in the opaque assembly in which they are installed or the assembly shall comply with Section C402.1.2.</p> <p>Exception: Heated slabs on grade insulated in accordance with Section C402.2.4.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AS/EC	D				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap															
Action	AS	AS/EC	D															
CE#127	Revises the provision. The changes enforce best practices that minimize airflow into enclosed air spaces and improve their thermal performance.																	
Related Mod: CEPI-48- 21	<p>C402.2.7 Airspaces. Where the <i>R</i>-value of an airspace is used for compliance in accordance with Section C402.1, the airspace shall be enclosed in an unventilated cavity constructed to minimize airflow into and out of the enclosed airspace. Airflow shall be deemed minimized where the enclosed airspace is located on the interior side of the continuous air barrier and is bounded on all sides by building components or constructed to minimize airflow into and out of the enclosed airspace. Airflow shall be deemed minimized where one of the following conditions occur:</p> <p>1. The enclosed airspace is unventilated.</p> <p>2. The enclosed airspace is bounded on at least one side by an anchored masonry veneer, constructed in accordance with Chapter 14 of the International Building Code and vented by veneer weep holes located only at the bottom of the airspace and spaced not less than 15 inches (381 mm) on center with top of the exterior cladding closed.</p> <p>Exception:</p> <p>The thermal resistance of airspaces located on the exterior side of the continuous air barrier and adjacent to and behind the exterior wall covering material shall be determined in accordance with ASTM C1363 modified with an airflow entering the bottom and exiting the top of the airspace at an air movement rate of not less than 70 mm/second.</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap					Action	AS	AS/EC	D				
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap															
Action	AS	AS/EC	D															
FSEC – Anticipated energy impact on FBC-EC – Decrease																		

<

Related Mod:
CEPI- 167-21

C402.4.1-C402.5.1 Maximum area. The vertical fenestration area, not including opaque doors and opaque spandrel panels, shall be not greater than 30 percent of the gross above-grade wall area. The skylight area shall be not greater than 3 percent of the gross roof area.

C402.4.1.1-C402.5.1.1 Increased vertical fenestration area with daylight responsive controls. In Climate Zones 0 through 6, not more than 40 percent of the gross above-grade wall area shall be vertical fenestration, provided that all of the following requirements are met:

1. In buildings not greater than two stories above grade, not less than 50 percent of the net floor area is within a primary sidelight daylight zone or a toplight daylight zone.
2. In buildings three or more stories above grade, not less than 25 percent of the net floor area is within a primary sidelight daylight zone or a toplight daylight zone.
3. Daylight responsive controls are installed in daylight zones.
4. Visible transmittance (VT) of vertical fenestration is not less than 1.1 times solar heat gain coefficient (SHGC).

$PF = A/B$

Exception: Fenestration that is outside the scope of NFRC 200 is not required to comply with Item 4.

C402.4.1.2-C402.5.1.2 Increased skylight area with daylight responsive controls. The skylight area shall be not more than 6 percent of the gross roof area provided that daylight responsive controls are installed in toplight daylight zones.

Original text of mod is not consistent with that of the 2023 FBC -EC.

Staff Classification	Correlates Directly	Energy Standard Reached	Over lap
			x
Action	AS	AS/IC	D
			DI/C

CE#135	Renumbers Section C402.4.2.
	Renumbers Section C402.4.2.1. Renumbers Section C402.4.2.2.

Related Mod:

CEPI- 167-21

C402.4.2-C402.5.2 Minimum skylight fenestration area. Skylights shall be provided in enclosed spaces greater than 2,500 square feet (232 m²) in floor area, directly under a roof with not less than 75 percent of the ceiling area with a ceiling height greater than 15 feet (4572 mm), and used as an office, lobby, atrium, concourse, corridor, storage space, gymnasium/ exercise center, convention center, automotive service area, space where manufacturing occurs, nonrefrigerated warehouse, retail store, distribution/sorting area, transportation depot or workshop. The total *toplit daylight zone* shall be not less than half the floor area and shall comply with one of the following:

1. A minimum skylight area to *toplit daylight zone* of not less than 3 percent where all skylights have a VT of not less than 0.40, or

VT_{annual}

of not less than 0.26, as determined in accordance with **Section C103.1.3.**
2. A minimum skylight effective aperture, determined in accordance with **Equation 4-3**, of:

2.1 Not less than 3 percent using a skylight's VT rating.

2.2 Not less than 0.66 percent using a Tubular Daylight Device's VT_{annual} rating.

Skylight Effective Aperture =

0.85 × Skylight Area × Skylight VT × WF

Toplit Zone

Equation 4-3

C402.4.2.1-C402.5.2.1 Lighting controls in toplit daylight zones. Daylight responsive controls shall be provided in toplit daylight zones.

C402.4.2.2-C402.5.2.2 Haze factor.

Staff Classification	Correlates Directly	Energy Standard Reached	Over lap
	x		
Action	AS	AS/IC	D
			DI/C

CE#136	Renumbers Section C402.4.3 and Renumbers the equation. Renumbers Section C402.4.3.1. Renumbers Section C402.4.3.2. Renumbers Section C402.4.3.3. Renumbers Section C402.4.3.4.
--------	--

Related Mod: CEPI- 167-21	<p>C402.4.3-C402.5.3 Maximum U-factor and SHGC. The maximum U-factor and solar heat gain coefficient (SHGC) for fenestration shall be as specified in Table C402.5.</p> <p>The window projection factor shall be determined in accordance with Equation 4-4.</p> <p>Where different windows or glass doors have different PF values, they shall each be evaluated separately.</p>
------------------------------	--

	<p>C402.4.3.1-C402.5.3.1 Increased skylight SHGC. In Climate Zones 0 through 6, skylights shall be permitted a maximum SHGC of 0.60 when located above daylight zones provided with daylight responsive controls :</p> <p>C402.4.3.2-C402.5.3.2 Increased skylight U-factor. Where skylights are installed above daylight zones provided with daylight responsive controls ; a maximum U-factor of 0.9 shall be permitted in Climate Zones 0 through 3 and a maximum U-factor of 0.75 shall be permitted in Climate Zones 4 through 8.</p> <p>C402.4.3.3-C402.5.3.3 Dynamic glazing.</p> <p>C402.4.3.4-C402.5.3.4 Area-weighted U-factor. An area-weighted average shall be permitted to satisfy the U-factor requirements for each fenestration product category listed in Table C402.5. Individual fenestration products from different fenestration product categories listed in Table C402.5 shall not be combined in calculating area-weighted average U-factor</p>																
	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Reached</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/IC</th><th>D</th></tr><tr><td></td><td>x</td><td></td><td>DI/C</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		x			Action	AS	AS/IC	D		x		DI/C
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap														
	x																
Action	AS	AS/IC	D														
	x		DI/C														

CE#137	Renumbers Section C402.4.4. Renumbers Section C402.4.5. Renumbers subsection C402.4.5.1. Renumbers subsection C402.4.5.2.
--------	---

Related Mod: CEPI- 167-21	<p>C402.4.4-C402.5.4 Daylight zones. Daylight zones referenced in Sections C402.5.1.1 through C402.5.3.2 shall comply with Sections C405.2.4.2 and C405.2.4.3, as applicable. Daylight zones shall include toplight daylight zones and sidelight daylight zones.</p> <p>C402.4.5-C402.5.5 Doors. Opaque swinging doors shall comply with Table C402.1.2. Opaque nonswinging doors shall comply with Table C402.1.2. Opaque doors shall be considered as part of the gross area of above-grade walls that are part of the building thermal envelope. Opaque doors shall comply with Section C402.5.5.1 or C402.5.5.2. Other doors shall comply with the provisions of Section C402.5.3 for vertical fenestration.</p> <p>C402.4.5.1-C402.5.5.1 Opaque swinging doors. Opaque swinging doors shall comply with Table C402.1.2.</p> <p>C402.4.5.2-C402.5.5.2 Nonswinging doors. Opaque nonswinging doors that are horizontally hinged sectional doors with a single row of fenestration shall have an assembly U-factor less than or equal to 0.440 in Climate Zones 0 through 6 and less than or equal to 0.360 in Climate Zones 7 and 8, provided that the fenestration area is not less than 14 percent and not more than 25 percent of the total door area.</p> <p>Exception: Other doors shall comply with the provisions of Section C402.5.3 for vertical fenestration.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td><td>DI/C x</td></tr></table>	Action	AS	AS/IC	D	DI/C x
Action	AS	AS/IC	D	DI/C x		

Staff Classification	Correlates Directly	Energy Standard Reached	Over lap



CE#138	Renumbers Section C402.5 renames the title and revises the provision. Renumbers Section C402.5.1 and revises the provision. This requires air leakage performance of the air barrier must be verified per Section C402.6.2.																	
Related Mod: CECP1-3- 21,CEPI- 58- 21,CEPI- 32- 21,CED1- 92-22	<p>C402.5 C402.6 Air leakage—building thermal envelope. The building thermal envelope shall comply with Sections C402.6.1 through C402.6.7. Section C402.6.1.1, or the building thermal envelope shall be tested in accordance with Section C402.6.2.2 or C402.6.2.1. Where compliance is based on such testing, the building shall also comply with Sections C402.6.5, C402.6.7 and C402.6.6.</p> <p>C402.5.1—C402.6.1 Air barriers. A continuous air barrier shall be provided throughout the building thermal envelope. The continuous air barriers shall air barrier is permitted to be located at any combination of on the inside, or outside or within the building thermal envelope, located within the assemblies composing the building thermal envelope, or any combination thereof. The air barrier shall comply with Sections C402.6.1.1 and C402.6.1.2. The air leakage performance of the air barrier shall be verified in accordance with Section C402.6.2.</p> <p>Exception: Air barriers are not required in buildings located in Climate Zone 2B</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/CS</td><td>CS</td></tr><tr><td></td><td></td><td></td><td>CS</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AS/CS	CS				CS
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	x																	
Action	AS	AS/CS	CS															
			CS															
CE#139	Adds new Section C402.6.1.1. New section was creating by re-organizing an existing section for clarity.																	
Related Mod: CECP1-3- 21,CED1- 92- 22,CED1- 128-22	<p>C402.6.1.1 Air barrier design and documentation requirements. Design of the continuous <i>air barrier</i> shall be documented as follows:</p> <ol style="list-style-type: none">Components comprising the continuous <i>air barrier</i> and their position within each <i>building thermal envelope</i> assembly shall be identified.Joints, interconnections and penetrations of the continuous <i>air barrier</i> components shall be detailed.The continuity of the <i>air barrier</i> building element assemblies that enclose <i>conditioned space</i> or provide a boundary between <i>conditioned space</i> and unconditioned space shall be identified.Documentation of the continuous <i>air barrier</i> shall detail methods of sealing the <i>air barrier</i>, such as wrapping, caulking, gasketing, taping or other <i>approved</i> methods at the following locations:<ol style="list-style-type: none">Joints around <i>fenestration</i> and door frames.Joints between walls and floors; between walls at building corners; between walls and roofs, including parapets and copings; where <i>above-grade walls</i> meet foundations; and at similar intersections.Penetrations or attachments through the continuous <i>air barrier</i>.Building assemblies used as <i>ducts</i> or plenums.Changes in continuous <i>air barrier</i> materials and assemblies.Identify where testing will or will not be performed in accordance with Section C402.6.2. Where testing will not be performed, a plan for field inspections required by Section C402.6.2.3 shall be provided that includes the following:<ol style="list-style-type: none">The continuous <i>air barrier</i> scope of work.A list of critical inspection items.Inspection documentation requirements.	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/CS</td><td>CS</td></tr><tr><td></td><td></td><td></td><td>CS</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AS/CS	CS				CS
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	x																	
Action	AS	AS/CS	CS															
			CS															
	5.5. Provisions for corrective actions where needed.																	
CE#140	Renumbers Section C402.5.1.1 and revises the provision. Adds new requirements for the electrical and communication boxes to comply with a new sub- section C402.6.1.2.2.																	
Related Mod: CECP1-3- 21,CEPI- 60- 21,CEPI- 32- 21,CED1- 130-22	<p>C402.5.1.1 C402.6.1.2 Air barrier construction. The continuous air barrier shall be constructed to comply with the following:</p> <ol style="list-style-type: none">The <i>air barrier</i> shall be continuous for all assemblies that are compromise the building thermal envelope of the building and across the joints and assemblies.<i>Air barrier</i> joints and seams shall be sealed, including sealing transitions in places and changes in materials. The joints and seals shall be securely installed in or on the joint for its entire length so as not to dislodge, loosen or otherwise impair its ability to resist positive and negative pressure from wind, stack effect and mechanical ventilation.Penetrations of the <i>air barrier</i> shall be caulked, gasketed or otherwise sealed in a manner compatible with the construction materials and location. Sealing shall allow for expansion, contraction and mechanical vibration.joints and seams associated with penetrations shall be sealed in the same manner or taped—Sealing materials shall be securely installed around the penetration so as not to dislodge, loosen or otherwise impair the penetrations' ability to resist positive and negative pressure from wind, stack effect and mechanical ventilation. Sealing of concealed fire sprinklers, where required, shall be in a manner that is recommended by the fire sprinkler manufacturer. Caulking or other adhesive sealants shall not be used to fill voids between fire sprinkler cover plates and walls or ceilings.Recessed lighting fixtures shall comply with Section C402.6.1.2.1. Where similar objects are installed that penetrate the <i>air barrier</i>, provisions shall be made to maintain the integrity of the <i>air barrier</i>.Electrical and communication boxes shall comply with Section C402.6.1.2.2.	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/CS</td><td>CS</td></tr><tr><td></td><td>x</td><td></td><td>CS</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AS/CS	CS		x		CS
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	x																	
Action	AS	AS/CS	CS															
	x		CS															
CE#141	Renumbers Section C402.5.10 and makes editorial changes. Adds new Section C402.6.1.2.2. This new subsection was created due to section re- arrangement. Adds new Section C402.6.1.2.2.1. This new subsection was created due to section re-arrangement.																	
Related Mod: CECP1-3- 21, CEPI- 60-21, CECP1-3- 21,	<p>C402.5.10 C402.6.1.2.1 Recessed lighting.—Recessed luminaires installed in the <i>building thermal envelope</i> shall be all of the following:</p> <ol style="list-style-type: none">IC-rated.Labeled as having an <i>air leakage</i> rate of with ASTM E283 at a 1.57 psf (75 Pa) pressure differential.Sealed with a gasket or caulk between the housing and interior wall or ceiling covering. <p>C402.6.1.2.2 Electrical and communication boxes. Electrical and communication boxes that penetrate the <i>air barrier</i> of the <i>building thermal envelope</i>, and that do not comply with Section C402.6.1.2.2.1, shall be caulked, taped, gasketed or otherwise sealed to the <i>air barrier</i> element being penetrated. All openings on the concealed portion of the box shall be sealed. Where present, insulation shall rest against all concealed portions of the box.</p> <p>C402.6.1.2.2.1 Air-sealed boxes. Where air-sealed boxes are installed, they shall be marked in accordance with NEMA OS 4. Air-sealed boxes shall be installed in accordance with the manufacturer's instructions.</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/CS</td><td>CS</td></tr><tr><td></td><td></td><td></td><td>CS</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AS/CS	CS				CS
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	x																	
Action	AS	AS/CS	CS															
			CS															
CE#142	Renumbers and renames the title of Section C402.5.1.2, revises the testing requirements, re-arranges the provisions, and modifies the exceptions. Reduces the measured air leakage threshold to 0.35 cfm/ft2 from 0.40 cfm/ft2 due to advances in air leakage control technology. Also, the measured air leakage upper limit was reduced to 0.45 cfm/ft2 from 0.60 cfm/ft2 for the exception. Exempts buildings larger than 25,000 ft2 floor area from the testing requirement in climate zones 0 through 4. Allows alternative testing method and maximum air-leakage rate for dwelling and sleeping units per Section C402.6.2.2. It increases the code stringency, but it is a cost-effective change and is equivalent to the ASHRAE 90.1-2022 requirement.																	

Related Mod: CECP1-3- 21,CEPI- 58- 21,CEPI- 32- 21,CEPI- 61- 131, CED1- 131- 22,CED1- 132- 22,CE2D- 9-23, CEPI-71- 21	<p>C402.5.1.2 C402.6.2 Air barrier leakage compliance. A continuous air barrier for the opaque building envelope shall comply with the following:</p> <p>1—Buildings or portions of buildings, including Group R and I occupancies, shall meet the provisions of Section C402.6.2.2. Exception: Buildings in Climate Zones 2B, 3C and 5C.</p> <p>2—Buildings or portions of buildings other than Group R and I occupancies shall meet the provisions of Section C402.6.2.1. Exceptions:</p> <p>1—Buildings in Climate Zones 2B, 3B, 3C and 5C.</p> <p>2—Buildings larger than 5,000 square feet (464.5 m²) floor area in Climate Zones 0B, 1, 2A, 4B and 4C.</p> <p>3—Buildings between 5,000 square feet (464.5 m²) and 50,000 square feet (4645 m²) floor area in Climate Zones 0A, 3A and 5B.</p> <p>3—Buildings or portions of buildings that do not complete air barrier testing shall meet the provisions of Section C402.6.2.3.1 or C402.6.2.3.2 in addition to Section C402.6.2.3.</p> <p>Air leakage of the building thermal envelope shall be tested by an approved third party in accordance with Section C402.6.2.1. The measured air leakage shall not be greater than</p> <p>0.35 cubic feet per minute per square foot (1.8 L/s x m²) of the building thermal envelope area at a pressure differential of 0.3 inch water gauge (75 Pa) with the calculated building thermal envelope surface area being the sum of the above- and below-grade building thermal envelope.</p>																
	<p>Exceptions:</p> <p>1. Where the measured air leakage rate is greater than 0.35 cfm/ft² (1.8 L/s x m²) but is not greater than 0.45 cfm/ft² (2.3 L/s x m²), the approved third party shall perform a diagnostic evaluation using a smoke tracer or infrared imaging. The evaluation shall be conducted while the building is pressurized or depressurized along with a visual inspection of the air barrier in accordance with ASTM E1186. All identified leaks shall be sealed where such sealing can be made without damaging existing building components. A report specifying the corrective actions taken to seal leaks shall be deemed to establish compliance with the requirements of this section where submitted to the code official and the building owner. Where the measured air leakage rate is greater than 0.45 cfm/ft² (2.3 L/s x m²), corrective actions must be made to the building and an additional test completed for which the results are 0.45 cfm/ft² (2.3 L/s x m²) or less.</p> <p>2. Buildings in Climate Zone 2B.</p> <p>3. Buildings larger than 25,000 square feet (2323 m²) floor area in Climate Zones 0 through 4, other than Group I and R occupancies, that comply with Section C402.6.2.3.</p> <p>3. As an alternative, buildings or portions of buildings containing Group I-1 and R-2 occupancies shall be permitted to be tested by an approved third party in accordance with Section C402.6.2.2. The reported air leakage of the building thermal envelope shall not be greater than 0.27 cfm/ft² (1.4 L/s x m²) of the testing unit enclosure area at a pressure differential of</p> <p>0.2 inch water gauge (50 Pa).</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Division</td><td>AS</td><td>AS/EC</td><td>AS/EC</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		x			Division	AS	AS/EC	AS/EC		x		
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap														
	x																
Division	AS	AS/EC	AS/EC														
	x																
CE#143	<p>Renumbers and renames the title of Section C402.5.3, re-arranges the provision, moves part of the requirements, and updates referenced sections.</p> <p>The modified exception permits air leakage testing of the entire building's thermal envelope for buildings with less than 10,000 ft2 of floor area and of a portion of the building's thermal envelope for buildings with greater than 50,000 ft2 of floor area.</p>																
Related Mod: CECP1-3- 21, CE2D-9- 23	<p>C402.5.3 C402.6.2.1 Building thermal envelope testing. Whole building test method and reporting. The building thermal envelope shall be tested by an approved third party in accordance with ASTM E779, ANSI/RESNET/ICC 380, ASTM E3158 or ASTM E1827 or an equivalent approved method approved by the code official. The measured air leakage shall not exceed</p> <p>0.40 cfm/ft² (2.0 L/s x m²) of the building thermal envelope area at a pressure differential of 0.3 inch water gauge (75 Pa). Alternatively, portions of the building shall be tested and the measured air leakages shall be area weighted by the surface areas of the building envelope in each portion. The weighted-average test results shall not exceed the whole building leakage</p>																
	<p>limit. In the alternative approach, the following portions of the building shall be tested: A report that includes the tested surface area, floor area, air by volume, stories above grade, and air leakage rates shall be submitted to the code official and the building owner.</p> <p>1—The entire envelope area of all stories that have any spaces directly under a roof.</p> <p>2—The entire envelope area of all stories that have a building entrance, exposed floor, or loading dock, or are below grade.</p> <p>3—Representative above-grade sections of the building totaling at least 25 percent of the wall area enclosing the remaining conditioned space.</p> <p>Exceptions:</p> <p>1. Where the measured air leakage rate exceeds 0.40 cfm/ft² (2.0 L/s x m²) but does not exceed 0.60 cfm/ft² (3.0 L/s x m²), a diagnostic evaluation using smoke tracer or infrared imaging shall be conducted while the building is pressurized along with a visual inspection of the air barrier. Any leaks noted shall be sealed where such sealing can be made without destruction of existing building components. An additional report identifying the corrective actions taken to seal leaks shall be submitted to the code official and the building owner, and shall be deemed to comply with the requirements of this section. For buildings less than 10,000 square feet (929 m²), the entire building thermal envelope shall be permitted to be tested in accordance with ASTM E779, ASTM E3158, ASTM E1827 or an equivalent approved method.</p> <p>2. For buildings greater than 50,000 square feet (4645 m²), portions of the building shall be permitted to be tested and the measured air leakage shall be area weighted by the surface areas of the building thermal envelope in each portion. The weighted-average tested air leakage shall not be greater than the whole building air leakage limit. The following portions of the building shall be tested:</p> <p>2.1. The entire building thermal envelope area of stories that have any conditioned spaces directly under a roof.</p> <p>2.2. The entire building thermal envelope area of stories that have a building entrance, have a floor over unconditioned space, have a loading dock or that are below grade.</p> <p>2.3. Representative above-grade portions of the building totaling not less than 25 percent of the wall area enclosing the remaining conditioned space.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Division</td><td>AS</td><td>AS/EC</td><td>AS/EC</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		x			Division	AS	AS/EC	AS/EC		x		
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap														
	x																
Division	AS	AS/EC	AS/EC														
	x																
CE#144	<p>Renumbers and renames Section C402.5.2 and revises the provision to clarify the testing method and requirements. No change in the stringency.</p>																
Related Mod: CECP1-3- 21,	<p>C402.5.2 C402.6.2.2 Dwelling and sleeping unit enclosure testing. method and reporting. The building thermal envelope shall be tested for air leakage in accordance with ASTM E779, ANSI/RESNET/ICC 380, ASTM E1827 or an equivalent approved method approved by the code official. The measured air leakage shall not exceed 0.30 cfm/ft² (1.5 L/s x m²) of the testing unit enclosure area at a pressure differential of 0.2 inch water gauge (50 Pa). Where multiple dwelling units or sleeping units or other occupiable conditioned spaces are contained within one building thermal envelope, each unit shall be</p>																

CE2D-9- 23		<p>considered an individual testing unit, and the <i>building air leakage</i> shall be the weighted average of all testing tested unit results, weighted by each testing <i>unit's unit enclosure area</i>. Units shall be tested separately with an unguarded blow er-door test as follows: without simultaneously testing adjacent units and shall be separately tested as follows:</p> <p>1. Where buildings have fewer less than eight total testing dwelling or sleeping units, each testing unit shall be tested:</p> <p>2. Where</p> <p>For buildings with have eight or more testing dwelling or sleeping units, the greater of seven units or 20 percent of the testing units in th e building shall be tested, including a top floor unit, a middle floor unit, a ground floor unit and a unit with the largest testing unit enclos ure area. For each tested unit that exceeds the maximum air leakage rate, an additional two three units shall be tested, including a mix ture of testing unit types and locations:</p> <p>3. <i>Enclosed spaces</i> with not less than one <i>exterior wall in the building thermal envelope</i> shall be tested in accordance with Section C402.6.2.1.</p> <p>Exception: Corridors, stairwells, and <i>enclosed spaces</i> having a <i>conditioned floor area</i> not greater than 1,500 square feet (139 m²) shall</p> <p>Section C402.6.2.3.2.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td></td><td></td><td></td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap					Action	AS	AL/EC	D				X				D/EC	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																				
Action	AS	AL/EC	D																				
			X																				
			D/EC																				
CE#145	Renumbers and renames Section C402.5.1.5 and makes editorial changes to clarify the code.																						
Related Mod: CECPI-3- 21, CED1-92- 22, CE2D-10- 23	<p>C402.5.1.5-C402.6.2.3 Building thermal envelope performance design and construction verification criteria. Where Section C402.6.2.1 and C402.6.2.2 are not applicable theThe installation of the continuous <i>air barrier</i> shall be verified by the <i>code official</i>; a registered design professional or approved agency in accordance with the following:</p> <p>1. A review of the <i>construction documents</i> and other supporting data shall be conducted to assess compliance with the requirements in Section C402.6.1.</p> <p>2. Inspection of continuous <i>air barrier</i> components and assemblies shall be conducted during construction while the <i>air barrier</i> is still accessible for inspection and <i>repair</i> to verify compliance with the requirements of Sections C402.6.2.3.1 and C402.6.2.3.2. The <i>air barrier</i> shall be provided with access for inspection and repair.</p> <p>3. A final commissioning inspection report shall be provided for inspections completed by the registered design professional or approved a gency. The commissioning inspection report shall be provided to the building owner or owner's authorized agent and the code official. The report shall identify deficiencies found during the review of the construction documents and inspection and details of corrective me asures taken.</p> <p>Original text of mod is not consistent with that of the 2023 FBC -EC.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td></td><td></td><td></td><td>D/EC</td></tr></table>		Staff Classification	Correlates Directly	Energy Standard Needed	Over lap					Action	AS	AL/EC	D				X				D/EC	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																				
Action	AS	AL/EC	D																				
			X																				
			D/EC																				
CE#146	Renumbers Section C402.5.1.3. Renumbers Section C402.5.1.3 and makes editorial changes.																						
Related Mod: CECPI-3- 21	<p>C402.5.1.3-C402.6.2.3.1 Materials. Materials with an air permeability not greater than 0.004 cfm/ft² (0.02 L/s × m²) under a pressure differential of 0.3 inch water gauge (75 Pa) when tested in accordance with ASTM E2178 shall comply with this section. Materials in Items 1 through 16 shall be deemed to comply with this section, provided that joints are sealed and materials are installed as <i>air barriers</i> in accordance with the manufacturer's instructions.</p> <p>C402.5.1.4-C402.6.2.3.2 Assemblies. Assemblies of materials and components with an average <i>air leakage</i> not greater than 0.04 cfm/ft² (0.2 L/s × m²) under a pressure differential of 0.3 inch of water gauge (w.g.) (75 Pa) when where tested in accor dance with ASTM E2357, ASTM E1677, ASTM D8052 or ASTM E283 shall comply with this section. Assemblies listed in items 1 through 3 below shall be deemed to comply, provided that joints are sealed and the requirements of Section C402.6.1.2 are met.</p> <p>1. Concrete masonry walls coated with either one application of block filler or two applications of a paint or sealer coating.</p> <p>2. Masonry walls constructed of clay or shale masonry units with a nominal width of greater than or equal to 4 inches (102 mm) or more.</p> <p>3. A Portland cement/sand parge, stucco or plaster not less than 1/2 inch (12.7 mm) in thickness.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td></td><td></td><td></td><td>D/EC</td></tr></table>		Staff Classification	Correlates Directly	Energy Standard Needed	Over lap					Action	AS	AL/EC	D				X				D/EC	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																				
Action	AS	AL/EC	D																				
			X																				
			D/EC																				
CE#147	Renumbers Section C402.5.4, renames the title, and makes editorial changes.																						
Related Mod: CECPI-3- 21, CEPI- 16-21 Part I	<p>C402.5.4-C402.6.3 Air leakage of fenestration and opaque doors. The <i>air leakage of fenestration and opaque door</i> assemblies shall comply with me et the provisions of Table C402.6.3. Testing shall be in accordance with the conducted by an accredited, independent testing laboratory in accor dce with applicable reference test standards in Table C402.6.3 by an accredited, independent testing laboratory and labeled by the manufactu rer.</p> <p>Exceptions:</p> <p>1. Field-fabricated fenestration assemblies that are sealed in accordance with Section C402.6.1.</p> <p>2. <i>Fenestration in buildings</i> that comply with the testing alternative of Section C402.6 is tested in accordance with Section C402.6.2 is are not required to meet the <i>air leakage</i> requirements in Table C402.6.3.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AL/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td></td><td></td><td></td><td>D/EC</td></tr></table>		Staff Classification	Correlates Directly	Energy Standard Needed	Over lap					Action	AS	AL/EC	D				X				D/EC	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																				
Action	AS	AL/EC	D																				
			X																				
			D/EC																				
CE#148	Renumbers table C402.5.2.																						
Related Mod: CECPI-3- 21	TABLE C402.5.4 TABLE C402.6.3 MAXIMUM AIR LEAKAGE RATE FOR FENESTRATION ASSEMBLIES																						
CE#149	Renumbers Section C402.5.6 and makes editorial changes. Renumbers Section C402.5.7 and replaces the text "envelope" with "thermal envelope." Renumbers Section C402.5.9, makes editorial changes, and revises the exception.																						
Related Mod: CECPI-3- 21, CECPI-3- 21, CED1-92- 22, CECPI-3- 21	<p>C402.5.6-C402.6.4 Doors and access openings to shafts, chutes, stairways and elevator lobbies. Doors and access openings from <i>conditioned space</i> – to shafts, chutes, stairways – and elevator lobbies not within the scope of the fenestration assemblies covered by Section C402.6.3 shall be gasketed, weather-stripped or sealed.</p> <p>Exceptions:</p> <p>1. Door openings required to comply with Section 716 of the <i>International Building Code</i>.</p> <p>2. Doors and door openings required to comply with the International Building Code to comply with UL-1784 by the International Building Code.</p> <p>C402.5.7-C402.6.5 Air intakes, exhaust openings, stairways and shafts. Stairway enclosures, elevator shaft vents and other outdoor air intakes and exhaust openings integral to the building <i>thermal</i> envelope shall be provided with dampers in accordance with Section C403.7.7.</p> <p>C402.5.9-C402.6.6 Vestibules. <i>Building entrances</i> shall be protected with an enclosed vestibule, with all doors. Doors opening into and out of the vestibule equipped with self-closing devices. Vestibules shall be designed so that in passing through the vestibule it is not necessary for the interior and exterior doors to open at the same time. The installation of one or more revolving doors in the <i>building entrance</i> shall not eliminate the requirement that a vestibule be provided on any doors adjacent to revolving doors.</p> <p>Exceptions: Vestibules are not required for the following:</p>																						

		<div>1. Buildings in Climate Zones 0 through 2.</div> <div>2. Doors not intended to be used by the public, such as doors to mechanical or electrical equipment rooms , or intended solely for employee use.</div> <div>3. Doors opening directly from a sleeping unit or dwelling unit .</div> <div>4. Doors that open directly from a space less than 3,000 square feet (298 m²) in area.</div> <div>5. Revolving doors.</div> <div>6. Doors used primarily to facilitate vehicular movement or material handling and adjacent personnel doors.</div> <div>7. Doors that have an air curtain unit with a velocity of not less than 6.56 feet per second (2 m/s) at 6 inches (152 mm) above the floor that have has been tested in accordance with ANSI/AMCA 220 or ISO 27327-1 and installed in accordance with the manufacturer's instructions. Manual or automatic controls shall be provided that will operate air curtain unit with the opening and closing of the door and comply with Section C403.4.1.5. Air and their controls shall comply with Section C408.2.3.</div>																		
		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>Q/C</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over top		x			Action	AS	AS/EC	D	Q/C		x			
Staff Classification	Correlates Directly	Energy Standard	Over top																	
	x																			
Action	AS	AS/EC	D	Q/C																
	x																			
CE#150	Renumbers Section C402.5.8 and replaces the text "infiltration" with "air leakage."																			
Related Mod:	C402.5.8 C402.6.7 Loading dock weather seals. Cargo door openings and loading door openings shall be equipped with weather seals that restrict infiltration air leakage and provide direct contact along the top and sides of vehicles that are parked in the doorway.																			
CECPI-3-21,CEPI-32-21		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>Q/C</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over top		x			Action	AS	AS/EC	D	Q/C		x			
Staff Classification	Correlates Directly	Energy Standard	Over top																	
	x																			
Action	AS	AS/EC	D	Q/C																
	x																			
CE#151	Adds a new section C402.7. Adds a provision for treatment of thermal bridges in above grade walls. Exempts climate zones 0 through 3 only. This increases the stringency for climate zones 4 through 8. Adds a new subsection C402.7.1. Adds a new subsection C402.7.2. Adds a new subsection C402.7.3. Adds a new subsection C402.7.4. Adds a new subsection C402.7.5.																			
Related Mod:	C402.7 Thermal bridges in above-grade walls. Thermal bridges in above-grade walls shall comply with this section or an approved design.																			
CECPI-4-21, CED1- 107-22, CED1-138-22	<div>Exceptions:</div> <div>1. Buildings and structures located in Climate Zones 0 through 3.</div> <div>2. Any thermal bridge with a material thermal conductivity not greater than 3.0 Btu/h x ft x°F (5.19 W/m x K).</div> <div>3. Blocking, coping, flashing and other similar materials for attachment of roof coverings.</div> <div>4. Thermal bridges accounted for in the U-factor or C-factor for a building thermal envelope .</div>																			
CED1-139-22, CED1-110-22	<div>C402.7.1 Balconies and floor decks. Balconies and concrete floor decks shall not penetrate the building thermal envelope . Such assemblies shall be separately supported or shall be supported by structural attachments or elements that minimize thermal bridging through the building thermal envelope .</div> <div>Exceptions: Balconies and concrete floor decks shall be permitted to penetrate the building thermal envelope where one of the following applies:</div> <div>1. An area-weighted U-factor is used for above-grade wall compliance that includes a U-factor of 0.8 Btu/h x °F x ft² (1.38 W/m x K) for the area of the above-grade wall penetrated by the concrete floor deck in accordance with C402.1.2.1.5.</div> <div>2. An approved thermal break device with not less than R-10 insulation material is installed in accordance with the manufacturer's instructions.</div> <div>3. An approved design where the above-grade wall U-factor used for compliance accounts for all balcony and concrete floor deck thermal bridges .</div>																			
	<div>C402.7.2 Cladding supports. Linear elements supporting opaque cladding shall be offset from the structure with attachments that allow the continuous insulation , where present, to pass behind the cladding support element except at the point of attachment.</div> <div>Exceptions:</div> <div>1. An approved design where the above-grade wall U-factor used for compliance accounts for the cladding support element thermal bridge .</div> <div>2. Anchoring for curtain wall and window wall systems where curtain wall and window wall systems comply with Section C402.7.4.</div> <div>C402.7.3 Structural beams and columns. Structural steel and concrete beams and columns that project through the building thermal envelope shall be covered with not less than R-5 insulation for not less than 2 feet (610 mm) beyond the interior or exterior surface of an insulation component within the building thermal envelope .</div> <div>Exceptions:</div> <div>1. Where an approved thermal break device is installed in accordance with the manufacturer's instructions.</div> <div>2. An approved design where the above-grade wall U-factor used to demonstrate compliance accounts for the beam or column thermal bridge .</div> <div>C402.7.4 Vertical fenestration. Vertical fenestration intersections with above-grade walls shall comply with one or more of the following:</div> <div>1. Where above-grade walls include continuous insulation , the plane of the exterior glazing layer or, for metal frame fenestration , a nonmetal thermal break in the frame shall be positioned within 2 inches (610 mm) of the interior or exterior surface of the continuous insulation .</div> <div>2. Where above-grade walls do not include continuous insulation , the plane of the exterior glazing layer or, for metal frame fenestration , a nonmetal thermal break in the frame shall be positioned within the thickness of the integral or cavity insulation .</div> <div>3. The surface of the rough opening, not covered by the fenestration frame, shall be insulated with insulation of not less than R-3 material or covered with a wood buck that is not less than 1.5 inches (38 mm) thick.</div> <div>4. For the intersection between vertical fenestration and opaque spandrel in a shared framing system, manufacturer's data for the spandrel U-factor shall account for thermal bridges .</div> <div>Exceptions:</div> <div>1. Where an approved design for the above-grade wall U-factor used for compliance accounts for thermal bridges at the intersection with the vertical fenestration .</div> <div>2. Doors.</div> <div>C402.7.5 Parapets. Parapets shall comply with one or more of the following as applicable:</div> <div>1. Where continuous insulation is installed on the exterior side of the above-grade wall and the roof is insulated with insulation entirely above deck, the continuous insulation shall extend up both sides of the parapet not less than 2 feet (610</div>																			
	<div>mm) above the roof covering or to the top of the parapet, whichever is less. Parapets that are an integral part of a fire-resistance rated wall, and the exterior continuous insulation applied to the parapet, shall comply with the fire-resistance ratings of the building code.</div> <div>2. Where continuous insulation is installed on the exterior side of the above-grade wall and the roof insulation is below the roof deck, the continuous insulation shall extend up the exterior side of the parapet to not less than the height of the top surface of the roof assembly .</div> <div>3. Where continuous insulation is not installed on the exterior side of the above-grade wall and the roof is insulated with insulation entirely above deck, the wall cavity or integral insulation shall extend into the parapet up to the exterior face of the roof insulation or equivalent R-value insulation shall be installed not less than 2 feet (610 mm) horizontally inward on the underside of the roof deck.</div> <div>4. Where continuous insulation is not installed on the exterior side of the above-grade wall and the roof insulation is below the roof deck, the wall and roof insulation components shall be adjacent to each other at the roof-ceiling-wall intersection.</div> <div>5. Where a thermal break device with not less than R-10 insulation material aligned with the above-grade wall and roof insulation is installed in accordance with the manufacturer's instructions.</div> <div>Exception: An approved design where the above-grade wall U-factor used for compliance accounts for the parapet thermal bridge .</div>																			

<div> <div>8</div> <div>0-16</div> </div>	<div> <div> <div> <div>Staff Classification</div> <div>Correlates Directly</div> <div>Energy Standard Needed</div> <div>Over lap</div> </div> <div> <div>AS</div> <div>AS</div> <div>AS/AC</div> <div>D</div> <div>D/C</div> </div> </div> <div> <div> <div>Staff Classification</div> <div>Correlates Directly</div> <div>Energy Standard Needed</div> <div>Over lap</div> </div> <div> <div>AS</div> <div>AS</div> <div>AS/AC</div> <div>D</div> <div>D/C</div> </div> </div> </div>
CE#155	<div>Editorial changes for clarification.</div>
<div>Related Mod:</div> <div>CEPI-86- 21</div>	<div> <div> <div>C403.2.3 Fault detection and diagnostics.</div> <div> <div>New buildings—Buildings with an HVAC system serving a gross conditioned floor area of not less than 100,000 square feet (9290 m²) served by one or more HVAC systems that are controlled by a direct digital control (DDC) system or larger shall include a fault detection and diagnostics (FDD) system to monitor the HVAC system's performance and automatically identify faults. The FDD system shall:</div> <div> <div>1. Include permanently installed sensors and devices to monitor the HVAC system's performance;</div> <div>2. Sample the HVAC system's performance at least once every 15 minutes;</div> <div>3. Automatically identify and report HVAC system faults;</div> <div>4. Automatically notify authorized personnel of identified HVAC system faults;</div> <div>5. Automatically provide prioritized recommendations for repair of identified faults based on analysis of data collected from the sampling of HVAC system performance;</div> <div>6. Be capable of transmitting the prioritized fault repair recommendations to remotely located authorized personnel.</div> </div> </div> </div> <div> <div>Exception: R-1 and R-2 occupancies.</div> <div>Original text of mod is not consistent with that of the 2023 FBC-EC.</div> </div> <div> <div> <div>Staff Classification</div> <div>Correlates Directly</div> <div>Energy Standard Needed</div> <div>Over lap</div> </div> <div> <div>AS</div> <div>AS</div> <div>AS/AC</div> <div>D</div> <div>D/C</div> </div> </div> </div>
CE#156	<div>Editorial changes for clarification and removes minimum efficiency values of before 1/1/2023.</div>
	<div> <div> <div>Staff Classification</div> <div>Correlates Directly</div> <div>Energy Standard Needed</div> <div>Over lap</div> </div> <div> <div>AS</div> <div>AS</div> <div>AS/AC</div> <div>D</div> <div>D/C</div> </div> </div>

| CE#157 | Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1. Removes minimum efficiency values of before 1/1/2023. |
| Related Mod: TABLE C403.3-2(1) | ELECTRICALLY OPERATED UNITARY AIR CONDITIONERS AND CONDENSING UNITS—MINIMUM EFFICIENCY SIZE CATEGORY HEADING SECTION TYPE REQUIREMENTS SUBCATEGORY OR RATING CONDITION MINIMUM EFFICIENCY TEST PROCEDURE Air-conditioners < 65,000 Btu/h^a All Split system, three-phase and applications outside US single-phase^{a, b} 13.0 SEER before 1/1/2023 13.4 SEER2 after 1/1/2023 AHRI 210/240—2017 before 1/1/2023—AHRI Single-package, three-phase and applications outside US single-phase^a 14.0 SEER before 1/1/2023 13.4 SEER2 after 1/1/2023 210/240—2023 after 1/1/2023 Space-cooled < 30,000 Btu/h^a All Split system, three-phase and applications outside US single-phase^{a, b} 12.0 SEER before 1/1/2023 11.7 SEER2 after 1/1/2023 AHRI 210/240—2017 before 1/1/2023—AHRI Single-package, three-phase and applications outside US single-phase^{a, b} 12.0 SEER before 1/1/2023 11.7 SEER2 after 1/1/2023 210/240—2023 after 1/1/2023 Small duct, high-velocity, air-cooled < 65,000 Btu/h^a All Split system, three-phase and applications outside US single-phase^{a, b} 12.0 SEER before 1/1/2023 12.4 SEER2 after 1/1/2023 AHRI 210/240—2017 before 1/1/2023—AHRI 210/240—2023 after 1/1/2023 Air-conditioners, air-cooled ≥ 65,000 Btu/h and < 135,000 Btu/h Electric-resistance (or non-e) Split system and single package 11.2 SEER 12.0 IEER before 1/1/2023 14.8 IEER after 1/1/2023 AHRI 340/360 ≥ 135,000 Btu/h and < 240,000 Btu/h Electric-resistance (or non-e) All-other 11.0 SEER 12.7 IEER before 1/1/2023 14.6 IEER after 1/1/2023 ≥ 135,000 Btu/h and < 240,000 Btu/h Electric-resistance (or non-e) All-other 11.0 SEER 12.4 IEER before 1/1/2023 14.2 IEER after 1/1/2023 ≥ 135,000 Btu/h and < 240,000 Btu/h Electric-resistance (or non-e) All-other 10.8 SEER 12.2 IEER before 1/1/2023 14.0 IEER after 1/1/2023 |

		≥240,000 Btu/h and <760,000 Btu/h	Electric resistance (or none)		before 1/1/2023 13.2 IEER after 1/1/2023	
					9.8 EER 11.4 IEER	
			All other	Split-system and single package	before 1/1/2023 13.0 IEER after 1/1/2023	AHRI-340/360
		≥760,000 Btu/h	Electric resistance (or none)		9.7 EER 11.2 IEER before 1/1/2023 12.5 IEER after 1/1/2023	
			All other		9.5 EER 11.0 IEER before 1/1/2023 12.3 IEER after 1/1/2023	
		<65,000 Btu/h	All		12.1 EER 12.3 IEER	AHRI-210/240
		≥65,000 Btu/h and <135,000 Btu/h	Electric resistance (or none)		12.1 EER 13.0 IEER	
			All other		11.9 EER 13.7 IEER	
		≥135,000 Btu/h and <240,000 Btu/h	Electric resistance (or none)		12.6 EER 13.9 IEER	
			All other		12.3 EER 13.7 IEER	
		≥240,000 Btu/h and <760,000 Btu/h	Electric resistance (or none)		12.4 EER 13.6 IEER	
			All other	Split-system and single package	12.2 EER 13.4 IEER	AHRI-340/360
	Air conditioners, water-cooled				12.2 EER 13.5 IEER	
		≥760,000 Btu/h	Electric resistance (or none)		12.0 EER 13.3 IEER	
			All other			
	Air conditioners, evaporatively cooled	<65,000 Btu/h ^b	All		12.1 EER 12.3 IEER	AHRI-210/240
		≥65,000 Btu/h and <135,000 Btu/h	Electric resistance (or none)	Split-system and single package	12.1 EER 12.3 IEER	AHRI-340/360
			All other		11.9 EER 12.1 IEER	
		≥135,000 Btu/h and <240,000 Btu/h	Electric resistance (or none)		12.0 EER 12.2 IEER	
			All other		11.8 EER 12.0 IEER	
		≥240,000 Btu/h and <760,000 Btu/h	Electric resistance (or none)		11.9 EER 12.1 IEER	
			All other		11.7 EER 11.9 IEER	
		≥760,000 Btu/h	Electric resistance (or none)		11.7 EER 11.9 IEER	
			All other		11.5 EER 11.7 IEER	
	Condensing units, air-cooled	≥135,000 Btu/h	—	—	10.6 EER 11.8 IEER	AHRI-365
	Condensing units, water-cooled	≥135,000 Btu/h	—	—	13.6 EER 14.0 IEER	AHRI-365
	Condensing units, evaporatively cooled	≥135,000 Btu/h	—	—	13.6 EER 14.0 IEER	AHRI-365
	For SI: 1 British thermal unit per hour = 0.2931 W.					
	a.—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.					
	b.—Single-phase, US air-cooled air conditioners less than 65,000 Btu/h are regulated as consumer products by the US Department of Energy Code of Federal Regulations—DOE 10 CFR 430. SEER and SEER2 values for single-phase products are set by the US Department of Energy.					
	c.—DOE 10 CFR 430 Subpart B Appendix M1 includes the test procedure updates effective 1/1/2023 that will be incorporated in AHRI-210/240—2023.					
	d.—This table is a replica of ASHRAE 90.1 Table 6.8.1-1					
	1 Electrically Operated Unitary Air Conditioners and Condensing Units—Minimum Efficiency Requirements.					
	TABLE C403.3.2(1) ELECTRICALLY OPERATED UNITARY AIR CONDITIONERS AND CONDENSING UNITS—MINIMUM EFFICIENCY REQUIREMENTS ^c					
	SIZE CATEGORY	HEADING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a	

	Air conditioners, air cooled	< 65,000 Btu/h ^b	All	Split system, three phase and applications outside US single phase ^b	13.4 SEER2	AHRI 210/240—2023
				Single-package, three phase and applications outside US single phase ^b	13.4 SEER2	
	Space constrained, air cooled	≤ 30,000 Btu/h ^b	All	Split system, three phase and applications outside US single phase ^b	11.7 SEER2	AHRI 210/240—2023
				Single package, three phase and applications outside US single phase ^b	11.7 SEER2	
	Small duct, high velocity, air cooled	< 65,000 Btu/h ^b	All	Split system, three phase and applications outside US single phase ^b	12.0 SEER2	AHRI 210/240—2023
	Air conditioners, air cooled	≥ 65,000 Btu/h and < 135,000 Btu/h	Electric resistance (or none)	Split system and single package	14.8 IEER	AHRI 340/360
			All other		14.6 IEER	
		≥ 135,000 Btu/h and < 240,000 Btu/h	Electric resistance (or none)		14.2 IEER	
			All other		14.0 IEER	
		≥ 240,000 Btu/h and < 760,000 Btu/h	Electric resistance (or none)	Split system and single package	13.2 IEER	AHRI 340/360
			All other		13.0 IEER	
		≥ 760,000 Btu/h	Electric resistance (or none)		12.5 IEER	
			All other		12.3 IEER	
	Air conditioners, water cooled	< 65,000 Btu/h	All	Split system and single package	12.1 EER 12.3 IEER	AHRI 210/240
		≥ 65,000 Btu/h and < 135,000 Btu/h	Electric resistance (or none)		12.1 EER 13.9 IEER	AHRI 340/360
			All other		11.9 EER 13.7 IEER	
		≥ 135,000 Btu/h and < 240,000 Btu/h	Electric resistance (or none)		12.5 EER 13.9 IEER	
			All other		12.3 EER 13.7 IEER	
		≥ 240,000 Btu/h and < 760,000 Btu/h	Electric resistance (or none)		12.4 EER 13.6 IEER	
			All other			
	Air conditioners, evaporatively cooled	760,000 Btu/h	All other		12.2 EER 13.4 IEER	
		≥ 760,000 Btu/h	Electric resistance (or none)		12.2 EER 13.5 IEER	
			All other		12.0 EER 13.3 IEER	
		< 65,000 Btu/h ^b	All	Split system and single package	12.1 EER 12.3 IEER	AHRI 210/240
		≥ 65,000 Btu/h and < 135,000 Btu/h	Electric resistance (or none)		12.1 EER 12.3 IEER	AHRI 340/360
			All other		11.9 EER 12.1 IEER	
		≥ 135,000 Btu/h and < 240,000 Btu/h	Electric resistance (or none)		12.0 EER 12.2 IEER	
			All other		11.8 EER 12.0 IEER	
		≥ 240,000 Btu/h and < 760,000 Btu/h	Electric resistance (or none)		11.9 EER 12.1 IEER	
			All other		11.7 EER 11.9 IEER	
	Condensing units, air cooled	≥ 135,000 Btu/h		—	10.5 EER 11.8 IEER	AHRI 365
	Condensing units, water cooled	≥ 135,000 Btu/h		—	13.5 EER 14.0 IEER	AHRI 365

Condensing units, ≥ 135,000 Btu/h — — 13.5 EER AHRI 365
 evaporatively cooled
 For SI: 1 British thermal unit per hour = 0.2931 W.

- a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.
 b. Single-phase, US air-cooled air conditioners less than 65,000 Btu/h are regulated as consumer products by the US Department of Energy Code of Federal Regulations DOE 10 CFR 430. SEER and SEER2 values for single-phase products are set by the US Department of Energy.
 c. DOE 10 CFR 430 Subpart B Appendix M1 includes the test procedure updates effective January 1, 2023, documented in AHRI

Staff Classification	Correlates Directly	Energy Standard Needed	Door Tag
	2		
Action	AS	SEEC	DC
	1		

CE#158 Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1. Removes minimum efficiency values of before 1/1/2023.

Related Mod:
CED1- 156-22,
CED2-13-23,
CED2-16-23,
CED2-18-23,
CED1- 157-22,
CED2-17-23,
CED2-19-23,
CED1- 12-22

TABLE C403.3.2(2) ELECTRICALLY OPERATED AIR-COOLED UNITARY HEAT PUMPS—MINIMUM EFFICIENCY REQUIREMENTS^a

	EQ UIP ME N	SIZE CATE GORY	HEADING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICI ENCY	TEST PROCEDURE
Air-cooled (cooling-mode)		< 66,000 Btu/h	All	Split-system, three-phase and applications outside US single phase ^b	14.0 SEER before 1/1/2023-14.3 SEER2 after 1/1/2023	AHRI-210/240—2017 before 1/1/2023— AHRI-210/240—2023 after 1/1/2023
				Single package, three-phase and applications outside US single phase ^b	14.0 SEER before 1/1/2023-13.4 SEER2 after 1/1/2023	
Space-constrained, air-cooled (heating-mode)		≤ 30,000 Btu/h		Split-system, three-phase and applications outside US single phase ^b	12.0 SEER before 1/1/2023-11.7 SEER2 after 1/1/2023	AHRI-210/240—2017 before 1/1/2023— AHRI-210/240—2023 after 1/1/2023

cooled (cooling-mode)		Btu/h	All	Single-package, three-phase and applications outside-US single-phase ^b	12.0 SEER before 1/1/2023-11.7 SEER2 after 1/1/2023	2023—AHRI 210/240—2023 after 1/1/2023
Single-duct, high-velocity, air-cooled (cooling-mode)		<65,000	All	Split-system, three-phase and applications outside-US single-phase ^b	12.0 SEER before 1/1/2023-12.0 SEER2 after 1/1/2023	AHRI 210/240—2017 before 1/1/2023—3-AHRI 210/240—2023 after 1/1/2023
Air-cooled (cooling-mode)	≥65,000 Btu/h and <135,000 Btu/h	Electric-resistance (or non-e)	Split-system and single-package	11.0 EER-12.2 IEER before 1/1/2023-14.1 IEER after 1/1/2023	AHRI 340/360	
		All-other		10.8 EER-12.0 IEER before 1/1/2023-13.9 IEER after 1/1/2023		
	≥135,000 Btu/h and <240,000 Btu/h	Electric-resistance (or non-e)		10.6 EER-11.6 IEER before 1/1/2023-13.6 IEER after 1/1/2023		
		All-other		10.4 EER-11.4 IEER before 1/1/2023-13.3 IEER after 1/1/2023		
	≥240,000 Btu/h	Electric-resistance (or non-e)		9.6 EER-10.6 IEER before 1/1/2023-12.6 IEER after 1/1/2023		
		All-other		9.3 EER-10.4 IEER before 1/1/2023-12.3 IEER after 1/1/2023		

Air-cooled (heating-mode)	<66,000 Btu/h	All	Split-system, three-phase and applications outside US single phase ^b	8.2 HSPF before 1/1/2023 7.5 HSPF2 after 1/1/2023	AHRI-210/240—2017 before 1/1/2023— AHRI-210/240—2023 after 1/1/2023	
			Single package, three phase and applications outside US single phase ^b	8.0 HSPF before 1/1/2023 6.7 HSPF2 after 1/1/2023		
Space-constrained, air-cooled (heating-mode)	≤ 30,000 Btu/h	All	Split-system, three-phase and applications outside US single phase ^b	7.4 HSPF before 1/1/2023 6.3 HSPF2 after 1/1/2023	AHRI-210/240—2017 before 1/1/2023— AHRI-210/240—2023 after 1/1/2023	
			Single package, three phase and applications outside US single phase ^b	7.4 HSPF before 1/1/2023 6.3 HSPF2 after 1/1/2023		
Small-duct, high-velocity, air-cooled (heating-mode)	<66,000 Btu/h	All	Split-system, three-phase and applications outside US single phase ^b	7.2 HSPF before 1/1/2023 6.1 HSPF2 after 1/1/2023	AHRI-210/240—2017 before 1/1/2023— AHRI-210/240—2023 after 1/1/2023	
Air-cooled (heating-mode)	≥66,000 Btu/h and <135,000 Btu/h (cooling-capacity)	All	47°F db/43°F wb outdoor-air if	2.30 COP _H before 1/1/2023 2.40 COP _H after 1/1/2023	AHRI-340/360	
			47°F db/45°F wb outdoor-air if	2.25 COP _H		
	≥135,000 Btu/h and <240,000 Btu/h (cooling-capacity)		47°F db/43°F wb outdoor-air if	2.20 COP _H before 1/1/2023 2.30 COP _H after 1/1/2023		
			47°F db/45°F wb outdoor-air if	2.05 COP _H		

130,000	47°F db/43°F wb			3:26 COP _H	
outdoor air					
Btu/h					
cooling	17°F db/15°F wb	2:25 COP capacity _H	outdoor air	H	

For SI: 1 British thermal unit per hour = 0.2931 W, °C = [(°F) – 32]/1.8, wb = wet bulb, db = dry bulb.

a—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.

b—Single-phase, US air-

cooled heat pumps less than 65,000 Btu/h are regulated as consumer products by the US Department of Energy Code of Federal Regulations DOE 10 CFR 430-SEER, SEER2 and HSPF values for single-phase products are set by the US Department of Energy.

c—DOE 10 CFR 430 Subpart B Appendix M1 includes the test procedure updates effective 1/1/2023 that will be incorporated in AHRI 210/240—2023.

d—This table is a replica of ASHRAE 90.1 Table 6.8.1-2 Electrically Operated Air-Cooled Unitary Heat Pumps—Minimum Efficiency Requirements.

TABLE C403.3.2(2)

ELECTRICALLY OPERATED AIR-COOLED UNITARY HEAT PUMPS—MINIMUM EFFICIENCY REQUIREMENTS^c

	EQ UIP ME	SIZE CATEGORY	HEADING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a
Air cooled (cooling mode)		< 65,000 Btu/h	All	Split system, three phase and applications outside US single phase ^b	14.3 SEER2	AHRI 210/240—2023
				Single package, three phase and applications outside US single phase ^b	13.4 SEER2	
Space constrained, air				Split system, three phase and applications outside US single phase ^b	11.7 SEER2	AHRI 210/240—2023
Air cooled (cooling mode)	cool ed (cooling mode)	≤ 30,000 Btu/h	All	Single package, three phase and applications outside US single phase ^b	11.7 SEER2	AHRI 210/240—2023
		< 65,000 Btu/h	All	Split system, three phase and applications outside US single phase ^b	12.0 SEER2	
		≥ 65,000 Btu/h and < 135,000 Btu/h	Electric resistance (or none)	Split system and single package	14.1 IEER	
			All other		13.9 IEER	
		≥ 135,000 Btu/h and < 240,000 Btu/h	Electric resistance (or none)		13.5 IEER	
			All other		13.3 IEER	
		≥ 240,000 Btu/h	Electric resistance (or none)		12.5 IEER	
			All other		12.3 IEER	
		< 65,000 Btu/h (cooling capacity)	—	Split system, three phase and applications outside US single phase ^b	7.5 HSPF2	AHRI 210/240—2023
			—	Single package, three phase and applications outside US single phase ^b	6.7 HSPF2	
Space constrained, air cooled (heating mode)		≤ 30,000 Btu/h (cooling capacity)	—	Split system, three phase and applications outside US single phase ^b	6.3 HSPF2	AHRI 210/240—2023
				Single package, three phase and applications outside US single phase ^b	6.3 HSPF2	

Small duct high velocity, air cooled (heating mode)	< 65,000 Btu/h	—	Split system, three phase and applications outside US single phase ^b	6.1 HSPF2	AHRI 210/240—2023
---	----------------	---	---	-----------	-------------------

Air cooled (heating mode)	≥ 65,000 Btu/h and < 135,000 Btu/h (cooling capacity)	—	47°F db/43°F wb outdoor air	3.40 COP _H	AHRI 340/360	
			17°F db/15°F wb outdoor air	2.25 COP _H		
	≥ 135,000 Btu/h and < 240,000 Btu/h (cooling capacity)		47°F db/43°F wb outdoor air	3.30 SOP _H		
			17°F db/15°F wb outdoor air	2.05 COP _H		
	≥ 240,000 Btu/h (cooling capacity)		47°F db/43°F wb outdoor air	3.20 COP _H		
			17°F db/15°F wb outdoor air	2.05 COP _H		

For SI: 1 British thermal unit per hour = 0.2931 W, °C = (°F – 32)/1.8, wb = wet bulb, db = dry bulb.

a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.

b. Single-phase, US air-cooled heat pumps less than 65,000 Btu/h are regulated as consumer products by the US Department of Energy Code of Federal Regulations DOE 10 CFR 430. SEER, SEER2 and HSPF values for single-phase products are set by the US Department of Energy.

c. DOE 10 CFR 430 Subpart B Appendix M1 includes the test procedure updates effective January 1, 2023, documented in AHRI 210/240–2023.

Staff Classification	Correlates Directly	Energy Standard Needed	Overlap	
	X			

Action	AS	AS/IC	D	D/IC
	x			

CE#159 Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1. Removes minimum efficiency values of before 1/1/2023.

Related Mods:

TABLE C403.3.2(3)
WATER-CHILLING PACKAGES—MINIMUM EFFICIENCY REQUIREMENTS ^{a,b,c,d}

EQUIPMENT TYPE	SIZE CATEGORY	UNITS	PÄTH A		PÄTH B		TEST PROCEDURE	
Air cooled chillers	<150-tons	EER (Btu/Wh)	≥10.100-FL	≥9.700-FL	≥15.800-IP	≥15.800-IP	AHRI 550/590	
			≥13.700-IP	≥13.700-IP				
	≥150-tons	EER (Btu/Wh)	≥10.100-FL	≥9.700-FL	≥15.800-IP	≥15.800-IP		
			≥14.000-IP	≥14.000-IP				
	Air-cooled-without-condenser, electrically-operated	All-capacities	EER (Btu/Wh)	Air-cooled chillers without condenser must be rated with matching condensers and comply with air-cooled chiller efficiency requirements				AHRI-550/590
	Water-cooled, electrically-operated positive-displacement	<75-tons	kW/ton	≤0.750-FL	≤0.750-FL	≤0.600-IP	≤0.600-IP	AHRI-550/590
		≥75-tons and <150-tons		≤0.600-IP	≤0.600-IP			
		≥150-tons and <300-tons		≤0.720-FL	≤0.750-FL			
		≥300-tons and <600-tons		≤0.560-IP	≤0.490-IP			
		≥600-tons		≤0.660-FL	≤0.680-FL			
≥600-tons		≤0.640-IP		≤0.440-IP				
≥600-tons		≤0.610-FL		≤0.625-FL				
≥600-tons		≤0.620-IP		≤0.410-IP				
Water-cooled, electrically-operated centrifugal	<150-tons	kW/ton	≤0.610-FL	≤0.605-FL	≤0.440-IP	≤0.440-IP	AHRI-550/590	
	≥150-tons and <300-tons		≤0.560-IP	≤0.440-IP				
	≥300-tons and <400-tons		≤0.610-FL	≤0.635-FL				
	≥400-tons		≤0.560-IP	≤0.400-IP				
	≥400-tons		≤0.560-FL	≤0.595-FL				
	≥400-tons		≤0.620-IP	≤0.390-IP				
	≥400-tons		≤0.660-FL	≤0.685-FL				
	≥400-tons		≤0.600-IP	≤0.380-IP				
Air-cooled-absorption, single-effect	<600-tons	COP (W/W)	≤0.560-FL	≤0.585-FL	NA ^d	NA ^d	AHRI-560	
	≥600-tons		≤0.600-IP	≤0.380-IP				
	All-capacities		≥0.600-FL	NA ^d				
	All-capacities		≥0.700-FL	NA ^d				
	All-capacities		≥1.000-FL	NA ^d				
	All-capacities		≥1.150-IP	NA ^d				
	All-capacities		≥1.000-FL	NA ^d				
	All-capacities		≥1.000-IP	NA ^d				
Water-cooled-absorption, single-effect	All-capacities	COP (W/W)	≥1.000-FL	NA ^d	NA ^d	AHRI-560		
	All-capacities	COP (W/W)	≥1.150-IP	NA ^d	NA ^d	AHRI-560		
	Absorption-double-effect-indirect-fired	All-capacities	COP (W/W)	≥1.000-FL	NA ^d	AHRI-560		
	Absorption-double-effect-direct-fired	All-capacities	COP (W/W)	≥1.000-IP	NA ^d	AHRI-560		

a—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.
b—The requirements for centrifugal chillers shall be adjusted for nonstandard rating conditions per Section C403.3.2.1 and are applicable only for the range of conditions listed there. The requirements for air-cooled, water-cooled positive displacement and absorption chillers are at standard rating conditions defined in the reference test procedure.
c—Both the full-load and IPLV/IP requirements must be met or exceeded to comply with this standard. When there is a Path B, compliance can be with either Path A or Path B for any application.
d—NA means the requirements are not applicable for Path B, and only Path A can be used for compliance.
e—FL is the full-load performance requirements, and IPLV/IP is for the part-load performance requirements.
f—This table is a replica of ASHRAE 90.1 Table 6.8.1-3 Water-Chilling Packages—Minimum Efficiency Requirements.
TABLE C403.3.2(3)
LIQUID-CHILLING PACKAGES—MINIMUM EFFICIENCY REQUIREMENTS^{a, b, c}

		E Q U I P M E N T		SIZE CATEGORY	UNITS	PATH A	PATH B	TEST PROCEDURE ^e
				< 150 tons	EER	≥ 10.100 FL ≥ 13.700 IPLV/IP	≥ 9.700 FL ≥ 15.800 IPLV/IP	
				≥ 150 tons	(Btu/Wh)	≥ 10.100 FL ≥ 14.000 IPLV/IP	≥ 9.700FL ≥ 16.100 IPLV/IP	AHRI 550/590
		Air cooled without condenser, electrically operated		All capacities	EER (Btu/Wh)	Air-cooled without condenser must be rated with matching condensers and comply with air-cooled chiller efficiency requirements		AHRI 550/590
		Liquid-cooled, electrically operated positive displacement		< 75 tons	kW/ton	≤ 0.750 FL ≤ 0.600 IPLV/IP	≤ 0.780 FL ≤ 0.500 IPLV/IP	AHRI 550/590
				≥ 75 tons and < 150 tons		≤ 0.720 FL ≤ 0.560 IPLV/IP	≤ 0.750 FL ≤ 0.490 IPLV/IP	
				≥ 150 tons and < 300 tons		≤ 0.660 FL ≤ 0.540 IPLV/IP	≤ 0.680 FL ≤ 0.440 IPLV/IP	
				≥ 300 tons and < 600 tons		≤ 0.610 FL ≤ 0.520 IPLV/IP	≤ 0.625 FL ≤ 0.410 IPLV/IP	
				≥ 600 tons		≤ 0.560 FL ≤ 0.500 IPLV/IP	≤ 0.585 FL ≤ 0.380 IPLV/IP	
				< 150 tons		kW/ton	≤ 0.610 FL ≤ 0.550 IPLV/IP	
		≥150 tons and <300 tons	≤ 0.610 FL ≤ 0.550 IPLV/IP	≤ 0.635 FL ≤ 0.400 IPLV/IP				
		≥ 300 tons and < 400 tons	≤ 0.560 FL ≤ 0.520 IPLV/IP	≤ 0.595 FL ≤ 0.390 IPLV/IP				
		≥ 400 tons and < 600 tons	≤ 0.560 FL ≤ 0.500 IPLV/IP	≤ 0.585 FL ≤ 0.380 IPLV/IP				
		≥ 600 tons	≤ 0.560 FL ≤ 0.500 IPLV/IP	≤ 0.585 FL ≤ 0.380 IPLV/IP				
Air cooled absorption, single effect	All capacities	COP (W/W)	≥ 0.600 FL	NA ^d	AHRI 560			
Liquid-cooled absorption, single effect	All capacities	COP (W/W)	≥ 0.700 FL	NA ^d	AHRI 560			
Absorption double effect, indirect fired	All capacities	COP (W/W)	≥ 1.000 FL	NA ^d	AHRI 560			
			≥ 0.150 IPLV/IP					
Absorption double effect, direct fired	All capacities	COP (W/W)	≥ 1.000 FL	NA ^d	AHRI 560			
			≥ 1.000 IPLV					

a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.
b. The requirements for centrifugal chillers shall be adjusted for nonstandard rating conditions per Section C403.3.2.1 and are applicable only for the range of conditions listed there. The requirements for air-cooled, water-cooled positive displacement and absorption chillers are at standard rating conditions defined in the reference test procedure.
c. Both the full-load and IPLV/IP requirements must be met or exceeded to comply with this standard. When there is a Path B, compliance can be with either Path A or Path B for any application.
d. NA means the requirements are not applicable for Path B, and only Path A can be used for compliance.
e. FL is the full-load performance requirements, and IPLV/IP is for the part-load performance requirements.

Staff Classification	Correlates Directly	Energy Standard Required	Other tags
	x		

	PTHP (cooling mode) nonstandard size ^b	$\geq 7,000$ Btu/h and $\leq 15,000$ Btu/h	95°F db/75°F wb outdoor air ^c	$10.8 - (0.213 \times \text{Cap}/1,000)$ EER ^d	AHRI 310/380
		$> 15,000$ Btu/h		7.6 EER	
	PTHP (heating mode) standard size	$< 7,000$ Btu/h		3.3 COP _H	AHRI 310/380
		$\geq 7,000$ Btu/h and $\leq 15,000$ Btu/h	47°F db/43°F wb outdoor air	$3.7 - (0.052 \times \text{Cap}/1,000)$ COP _H ^d	
		$> 15,000$ Btu/h		2.90 COP _H	
	PTHP (heating mode) nonstandard size ^b	$< 7,000$ Btu/h		2.7 COP _H	AHRI 310/380
		$\geq 7,000$ Btu/h and $\leq 15,000$ Btu/h	47°F db/43°F wb outdoor air	$2.9 - (0.026 \times \text{Cap}/1,000)$ COP _H ^d	
		$> 15,000$ Btu/h		2.5 COP _H	
	SP/VAC (cooling mode) single and three phase	$< 65,000$ Btu/h		11.0 EER	AHRI 390
		$\geq 65,000$ Btu/h and $\leq 135,000$ Btu/h	95°F db/75°F wb outdoor air ^c	10.0 EER	
	SPVHP (cooling mode)	$\geq 135,000$ Btu/h and $\leq 240,000$ Btu/h		10.0 EER	AHRI 390
		$< 65,000$ Btu/h	95°F db/75°F wb outdoor air ^c	11.0 EER	
		$\geq 65,000$ Btu/h and $\leq 135,000$ Btu/h		10.0 EER	
		$\geq 135,000$ Btu/h and $\leq 240,000$ Btu/h		10.0 EER	
	SPVHP (heating mode)	$< 65,000$ Btu/h	47°F db/43°F wb outdoor air	3.3 COP _H	AHRI 390
		$\geq 65,000$ Btu/h and $\leq 135,000$ Btu/h		3.0 COP _H	
		$\geq 135,000$ Btu/h and $\leq 240,000$ Btu/h		3.0 COP _H	
	Room air conditioners without reverse cycle with louvered sides for applications outside US ^d	$< 6,000$ Btu/h	—	11.0 CEER	ANSI/AHAM RAC-1
		$\geq 6,000$ Btu/h and $< 8,000$ Btu/h	—	11.0 CEER	
		$\geq 8,000$ Btu/h and $< 14,000$ Btu/h	—	10.9 CEER	
		$\geq 14,000$ Btu/h and $< 20,000$ Btu/h	—	10.7 CEER	
		$\geq 20,000$ Btu/h and $< 28,000$ Btu/h	—	9.4 CEER	
		$\geq 28,000$ Btu/h	—	9.0 CEER	
	Room air conditioners without louvered sides	$< 6,000$ Btu/h	—	10.0 CEER	ANSI/AHAM RAC-1
		$\geq 6,000$ Btu/h and $< 8,000$ Btu/h	—	10.0 CEER	
		$\geq 8,000$ Btu/h and $< 11,000$ Btu/h	—	9.6 CEER	
		$\geq 11,000$ Btu/h and $< 14,000$ Btu/h	—	9.5 CEER	
			—	9.3 CEER	
		$\geq 20,000$ Btu/h	—	9.4 CEER	
			—	9.4 CEER	
	Room air conditioners with reverse cycle, with louvered sides for applications outside US ^d	$< 20,000$ Btu/h	—	9.8 CEER	ANSI/AHAM RAC-1
		$\geq 20,000$ Btu/h	—	9.3 CEER	
	Room air conditioners with reverse cycle without louvered sides for applications outside US ^d	$< 14,000$ Btu/h	—	9.3 CEER	ANSI/AHAM RAC-1
		$\geq 14,000$ Btu/h	—	8.7 CEER	
	Room air conditioners, casement only for applications outside US ^d	All	—	9.5 CEER	ANSI/AHAM RAC-1
	Room air conditioners, casement slider for applications outside US ^d	All	—	10.4 CEER	ANSI/AHAM RAC-1

	<div>For SI: 1 British thermal unit per hour = 0.2931 W, °C = (°F – 32)/1.8, wb = wet bulb, db = dry bulb. “Cap” = The rated cooling capacity of the project in Btu/h. Where the unit’s capacity is less than 7,000 Btu/h, use 7,000 Btu/h in the calculation. Where the unit’s capacity is greater than 15,000 Btu/h, use 15,000 Btu/h in the calculations. a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. b. Nonstandard size units must be factory labeled as follows: “MANUFACTURED FOR NONSTANDARD SIZE APPLICATIONS ONLY; NOT TO BE INSTALLED IN NEW STANDARD PROJECTS.” Nonstandard size efficiencies apply only to units being installed in existing sleeves having an external wall opening of less than 16 inches high or less than 42 inches wide and having a cross-sectional area less than 670 square inches. c. The cooling-mode wet bulb temperature requirement only applies for units that reject condensate to the condenser coil. d. Room air conditioners are regulated as consumer products by 10 CFR 430. For US applications of room air conditioners, refer to Informative Appendix F, Table F-3, for the US DOE minimum efficiency requirements for US applications. e. “Cap” in EER and COP_l equations for PTACs and PTHPs means cooling capacity in Btu/h at 95°F outdoor dry-bulb temperature.</div>																																																						
	<table><tr><th>Efficiency Classification</th><th>Compliance Directly</th><th>Energy Standard Number</th><th>Test Procedure</th></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AE</th><th>ALUE</th><th>CE</th><th>DCE</th></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Efficiency Classification	Compliance Directly	Energy Standard Number	Test Procedure		x			Action	AE	ALUE	CE	DCE		x																																							
Efficiency Classification	Compliance Directly	Energy Standard Number	Test Procedure																																																				
	x																																																						
Action	AE	ALUE	CE	DCE																																																			
	x																																																						
CE#161	Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1. Removes minimum efficiency values of before 1/1/2023.																																																						
Related Models: CED1-156-22, CED2D-13-23, CED2D-16-23, CED2D-18-23, CED1-157-22, CED2D-17-23, CED2D-19-23, CED2D-12-22	<div>TABLE C403.3.2(5) WARM-AIR FURNACES AND COMBINATION WARM-AIR FURNACES/AIR-CONDITIONING UNITS, WARM-AIR DUCT FURNACES AND UNIT HEATERS—MINIMUM EFFICIENCY REQUIREMENTS^a</div> <table><tr><th>DESCRIPTION</th><th>FUEL</th><th>ELECTRIC POWER PHASE</th><th>APPLICATION LOCATION</th><th>HEATING CAPACITY (INPUT), Btu/h^b</th><th>COMBO-UNIT COOLING CAPACITY, Btu/h</th><th>HEATERS—MINIMUM EFFICIENCY REQUIREMENTS^a</th><th>TEST PROCEDURE^c</th></tr><tr><td>Warm-air furnace, gas-fired for application outside the US</td><td>Gas</td><td>1</td><td>Inside US</td><td>< 225,000</td><td>< 65,000</td><td>See Informative Appendix F, Table F-4^f</td><td></td></tr><tr><td rowspan="2">Warm-air furnace, oil-fired for application outside the US</td><td rowspan="2">Oil</td><td rowspan="2">1</td><td rowspan="2">Inside US</td><td rowspan="2">< 225,000</td><td rowspan="2">≥ 65,000</td><td>Nonweatherized</td><td>80% AFUE Appendix N^g</td></tr><tr><td>Weatherized</td><td>81% AFUE or 80% E_{comb} Appendix N^g ANSI Z21.47</td></tr><tr><td rowspan="2">Warm-air furnace, oil-fired</td><td rowspan="2">Oil</td><td rowspan="2">1</td><td rowspan="2">Outside US</td><td rowspan="2">< 225,000</td><td rowspan="2">All</td><td>Nonweatherized</td><td>80% AFUE Appendix N^g</td></tr><tr><td>Weatherized</td><td>81% AFUE or 80% E_{comb} Appendix N^g ANSI Z21.47</td></tr><tr><td rowspan="2">Warm-air furnace, gas</td><td rowspan="2">Gas</td><td rowspan="2">3</td><td rowspan="2">All</td><td rowspan="2">< 225,000</td><td rowspan="2">All</td><td>Nonweatherized</td><td>80% AFUE Appendix N^g</td></tr><tr><td>Weatherized</td><td>81% AFUE or 80% E_{comb} Appendix N^g ANSI Z21.47</td></tr><tr><td>Warm-air furnace</td><td>Gas</td><td rowspan="2">All</td><td rowspan="2">All</td><td rowspan="2">≥ 225,000 and ≤ 400,000</td><td rowspan="2">All</td><td>All</td><td>81% E_{comb} ANSI Z21.47</td></tr></table>	DESCRIPTION	FUEL	ELECTRIC POWER PHASE	APPLICATION LOCATION	HEATING CAPACITY (INPUT), Btu/h ^b	COMBO-UNIT COOLING CAPACITY, Btu/h	HEATERS—MINIMUM EFFICIENCY REQUIREMENTS ^a	TEST PROCEDURE ^c	Warm-air furnace, gas-fired for application outside the US	Gas	1	Inside US	< 225,000	< 65,000	See Informative Appendix F, Table F-4 ^f		Warm-air furnace, oil-fired for application outside the US	Oil	1	Inside US	< 225,000	≥ 65,000	Nonweatherized	80% AFUE Appendix N ^g	Weatherized	81% AFUE or 80% E _{comb} Appendix N ^g ANSI Z21.47	Warm-air furnace, oil-fired	Oil	1	Outside US	< 225,000	All	Nonweatherized	80% AFUE Appendix N ^g	Weatherized	81% AFUE or 80% E _{comb} Appendix N ^g ANSI Z21.47	Warm-air furnace, gas	Gas	3	All	< 225,000	All	Nonweatherized	80% AFUE Appendix N ^g	Weatherized	81% AFUE or 80% E _{comb} Appendix N ^g ANSI Z21.47	Warm-air furnace	Gas	All	All	≥ 225,000 and ≤ 400,000	All	All	81% E _{comb} ANSI Z21.47
DESCRIPTION	FUEL	ELECTRIC POWER PHASE	APPLICATION LOCATION	HEATING CAPACITY (INPUT), Btu/h ^b	COMBO-UNIT COOLING CAPACITY, Btu/h	HEATERS—MINIMUM EFFICIENCY REQUIREMENTS ^a	TEST PROCEDURE ^c																																																
Warm-air furnace, gas-fired for application outside the US	Gas	1	Inside US	< 225,000	< 65,000	See Informative Appendix F, Table F-4 ^f																																																	
Warm-air furnace, oil-fired for application outside the US	Oil	1	Inside US	< 225,000	≥ 65,000	Nonweatherized	80% AFUE Appendix N ^g																																																
						Weatherized	81% AFUE or 80% E _{comb} Appendix N ^g ANSI Z21.47																																																
Warm-air furnace, oil-fired	Oil	1	Outside US	< 225,000	All	Nonweatherized	80% AFUE Appendix N ^g																																																
						Weatherized	81% AFUE or 80% E _{comb} Appendix N ^g ANSI Z21.47																																																
Warm-air furnace, gas	Gas	3	All	< 225,000	All	Nonweatherized	80% AFUE Appendix N ^g																																																
						Weatherized	81% AFUE or 80% E _{comb} Appendix N ^g ANSI Z21.47																																																
Warm-air furnace	Gas	All	All	≥ 225,000 and ≤ 400,000	All	All	81% E _{comb} ANSI Z21.47																																																
	<div>For SI: 1 British thermal unit per hour = 0.2931 W. a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. b. Combination units (i.e., furnaces contained within the same cabinet as an air conditioner) not covered by DOE 10 CFR 430 (i.e., three-phase power or with cooling capacity greater than or equal to 65,000 Btu/h) may comply with either rating. All other units greater than 225,000 Btu/h sold in the US must meet the AFUE standard for consumer products and test using USDOE’s AFUE test procedure at DOE 10 CFR 430, Subpart B, Appendix N. c. Compliance of multiple firing rate units shall be at the maximum firing rate. d. E_{comb} = thermal efficiency. Units must also include an interrupted or intermittent ignition device (IIG) have jacket losses not exceeding 0.75 percent of the input rating, and have either power venting or a flue damper. A vent damper is an acceptable alternative to a flue damper for those furnaces where combustion air is drawn from the conditioned space. e. E_{comb} = combustion efficiency (100 percent less flue losses). See test procedure for detailed discussion. f. Units must also include an interrupted or intermittent ignition device (IIG) and have either power venting or an automatic flue damper. g. This table is a replica of ASHRAE 90.1 Table 6.8.1-5 Warm-Air Furnaces and Combination Warm-Air Furnaces/Air-Conditioning Units, Warm-Air Duct Furnaces, and Unit Heaters—Minimum Efficiency Requirements.</div>																																																						

Warm-air furnace	Gas	All	Inside US	> 400,000	All	All	81% E ₁ before 1/1/2023 81% E ₁ after 1/1/2023	ANSI Z21.47
Warm-air furnace	Gas	All	Outside US	> 400,000	All	All	80% E ₁ before 1/1/2023 81% E ₁ after 1/1/2023	ANSI Z21.47 or ANSI Z83.8
Warm-air furnace	Oil	1	Inside US	< 225,000	< 65,000	See Informative Appendix F, Table F-4 ^f		
Warm-air furnace	Oil	1	Inside US	< 225,000	≥ 65,000	Nonweatherized	83% AFUE	Appendix N ^g
						Weatherized	78% AFUE or 80% E ₁	Appendix N ^g
								Section 42 UL 727
Warm-air furnace	Oil	1	Outside US	< 225,000	All	Nonweatherized	83% AFUE	Appendix N ^g
						Weatherized	78% AFUE or 80% E ₁	Appendix N ^g
								Section 42 UL 727
Warm-air furnace	Oil	3	All	< 225,000	All	Nonweatherized	83% AFUE	Appendix N ^g
						Weatherized	78% AFUE or 80% E ₁	Appendix N ^g
								Section 42 UL 727
Warm-air unit heaters	Oil	All	All	≥ 225,000	All	All	82% E ₁	Section 42 UL 727
Warm-air unit heaters	Electric	1	Inside US	< 225,000	< 65,000	See Informative Appendix F, Table F-4 ^f		
Warm-air unit heaters	Electric	1	Inside US	< 225,000	≥ 65,000	All	96% AFUE	Appendix N ^g
Warm-air unit heaters	Electric	1	Outside US	< 225,000	All	All	96% AFUE	Appendix N ^g
Warm-air unit heaters	Electric	3	All	< 225,000	All	All	96% AFUE	Appendix N ^g
Warm-air duct furnaces	Gas	All	All	All	All	All	80% E ₁	ANSI Z83.8
Warm-air unit heaters	Gas	All	All	All	All	All	80% E ₁	ANSI Z83.8
Warm-air unit heaters	Oil	All	All	All	All	All	80% E ₁	Section 40 UL 731

For SI: 1 British thermal unit per hour = 0.2931 W.

a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. For this table, the following applies:

- Appendix N = 10 CFR 430 Appendix N
- ANSI Z21.47 = Section 2.39, Thermal Efficiency, ANSI Z21.47
- ANSI Z83.3 = Section 2.10, Efficiency, ANSI Z83.3
- UL 727 = Section 42, Combustion, UL 727
- UL 731 = Section 40, Combustion, UL 731

b. Compliance of multiple firing rate units shall be at the maximum firing rate.

c. E₁ = Thermal efficiency. Units must also include an interrupted or intermittent ignition device (IID), have jacket losses not exceeding 0.75 percent of the input rating, and have either power venting or a flue damper. A vent damper is an acceptable alternative to a flue damper for those furnaces where combustion air is drawn from the conditioned space.

d. E₂ = Combustion efficiency (100 percent less heat losses). See test procedure for detailed discussion.

e. Units must also include an interrupted or intermittent ignition device (IID) and have either power venting or an automatic flue damper.

f. Includes combination units with cooling capacity < 65,000 Btu/h. For US applications of federally covered < 225,000 Btu/h products, see Informative Appendix F, Table F-4.
g. 10CFR430 limited to single-phase equipment that is not contained within the same cabinet with a central air conditioner whose rated cooling capacity is above 65,000 Btu/h but for the test and rating procedures are not impacted for three-phase and can be used for AFUE ratings for ASHRAE/IES Standard 90.1 three-phase products and single-phase products with a cooling capacity greater than 65,000 Btu/h.

																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																	</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

Gas-fired—natural draft	$\geq 300,000$ Btu/h and $\leq 2,500,000$ Btu/h ^e	77% $E_{1,2}$ –	79% $E_{1,2}$
	$> 2,500,000$ Btu/h ^b	77% $E_{1,2}$ –	79% $E_{1,2}$

$< 300,000$ Btu/h ^h for applications outside US	82% AFUE	82% AFUE	DOE 10 CFR 431.86
$\geq 300,000$ Btu/h and $\leq 2,500,000$ Btu/h ^e	81% $E_{1,2}$	81% $E_{1,2}$ –	
$> 2,500,000$ Btu/h ^b	81% $E_{1,2}$	81% $E_{1,2}$ –	

DOE 10 CFR
430-Appendix N

For SI: 1 British thermal unit per hour = 0.2931 W.

a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.

b. These requirements apply to boilers with rated input of 8,000,000 Btu/h or less that are not packaged boilers and to all packaged boilers. Minimum efficiency requirements for boilers cover all capacities of packaged boilers.

c. $E_{1,2}$ = Combustion efficiency (100 percent less fuel losses).

d. E_t = Thermal efficiency.

e. Maximum capacity—minimum and maximum ratings as provided for and allowed by the unit's controls.

f. Includes oil-fired (residual).

g. Boilers shall not be equipped with a constant burning pilot light.

h. A boiler not equipped with a tankless domestic water-heating coil shall be equipped with an automatic means for adjusting the temperature of the water such that an incremental change in inferred heat load produces a corresponding incremental change in the temperature of the water supplied.

i. This table is a replica of ASHRAE 90.1 Table 6.8.1-6 Gas- and Oil-Fired Boilers—Minimum Efficiency Requirements.

TABLE
C403.3.
2(6)

GAS- AND OIL-FIRED BOILERS—MINIMUM EFFICIENCY REQUIREMENTS¹

EQUIPMENT TYPE ^a	SUBCATEGORY OR RATING CONDITION	SIZE CATEGORY (INPUT)	MINIMUM EFFICIENCY	TEST PROCEDURE ²
Boilers, hot water	Gas fired	$< 300,000$ Btu/h ^{b, h} for applications outside US	84% AFUE	DOE 10 CFR 430 Appendix N
		$\geq 300,000$ Btu/h and $\leq 2,500,000$ Btu/h ^e	84% $E_{1,2}$	DOE 10 CFR 431.86
		$> 2,500,000$ Btu/h ^b and $\leq 10,000,000$ Btu/h ^b	82% $E_{1,2}$	
		$> 10,000,000$ Btu/h ^b	82% E_t	
	Oil fired ^f	$< 300,000$ Btu/h ^{b, h} for applications outside US	86% AFUE	DOE 10 CFR 430 Appendix N
		$\geq 300,000$ Btu/h and $\leq 2,500,000$ Btu/h ^e	82% $E_{1,2}$	DOE 10 CFR 431.86
		$> 2,500,000$ Btu/h ^b and $\leq 10,000,000$ Btu/h ^b	84% $E_{1,2}$	
		$> 10,000,000$ Btu/h ^b	84% E_t	
	Gas fired	$< 300,000$ Btu/h ^g for applications outside US	82% AFUE	DOE 10 CFR 430 Appendix N

$\geq 300,000$ Btu/h and $\leq 2,500,000$ Btu/h^e 79% $E_{1,2}$

Gas-fired—all, except natural draft $> 2,500,000$ Btu/h and $\leq 10,000,000$ Btu/h^b 79% $E_{1,2}$ DOE 10 CFR 431.86

$> 10,000,000$ Btu/h^b 79% E_t

Boilers, Gas-fired—natural draft $\geq 300,000$ Btu/h and $\leq 2,500,000$ Btu/h^e 79% $E_{1,2}$

steam $> 2,500,000$ Btu/h^b 79% E_t

$< 300,000$ Btu/h^g for applications outside US 82% AFUE DOE 10 CFR 430 Appendix N

$\geq 300,000$ Btu/h and $\leq 2,500,000$ Btu/h^e 84% $E_{1,2}$

Oil-fired^f $> 2,500,000$ Btu/h^b and $\leq 10,000,000$ Btu/h^b 81% $E_{1,2}$ DOE 10 CFR 431.86

$> 10,000,000$ Btu/h^b 81% E_t

For SI: 1 British thermal unit per hour = 0.2931 W.

a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.

b. These requirements apply to boilers with rated input of 8,000,000 Btu/h or less that are not packaged boilers and to all packaged boilers. Minimum efficiency requirements for boilers cover all capacities of packaged boilers.

c. $E_{1,2}$ = Combustion efficiency (100 percent less fuel losses).

d. E_t = Thermal efficiency.

e. Maximum capacity—minimum and maximum ratings as provided for and allowed by the unit's controls.

f. Includes oil-fired (residual).

g. Boilers shall not be equipped with a constant burning pilot light.

h. A boiler not equipped with a tankless domestic water-heating coil shall be equipped with an automatic means for adjusting the temperature of the water such that an incremental change in inferred heat load produces a corresponding incremental change in the temperature of the water supplied.

Boiler Classification	Correlates Directly	Energy Standard Required	Test Procedure
Gas	x		
Oil			
Electric			
Geothermal			
Solar			
Waste Heat			
Other			

CE#163 Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.

[illegible]

c. For purposes of this table, closed-circuit cooling tower performance is defined as the process water-flow rating of the tower at the thermal rating condition listed in the table divided by the sum of the fan motor nameplate power and the integral spray pump motor nameplate power.

d. For purposes of this table, dry-cooler performance is defined as the process water-flow rating of the unit at the thermal rating condition listed in the table divided by the total fan motor nameplate power of the unit, and air-cooled condenser performance is defined as the heat rejected from the refrigerant divided by the total fan motor nameplate power of the unit.

e. The efficiencies and test procedures for both open- and closed-circuit cooling towers are not applicable to hybrid cooling towers that contain a combination of separate wet and dry heat exchange sections. The certification requirements do not apply to field-erected cooling towers.

f. All cooling towers shall comply with the minimum efficiency listed in the table for that specific type of tower with the capacity effect of any project-specific accessories and/or options included in the capacity of the cooling tower.

g. For purposes of this table, evaporative condenser performance is defined as the heat rejected at the specified rating condition in the table, divided by the sum of the fan motor nameplate power and the integral spray pump nameplate power.

h. Requirements for evaporative condensers are listed with ammonia (R-717) and R-448A as test fluids in the table. Evaporative condensers intended for use with halocarbon refrigerants other than R-448A must meet the minimum efficiency requirements listed with R-448A as the test fluid. For ammonia, the condensing temperature is defined as the saturation temperature corresponding to the refrigerant pressure at the condenser entrance. For R-448A, which is a zeotropic refrigerant, the condensing temperature is defined as the arithmetic average of the dew point and the bubble point temperatures corresponding to the refrigerant pressure at the condenser entrance.

i. This table is a replica of ASHRAE 90.1 Table 6.8.1.

7. Performance Requirements for Heat Rejection Equipment—Minimum Efficiency Requirements.

TABLE C403.3.2(7)
PERFORMANCE REQUIREMENTS FOR HEAT REJECTION EQUIPMENT—MINIMUM EFFICIENCY REQUIREMENTS

EQUIPMENT TYPE	TOTAL SYSTEM HEAT-REJECTION CAPACITY AT RATED CONDITIONS	SUBCATEGORY OR RATING CONDITION ^b	PERFORMANCE ^c REQUIRED ^{a, b, c, f, g}	TEST PROCEDURE ^d
Propeller or axial fan open-circuit cooling towers	All	95°F entering water 85°F leaving water 75°F entering wb	≥ 40.2 gpm/hp	CTI ATC-105 and CTI STD-201 RS
Centrifugal fan open-circuit cooling towers	All	95°F entering water 85°F leaving water 75°F entering wb	≥ 20.0 gpm/hp	CTI ATC-105 and CTI STD-201 RS
Propeller or axial fan closed-circuit cooling towers	All	102°F entering water 90°F leaving water 75°F entering wb	≥ 16.1 gpm/hp	CTI ATC-105S and CTI STD-201 RS
Centrifugal fan closed-circuit cooling towers	All	102°F entering water 90°F leaving water 75°F entering wb	≥ 7.0 gpm/hp	CTI ATC-105S and CTI STD-201 RS
Propeller or axial fan dry coolers (air-cooled fluid coolers)	All	115°F entering water 105°F leaving water 95°F entering wb	≥ 4.5 gpm/hp	CTI ATC-105DS
Propeller or axial fan evaporative condensers	All	R-448A test fluid 165°F entering gas temperature 105°F condensing temperature 75°F entering wb Ammonia test fluid 140°F entering gas temperature 96.3°F condensing temperature 75°F entering wb	≥ 160,000 Btu/h x hp	CTI ATC-106
Propeller or axial fan evaporative condensers	All	R-448A test fluid 165°F entering gas temperature 105°F condensing temperature 75°F entering wb Ammonia test fluid 140°F entering gas temperature 96.3°F condensing temperature 75°F entering wb	≥ 134,000 Btu/h x hp	CTI ATC-106
Centrifugal fan evaporative condensers	All	R-448A test fluid 165°F entering gas temperature 105°F condensing temperature 75°F entering wb	≥ 137,000 Btu/h x hp	CTI ATC-106
Centrifugal fan evaporative condensers	All	Ammonia test fluid 140°F entering gas temperature 96.3°F condensing temperature 75°F entering wb	≥ 110,000 Btu/h x hp	CTI ATC-106
Air-cooled condensers	All	125°F condensing temperature 190°F entering gas temperature 15°F subcooling 95°F entering db	≥ 176,000 Btu/h x hp	AHRI 460

For SI: °C = (°F – 32)/1.8, L/s × kW = (gpm/hp)/(11.83), COP = (Btu/h × hp)/(2550.7), db = dry bulb temperature, wb = wet bulb temperature.

a. For purposes of this table, open-circuit cooling tower performance is defined as the water-flow rating of the tower at the thermal rating condition listed in the table divided by the fan motor nameplate power.

b. For purposes of this table, closed-circuit cooling tower performance is defined as the process water-flow rating of the tower at the thermal rating condition listed in the table divided by the sum of the fan motor nameplate power and the integral spray pump motor nameplate power.

c. For purposes of this table, dry-cooler performance is defined as the process water-flow rating of the unit at the thermal rating condition listed in the table divided by the total fan motor nameplate power of the unit, and air-cooled condenser performance is defined as the heat rejected from the refrigerant divided by the total fan motor nameplate power of the unit.

d. ASHRAE 90.1 Section 13 contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure, towers.

- e. The efficiencies and test procedures for both open- and closed-circuit cooling towers are not applicable to hybrid cooling towers that contain a combination of separate wet and dry heat exchange sections. The certification requirements do not apply to field-erected cooling.
- f. All cooling towers shall comply with the minimum efficiency listed in the table for that specific type of tower with the capacity effect of any project-specific accessories and/or options included in the capacity of the cooling tower.
- g. For purposes of this table, evaporative condenser performance is defined as the heat rejected at the specified rating condition in the table, divided by the sum of the fan motor nameplate power and the integral spray pump nameplate power.
- h. Requirements for evaporative condensers are listed with ammonia R-717 and R-448A as test fluids in the table. Evaporative condensers intended for use with halocarbon refrigerants other than R-448A must meet the minimum efficiency requirements listed with R-448A as the test fluid. For ammonia, the condensing temperature is defined as the saturation temperature

corresponding to the refrigerant pressure at the condenser entrance. For R-448A, which is a zeotropic refrigerant, the condensing temperature is defined as the arithmetic average of the dew point and the bubble point temperatures corresponding to the refrigerant pressure at the condenser entrance.

Staff Classification	Complies Directly	Energy Standard Exceeded	Over top
	x		
Action	AS	AS/EC	EC
	x		

CE#164 Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.

Related Mod: CED1- 156-22, CED20-13- 23, CED20-16- 23, CED20-18- 23, CED1- 157-22, CED20-17- 23, CED20-19- 23, CED1- 12-22	TABLE C403.3.2(8) ELECTRICALLY OPERATED VARIABLE-REFRIGERANT-FLOW AIR CONDITIONERS—MINIMUM EFFICIENCY REQUIREMENTS ^a					TEST PROCEDURE ^a	
	EQUIPMENT TYPE	SIZE CATEGORY	HEATING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY		
	VRF air conditioners, air-cooled	< 65,000 Btu/h	All	VRF multisplit system	13.0 SEER		
		≥ 65,000 Btu/h and < 135,000 Btu/h	Electric resistance (or none)	VRF multisplit system	11.2 EER 13.4 IEER 15.6 IEER		
		≥ 135,000 Btu/h and < 240,000 Btu/h	Electric resistance (or none)	VRF multisplit system	11.0 EER 12.9 IEER 14.9 IEER		
		≥ 240,000 Btu/h	Electric resistance (or none)	VRF multisplit system	10.0 EER 11.6 IEER 13.9 IEER		
For SI: 1 British thermal unit per hour = 0.2931 W. ^a —Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. ^b —This table is a replica of ASHRAE 90.1 Table 6.8.1.8 Electrically Operated Variable- Refrigerant-Flow Air Conditioners—Minimum Efficiency Requirements.							
TABLE C403.3.2(8) ELECTRICALLY OPERATED VARIABLE-REFRIGERANT-FLOW AIR CONDITIONERS—MINIMUM EFFICIENCY REQUIREMENTS							

EQUIPMENT TYPE	SIZE CATEGORY	HEATING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a
VRF air conditioners, air-cooled	< 65,000 Btu/h three-phase for applications in the US and single- and three-phase for applications outside the US	All	VRF multisplit system	13.0 SEER	AHRI 210/240
	≥ 65,000 Btu/h and < 135,000 Btu/h	Electric resistance (or none)	VRF multisplit system	10.5 EER 15.5 IEER	AHRI 1230
	≥ 135,000 Btu/h and < 240,000 Btu/h	Electric resistance (or none)	VRF multisplit system	10.3 EER 14.9 IEER	
	≥ 240,000 Btu/h	Electric resistance (or none)	VRF multisplit system	9.5 EER 13.9 IEER	

For SI: 1 British thermal unit per hour = 0.2931 W.
^a Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.

Staff Classification	Complies Directly	Energy Standard Exceeded	Over top
	x		
Action	AS	AS/EC	EC
	x		

CE#165 Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.

Related Mod: CED1- 156-22, CED20-13- 23, CED20-16- 23,	TABLE C403.3.2(9) ELECTRICALLY OPERATED VARIABLE-REFRIGERANT-FLOW AND APPLIED HEAT PUMPS—MINIMUM EFFICIENCY REQUIREMENTS					TEST PROCEDURE ^a
	EQUIPMENT TYPE	SIZE CATEGORY	HEATING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	

CE2D-18- 23, CED1- 157-22, CE2D-17- 23, CE2D-19- 23, CED1- 12-22	VRFair-cooled (cooling-mode)	<65,000 Btu/h	All		VRFmultisplit-system	13.0 SEER	AHRI-1230		
		≥65,000 Btu/h and <135,000 Btu/h	Electric resistance (or none)	VRFmultisplit-system with heat-recovery	10.8 EER 12.7 IEER 14.4 IEER				
				VRFmultisplit-system	10.6 EER 12.3 IEER 13.9 IEER				
		VRFmultisplit-system with heat-recovery		10.4 EER 12.4 IEER 13.7 IEER					
				VRFmultisplit-system	9.6 EER 11.0 IEER 12.7 IEER				
		≥240,000 Btu/h		VRFmultisplit-system with heat-recovery	9.3 EER 10.8 IEER 12.6 IEER				
		VRFwater-source (cooling-mode)		<65,000 Btu/h	All	VRFmultisplit-systems 86°F entering-water		12.0 EER 16.0 IEER	AHRI-1230
				≥65,000 Btu/h and <135,000 Btu/h		VRFmultisplit-systems with heat-recovery 86°F entering-water		11.8 EER 15.8 IEER	
						VRFmultisplit-system 86°F entering-water		12.0 EER 16.0 IEER	
	VRFmultisplit-system with heat-recovery 86°F entering-water			11.8 EER 15.8 IEER					
			≥135,000 Btu/h and <240,000 Btu/h	VRFmultisplit-system 86°F entering-water		10.0 EER 14.0 IEER			
	VRFmultisplit-system with heat-recovery 86°F entering-water		9.8 EER 13.8 IEER						
			≥240,000 Btu/h	VRFmultisplit-system 86°F entering-water		10.0 EER 12.0 IEER			
	VRFmultisplit-system with heat-recovery 86°F entering-water			9.8 EER 11.8 IEER					
	VRFgroundwater-source (cooling-mode)		<135,000 Btu/h	All		VRFmultisplit-system 59°F entering-water	16.2 EER	AHRI-1230	
			VRFmultisplit-system with heat-recovery 59°F entering-water			16.0 EER			
		≥135,000 Btu/h			VRFmultisplit-system 59°F entering-water	13.8 EER			
		VRFmultisplit-system with heat-recovery 59°F entering-water	13.6 EER						
	VRFground-source (cooling-mode)	<135,000 Btu/h	All	VRFmultisplit-system 77°F entering-water	13.4 EER	AHRI-1230			
VRFmultisplit-system with heat-recovery 77°F entering-water		13.2 EER							
		≥135,000 Btu/h		VRFmultisplit-system 77°F entering-water	11.0 EER				
VRFmultisplit-system with heat-recovery 77°F entering-water	10.8 EER	AHRI-1230							
VRFair-cooled (heating-mode)	<65,000 Btu/h (cooling capacity)		VRFmultisplit-system	7.7 HSPF	AHRI-1230				

≥65,000 VRFmultispl
 it-system
 Btu/h-and 47°F db/43°F 3.3 COP_H
 Btu/h wb-outdoor-air
 (cooling capacity)
 47°F db/43°F 3.25 COP_H
 ≥135,000 wb-outdoor-air-Btu/h
 (cooling capacity) VRF
 multisplit
 system 3.2 COP_H
 47°F db/43°F
 wb-outdoor-air
 Btu/h 17°F db/13°F 2.05 COP_H
 wb-outdoor-air
 (cooling VRFmultispl
 68°F entering 4.3 COP_H it-system 4.3 COP_H
 water
 AHRI-1230
 capacity)

VRFwater-source (heating mode)			VRFmultispl t-system 68°F-entering -water	4.3 COP _H 4.3 COP _H	
	≥65,000		VRFmultispl t-system 68°F-entering -water	3.3 COP _H 4.0 COP _H	
	Btu/h-and		VRFmultispl t-system-68°F F-entering water	3.3 COP _H	
	<135,000		VRFmultispl t-system-60°F F-entering water	3.3 COP _H	
	Btu/h		VRFmultispl t-system-60°F F-entering water	3.3 COP _H	AHRI-1230
	(cooling capacity)		VRFmultispl t-system-32°F F-entering-w ater	3.4 COP _H	AHRI-1230
VRFgroundwater-source (heating mode)	≥135,000 Btu/h-and <240,000 Btu/h (cooling capacity)				
	≥240,000 Btu/h (cooling capacity)				
VRFgroundwater-source (heating mode)	<135,000 Btu/h (cooling capacity)				
	≥135,000 Btu/h (cooling capacity)				
VRF-ground-source (heating mode)	<135,000 Btu/h (cooling capacity)				
	≥135,000 Btu/h (cooling capacity)		VRFmultispl system	2.9 COP _H	

For SI: °C = ((°F) - 32)/1.8; 1 British thermal unit per hour = 0.2931 W; db = dry-bulb temperature; wb = wet-bulb temperature.
 a.—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.
 b.—This table is a replica of ASHRAE 90.1 Table 6.8.1-9 Electrically-Operated Variable-Refrigerant-Flow and Applied Heat Pumps—Minimum Efficiency Requirements.

TABLE
 C403.3. ELECTRICALLY OPERATED VARIABLE-REFRIGERANT-FLOW AND APPLIED HEAT PUMPS—MINIMUM EFFICIENCY REQUIREMENTS
 2(9)

EQUIPMENT TYPE	SIZE CATEGORY	HEATING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a
VRF air cooled	< 65,000 Btu/h three-phase for applications in the US and single- and three-phase for applications outside the US	All	VRF multisplit system	SEER2 = 13.4	AHRI 210/240
	≥ 65,000 Btu/h and < 135,000 Btu/h		VRF multisplit system with heat recovery	10.3 EER 14.6 IEER	
				10.1 EER 14.4 IEER	

(cooling mode)	≥ 135,000 Btu/h and < 240,000 Btu/h	Electric resistance (or none)	VRF multisplit system	9.9 EER 14.4 IEER	AHRI 1230
	≥ 240,000 Btu/h		VRF multisplit system with heat recovery	9.7 EER 13.9 IEER	
			VRF multisplit system	9.1 EER 12.7 IEER	
			VRF multisplit system with heat recovery	8.9 EER 12.5 IEER	
VRF water source (cooling mode)	< 65,000 Btu/h	All	VRF multisplit systems 86°F entering water	12.0 EER 16.0 IEER	AHRI 1230
			VRF multisplit systems with heat recovery 86°F entering water	11.8 EER 15.8 IEER	
	≥ 65,000 Btu/h and < 135,000 Btu/h		VRF multisplit system 86°F entering water	12.0 EER 16.0 IEER	
			VRF multisplit system with heat recovery 86°F entering water	11.8 EER 15.8 IEER	
	≥ 135,000 Btu/h and < 240,000 Btu/h		VRF multisplit system 86°F entering water	10.0 EER 14.0 IEER	
			VRF multisplit system with heat recovery 86°F entering water	9.8 EER 13.8 IEER	
	≥ 240,000 Btu/h		VRF multisplit system 86°F entering water	10.0 EER 12.0 IEER	
			VRF multisplit system with heat recovery 86°F entering water	9.8 EER 11.8 IEER	
VRF groundwater source (cooling mode)	< 135,000 Btu/h	All	VRF multisplit system 59°F entering water	16.2 EER	AHRI 1230
			VRF multisplit system with heat recovery 59°F entering water	16.0 EER	
	≥ 135,000 Btu/h		VRF multisplit system 59°F entering water	13.8 EER	
			VRF multisplit system with heat recovery 59°F entering water	13.6 EER	
VRF ground source (cooling mode)	< 135,000 Btu/h	All	VRF multisplit system 77°F entering water	13.4 EER	AHRI 1230
			VRF multisplit system with heat recovery 77°F entering water	13.2 EER	

			VRF multisplit system 77°F entering water	11.0 EER	
VRF air cooled (heating mode)	≥ 135,000 Btu/h				
	< 65,000 Btu/h (cooling capacity) three-phase for applications in the US and single- and three- phase for applications outside the US		VRF multisplit system with heat recovery 77°F entering water	10.8 EER	
	≥ 65,000 Btu/h and < 135,000 Btu/h (cooling capacity)		VRF multisplit system	HSPF2 = 7.5	AHRI 210/240
	≥ 135,000 Btu/h (cooling capacity)		VRF multisplit system 47°F db/43°F wb outdoor air	1.0 COP _H	
	< 65,000 Btu/h		17°F db/15°F wb outdoor air	1.20 COP _H	AHRI 1230

		(cooling capacity)		VRF multisplit system 47°F db/43°F wb outdoor air	3.2 COP _H																	
		≥ 65,000 Btu/h and <		17°F db/15°F wb outdoor air	3.05 COP _H																	
		135,000 Btu/h (cooling capacity)		VRF multisplit system 68°F entering water	4.3 COP _H	AHRI 1230																
		≥ 135,000 Btu/h and < 240,000 Btu/h		VRF multisplit system 68°F entering water	4.3 COP _H																	
		(cooling capacity)		VRF multisplit system 68°F entering water	4.0 COP _H																	
		≥ 240,000 Btu/h (cooling capacity)		VRF multisplit system 68°F entering water	3.9 COP _H																	
		< 135,000 Btu/h (cooling capacity)		VRF multisplit system 50°F entering	3.6 COP _H	AHRI 1230																
		≥ 135,000 Btu/h (cooling capacity)		water VRF multisplit system 50°F entering	3.3 COP _H																	
VRF ground source (heating mode)	< 135,000 Btu/h (cooling capacity)	water VRF multisplit system 32°F entering	3.1 COP _H			AHRI 1230																
	≥ 135,000 Btu/h (cooling capacity)	water VRF multisplit system 32°F entering	2.8 COP _H																			
		water																				
For SI: °C = (°F – 32)/1.8, 1 British thermal unit per hour = 0.2931 W, db = dry bulb temperature, wb = wet bulb temperature. a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.																						
				<table><tr><th>Diff Classification</th><th>Correlates Directly</th><th>Energy Standard Required</th><th>See also</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>US</th><th>ANSI</th><th>ANSI</th></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>			Diff Classification	Correlates Directly	Energy Standard Required	See also		x			Action	US	ANSI	ANSI		x		
Diff Classification	Correlates Directly	Energy Standard Required	See also																			
	x																					
Action	US	ANSI	ANSI																			
	x																					
CE#166	Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.																					
Related Mods:	TABLE C403.3.2(10) FLOOR-MOUNTED AIR CONDITIONERS AND CONDENSING UNITS SERVING COMPUTER ROOMS—MINIMUM EFFICIENCY REQUIREMENTS. ^a																					
CED1- 156-22, CE2D-13- 23, CE2D-16- 23, CE2D-18- 23, CED1- 157-22, , CE2D-17- 23,	TABLE C403.3.2(10) FLOOR-MOUNTED AIR CONDITIONERS AND CONDENSING UNITS SERVING COMPUTER ROOMS—MINIMUM EFFICIENCY REQUIREMENTS. ^a and ≥ 65,000 Btu/h and < 240,000 Btu/h and ≥ 240,000 Btu/h For SI: 1 British thermal unit per hour = 0.2931 W, °C = [(°F) – 32]/1.8, COP = (Btu/h × hp)/(2,550.7).																					

CE2D-19- 23, CECD1- 12-22	a—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. b—This table is a replica of ASHRAE 90.1 Table 6.8.1-10 Floor-Mounted Air Conditioners and Condensing Units Serving Computer Rooms—Minimum Efficiency Requirements. TABLE C403.3.2(10) FLOOR-MOUNTED AIR CONDITIONERS AND CONDENSING UNITS SERVING COMPUTER ROOMS—MINIMUM EFFICIENCY REQUIREMENTS							
		STANDARD MODEL	NET SENSIBLE COOLING CAPACITY	MINIMUM NET SENSIBLE COP	RATING CONDITIONS RETURN AIR (dry bulb/dew point)	TEST PROCEDURE		
	Air cooled	Downflow	< 80,000 Btu/h ≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.70 2.58 2.36	85°F/52°F (Class 2)	AHRI 1360		
	Upflow—ducted	< 80,000 Btu/h ≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.67 2.55 2.33					
	Upflow—nonducted	< 65,000 Btu/h ≥ 65,000 Btu/h and < 240,000 Btu/h ≥ 240,000 Btu/h	2.16 2.04 1.89					
	Horizontal	< 65,000 Btu/h ≥ 65,000 Btu/h and < 240,000 Btu/h	2.65 2.55	95°F/52°F (Class 3)				
	Air cooled with fluid economizer	Downflow	≥ 240,000 Btu/h < 80,000 Btu/h ≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.47 2.70 2.58 2.36	85°F/52°F (Class 1)		AHRI 1360	
	Upflow—ducted	< 80,000 Btu/h ≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.67 2.55 2.33					
	Upflow—nonducted	< 65,000 Btu/h ≥ 65,000 Btu/h and < 240,000 Btu/h ≥ 240,000 Btu/h	2.09 1.99 1.81					
	Horizontal	< 65,000 Btu/h ≥ 65,000 Btu/h and < 240,000 Btu/h ≥ 240,000 Btu/h	2.65 2.55 2.47	95°F/52°F (Class 3)				
	Downflow	< 80,000 Btu/h ≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.82 2.73 2.67	85°F/52°F (Class 1)				
		< 80,000 Btu/h	2.79					
	Upflow—ducted	≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.70 2.64	75°F/52°F (Class 1)	AHRI 1360			
	Upflow—nonducted	< 65,000 Btu/h ≥ 65,000 Btu/h and < 240,000 Btu/h ≥ 240,000 Btu/h	2.43 2.32 2.20					
	Horizontal	< 65,000 Btu/h ≥ 65,000 Btu/h and < 240,000 Btu/h ≥ 240,000 Btu/h	2.79 2.68 2.60					
	Water cooled with fluid economizer	Downflow	< 80,000 Btu/h ≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.77 2.68 2.61		85°F/52°F (Class 1)		AHRI 1360
	Upflow—ducted	< 80,000 Btu/h ≥ 80,000 Btu/h and < 295,000 Btu/h ≥ 295,000 Btu/h	2.74 2.65 2.58					

				< 65,000 Btu/h	2.35	75°F/52°F (Class 1)																			
		Upflow—nonducted		≥ 65,000 Btu/h and < 240,000 Btu/h	2.24																				
				≥ 240,000 Btu/h	2.12																				
		Horizontal		< 65,000 Btu/h	2.71	95°F/52°F (Class 3)																			
			≥ 65,000 Btu/h and < 240,000 Btu/h	2.60																					
			≥ 240,000 Btu/h	2.54																					
	Glycol cooled	Downflow		< 80,000 Btu/h	2.56	85°F/52°F (Class 1)	AHRI 1360																		
				≥ 80,000 Btu/h and < 295,000 Btu/h	2.24																				
				≥ 295,000 Btu/h	2.21																				
		Upflow—ducted		< 80,000 Btu/h	2.53																				
				≥ 80,000 Btu/h and < 295,000 Btu/h	2.21																				
				≥ 295,000 Btu/h	2.18																				
		Upflow, nonducted		< 65,000 Btu/h	2.08	75°F/52°F (Class 1)																			
				≥ 65,000 Btu/h and < 240,000 Btu/h	1.90																				
				≥ 240,000 Btu/h	1.81																				
		Horizontal		< 65,000 Btu/h	2.48	95°F/52°F (Class 3)																			
				≥ 65,000 Btu/h and < 240,000 Btu/h	2.18																				
				≥ 240,000 Btu/h	2.18																				
					< 80,000 Btu/h	2.51																			
Downflow		≥ 80,000 Btu/h and < 295,000 Btu/h	2.19	85°F/52°F (Class 1)																					
	≥ 295,000 Btu/h						2.15																		
	Upflow—ducted	< 80,000 Btu/h	2.48																						
		≥ 80,000 Btu/h and < 295,000 Btu/h	2.16																						
		≥ 295,000 Btu/h	2.12																						
	Upflow—nonducted	< 65,000 Btu/h	2.00				75°F/52°F (Class 1)																		
		≥ 65,000 Btu/h and < 240,000 Btu/h	1.82																						
		≥ 240,000 Btu/h	1.73																						
	Horizontal	< 65,000 Btu/h	2.44				95°F/52°F (Class 3)																		
		≥ 65,000 Btu/h and < 240,000 Btu/h	2.10																						
≥ 240,000 Btu/h		2.10																							
<div>Glycol cooled with fluid economizer</div> <div>AHRI 1360</div>																									
<div>For SI: 1 British thermal unit per hour = 0.2931 W, °C = (°F – 32)/1.8, COP = (Btu/h × hp)/(2,550.7).</div> <div><table><tr><td>Staff Classification</td><td>Corrosion: Directly</td><td>Energy Standard Needed</td><td>Over Top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Condition</td><td>AS</td><td>AS/NZS</td><td>D</td><td>CISC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table></div>								Staff Classification	Corrosion: Directly	Energy Standard Needed	Over Top		x			Condition	AS	AS/NZS	D	CISC		x			
Staff Classification	Corrosion: Directly	Energy Standard Needed	Over Top																						
	x																								
Condition	AS	AS/NZS	D	CISC																					
	x																								
CE#167	Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.																								
Related Mods: CED1- 156-22, CE2D-13-	<div>TABLE C403-3-2(1)</div> <div>VAPOR-COMPRESSION-BASED INDOOR POOL DEHUMIDIFIERS—MINIMUM EFFICIENCY REQUIREMENTS</div> <table><tr><td>SUBCATEGORY OR</td><td>MINIMUM</td><td>TEST EQUIPMENT TYPE</td><td>RATING CONDITION</td><td>EFFICIENCY</td><td>PROCEEDURE</td></tr><tr><td colspan="6"></td></tr></table>							SUBCATEGORY OR	MINIMUM	TEST EQUIPMENT TYPE	RATING CONDITION	EFFICIENCY	PROCEEDURE												
SUBCATEGORY OR	MINIMUM	TEST EQUIPMENT TYPE	RATING CONDITION	EFFICIENCY	PROCEEDURE																				

23, CE2D-16- 23, CE2D-18- 23, CED1- 157-22, , CE2D-17- 23, CE2D-19- 23, CECD1- 12-22	Single-package indoor (with or without economizer)		Rating Conditions: A or C	3.5 MRE	AHRI 910																		
	Single-package indoor water-cooled (with or without economizer)		Rating Conditions: A, B or C	3.5 MRE																			
	Single-package indoor air-cooled (with or without economizer)		Rating Conditions: A, B or C	3.5 MRE																			
	Split-system indoor air-cooled (with or without economizer)		Rating Conditions: A, B or C	3.5 MRE																			
	a—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. b—This table is a replica of ASHRAE 90.1 Table 6.8.1-12 Vapor-Compression-Based Indoor Pool Dehumidifiers—Minimum Efficiency Requirements.																						
TABLE C403.3.2(11) VAPOR-COMPRESSION-BASED INDOOR POOL DEHUMIDIFIERS—MINIMUM EFFICIENCY REQUIREMENTS																							
		EQUIPMENT TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE																		
		Single package indoor (with or without economizer)	Rating conditions: A or C	3.5 MRE	AHRI 910																		
		Single package indoor water-cooled (with or without economizer)	Rating conditions: A, B or C	3.5 MRE																			
		Single package indoor air-cooled (with or without economizer)	Rating conditions: A, B or C	3.5 MRE																			
		Split system indoor air-cooled (with or without economizer)	Rating conditions: A, B or C	3.5 MRE																			
<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS-OP</td><td>D</td><td>DOE</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>						Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		x			Action	AS	AS-OP	D	DOE		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																				
	x																						
Action	AS	AS-OP	D	DOE																			
	x																						
CE#168	Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.																						
Related Mods:	TABLE C403.3.2(12) ELECTRICALLY-OPERATED DX-DOAS UNITS, SINGLE-PACKAGE AND REMOTE CONDENSER, WITHOUT ENERGY RECOVERY—MINIMUM EFFICIENCY REQUIREMENTS																						
CED1- 156-22, CE2D-13- 23, CE2D-16- 23, CE2D-18- 23, CED1- 157-22, , CE2D-17- 23, CE2D-19- 23, CECD1- 12-22	EQUIPMENT TYPE		SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE																		
	Air-cooled (dehumidification mode)		—	4.0 ISMRE	AHRI 920																		
	Air-source heat pumps (dehumidification mode)		—	4.0 ISMRE	AHRI 920																		
	Water-cooled (dehumidification mode)		Cooling tower condenser water	4.0 ISMRE	AHRI 920																		
			Chilled water	6.0 ISMRE																			
	Air-source heat pump (heating mode)		—	2.7 ISGOP	AHRI 920																		
	Water-source heat pump (dehumidification mode)		Ground source, closed-loop	4.8 ISMRE	AHRI 920																		
			Ground-water source	5.0 ISMRE																			
			Water source	4.0 ISMRE																			
	Water-source heat pump (heating mode)		Ground source, closed-loop	2.0 ISGOP	AHRI 920																		
			Ground-water source	3.2 ISGOP																			
			Water source	3.5 ISGOP																			
a—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. b—This table is a replica of ASHRAE 90.1 Table 6.8.1-13 Electrically-Operated DX-DOAS Units, Single-Package and Remote Condenser, without Energy Recovery—Minimum Efficiency Requirements.																							
TABLE C403.3.2(12) ELECTRICALLY OPERATED DX-DOAS UNITS, SINGLE-PACKAGE AND REMOTE CONDENSER, WITHOUT ENERGY RECOVERY—MINIMUM EFFICIENCY REQUIREMENTS																							
		EQUIPMENT TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a																		
		Air cooled (dehumidification mode)	—	3.8 ISMRE2	AHRI 920																		
		Air-source heat pumps (dehumidification mode)	—	3.8 ISMRE2	AHRI 920																		
		Water cooled (dehumidification mode)	Cooling tower condenser water	4.7 ISMRE2	AHRI 920																		
Air-source heat pump (heating mode)		—	2.05 ISGOP2	AHRI 920																			
Water-source heat pump (dehumidification mode)		Ground source, closed and open loop ^b	4.6 ISMRE2	AHRI 920																			
		Water source	3.8 ISMRE2																				
Water-source heat pump (heating mode)		Ground source, closed and open loop ^b	2.13 ISGOP2	AHRI 920																			
		Water source	2.13 ISGOP2																				
a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. b. Open-loop systems are rated using closed-loop test conditions.																							
<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td></td></tr></table>						Staff Classification	Correlates Directly	Energy Standard Needed	Overlap														
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																				

[illegible]

	<table><tr><td>Water-to-air, ground-water (heating-mode)</td><td><135,000 Btu/h (cooling-capacity)</td><td>—</td><td>50°F entering-water</td><td>3.7 COP_H</td><td>ISO-13256-1</td></tr><tr><td>Brine-to-air, ground-loop (heating-mode)</td><td><135,000 Btu/h (cooling-capacity)</td><td>—</td><td>32°F entering-water</td><td>3.2 COP_H</td><td>ISO-13256-4</td></tr><tr><td>Water-to-water, water-loop (heating-mode)</td><td><135,000 Btu/h (cooling-capacity)</td><td>—</td><td>68°F entering-water</td><td>3.7 COP_H</td><td>ISO-13256-4</td></tr><tr><td>Water-to-water, ground-water (heating-mode)</td><td><135,000 Btu/h (cooling-capacity)</td><td>—</td><td>50°F entering-water</td><td>3.1 COP_H</td><td>ISO-13256-2</td></tr><tr><td>Brine-to-water, ground-loop (heating-mode)</td><td><135,000 Btu/h (cooling-capacity)</td><td>—</td><td>32°F entering-water</td><td>3.2 COP_H</td><td>ISO-13256-2</td></tr></table>	Water-to-air, ground-water (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	50°F entering-water	3.7 COP _H	ISO-13256-1	Brine-to-air, ground-loop (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	32°F entering-water	3.2 COP _H	ISO-13256-4	Water-to-water, water-loop (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	68°F entering-water	3.7 COP _H	ISO-13256-4	Water-to-water, ground-water (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	50°F entering-water	3.1 COP _H	ISO-13256-2	Brine-to-water, ground-loop (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	32°F entering-water	3.2 COP _H	ISO-13256-2																																															
Water-to-air, ground-water (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	50°F entering-water	3.7 COP _H	ISO-13256-1																																																																									
Brine-to-air, ground-loop (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	32°F entering-water	3.2 COP _H	ISO-13256-4																																																																									
Water-to-water, water-loop (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	68°F entering-water	3.7 COP _H	ISO-13256-4																																																																									
Water-to-water, ground-water (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	50°F entering-water	3.1 COP _H	ISO-13256-2																																																																									
Brine-to-water, ground-loop (heating-mode)	<135,000 Btu/h (cooling-capacity)	—	32°F entering-water	3.2 COP _H	ISO-13256-2																																																																									
For SI: 1 British thermal unit per hour = 0.2931 W, °C = (°F – 32)/1.8.																																																																														
a.—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.																																																																														
b.—Single-phase, US air-cooled heat pumps less than 19 kW are regulated as consumer products by DOE 10 CFR 430. SCOPC, SCOP2C, SCOPH and SCOP2H values for single-phase products are set by the US DOE.																																																																														
c.—This table is a replica of ASHRAE 90.1 Table 6.8.1-15 Electrically Operated Water-Source Heat Pumps—Minimum Efficiency Requirements.																																																																														
TABLE C403.3.2(14)																																																																														
ELECTRICALLY OPERATED WATER-SOURCE HEAT PUMPS—MINIMUM EFFICIENCY REQUIREMENTS ^a																																																																														
	<table><tr><th>EQUIPMENT TYPE</th><th>SIZE CATEGORY</th><th>HEATING SECTION TYPE</th><th>SUBCATEGORY OR RATING CONDITION</th><th>MINIMUM EFFICIENCY</th><th>TEST PROCEDURE^a</th></tr><tr><td rowspan="3">Water-to-air, water loop (cooling mode)</td><td>< 17,000 Btu/h</td><td rowspan="3">All</td><td rowspan="3">86°F entering water</td><td>12.2 EER</td><td rowspan="3">ISO 13256-1</td></tr><tr><td>≥ 17,000 Btu/h and < 65,000 Btu/h</td><td>13.0 EER</td></tr><tr><td>≥ 65,000 Btu/h and < 135,000 Btu/h</td><td>13.0 EER</td></tr><tr><td>Water-to-air, ground water (cooling mode)</td><td>< 135,000 Btu/h</td><td>All</td><td>59°F entering water</td><td>18.0 EER</td><td>ISO 13256-1</td></tr><tr><td>Brine-to-air, ground loop (cooling mode)</td><td>< 135,000 Btu/h</td><td>All</td><td>77°F entering water</td><td>14.1 EER</td><td>ISO 13256-1</td></tr><tr><td>Water-to-water, water loop (cooling mode)</td><td>< 135,000 Btu/h</td><td>All</td><td>96°F entering water</td><td>10.6 EER</td><td>ISO 13256-2</td></tr><tr><td>Water-to-water, ground water (cooling mode)</td><td>< 135,000 Btu/h</td><td>All</td><td>59°F entering water</td><td>16.3 EER</td><td>ISO 13256-2</td></tr><tr><td>Brine-to-water, ground loop (cooling mode)</td><td>< 135,000 Btu/h</td><td>All</td><td>77°F entering water</td><td>12.1 EER</td><td>ISO 13256-2</td></tr><tr><td>Water-to-water, water loop (heating mode)</td><td>< 135,000 Btu/h (cooling capacity)</td><td>—</td><td>68°F entering water</td><td>4.3 COP_H</td><td>ISO 13256-1</td></tr><tr><td>Water-to-air, ground water (heating mode)</td><td>< 135,000 Btu/h (cooling capacity)</td><td>—</td><td>50°F entering water</td><td>3.7 COP_H</td><td>ISO 13256-1</td></tr><tr><td>Brine-to-air, ground loop (heating mode)</td><td>< 135,000 Btu/h (cooling capacity)</td><td>—</td><td>32°F entering water</td><td>3.2 COP_H</td><td>ISO 13256-1</td></tr></table>	EQUIPMENT TYPE	SIZE CATEGORY	HEATING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a	Water-to-air, water loop (cooling mode)	< 17,000 Btu/h	All	86°F entering water	12.2 EER	ISO 13256-1	≥ 17,000 Btu/h and < 65,000 Btu/h	13.0 EER	≥ 65,000 Btu/h and < 135,000 Btu/h	13.0 EER	Water-to-air, ground water (cooling mode)	< 135,000 Btu/h	All	59°F entering water	18.0 EER	ISO 13256-1	Brine-to-air, ground loop (cooling mode)	< 135,000 Btu/h	All	77°F entering water	14.1 EER	ISO 13256-1	Water-to-water, water loop (cooling mode)	< 135,000 Btu/h	All	96°F entering water	10.6 EER	ISO 13256-2	Water-to-water, ground water (cooling mode)	< 135,000 Btu/h	All	59°F entering water	16.3 EER	ISO 13256-2	Brine-to-water, ground loop (cooling mode)	< 135,000 Btu/h	All	77°F entering water	12.1 EER	ISO 13256-2	Water-to-water, water loop (heating mode)	< 135,000 Btu/h (cooling capacity)	—	68°F entering water	4.3 COP _H	ISO 13256-1	Water-to-air, ground water (heating mode)	< 135,000 Btu/h (cooling capacity)	—	50°F entering water	3.7 COP _H	ISO 13256-1	Brine-to-air, ground loop (heating mode)	< 135,000 Btu/h (cooling capacity)	—	32°F entering water	3.2 COP _H	ISO 13256-1	<table><tr><td>Water-to-water, water loop (heating mode)</td><td>< 135,000 Btu/h (cooling capacity)</td><td>—</td><td>68°F entering water</td><td>3.7 COP_H</td><td>ISO 13256-1</td></tr><tr><td>Water-to-water, ground water (heating mode)</td><td>< 135,000 Btu/h (cooling capacity)</td><td>—</td><td>50°F entering water</td><td>3.1 COP_H</td><td>ISO 13256-2</td></tr></table>	Water-to-water, water loop (heating mode)	< 135,000 Btu/h (cooling capacity)	—	68°F entering water	3.7 COP _H	ISO 13256-1	Water-to-water, ground water (heating mode)	< 135,000 Btu/h (cooling capacity)	—	50°F entering water	3.1 COP _H	ISO 13256-2
EQUIPMENT TYPE	SIZE CATEGORY	HEATING SECTION TYPE	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a																																																																									
Water-to-air, water loop (cooling mode)	< 17,000 Btu/h	All	86°F entering water	12.2 EER	ISO 13256-1																																																																									
	≥ 17,000 Btu/h and < 65,000 Btu/h			13.0 EER																																																																										
	≥ 65,000 Btu/h and < 135,000 Btu/h			13.0 EER																																																																										
Water-to-air, ground water (cooling mode)	< 135,000 Btu/h	All	59°F entering water	18.0 EER	ISO 13256-1																																																																									
Brine-to-air, ground loop (cooling mode)	< 135,000 Btu/h	All	77°F entering water	14.1 EER	ISO 13256-1																																																																									
Water-to-water, water loop (cooling mode)	< 135,000 Btu/h	All	96°F entering water	10.6 EER	ISO 13256-2																																																																									
Water-to-water, ground water (cooling mode)	< 135,000 Btu/h	All	59°F entering water	16.3 EER	ISO 13256-2																																																																									
Brine-to-water, ground loop (cooling mode)	< 135,000 Btu/h	All	77°F entering water	12.1 EER	ISO 13256-2																																																																									
Water-to-water, water loop (heating mode)	< 135,000 Btu/h (cooling capacity)	—	68°F entering water	4.3 COP _H	ISO 13256-1																																																																									
Water-to-air, ground water (heating mode)	< 135,000 Btu/h (cooling capacity)	—	50°F entering water	3.7 COP _H	ISO 13256-1																																																																									
Brine-to-air, ground loop (heating mode)	< 135,000 Btu/h (cooling capacity)	—	32°F entering water	3.2 COP _H	ISO 13256-1																																																																									
Water-to-water, water loop (heating mode)	< 135,000 Btu/h (cooling capacity)	—	68°F entering water	3.7 COP _H	ISO 13256-1																																																																									
Water-to-water, ground water (heating mode)	< 135,000 Btu/h (cooling capacity)	—	50°F entering water	3.1 COP _H	ISO 13256-2																																																																									
	<table><tr><td>Brine-to-water, ground loop</td><td>< 135,000</td><td>32°F entering</td><td>2.5 COP_H</td><td>ISO 13256-2</td></tr></table>	Brine-to-water, ground loop	< 135,000	32°F entering	2.5 COP _H	ISO 13256-2	<table><tr><td>(heating mode)</td><td>Btu/h (cooling capacity)</td><td>water</td><td></td><td></td></tr></table>	(heating mode)	Btu/h (cooling capacity)	water			<p>For SI: 1 British thermal unit per hour = 0.2931 W, °C = (°F – 32)/1.8.</p> <p>a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure.</p> <p>b. Single-phase, US air-cooled heat pumps < 65,000 Btu/h are regulated as consumer products by 10 CFR 430. SEER, SEER2, HPSF and HPSF2 values for single-phase products are set by the US DOE. Informative Note: See ASHRAE 90.1 Informative Appendix F</p> <p>for the US DOE minimum.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Number</td><td>Test Site</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>ALUC</td><td>SD</td></tr><tr><td></td><td>x</td><td></td><td>DNV</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Number	Test Site		x			Action	AS	ALUC	SD		x		DNV																																																	
Brine-to-water, ground loop	< 135,000	32°F entering	2.5 COP _H	ISO 13256-2																																																																										
(heating mode)	Btu/h (cooling capacity)	water																																																																												
Staff Classification	Correlates Directly	Energy Standard Number	Test Site																																																																											
	x																																																																													
Action	AS	ALUC	SD																																																																											
	x		DNV																																																																											
CE#171	Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.																																																																													

<p>Related Model: CED1- 156-22, CE2D-13- 23, CE2D-16- 23, CE2D-18- 23, CED1- 157-22, CE2D-17- 23, CE2D-19- 23,</p>	<div style="text-align: center;"> <h2>Delete entire Table</h2> <h3>TABLE C403.3.2(15)</h3> </div> <p>HEAT PUMP AND HEAT RECOVERY CHILLER PACKAGES—MINIMUM EFFICIENCY REQUIREMENTS^a</p> <p>(a) ASHRAE 90.1-2013 Table 6.8.1-16.</p> <p>b—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year/version of the test procedure:</p> <p>b-1—Cooling-only rating conditions are standard rating conditions defined in ASHRAE 55/59/90, Table 3.</p> <p>b-2—Heating full-load rating conditions are at rating conditions defined in ASHRAE 55/59/90, Table 3.</p> <p>c—For water-</p> <p>d—Cooled heat recovery chillers that have capabilities for heat rejection to a heat recovery condenser and a tower-</p> <p>e—Outdoor air entering dry-bulb (db) temperature and wet-bulb (wb) temperature.</p> <p>f—Source water entering and leaving water temperature.</p> <p>g—This table is a replica of ASHRAE 90.1 Table 6.8.1-16 Heat Pump and Heat Recovery Chiller Packages—Minimum Efficiency Requirements.</p>
<p>CED1- 12-22</p>	
	<p>TABLE C403.3.2(15)</p> <p>HEAT PUMP AND HEAT RECOVERY CHILLER PACKAGES—MINIMUM EFFICIENCY REQUIREMENTS^a</p> <p>(a) ASHRAE 90.1-2013 Table 6.8.1-16.</p> <p>b—Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year/version of the test procedure:</p> <p>b-1—Cooling-only rating conditions are standard rating conditions defined in ASHRAE 55/59/90, Table 3.</p> <p>b-2—Heating full-load rating conditions are at rating conditions defined in ASHRAE 55/59/90, Table 3.</p> <p>c—For water-</p> <p>d—Cooled heat recovery chillers that have capabilities for heat rejection to a heat recovery condenser and a tower-</p> <p>e—Outdoor air entering dry-bulb (db) temperature and wet-bulb (wb) temperature.</p> <p>f—Source water entering and leaving water temperature.</p> <p>g—This table is a replica of ASHRAE 90.1 Table 6.8.1-16 Heat Pump and Heat Recovery Chiller Packages—Minimum Efficiency Requirements.</p>

01-22-2021

TABLE 09-1.3.2(15)

HEAT PUMP AND HEAT RECOVERY CHILLER PACKAGES—MINIMUM EFFICIENCY REQUIREMENTS¹

A00 (ENTIRE TABLE Table 09-1.3.2(15))

For 1°C = 1.8°F (1.8)

A01 Not Applicable

- Cooling rating conditions are standard rating conditions defined in **ASHRAE 55/59/90 0-P1**, Table 4, except for liquid-cooled centrifugal chilling packages which can adjust cooling efficiency for rated condenser cooling water temperature t_{cw} (provided in accordance with **ASHRAE 90.1** footnote 6.1.1).
- Heating full-load rating conditions are at standard rating conditions defined in **ASHRAE 55/59/90 0-P1**, Table 4, includes the impact of defrost for air source heating ratings.
 - The heat pump must be designed to operate in both heating and cooling modes and must operate at the t_{cw} (within 10°C) at full-load with 100 percent heat recovery (no blow rejection). Units that only have capabilities for partial heat recovery shall meet the requirements of **ASHRAE 90.1** Table 6.8.1.3.
- For cooling operation, compliance with both the FL and PLV is required, but only compliance with Path A or Path B cooling efficiency is required.
- For units that operate in both cooling and heating, compliance with both the cooling and heating efficiency is required.
- The equipment must be designed to operate in both heating and cooling modes and must be designed to operate at the t_{cw} (within 10°C) at full-load with 100 percent heat recovery (no blow rejection).
- ASHRAE 55/59/90 0-P1** standard rating conditions of Low, Medium, High, or Boost. Compliance with cooling performance is not required.
- For air source heat pumps, compliance with both the 47°F and 17°F heating source outdoor air temperature (OAT) rating efficiency is required for heating.
 - For air source heat pumps, compliance with both the 47°F and 17°F heating source outdoor air temperature (OAT) rating efficiency is required for heating.
- For simultaneous cooling and heating chillers applications where there is simultaneous cooling and heating, compliance with the simultaneous cooling performance heat recovery t_{cw} (if any) required at one of the four simultaneous cooling and heating, **ASHRAE 55/59/90 0-P1** standard rating conditions of Low, Medium, High, or Boost. Compliance with the cooling performance is required as defined in notes a and d, and except in note f.
- For simultaneous cooling and heating chillers applications where there is simultaneous cooling and heating, compliance with the simultaneous cooling performance heat recovery t_{cw} (if any) required at one of the four simultaneous cooling and heating, **ASHRAE 55/59/90 0-P1** standard rating conditions of Low, Medium, High, or Boost. Compliance with the cooling only performance is required as defined in notes a and d.
 - The minimum heating and cooling performance shall be determined with the ASHRAE Standard test conditions (STC) t_{cw} is only required at one of the four heating.
- ASHRAE 55/59/90 0-P1** standard rating conditions of Low, Medium, Hot Water 1, or Hot Water 2. Compliance with the cooling only performance is required as defined in notes a and d.
- Chilling packages employing a freeze protection liquid in accordance with **ASHRAE 90.1** Section 6.4.1.2.2 shall be tested or rated with water for the purpose of compliance with the requirements of this table.
 - Outdoor air entering the fluid (80) temperature and wet-bulb (60) temperature.
 - Source leaving fluid temperature.
- The cooling evaporator liquid flow rate used for the heating rating for a reverse cycle air-to-water heat pump shall be the flow rate determined during the full-load cooling rating.
 - The cooling evaporator liquid flow rate for the simultaneous cooling and heating and heat recovery liquid cooled chilling packages rating shall be the liquid flow rates from the cooling operation full-load rating.
 - For heating only fluid-to-fluid chiller packages, the evaporator flow rate obtained with an entering liquid temperature of 54°F and a leaving liquid temperature of 44°F shall be used.
 - The size category is the full-load net refrigerating cooling mode capacity, which is the capacity of the evaporator available for cooling of the thermal load external to the chilling package.
 - A heat recovery condenser at its maximum load point must remove enough heat from the refrigerant to cool the refrigerant to remove at superheat energy and begin condensation of the refrigerant. A heat recovery system where only the superheat is reduced is not covered by **ASHRAE 90.1** Table 6.8.1-16 and is considered a deaerator, and the chiller package must comply with **ASHRAE 90.1** Table 6.8.1-3.
 - Water-to-water heat pumps with a capacity less than 135,000 Btu/h are covered by **ASHRAE 90.1** Table 6.8.1-15.

Staff Classification	Correlates Directly	Energy Standard Based	Overlap
			X

Action	AS	AS/IC	D	D/IC
			X	

		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Based</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>ASAC</td><td>CS</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>				Staff Classification	Correlates Directly	Energy Standard Based	Over lap				x	Action	AS	ASAC	CS				x
Staff Classification	Correlates Directly	Energy Standard Based	Over lap																		
			x																		
Action	AS	ASAC	CS																		
			x																		
		Original text of mod is not consistent with that of the 2023 FBC -EC.																			
CE#172	Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.																				
Related Mods:	TABLE C403.3.2(16)																				
		CEILING-MOUNTED COMPUTER-ROOM AIR CONDITIONERS—MINIMUM EFFICIENCY REQUIREMENTS ^a																			
CE2D-156-22, CE2D-13- 23, CE2D-16-	EQUIPMENT TYPE	STANDARD MODEL	NET SENSIBLE- COOLING CAPA- CITY	MINIMUM-N ET-SENSIBLE E-COP	RATING CONDITIONS- RETURN AIR (dry-bulb/dew-point)	TEST PROCEDURE ^a															
23, CE2D-18- 23, CE2D-157-22, CE2D-17- 23,	Air-cooled-with-free air discharge-condenser	Ducted	<20,000 Btu/h	2-06	75°F/62°F (Class 1)	AHRI-1360															
			≥20,000 Btu/h and <65,000 Btu/h	2-02																	
			≥65,000 Btu/h	1-02																	
CE2D-19- 23, CE2D-1- 12-22		Nonducted	<20,000 Btu/h	2-08																	
			≥20,000 Btu/h and <65,000 Btu/h	2-05																	
			≥65,000 Btu/h	1-04																	
	Air-cooled-with-free air discharge-condenser with fluid-coolant	Ducted	<20,000 Btu/h	2-04	75°F/62°F (Class 1)	AHRI-1360															
			≥20,000 Btu/h and <65,000 Btu/h	1-07																	
		Nonducted	<20,000 Btu/h	2-04																	
			≥20,000 Btu/h and <65,000 Btu/h	2-00																	
			≥65,000 Btu/h	1-09																	

		Original text of mod is not consistent with that of the 2023 FBC -EC.				<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Standard</td><td>Over Lap</td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>01</td><td>0000</td><td>0</td><td>0000</td></tr></table>				Staff Classification	Correlates Directly	Energy Standard	Standard	Over Lap						Action	01	0000	0	0000
Staff Classification	Correlates Directly	Energy Standard	Standard	Over Lap																				
Action	01	0000	0	0000																				
CE#172	Aligns the minimum efficiency requirements with the 2022 ASHRAE 90.1.																							
Related Mods:	TABLE C403.3.2(16)																							
CE#1- 156-22, CE#2D-18- 23, CE#2D-16-	CEILING-MOUNTED COMPUTER-ROOM AIR CONDITIONERS—MINIMUM EFFICIENCY REQUIREMENTS ^b _____					TEST PROCEDURE ^a																		
	EQUIPMENT TYPE	STANDARD MODEL	NET-SENSIBLE-COOLING CAPACITY	MINIMUM NET-SENSIBLE E-COP	RATING CONDITIONS RETURN-AIR (dry-bulb/dew-point)																			
23, CE#2D-18- 23, CE#1- 157-22, CE#2D-17- 23, CE#2D-19- 23, CE#1- 12- 22	Air-cooled-with-free-air-discharge-condenser	Ducted	<29,000 Btu/h	2.05	75°F/62°F (Class 1)	AHRI-1360																		
≥29,000 Btu/h and <65,000 Btu/h			2.02																					
≥65,000 Btu/h			1.92																					
Nonducted		<29,000 Btu/h	2.08																					
		≥29,000 Btu/h and <65,000 Btu/h	2.05																					
		≥65,000 Btu/h	1.94																					
Ducted	<29,000 Btu/h	2.01																						
	≥29,000 Btu/h and <65,000 Btu/h	1.97																						
	Air-cooled-with-free-air-discharge-condenser-with-fluid-coolant	Nonducted	≥65,000 Btu/h	1.87	75°F/62°F (Class 1)	AHRI-1360																		
	<29,000 Btu/h		2.04																					
	≥29,000 Btu/h and <65,000 Btu/h		2.00																					
	≥65,000 Btu/h		1.89																					

	Air-cooled-with-ducted-condenser	Ducted	<29,000 Btu/h	1-86	75°F/52°F (Class-1)	AHRI-1360
			≥29,000 Btu/h and <65,000 Btu/h	1-83		
			≥65,000 Btu/h	1-73		
		Nonducted	<29,000 Btu/h	1-89		
			≥29,000 Btu/h and <65,000 Btu/h	1-86		
			≥65,000 Btu/h	1-75		
	Air-cooled-with-fluid economizer-and-ducted-condenser	Ducted	<29,000 Btu/h	1-82	75°F/52°F (Class-1)	AHRI-1360
			≥29,000 Btu/h and <65,000 Btu/h	1-78		
			≥65,000 Btu/h	1-68		
		Nonducted	<29,000 Btu/h	1-85		
			≥29,000 Btu/h and <65,000 Btu/h	1-81		
			≥65,000 Btu/h	1-70		
	Water-cooled	Ducted	<29,000 Btu/h	2-38	75°F/52°F (Class-1)	AHRI-1360
			≥29,000 Btu/h and <65,000 Btu/h	2-28		
			≥65,000 Btu/h	2-18		
		Nonducted	<29,000 Btu/h	2-44		
			≥29,000 Btu/h and <65,000 Btu/h	2-34		
			≥65,000 Btu/h	2-20		
	Water-cooled-with-fluid-economizer	Ducted	<29,000 Btu/h	2-33	75°F/52°F (Class-1)	AHRI-1360
			≥29,000 Btu/h and <65,000 Btu/h	2-23		
			≥65,000 Btu/h	2-13		
		Nonducted	<29,000 Btu/h	2-36		
			≥29,000 Btu/h and <65,000 Btu/h	2-26		
			≥65,000 Btu/h	2-16		
	Glycol-cooled	Ducted	<29,000 Btu/h	1-07	75°F/52°F (Class-1)	AHRI-1360
			≥29,000 Btu/h and <65,000 Btu/h	1-03		
			≥65,000 Btu/h	1-78		
		Nonducted	<29,000 Btu/h	2-00		
			≥29,000 Btu/h and <65,000 Btu/h	1-08		
			≥65,000 Btu/h	1-84		
	Glycol-cooled-with-fluid-economizer	Ducted	<29,000 Btu/h	1-02	75°F/52°F (Class-1)	AHRI-1360
			≥29,000 Btu/h and <65,000 Btu/h	1-88		
			≥65,000 Btu/h	1-73		
		Nonducted	<29,000 Btu/h	1-95		
			≥29,000 Btu/h and <65,000 Btu/h	1-85		
			≥65,000 Btu/h	1-70		

	≥29,000					
	Btu/h and	≥23				
	<65,000					
	Btu/h	≥20				
For SI: 1 British thermal unit per hour = 0.2931 W, °C = [(°F) – 32]/1.8, COP = (Btu/h × hp)/(0.5607). a. Chapter 6 contains a complete specification of the referenced standards, which include test procedures, including the reference year version of the test procedure. b. This is a replica of ASHRAE 90.1 Table 6.8.1-2 Ceiling-Mounted Computer Room Air Conditioners—Minimum Efficiency Requirements. TABLE C403.3.2(16) CEILING-MOUNTED COMPUTER ROOM AIR CONDITIONERS—MINIMUM EFFICIENCY REQUIREMENTS						
	EQUIPE NT TYPE	STANDARD MODEL	NET SENSIBLE COOLING CAPACITY	MINIMUM NET SENSIBLE COP	RATING CONDITIONS RETURN AIR (dry bulb/dew point)	TEST PROCEDURE ^a
Air cooled with free air discharge condenser	Ducted		< 29,000 Btu/h	2.05	75°F/52°F (Class 1)	AHRI 1360
			≥ 29,000 Btu/h and < 65,000 Btu/h	2.02		
			≥ 65,000 Btu/h	1.92		
	Nonducted		< 29,000 Btu/h	2.08		
			≥ 29,000 Btu/h and < 65,000 Btu/h	2.05		
			≥ 65,000 Btu/h	1.94		
Air cooled with free air discharge condenser with fluid economizer	Ducted		< 29,000 Btu/h	2.01	75°F/52°F (Class 1)	AHRI 1360
			≥ 29,000 Btu/h and < 65,000 Btu/h	1.97		
			≥ 65,000 Btu/h	1.87		
	Nonducted		< 29,000 Btu/h	2.04		
			≥ 29,000 Btu/h and < 65,000 Btu/h	2.00		
			≥ 65,000 Btu/h	1.89		
	Ducted		< 29,000 Btu/h	1.86	75°F/52°F (Class 1)	AHRI 1360
			≥ 29,000 Btu/h and < 65,000 Btu/h	1.83		
			≥ 65,000 Btu/h	1.73		
	Nonducted		< 29,000 Btu/h	1.89		
			≥ 29,000 Btu/h and < 65,000 Btu/h	1.86		
			≥ 65,000 Btu/h	1.75		
Air cooled with fluid economizer and ducted condenser	Ducted		< 29,000 Btu/h	1.82	75°F/52°F (Class 1)	AHRI 1360
			≥ 29,000 Btu/h and < 65,000 Btu/h	1.78		
	Nonducted		≥ 65,000 Btu/h	1.68		
			< 29,000 Btu/h	1.85		
			≥ 29,000 Btu/h and < 65,000 Btu/h	1.81		
			≥ 65,000 Btu/h	1.70		
	Ducted		< 29,000 Btu/h	2.38		AHRI 1360
			≥ 29,000 Btu/h and < 65,000 Btu/h	2.28		
			≥ 65,000 Btu/h	2.18		
			< 29,000 Btu/h	2.41		
Water cooled	Nonducted		≥ 29,000 Btu/h and < 65,000 Btu/h	2.31		
			≥ 65,000 Btu/h	2.20		

	<p>C403.3.4-C403.3.4.2 Boiler turndown. Boiler systems with design input of greater than 1,000,000 Btu/h (293 kW) shall comply with the turndown ratio specified in Table C403.3.4.2.</p> <p>The system turndown requirement shall be met through the use of multiple single-input boilers, one or more <i>modulating</i> boilers or a combination of single-input and <i>modulating</i> boilers .</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AL/EC</th><th>DI</th><th>DR/EC</th></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AL/EC	DI	DR/EC		x									
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																						
	x																								
Action	AS	AL/EC	DI	DR/EC																					
	x																								
CE#175	Adds a new table C403.3.4.1.																								
Related Mods: CEPI-97-21.	TABLE C403.3.4.1 BOILER OXYGEN CONCENTRATIONS																								
CED1- 158-22	<table><tr><th>BOILER APPLICATION</th><th>MAXIMUM STACK-GAS OXYGEN CONCENTRATION^a</th></tr><tr><td>Commercial boilers or where ≤ 10% of the boiler system capacity is used for process applications at design conditions</td><td>5%</td></tr><tr><td>Process boilers</td><td>3%</td></tr></table> <p>a. Concentration levels measured by volume on a dry basis over firing rates of 20 to 100 percent. These concentration limits do not apply where 50 percent or more of the boiler system capacity serves Group R-2 occupancies.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AL/EC</th><th>DI</th><th>DR/EC</th></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	BOILER APPLICATION	MAXIMUM STACK-GAS OXYGEN CONCENTRATION ^a	Commercial boilers or where ≤ 10% of the boiler system capacity is used for process applications at design conditions	5%	Process boilers	3%	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AL/EC	DI	DR/EC		x			
BOILER APPLICATION	MAXIMUM STACK-GAS OXYGEN CONCENTRATION ^a																								
Commercial boilers or where ≤ 10% of the boiler system capacity is used for process applications at design conditions	5%																								
Process boilers	3%																								
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																						
	x																								
Action	AS	AL/EC	DI	DR/EC																					
	x																								
CE#176	Renumbers Table C403.3.4.																								
Related Mods: CEPI-97- 21, CED1- 158-22	TABLE C403.3.4- TABLE C403.3.4.2 BOILER TURNDOWN																								
CE#177	Replaces the text "Each heating" with "Heating" and updates referenced section. Replaces the text "building envelope" with "building thermal envelope" in the exception.																								
Related Mods: CEPI-99- 21, CED1-92- 22	<p>C403.4 Heating and cooling system controls.</p> <p>Each heating Heating and cooling system shall be provided with controls in accordance with Sections C403.4.1 through C403.4.8:</p> <p>C403.4.1 Thermostatic controls. The supply of heating and cooling energy to each zone shall be controlled by individual thermostatic controls capable of responding to temperature within the zone . Where humidification or dehumidification or both is provided, not fewer than one humidity control device shall be provided for each humidity control system.</p> <p>Exception: Independent perimeter systems that are designed to offset only <i>building thermal envelope</i> heat losses, gains or both serving one or more perimeter zones also served by an interior system provided that both of the following conditions are met:</p> <p>C403.4.1.1 Heat pump supplementary heat. Heat pumps having supplementary electric resistance heat shall have controls that limit supplemental heat operation to only those times when one of the following applies:</p> <ol style="list-style-type: none">1. The vapor compression cycle cannot provide the necessary heating energy to satisfy the <i>thermostat</i> setting.2. The heat pump is operating in defrost mode.3. The vapor compression cycle malfunctions.4. The <i>thermostat</i> malfunctions. <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AL/EC</th><th>DI</th><th>DR/EC</th></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AL/EC	DI	DR/EC		x									
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																						
	x																								
Action	AS	AL/EC	DI	DR/EC																					
	x																								
CE#178	<p>Revises thermostat deadband requirements for zones with heating and cooling controls.</p> <p>°F °C °F °C</p> <p>Requires: separately adjustable cooling and heating set-points, minimum dead band range of 1 (0.56), and capable of supporting a dead band range of 5 (3). Also revises the exceptions.</p>																								
Related Mods: CEC2D- 6-23	<p>C403.4.1.2 Deadband. Where used to control both heating and cooling, zone thermostatic controls shall: be configured to provide a temperature range or deadband of not less than 5°F (2.8°C) within which the supply of heating and cooling energy to the zone is shut off or reduced to a minimum.</p> <ol style="list-style-type: none">1. Have separate setpoints for heating and cooling, each individually adjustable.2. Be capable of and initially configured to provide a temperature range or deadband between the two setpoints of not less than 5°F (3°C) within which the supply of heating and cooling energy to the zone is shut off or reduced to a minimum.3. Have a minimum deadband of not less than 1°F (0.56°C) when setpoints are adjusted. <p>Exceptions:</p> <ol style="list-style-type: none">1. <i>Thermostats</i> requiring <i>manual</i> changeover between heating and cooling modes.2. Occupancies or applications <i>where applicable codes or accreditation standards</i> requiring precision in indoor temperature control as approved by the code official -shall be permitted to be initially configured to not less than 1°F (0.56°C) dead band. <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AL/EC</th><th>DI</th><th>DR/EC</th></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AL/EC	DI	DR/EC		x									
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																						
	x																								
Action	AS	AL/EC	DI	DR/EC																					
	x																								
CE#179	Adds new Section C403.4.1.3. This is mainly a clarification but may increase the stringency in some circumstances. Renumbers Section C403.4.1.3 and revises the requirement that mechanical or software means must be used to prevent heating set-point and cooling set-point overlap. In some situation the stringency may increase. Renumbers Section C403.4.1.4. Renumbers Section C403.4.1.5.																								
Related Mods: CEC2D- 6-23	<p>C403.4.1.3 Setpoint adjustment and display. Where thermostatic control setpoints are capable of being adjusted by occupants or HVAC system operators, the adjustment shall be independent for the heating setpoint and the cooling setpoint; when one setpoint is changed, the other shall not change except as needed to maintain the minimum deadband required by Section C403.4.1.2. For thermostatic controls that display setpoints, both the heating and cooling setpoints shall be displayed simultaneously, or the setpoint of the currently active mode (heating or cooling) shall be displayed along with an indication of that mode.</p>																								

	<p>C403.4.1.3-C403.4.1.4 Setpoint overlap restriction. Where heating and cooling to a zone are controlled by a separate heating and a separate cooling zone thermostatic control controls located within the zone, mechanical or software means shall be provided a limit switch, mechanical stop or direct digital control system with software programming shall be configured to prevent the heating setpoint from exceeding the cooling setpoint, minus the deadband required by and to maintain a deadband in accordance with Section C403.4.1.2.</p> <p>C403.4.1.4-C403.4.1.5 Heated or cooled vestibules. The heating system for heated vestibules and air curtains with integral heating shall be provided with controls configured to shut off the source of heating when the outdoor air temperature is greater than 45°F (7°C). Vestibule heating and cooling systems shall be controlled by a thermostat located in the vestibule configured to limit heating to a temperature not greater than 60°F (16°C) and cooling to a temperature not less than 55°F (13°C).</p> <p>Exception: Control of heating or cooling provided by site-recovered energy or transfer air that would otherwise be exhausted.</p> <p>C403.4.1.5-C403.4.1.6 Hot water boiler outdoor temperature setback control. Hot water boilers that supply heat to the building through one- or two-pipe heating systems shall have an outdoor setback control that lowers the boiler water temperature based on the outdoor temperature.</p>	<p>Original text is not consistent with that of the 2023 FBC – EC</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>ES</th><th>ES/EC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	ES	ES/EC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																		
			x																		
Action	AS	AS/EC	ES	ES/EC																	
			x																		
CE#180	<p>Renames the section and makes editorial changes for clarification.</p> <p>The change exempts Dwelling and Sleeping units from the optimum start and stop requirement. The exemption may decrease the stringency.</p>																				
Related Mods: CEPI- 100-21, CED1- 160-22	<p>C403.4.2.3 Automatic Optimum start and stop. Automatic Optimum start and stop controls shall be provided for each heating and cooling system with direct control of individual zones. HVAC system. The automatic optimum start controls shall be configured to automatically adjust the daily start time of the heating and cooling system. HVAC system in order to bring each space to the desired occupied temperature immediately prior to scheduled occupancy. Automatic stop controls shall be provided for each HVAC system with direct digital control of individual zones. The automatic optimum stop controls shall be configured to reduce the heating and cooling HVAC system's heating temperature setpoint and increase the cooling temperature setpoint by not less than 2°F (1.11°C) before scheduled unoccupied periods based on the thermal lag and acceptable drift in space temperature that is within comfort limits.</p> <p>Exception: Dwelling units and sleeping units are not required to have optimum start controls.</p>	<p>Original text is not consistent with that of the 2023 FBC – EC</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>ES</th><th>ES/EC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	ES	ES/EC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																		
			x																		
Action	AS	AS/EC	ES	ES/EC																	
			x																		
CE#181	Reserved																				
Related Mods: CEPI-99- 21, CEC2D- 1-23, CED1- 161-22, CED1- 164-22	<p>C403.4.6 Reserved.</p>	<p>Original text is not consistent with that of the 2023 FBC – EC</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>ES</th><th>ES/EC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	ES	ES/EC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																		
			x																		
Action	AS	AS/EC	ES	ES/EC																	
			x																		
CE#182	<p>Renumbers Section C402.5.11, renames the section titled "Operable openings interlocking" and revises the provision.</p> <p>Reduces HVAC system disabling cut-out time to 5 minutes from 10 minutes. Adds six new exemptions.</p>																				
Related Mods: CEPI-65- 21, CED1- 160-22	<p>C402.5.11-C403.4.7 Operable openings interlocking. Heating and cooling system controls for operable openings to the outdoors. Where occupancies utilize operable openings to All doors from a conditioned space to the outdoors and all other operable openings from a conditioned space to the outdoors that are larger than 40 square feet (3.7 m²) when fully open shall have automatic controls interlocked with the heating and cooling system. The controls shall be configured to do the following within 5 minutes of opening:</p> <p>in area, such openings shall be interlocked with the heating and cooling system so as to raise the cooling setpoint to 90°F (32°C) and lower the heating setpoint to 55°F (13°C) whenever the operable opening is open. The change in heating and cooling setpoints shall occur within 10 minutes of opening the operable opening:</p>																				
	<p>1. Disable mechanical heating to the zone or reset the space heating temperature setpoint to 55°F (12.5°C) or less.</p> <p>2. Disable mechanical cooling to the zone or reset the space cooling temperature setpoint to 90°F (32°C) or more. Mechanical cooling can remain enabled if the outdoor air temperature is below the space temperature.</p> <p>Exceptions:</p> <p>1. Separately zoned areas associated with the preparation of food that contain appliances that contribute to the HVAC loads of a restaurant or similar type of occupancy. Building entrances with automatic closing devices.</p> <p>2. Emergency exits with an automatic alarm that sounds when open.</p> <p>3. Operable openings and doors serving enclosed spaces without a thermostat or heating or cooling temperature sensor.</p> <p>4. Separately zoned areas associated with the preparation of food that contain appliances that contribute to the heating or cooling loads of a restaurant or similar type of occupancy.</p> <p>2-5. Warehouses that utilize overhead doors operable openings for the function of the occupancy, where approved by the code official.</p> <p>3-6. The first entrance doors where located in the exterior wall and are part of a vestibule system.</p> <p>7. Operable openings into spaces served by radiant heating and cooling systems.</p> <p>8. Alterations where walls would have to be opened solely for the purpose of meeting this requirement and where approved.</p> <p>9. Doors served by air curtains meeting the requirements of Section C402.6.6.</p>																				
CE#183	<p>Adds new Section C403.4.8 and three subsections. This change adds clarifications to humidity control requirements and allows lower relative humidity where mechanical cooling is used for temperature control. No impact on construction costs but may avoid simultaneous dehumidification and humidification process that reduces energy use. May decrease the stringency in some circumstances. Adds new Section C403.4.8.1. Adds new Section C403.4.8.2. Adds new Section C403.4.8.3.</p>	<p>Original text is not consistent with that of the 2023 FBC – EC FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>ES</th><th>ES/EC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	ES	ES/EC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																		
			x																		
Action	AS	AS/EC	ES	ES/EC																	
			x																		

Related Mods:	<p>C403.4.8 Humidification and dehumidification controls. Humidification and dehumidification controls shall be in accordance with this section.</p> <p>C403.4.8.1 Dehumidification. Humidistatic controls shall not use mechanical cooling to reduce the humidity below the lower of a dew point of 55°F (13°C) or relative humidity of 60 percent in the coldest zone served by the system. Lower humidity shall be permitted where mechanical cooling is being used for temperature control.</p>																		
	<p>Exceptions:</p> <p>1. Where approved, systems serving zones where specific humidity levels are required, such as museums and hospitals, and where humidistatic controls are capable of and configured to maintain a dead band of at least 10 percent relative humidity where no active humidification or dehumidification takes place.</p> <p>2. Systems serving zones where humidity levels are required to be maintained with precision of not more than ±5 percent relative humidity to comply with applicable codes or accreditation standards or as approved by the authority having jurisdiction.</p> <p>C403.4.8.2 Humidification. Humidistatic controls shall not use fossil fuels or electricity to produce relative humidity above 30 percent in the warmest zone served by the system.</p> <p>Exceptions:</p> <p>1. Where approved, systems serving zones where specific humidity levels are required, such as museums and hospitals, and where humidistatic controls are capable of and configured to maintain a deadband of at least 10 percent relative humidity where no active humidification or dehumidification takes place.</p> <p>2. Systems serving zones where humidity levels are required to be maintained with precision of not more than ±5 percent relative humidity to comply with applicable codes or accreditation standards or as approved by the authority having jurisdiction.</p> <p>C403.4.8.3 Control interlock. Where a zone is served by a system or systems with both humidification and dehumidification capability, means such as limit switches, mechanical stops, or for DDC systems, software programming, shall be provided capable of and configured to prevent simultaneous operation of humidification and dehumidification equipment.</p> <p>Exception: Systems serving zones where humidity levels are required to be maintained with precision of not more than ±5 percent relative humidity to comply with applicable codes or accreditation standards or as approved by the authority having jurisdiction.</p> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DDC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table><p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AS/EC	D	DDC		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	AS/EC	D	DDC															
	x																		
CE#184	Removes air-economizer exception for VRF systems installed with a dedicated outdoor air system(DOAS) but adds an air-economizer exemption for DX systems with multi stage compressor capacity less than 54 kBtuh used with DOAS. Reduces the stringency by adding exception for the most common used DX system types																		
Related Mods:	<p>C403.5 Economizers. Economizers shall comply with Sections C403.5.1 through C403.5.5.</p> <p>An air or water economizer shall be provided for the following cooling systems:</p>																		
CEPI- 103-21	<p>3. Individual fan systems with cooling capacity greater than or equal to 270,000 Btu/h (79.1 kW) in buildings having a Group R occupancy.</p> <p>The total supply capacity of all fan cooling units not provided with economizers shall not exceed 20 percent of the total supply capacity of all fan cooling units in the building or 1,500,000 Btu/h (440 kW), whichever is greater.</p> <p>Exceptions: Economizers are not required for the following systems.</p> <p>1. Individual fan systems not served by chilled water for buildings located in Climate Zones 0A, 0B, 1A and 1B.</p> <p>2. Where more than 25 percent of the air designed to be supplied by the system is to spaces that are designed to be humidified above 35°F (1.7°C) dew-point temperature to satisfy process needs.</p> <p>3. Systems expected to operate less than 20 hours per week.</p> <p>4. Systems serving supermarket areas with open refrigerated casework.</p> <p>5. Where the cooling efficiency is greater than or equal to the efficiency requirements in Table C403.5(2).</p> <p>6. Systems that include a heat recovery system in accordance with Section C403.11.5.</p> <p>7. VRF systems installed with a dedicated outdoor air system –Direct-expansion fan coils or unitary equipment with a capacity less than 54,000 Btu/h (15.8 kW) and multiple stages of compressor capacity installed with a dedicated outdoor air system.</p> <p>Original text is not consistent with that of the 2023 FBC – EC</p> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DDC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				x	Action	AS	AS/EC	D	DDC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			x																
Action	AS	AS/EC	D	DDC															
			x																
CE#185	Revised the provision to clarify how to relieve excess outdoor air during economizer operation when the building is pressurized. Two options are provided that add to design flexibility.																		
Related Mods: CEPI- 106-21	<p>C403.5.3.4 Relief of excess outdoor air.</p> <p>Systems shall be capable of relieving excess outdoor air during air-economizer operation to prevent overpressurizing the building. The relief air outlet shall be located to avoid recirculation into the building -</p> <p>1. Return or relief fan(s) meeting the requirements of Section C403.11.1.</p> <p>2. A barometric or motorized damper relief path with a total pressure drop at a design relief airflow rate less than 0.10 inches water column (25 Pa) from the occupied space to the outdoors. Design relief airflow rate shall be the design supply airflow rate minus any continuous exhaust flows, such as toilet exhaust fans, whose makeup is provided by the economizer system.</p> <p>The relief air outlet shall be located to avoid recirculation into the building.</p> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DDC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	AS/EC	D	DDC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	AS/EC	D	DDC															
			x																
CE#186	Revised the minimum airflow requirement for VAV systems.																		
	For the DDC systems the minimum flow can be sized using the ASHRAE 62.1 minimum ventilation requirement per the Simplified Ventilation Procedure. The modification provides design flexibility and in some cases may reduce energy cost.																		

Related Mods: CEPI- 107-21	<p>C403.6 Requirements for mechanical systems serving multiple zones. Sections C403.6.1 through C403.6.9 shall apply to mechanical systems serving multiple zones .</p> <p>C403.6.1 Variable air volume and multiple-zone systems. Supply air systems serving multiple zones shall be variable air volume (VAV) systems that have zone controls configured to reduce the volume of air that is reheated, recooled or mixed in each zone to one of the following:</p> <ol style="list-style-type: none">1. Twenty Thirty percent of the zone design peak supply for systems with direct digital control (DDC) and 30 percent for other systems.2. Systems with DDC where all of the following apply:<ol style="list-style-type: none">2.1. The airflow rate in the deadband between heating and cooling does not exceed 20 percent of the zone design peak supply rate or higher the highest of the allowed rates under Items 3, 4, and 5 or 6 of this section.2.2. The first stage of heating modulates the zone supply air temperature setpoint up to a maximum setpoint while the airflow is maintained at the deadband flow rate.2.3. The second stage of heating modulates the airflow rate from the deadband flow rate up to the heating maximum flow rate that is less than 50 percent of the zone design peak supply rate.3. The outdoor airflow rate required to meet the minimum ventilation requirements of Chapter 4 of the International Mechanical Code .4. The minimum primary airflow rate required to meet the Simplified Procedure ventilation requirements of ASHRAE 62.1 for the zone and is permitted to be the average airflow rate as allowed by ASHRAE 62.1.4-5. Any higher rate that can be demonstrated to reduce overall system annual energy useby offsetting reheat/recool energy losses through a reduction in outdoor air intake for the system as <i>approved by the code official.</i>5. 6. The airflow rate required to comply with applicable codes or accreditation standards such as pressure relationships or minimum air change rates.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>NEEC</td><td>DC</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	NEEC	DC				X
Staff Classification	Correlates Directly	Energy Standard	Over lap															
	X																	
Action	AS	NEEC	DC															
			X															
CE#187	<p>Replaces referenced code Sections "C403.7.1 through C403.7.7" with "C403.7.1 through C403.7.9." Revised demand control ventilation (DCV) requirements. Modified the minimum floor area threshold for the DCV requirement by climate zones.</p> <p>Spaces served with heat recovery exemptions are now based on climate zone and floor area; the exception now applies to small floor areas only and is, hence, more restrictive. Increase the DCV stringency for climate zone 1A and 2A.</p>																	
Related Mods:	<p>Also, adds one new exception: ventilation system design professional engineers prevent the maximum limit of contaminant concentration from being higher than that obtainable by the required outdoor ventilation rate and maintain a ventilation threshold of 15% or higher.</p> <p>C403.7.1 Demand control ventilation. Demand control ventilation (DCV) shall be provided for all single-zone systems required to comply with Sections C403.5 through C403.5.3 and spaces larger than 500 square feet (46.5 m²) and with an average occupant load of 15 people or greater per 1,000 square feet (93 m²) of floor area, as established in Table 403.3.1.1 of the International Mechanical Code , and served by systems with one or more of the following:</p> <ol style="list-style-type: none">1. An air-side economizer. Spaces with ventilation provided by single-zone systems where an air-side economizer is provided in accordance with Section C403.5:<ol style="list-style-type: none">2. Spaces larger than 250 square feet (23 m²) in Climate Zones 5A, 6, 7, and 8 and spaces larger than 500 square feet (46.5 m²) in other climate zones that have a design occupant load of 15 people or greater per 1,000 square feet (93 m²) of floor area, as established in Table 403.3.1.1 of the International Mechanical Code , and are served by systems with one or more of the following:<ol style="list-style-type: none">2.1. An air-side economizer.2.2. Automatic modulating control of the outdoor air damper.2.3. A design outdoor airflow greater than 3,000 cfm (1416 L/s).2- Automatic modulating control of the outdoor air damper.3- A design outdoor airflow greater than 3,000 cfm (1416 L/s).Exceptions:<ol style="list-style-type: none">1. Systems Spaces served by systems with energy recovery in accordance with Section C403.7.4.2 and that have a floor area less than:<ol style="list-style-type: none">1.1. 6,000 square feet (557 m²) in Climate Zone 3C.1.2. 2,000 square feet (186 m²) in Climate Zones 1A, 3B and 4B.1.3. 1,000 square feet (93 m²) in Climate Zones 2A, 2B, 3A, 4A, 4C, 5 and 6.1.4. 400 square feet (37 m²) in Climate Zones 7 and 8.2. Multiple-zone systems without <i>direct digital control</i> of individual zones communicating with a central control panel.3. Spaces served by Multiple multiple-zone systems with a design outdoor airflow less than 750 cfm (354 L/s).4. Spaces where more than 75 percent of the space design outdoor airflow is required for makeup air that is exhausted from the space or transfer air that is required for makeup air that is exhausted from other spaces.5. Spaces with one of the following occupancy classifications as defined in Table 403.3.1.1 of the International Mechanical Code : correctional cells, education laboratories, barber, beauty and nail salons, and bowling alley seating areas.6. Spaces where the <i>registered design professional</i> demonstrates an engineered ventilation system design that:<ol style="list-style-type: none">6.1. Prevents the maximum concentration of contaminants from being more than that obtainable by the required rate of outdoor air ventilation .6.2. Allows the required minimum design rate of outdoor air to be reduced by not less than 15 percent.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>NEEC</td><td>DC</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	NEEC	DC				X
Staff Classification	Correlates Directly	Energy Standard	Over lap															
	X																	
Action	AS	NEEC	DC															
			X															
	<p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>																	
CE#188	<p>Renamed the title of Section C403.7.2, and revised the provision to comply with Section C404.1 of IMC. Also modified the exception to be based on the fan motor power instead of the ventilation flow rate.</p>																	

Related Mods: CECPI-6-21, CED1-166-22 FBC C403.2.6. 2	<p>C403.7.2 Enclosed parking-Parking garage ventilation controls. Enclosed parking garages used for storing or handling automobiles operating under their own power shall employ carbon monoxide detectors applied in conjunction with nitrogen dioxide detectors and automatic controls configured to stage fans or modulate fan average airflow rates to 50 percent or less of design capacity, or intermittently operate fans less than 20 percent of the occupied time or as required to maintain acceptable contaminant levels in accordance with International Mechanical Code provisions. Failure of contamination-sensing devices shall cause the exhaust fans to operate continuously at design airflow. Ventilation systems employed in enclosed parking garages shall comply with Section 404.1 of the International Mechanical Code and the following:</p> <ol style="list-style-type: none"> 1. Separate ventilation systems and control systems shall be provided for each parking garage section. 2. Control systems for each parking garage section shall be capable of and configured to reduce fan airflow to not less than 0.05 cfm per square foot [0.00025 m³/(s × m²)] of the floor area served and not more than 20 percent of the design capacity. 3. The ventilation system for each parking garage section shall have controls and devices that result in fan motor demand of not more than 30 percent of design wattage at 50 percent of the design airflow. <p>Exceptions: Garage ventilation systems serving a single parking garage section having a total ventilation system motor nameplate horsepower (ventilation system motor nameplate kilowatt) not exceeding 5 hp (3.7 kW) at fan system design conditions and where the parking garage section has no mechanical cooling or mechanical heating.</p> <ol style="list-style-type: none"> 1. Garages with a total exhaust capacity less than 8,000 cfm (3,755 L/s) with ventilation systems that do not utilize heating or mechanical cooling. 2. Garages that have a garage area to ventilation system motor nameplate power ratio that exceeds 1,125 cfm/hp (710 L/s/kW) and do not utilize heating or mechanical cooling. <p>Nothing in this section shall be construed to require more than one parking garage section</p>
---	--

in any parking structure.
FSEC – Anticipated energy impact on FBC-EC – Decrease

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	X		

Action	AS	AS/EC	D	D/EC
			X	

CE#189	<p>Adds new exception: "Units that heat the airstream using only series energy recovery when representative building loads or outdoor air temperature indicates that the majority of zones require cooling in Climate Zones 0A, 1A, 2A, 3A, and 4A."</p>
--------	--

Related Mods: CEPI-112-21	<p>C403.7.3 Ventilation air heating control. Units that provide ventilation air to multiple zones and operate in conjunction with zone heating and cooling systems shall not use heating or heat recovery to warm supply air to a temperature greater than 60°F (16°C) when representative building loads or outdoor air temperatures indicate that the majority of zones require cooling.</p> <p>Exception: Units that heat the airstream using only series energy recovery when representative building loads or outdoor air temperature indicates that the majority of zones require cooling in Climate Zones 0A, 1A, 2A, 3A and 4A.</p> <p>Original text is not consistent with that of the 2023 FBC – EC</p>
------------------------------	---

CE#190	<p>Revised the subsection to include sensible recovery efficiency (SRE) and net moisture transfer (NMT) requirements as an alternative to enthalpy recovery ratio requirement. Revises two existing exceptions. Exception item #4 only applies to climate zones 5 through 8. Exception item #7 only applies to climate zones 0 through 4 and has a minimum SERR value of 0.4.</p>
--------	---

Related Mods: CEPI-113-21, CED1-25-22, CED1-167-22	<p>C403.7.4 Energy recovery systems. Energy recovery ventilation systems shall be provided as specified in either Section C403.7.4.1 or C403.7.4.2, as applicable.</p> <p>C403.7.4.1 Nontransient dwelling units. Nontransient dwelling units shall be provided with outdoor air energy recovery ventilation systems complying with</p> <p>an enthalpy recovery ratio of not less than 50 percent at cooling design condition and not less than 60 percent at heating design condition one of the following:</p> <ol style="list-style-type: none"> 1. The system shall have an enthalpy recovery ratio of not less than 50 percent at cooling design condition and not less than 60 percent at heating design condition. 2. The system shall have a sensible recovery efficiency (SRE) that is not less than 65 percent at 32°F (0°C) and in Climate Zones 0A, 1A, 2A and 3A shall have a net moisture transfer (NMT) that is not less than 40 percent at 95°F (35°C). SRE and NMT shall be determined from a listed value or from interpolation of listed values at an airflow not less than the design airflow, based on testing in accordance with CAN/CSA C439. <p>Exceptions:</p> <ol style="list-style-type: none"> 1. Nontransient dwelling units in Climate Zone 3C. 2. Nontransient dwelling units with not more than 500 square feet (46 m²) of conditioned floor area in Climate Zones 0, 1, 2, 3, 4C and 5C. 3. Enthalpy recovery ratio requirements at heating design condition in Climate Zones 0, 1 and 2. 4. Enthalpy recovery ratio requirements at cooling design condition in Climate Zones 4, 5, 6, 7 and 8.
---	---

Staff Classification		Correlates Directly	Energy Standard Needed	Overlap
				X
Action	AS	AS/IC	D	D/IC
			X	

Original text is not consistent with that of the 2023 FBC – EC

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap	
			X	

Action	AS	AS/IC	D	D/IC
			X	

CE#191	<p>Revises two existing exceptions. Exception item #4 only applies to climate zones 5 through 8. Exception item #7 only applies to climate zones 0 through 4 and has a minimum SERR value of 0.4.</p>
--------	---

Related Mods: CEPI-116-21	<p>C403.7.4.2 Spaces other than nontransient dwelling units. Where the supply airflow rate of a fan system serving a space other than a nontransient dwelling unit exceeds the values specified in Tables C403.7.4.2(1) and C403.7.4.2(2), the system shall include an energy recovery system. The energy recovery system shall provide an enthalpy recovery ratio of not less than 50 percent at design conditions. Where an <i>air economizer</i> is required, the energy recovery system shall include a bypass or controls that permit operation of the economizer as required by Section C403.5.</p> <p>Exception: An energy recovery ventilation system shall not be required in any of the following conditions:</p> <ol style="list-style-type: none"> 1. Where energy recovery systems are prohibited by the International Mechanical Code. 2. Laboratory fume hood systems that include not fewer than one of the following features: <ol style="list-style-type: none"> 2.1. Variable-air-volume hood exhaust and room supply systems configured to reduce exhaust and makeup air volume to 50 percent or less of design values. 2.2. Direct makeup (auxiliary) air supply equal to or greater than 75 percent of the exhaust rate, heated not warmer than 2°F (1.1°C) above room setpoint, cooled to not cooler than 3°F (1.7°C) below room setpoint, with no humidification added, and no simultaneous heating and cooling used for
------------------------------	--

	<div>3. Systems serving spaces that are heated to less than 60°F (15.5°C) and that are not cooled.</div> <div>4. Heating energy recovery where more than 60 percent of the outdoor heating energy is provided from site-recovered or site solar energy in Climate Zones 5 through 8.</div> <div>5. Enthalpy recovery ratio requirements at heating design condition in Climate Zones 0, 1 and 2.</div> <div>6. Enthalpy recovery ratio requirements at cooling design condition in Climate Zones 3C, 4C, 5B, 5C, 6B, 7 and 8.</div> <div>7. Systems in Climate Zones 0 through 4 requiring dehumidification that employ series energy recovery in series with the cooling coil and have a minimum SERA of 0.40.</div> <div>8. Where the largest source of air exhausted at a single location at the building exterior is less than 75 percent of the design outdoor air flow rate.</div> <div>9. Systems expected to operate less than 20 hours per week at the outdoor air percentage covered by Table C403.7.4.2(1).</div>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			X																
Action	AS	AS/EC	D																
			X																
11.	Commercial kitchen hoods used for collecting and removing grease vapors and smoke	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			X																
Action	AS	AS/EC	D																
			X																
	Original text is not consistent with that of the 2023 FBC – EC																		
CE#192	Clarifies the provision to require demand control ventilation (DCKV) for Kitchen exhaust hood systems serving Type I only. Revised an existing exception and added a new exception, "An energy recovery ventilation system installed on the kitchen exhaust with a sensible heat recovery effectiveness of ≥ 40 percent on not less than 50 percent of the total exhaust hood airflow." No change in stringency.																		
Related Mods: CEPI-9- 21 FBC – C403.2.8	<p>C403.7.5 Kitchen exhaust systems. Replacement air introduced directly into the exhaust hood cavity shall not be greater than 10 percent of the hood exhaust airflow rate. Conditioned supply air delivered to any space shall not exceed the greater of the following:</p> <ol style="list-style-type: none">The ventilation rate required to meet the space heating or cooling load.The hood exhaust flow minus the available transfer air from adjacent space where available transfer air is considered to be that portion of outdoor ventilation air not required to satisfy other exhaust needs, such as restrooms, and not required to maintain pressurization of adjacent spaces. <p>Kitchen exhaust hood systems serving Type I exhaust hoods shall be provided with demand control kitchen ventilation (DCKV) controls where a kitchen or kitchen/dining facility has a total Type I kitchen hood exhaust airflow rate greater than 5,000 cubic feet per minute (2360 L/s). DCKV systems shall be configured to provide a minimum of 50 percent reduction in exhaust and replacement air system airflow rates. Systems shall include controls necessary to modulate exhaust and replacement air system airflows in response to appliance operation and to maintain full capture and containment of smoke, effluent and combustion products during cooking and idle operation. Each hood shall be a factory-built commercial exhaust hood listed by a nationally recognized testing laboratory and shall have a maximum exhaust rate as specified in Table C403.7.5.</p> <p>Where total kitchen hood exhaust airflow rate is greater than 5,000 cfm (2360 L/s), each hood shall be a factory-built commercial exhaust hood listed by a nationally recognized testing laboratory in compliance with UL-710. Each hood shall have a maximum exhaust rate as specified in Table C403.7.5 and shall comply with one of the following:</p> <ol style="list-style-type: none">Not less than 50 percent of all replacement air shall be transfer air that would otherwise be exhausted.Demand ventilation systems on not less than 75 percent of the exhaust air that are configured to provide not less than a 50-percent reduction in exhaust and replacement air system airflow rates, including controls necessary to modulate airflow in response to appliance operation and to maintain full capture and containment of smoke, effluent and combustion products during cooking and idle.Listed energy recovery devices with a sensible heat recovery effectiveness of not less than 40 percent on not less than 50 percent of the total exhaust airflow. <p>Where a single hood, or hood section, is installed over appliances with different duty ratings, the maximum allowable flow rate for the hood or hood section shall be based on the requirements for the highest appliance duty rating under the hood or hood section.</p>																		
	<div>Exceptions:</div> <div>1.</div> <div>Where not less than 75 percent of all the replacement air is transfer air that would otherwise be exhausted, UL-710-listed exhaust hoods that have a design maximum exhaust flow rate not greater than 250 cubic feet per minute (118 L/s) per linear foot (305 mm) of hood that serve kitchen or kitchen/dining facilities with a total kitchen hood exhaust airflow rate less than 5,000 cfm (2360 L/s).</div> <div>2. Where allowed by the International Mechanical Code, an energy recovery ventilation system is installed on the kitchen exhaust with a sensible heat recovery effectiveness of not less than 40 percent on not less than 50 percent of the total exhaust hood airflow.</div>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			X																
Action	AS	AS/EC	D																
			X																
CE#193	Deletes the text "Card key controls comply with these requirements."																		
Related Mods: CEPI- 118-21 FBC C403.2.4.3	<p>C403.7.6 Automatic control of HVAC systems serving guestrooms. In Group R-1 buildings containing more than 50 guestrooms, each guestroom shall be provided with controls complying with the provisions of Sections C403.7.6.1 and C403.7.6.2. Card key controls comply with these requirements.</p>		<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D				X
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			X																
Action	AS	AS/EC	D																
			X																
	Original text is not consistent with that of the 2023 FBC – EC																		
CE#194	Made editorial changes by adding the texts "elevator", "or by thermostatic control systems", and deleting the text "or" for clarity.																		
Related Mods: CEPI- 118-21 FBC C403.2.4.3	<p>C403.7.7 Shutoff dampers. Outdoor air intake and exhaust openings and stairway and shaft vents shall be provided with Class I motorized dampers. The dampers shall have an air leakage rate not greater than 4 cfm/ft² (20.3 L/s × m²) of damper surface area at 1.0 inch water gauge (249 Pa) and shall be labeled by an approved agency when tested in accordance with AMCA 500D for such purpose.</p> <p>Outdoor air intake and exhaust dampers shall be installed with automatic controls configured to close when the systems or spaces served are not in use or during unoccupied period warm-up and setback operation, unless the systems served require outdoor or exhaust air in accordance with the International Mechanical Code or the dampers are opened to provide intentional economizer cooling.</p> <p>Stairway and elevator shaft vent dampers shall be installed with automatic controls configured to open upon the activation of any fire alarm initiating device of the building's fire alarm system, or the interruption of power to the damper, or by thermostatic control systems.</p>		<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D				X
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			X																
Action	AS	AS/EC	D																
			X																
			<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>X</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap				X	Action	AS	AS/EC	D				X
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
			X																
Action	AS	AS/EC	D																
			X																
CE#195	Adds a new Section C403.7.8. Occupied standby controls are required in the following space types: postsecondary classrooms, lecture rooms, and training rooms; Conference/meeting/multipurpose rooms; Lounges/breakrooms; Enclosed offices; Open-plan office areas; and Corridors. The change incurs minimal or no construction cost increase while reduces lighting and fan power energy. This change is cost-effective and already included in the 2022 ASHRAE 90.1 code. Adds new subsection C403.7.8.1. Adds new subsection C403.7.8.1.1.																		
Related																			

<div>Mods:</div> <div>CEPI- 108-21, CED1- 168-22, CE2D-24- 23</div>	<div>C403.7.8 Occupied standby controls. The following spaces shall be equipped with occupied standby controls in accordance with Section C403.7.8.1 for each ventilation zone:</div> <div><div><div>1. Postsecondary classrooms, lecture rooms and training rooms.</div><div>2. Conference/meeting/multipurpose rooms.</div><div>3. Lounges/breakrooms.</div><div>4. Enclosed offices.</div><div>5. Open-plan office areas.</div><div>6. Corridors.</div></div></div> <div>Exception: Zones that are part of a multiple-zone system without automatic zone flow control dampers.</div> <div>C403.7.8.1 Occupied-standby zone controls. Within 5 minutes of all spaces in that zone entering occupied-standby mode , the zone control shall operate as follows:</div> <div><div><div>1. The active heating setpoint shall be set back by not less than 1°F (0.55°C).</div><div>2. The active cooling setpoint shall be set up by not less than 1°F (0.55°C).</div><div>3. All airflow supplied to the zone shall be shut off whenever the space temperature is between the active heating and cooling setpoints.</div><div>4. Multiple-zone systems shall comply with Section C403.7.8.1.1.</div></div></div> <div>C403.7.8.1.1 Multiple-zone system controls. Multiple-zone systems required to automatically reset the effective minimum outdoor air setpoint, per Section C403.6.6, shall reset the effective minimum outdoor air setpoint based on a zone outdoor air requirement of zero for all zones in occupied-standby mode . Sequences of operation for system outside air reset shall comply with an approved method.</div>																
	<div>FSEC – Anticipated energy impact on FBC-EC – Decrease</div> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	EC				x
Staff Classification	Correlates Directly	Energy Standard	Over lap														
	x																
Action	AS	AS/EC	EC														
			x														
CE#196	Adds a new Section C403.7.9. This change prohibits integrated central fan system design for ventilation air delivery.																
Related Mods: CEPI- 120-21	<div>C403.7.9 Dwelling unit ventilation system. A fan that is the air mover for a heating or cooling system that serves an individual dwelling unit shall not be used to provide outdoor air.</div> <div>Exception: Where the fan efficacy is not less than 1.2 cubic feet per minute (0.56 L/s) of outdoor airflow per watt when there is no demand for heating or cooling.</div> <div>FSEC – Anticipated energy impact on FBC-EC – Decrease</div> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	EC				x
Staff Classification	Correlates Directly	Energy Standard	Over lap														
	x																
Action	AS	AS/EC	EC														
			x														
CE#197	Editorial changes for clarification.																
Related Mods: CEPI- 119-21, CECD1- 17-22	<div>C403.8 Fans and fan controls. Fans in HVAC systems shall comply with Sections C403.8.1 through C403.8.6.1.</div> <div>C403.8.1 Allowable fan horsepower.</div> <div>Each HVAC system having a total Where the summed fan system motor nameplate horsepower on an HVAC fan system is greater than exceeding 5 hp (3.7 kW) at fan system design conditions , it shall not exceed be greater than the allowable total fan system motor nameplate hp (Option 1) or fan system bhp (Option 2), shown as specified in Table C403.8.1(1) : Such summed HVAC fan system motor nameplate horsepower shall include This includes supply fans, exhaust fans, return / or relief fans, and fan-powered terminal units associated with systems providing heating or cooling capability. Single-zone variable air volume systems shall comply with the constant volume fan power limitation.</div> <div>Exceptions:</div> <div><div><div>1. Hospital, vivarium and laboratory systems that utilize flow control devices on exhaust or return to maintain space pressure relationships necessary for occupant health and safety or environmental control shall be permitted to use variable volume fan power limitation.</div><div>2. Individual exhaust fans with motor nameplate horsepower of 1 hp (0.746 kW) or less are exempt from the allowable fan horsepower requirement.</div></div></div>																
	<div>Original text is not consistent with that of the 2023 FBC – EC</div> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td></td><td>Revised</td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap			Revised		Action	AS	AS/EC	EC				x
Staff Classification	Correlates Directly	Energy Standard	Over lap														
		Revised															
Action	AS	AS/EC	EC														
			x														
CE#198	Editorial changes for clarification.																
Related Mods: FBC C403.2.1 2.4	<div>C403.8.4 Fractional hp fan motors. Motors for fans that are not less than 1/10 hp (0.062 kW) and are less than 1 hp (0.746 kW) shall be electronically commutated motors or shall have a minimum motor efficiency of 70 percent, rated in accordance with DOE 10 CFR 431. These motors shall have the means to adjust motor speed for either balancing or remote control. The use of belt-driven fans to sheave adjustments for airflow balancing instead of a varying motorspeed shall be permitted.</div>																
	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td>x</td><td>Revised</td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x	Revised		Action	AS	AS/EC	EC		x		
Staff Classification	Correlates Directly	Energy Standard	Over lap														
	x	Revised															
Action	AS	AS/EC	EC														
	x																
CE#199	Revises Section C403.8.5 for clarity, adds three new exceptions that preempts the federal regulations and aligns the section with ASHRAE 90.1 and Energy Star requirements. No change in stringency.																
Related Mods: CEPI- 121-21 FBC C403.2.1 2.7	<div>C403.8.5 Low-capacity ventilation fans. Mechanical ventilation system fans with motors less than 1/10 hp (0.062 kW) in capacity shall meet the efficacy requirements of Table C403.8.5 at one or more rating points. Airflow shall be tested in accordance with the test procedure referenced in Table C403.8.5 and listed . The airflow shall be reported in the product listing or on the label. Fan efficacy shall be reported in the product listing or shall be derived from the input power and airflow values reported in the product listing or on the label. Fan efficacy for fully ducted HRV, ERV, balanced and in-line fans shall be determined at a static pressure not less than 0.2 inch w.c. (49.8 Pa). Fan efficacy for ducted range hoods, bathroom and utility room fans shall be determined at a static pressure not less than 0.1 inch w.c. (24.9 Pa).</div> <div>Exceptions:</div> <div><div><div>1. Where ventilation fans are a component of a listed heating or cooling appliance.</div><div>2. Dryer exhaust duct power ventilators, domestic range hoods and domestic range booster fans that operate intermittently.</div><div>3. Fans in radon mitigation systems.</div><div>4. Fans not covered within the scope of the test methods referenced in Table C403.8.5.</div><div>5. Ceiling fans regulated under 10 CFR 430, Appendix U.</div></div></div>																
	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td>x</td><td>Revised</td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x	Revised		Action	AS	AS/EC	EC				x
Staff Classification	Correlates Directly	Energy Standard	Over lap														
	x	Revised															
Action	AS	AS/EC	EC														
			x														

CE#200	Updates Table C403.8.5 by adding test procedure by system type. Adds new system type category and edits the footnote.																												
Related Mods: CEPI- 121-21	TABLE C403.8.5 LOW-CAPACITY VENTILATION FAN																												
	<table><thead><tr><th>SYS TEM TYP E</th><th>AIRFLOW RATE (CFM)</th><th>MINIMUM EFFICACY (CFM/ WATT)</th><th>TEST PROCEDURE</th></tr></thead><tbody><tr><td>Balanced ventilation system without heat or energy recovery</td><td>Any</td><td>1.2^a</td><td>ASHRAE Standard 51 (ANSI/AMCA Standard 210)</td></tr><tr><td>HRV, ERV</td><td>Any</td><td>1.2</td><td>CAN/CSA 439</td></tr><tr><td>Range hood</td><td>Any</td><td>2.8</td><td rowspan="5">ASHRAE 51 (ANSI/AMCA Standard 210)</td></tr><tr><td>In-line supply or exhaust fan</td><td>Any</td><td>3.8</td></tr><tr><td rowspan="3">Other exhaust fan</td><td>≤ 90</td><td>2.8</td></tr><tr><td>≥ 90 and < 200</td><td>3.5</td></tr><tr><td>≥ 200</td><td>4.0</td></tr></tbody></table>	SYS TEM TYP E	AIRFLOW RATE (CFM)	MINIMUM EFFICACY (CFM/ WATT)	TEST PROCEDURE	Balanced ventilation system without heat or energy recovery	Any	1.2 ^a	ASHRAE Standard 51 (ANSI/AMCA Standard 210)	HRV, ERV	Any	1.2	CAN/CSA 439	Range hood	Any	2.8	ASHRAE 51 (ANSI/AMCA Standard 210)	In-line supply or exhaust fan	Any	3.8	Other exhaust fan	≤ 90	2.8	≥ 90 and < 200	3.5	≥ 200	4.0		
SYS TEM TYP E	AIRFLOW RATE (CFM)	MINIMUM EFFICACY (CFM/ WATT)	TEST PROCEDURE																										
Balanced ventilation system without heat or energy recovery	Any	1.2 ^a	ASHRAE Standard 51 (ANSI/AMCA Standard 210)																										
HRV, ERV	Any	1.2	CAN/CSA 439																										
Range hood	Any	2.8	ASHRAE 51 (ANSI/AMCA Standard 210)																										
In-line supply or exhaust fan	Any	3.8																											
Other exhaust fan	≤ 90	2.8																											
	≥ 90 and < 200	3.5																											
	≥ 200	4.0																											
	For SI: 1 cfm/ft = 0.47 L/s. a. For balanced systems, HRVs and ERVs, determine the efficacy as the outdoor airflow divided by the total fan power.																												
	<table><thead><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td></tr></tbody></table> <table><thead><tr><th>Action</th><th>AS</th><th>AS/AC</th><th>D</th><th>D/AC</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td><td></td></tr></tbody></table>			Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	AS/AC	D	D/AC		X											
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																										
	X																												
Action	AS	AS/AC	D	D/AC																									
	X																												
CE#201	Adds new Section C403.8.6.2. This change make increase construction cost but reduce energy cost by reducing the fan runtime and avoid increasing the infiltration of outside air.																												
Related Mods: CEPI- 123-21	C403.8.6.2 Intermittent exhaust control for bathrooms and toilet rooms. Where an exhaust system serving a bathroom or toilet room is designed for intermittent operation, the exhaust system shall be provided with <i>manual</i> on capability and one or more of the following controls: 1. A timer control that has a minimum setpoint not greater than 30 minutes. 2. An <i>occupant sensor control</i> that automatically turns off exhaust fans within 30 minutes after all occupants have left the space. 3. A humidity control capable of <i>manual</i> or <i>automatic</i> adjustment from a minimum setpoint not greater than 50 percent to a maximum setpoint not greater than 80 percent relative humidity. 4. A contaminant control that responds to a particle or gaseous concentration. Exception: Bathroom and toilet room exhaust systems serving as an integral component of an outdoor air ventilation system in Group R-2, R-3 and R-4 occupancies shall not be required to provide controls other than <i>manual</i> on capability. An off setpoint shall not be used to comply with a minimum setpoint requirement.																												
	<table><thead><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td></tr></tbody></table> <table><thead><tr><th>Action</th><th>AS</th><th>AS/AC</th><th>D</th><th>D/AC</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td><td></td></tr></tbody></table>			Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	AS/AC	D	D/AC		X											
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																										
	X																												
Action	AS	AS/AC	D	D/AC																									
	X																												
CE#202	Revised Section C403.9. Adds minimum efficiency requirement based on current technology in the market. The change has no impact on the construction cost. Adds new subsection C403.9.1.																												
Related Mods: CEPI- 124-21	C403.9 Large-diameter ceiling fans. Where provided, <i>large-diameter ceiling fans</i> shall be tested and <i>labeled</i> in accordance with AMCA 230 and shall meet the efficiency requirements of Table C403.9 and Section C403.9.1 . C403.9.1 Ceiling Fan Energy Index (CFEI). The Ceiling Fan Energy Index shall be calculated as the ratio of the electric input power of a reference <i>large-diameter ceiling fan</i> to the electric input power of the actual <i>large-diameter ceiling fan</i> as calculated in accordance with AMCA 208 with the following modifications to the calculations for the reference fan: using an airflow constant (Q) of 26,500 cfm (12.5 m ³ /s), a pressure constant (P) of 0.0027 inch of water (0.6719 Pa), and fan efficiency constant (η) of 42 percent.																												
	<table><thead><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td></tr></tbody></table> <table><thead><tr><th>Action</th><th>AS</th><th>AS/AC</th><th>D</th><th>D/AC</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td><td></td></tr></tbody></table>			Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	AS/AC	D	D/AC		X											
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																										
	X																												
Action	AS	AS/AC	D	D/AC																									
	X																												
CE#203	Adds new Table C403.9.																												
Related Mods: CEPI- 124-21	TABLE C403.9 CEILING FAN EFFICIENCY REQUIREMENTS ^a																												
	<table><thead><tr><th>EQUIPME</th><th>MINIMUM EFFICIENCY^{a, c}</th><th>TEST PROCEDURE</th></tr></thead><tbody><tr><td>Large-diameter ceiling fan for applications outside the US^c</td><td>CFEI ≥ 1.00 at high (maximum) speed CFEI ≥ 1.31 at 40% of high speed or the nearest speed that is not less than 40% of high speed</td><td>10 CFR 430, Appendix U or AMCA 230 and AMCA 208 (for FCI calculations)</td></tr><tr><td>Large-diameter ceiling fan</td><td>CFEI ≥ 1.00 at high (maximum) speed; and CFEI ≥ 1.31 at 40% of high speed or the nearest speed that is not less than 40% of high speed</td><td>10 CFR 430, Appendix U</td></tr></tbody></table>	EQUIPME	MINIMUM EFFICIENCY ^{a, c}	TEST PROCEDURE	Large-diameter ceiling fan for applications outside the US ^c	CFEI ≥ 1.00 at high (maximum) speed CFEI ≥ 1.31 at 40% of high speed or the nearest speed that is not less than 40% of high speed	10 CFR 430, Appendix U or AMCA 230 and AMCA 208 (for FCI calculations)	Large-diameter ceiling fan	CFEI ≥ 1.00 at high (maximum) speed; and CFEI ≥ 1.31 at 40% of high speed or the nearest speed that is not less than 40% of high speed	10 CFR 430, Appendix U																			
EQUIPME	MINIMUM EFFICIENCY ^{a, c}	TEST PROCEDURE																											
Large-diameter ceiling fan for applications outside the US ^c	CFEI ≥ 1.00 at high (maximum) speed CFEI ≥ 1.31 at 40% of high speed or the nearest speed that is not less than 40% of high speed	10 CFR 430, Appendix U or AMCA 230 and AMCA 208 (for FCI calculations)																											
Large-diameter ceiling fan	CFEI ≥ 1.00 at high (maximum) speed; and CFEI ≥ 1.31 at 40% of high speed or the nearest speed that is not less than 40% of high speed	10 CFR 430, Appendix U																											
	a. The minimum efficiency requirements at both high speed and 40% of maximum speed shall be met or exceeded to comply with this code. b. Ceiling fans are regulated as consumer products by 10 CFR 430. c. Chapter 6 contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure.																												
	<table><thead><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td></tr></tbody></table> <table><thead><tr><th>Action</th><th>AS</th><th>AS/AC</th><th>D</th><th>D/AC</th></tr></thead><tbody><tr><td></td><td>X</td><td></td><td></td><td></td></tr></tbody></table>			Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	AS/AC	D	D/AC		X											
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																										
	X																												
Action	AS	AS/AC	D	D/AC																									
	X																												
CE#204	Adds new Section C403.10. The changes require new construction condensing boiler to reach 90.0% efficiency levels. The changes increase the code stringency but is cost-effective. Adds new subsection C403.10.1. Adds new subsection C403.10.2.																												

Related Mods: CEPI-77- 21	<p>C403.10 Buildings with high-capacity space-heating gas boiler systems. Gas hot water boiler systems for space heating with system input capacities of not less than 1,000,000 Btu/h (293 kW) and not greater than 10,000,000 Btu/h (2931 kW) in new buildings shall comply with Sections C403.10.1 and C403.10.2.</p> <p>Exceptions:</p> <ol style="list-style-type: none">Where 25 percent of the annual space heating requirement is provided by <i>on-site renewable energy</i>, site-recovered energy or heat recovery chillers.Space heating boilers installed in individual <i>dwelling units</i>.Where 50 percent or more of the design heating load is served using perimeter convective heating, radiant ceiling panels or both.Individual gas boilers with input capacity less than 300,000 Btu/h (88 kW) shall not be included in the calculations of the total system input or total system efficiency. <p>C403.10.1 Boiler efficiency. Gas hot water boilers shall have a thermal efficiency (E_t) of not less than 90 percent when rated in accordance with the test procedures in Table C403.3.2(6). Systems with multiple boilers are allowed to meet this requirement where the space heating input provided by equipment with E_t above or below 90 percent provides an input capacity-weighted average E_t of not less than 90 percent. For boilers rated only for combustion efficiency, the calculation for the input capacity-weighted average E_t shall use the combustion efficiency value.</p> <p>C403.10.2 Hot water distribution system design. The hot water distribution system shall be designed to meet the following:</p> <ol style="list-style-type: none">Coils and other heat exchangers shall be selected so that at design conditions the hot water return temperature entering the boilers is 120°F (49°C) or less.																		
	<p>2. Under all operating conditions, the water temperature entering the boiler is not greater than 120°F (49°C) or the flow rate of supply hot water that recirculates directly into the return system, such as by three-way valves or minimum flow bypass controls, shall be not greater than 30 percent of the design flow of the boiler.</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th><th>DEC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		x			Action	AS	AS/EC	EC	DEC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
	x																		
Action	AS	AS/EC	EC	DEC															
			x																
CE#205	Renumbers Section C403.10. Renumbers C403.10.1 through C403.10.5.																		
Related Mods: FBC C403.4-3	<p>C403.10-C403.11 Heat rejection equipment. Heat rejection equipment, including air-cooled condensers, dry coolers, open-circuit cooling towers, closed-circuit cooling towers and evaporative condensers, shall comply with this section.</p> <p>Exception: Heat rejection devices where energy usage is included in the equipment efficiency ratings listed in Tables C403.3.2(6) and C403.3.2(7).</p> <p>C403.10.1-C403.11.4 Fan speed control. Each fan system powered by an individual motor or array of motors with connected power, including the motor service factor, totaling 5 hp (3.7 kW) or more shall have controls and devices configured to automatically modulate the fan speed to control the leaving fluid temperature or condensing temperature and pressure of the C403.10.2-C403.11.2 Multiple-cell heat rejection equipment. Multiple-cell heat rejection equipment with variable speed fan drives shall be controlled to operate the maximum number of fans allowed that comply with the manufacturer's requirements for all system components and so that all fans operate at the same fan speed required for the instantaneous cooling duty, as opposed to staged on and off operation. The minimum fan speed shall be the minimum allowable speed of the fan drive system in accordance with the manufacturer's recommendations.</p> <p>C403.10.3-C403.11.3 Limitation on centrifugal fan open-circuit cooling towers. Centrifugal fan open-circuit cooling towers with a combined rated capacity of ≥ 100 gpm (4164 L/m) or greater at 95°F (35°C) condenser water return, 85°F (29°C) condenser water supply, and 75°F (24°C) outdoor air wet-bulb temperature shall meet the energy efficiency requirement for axial fan open-circuit cooling towers listed in Table C403.3.2(7).</p> <p>C403.10.4-C403.11.4 Tower flow turnaround. Open-circuit cooling towers used on water-cooled chiller systems that are configured with multiple or variable speed condenser water pumps shall be designed so that all open-circuit cooling tower cells can be run in parallel with the larger of the flow that is produced by the smallest pump at its minimum expected flow rate.</p> <p>C403.10.5-C403.11.5 Heat recovery for service water heating. Original text of mod is not consistent with that of the FBC-EC.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th><th>DEC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	EC	DEC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
			x																
Action	AS	AS/EC	EC	DEC															
			x																
CE#206	Renumbers Section C403.10.6, revises the provision to clarify the heat recovery implementation, and updates exception item #1. This change neither impacts the stringency nor impacts the construction cost.																		
Related Mods: CED1- 13-22	<p>C403.10.6-C403.11.6 Heat recovery for space conditioning in health care facilities. Where heated water is used for space heating, a heat pump chiller meeting the requirements of Table C403.3.2(15) for condenser heat recovery system shall be installed provided that all of and that uses the cooling system return water as the heat source shall be installed where the following are true:</p> <ol style="list-style-type: none">The building is a Group I-2, Condition 2 occupancy.The total design chilled water capacity for the Group I-2, Condition 2 occupancy, either air cooled or water cooled, required at cooling design conditions exceeds 3,600,000 Btu/h (1100 kw) of cooling.Simultaneous heating, including reheat, and cooling occurs above 60°F (16°C) outdoor air temperature. <p>The required heat recovery system shall have a cooling capacity that is of not less than 7 percent of the total design chilled water capacity of the Group I-2, Condition 2 occupancy at peak design conditions.</p> <p>Exceptions:</p> <ol style="list-style-type: none">Buildings that provide 60 percent or more of their reheat energy from <i>on-site renewable energy</i> or other site-recovered energy. <i>On-site renewable energy</i> used to meet Section C405.15.1 or C406.3.1 shall not be used to meet this exception.Buildings in Climate Zones 5C, 6B, 7 and 8. <p>Original text of mod is not consistent with that of the FBC-EC.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th><th>DEC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	EC	DEC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																
			x																
Action	AS	AS/EC	EC	DEC															
			x																
CE#207	Renumbers Section C403.11. Renumbers Section C403.11.1. Renumbers Table C403.11.1. Renumbers Section C403.11.2. Renumbers Section C403.11.2.1.																		
Related Mods: CED1- 156-22 FBC C403.2.4	<p>C403.11-C403.12 Refrigeration equipment performance. Refrigeration equipment performance shall be determined in accordance with Sections C403.12.1 and C403.12.2 for commercial refrigerators, freezers, refrigerator-freezers, walk-in coolers, walk-in freezers and refrigeration equipment. The energy use shall be verified through certification under an approved certification program or, where a certification program does not exist, the energy use shall be supported by data furnished by the equipment manufacturer.</p> <p>Exception: Walk-in coolers and walk-in freezers regulated under federal law in accordance with Subpart R of DOE 10 CFR 431.</p> <p>C403.11.1-C403.12.1 Commercial refrigerators, refrigerator-freezers and refrigeration. Refrigeration equipment, defined in DOE 10 CFR Part 431.62, shall have an energy use in kWh/day not greater than the values of Table C403.12.1 when tested and rated in accordance with AHRI Standard 1200.</p> <p>TABLE C403.11.1-TABLE C403.12.1 MINIMUM EFFICIENCY REQUIREMENTS: COMMERCIAL REFRIGERATORS AND FREEZERS AND REFRIGERATION</p>																		

For SI: 1 square foot = 0.0929 m², 1 cubic foot = 0.02832 m³, °C = (°F – 32)/1.8.

a. The meaning of the letters in this column is indicated in the columns to the left.

b. Ice cream freezer is defined in **DOE 10 CFR 431.62** as a commercial freezer that is designed to operate at or below -5 °F and that the manufacturer designs, markets or intends for the storing, displaying or dispensing of ice cream.

c. Equipment class designations consist of a combination (in sequential order separated by periods (AAA).(BB).(C)) of the following:

• (AAA)—An equipment family code (VOP = vertical open, SVO = semi-vertical open, HZO = horizontal open, VCT = vertical closed transparent doors, VCS = vertical closed solid doors, HCT = horizontal closed transparent doors, HCS = horizontal closed solid doors, and SOC = service over counter);

• (BB)—An operating mode code (RC = remote condensing and SC = self-contained); and

• (C)—A rating temperature code (M = medium temperature (38°F), L = low temperature (0°F), or I = ice cream temperature (-15°F)).

• For example, "VOP.RC.M" refers to the "vertical open, remote condensing, medium temperature" equipment class.

d. V is the volume of the case (ft³) as measured in **AHRI 1200**, Appendix C.

e. TDA is the total display area of the case (ft²) as measured in **AHRI 1200**, Appendix D.

C403.11.2 C403.12.2 Walk-in coolers and walk-in freezers. Walk-in cooler and walk-in freezer refrigeration systems, except for walk-in process-cooling-refrigeration systems as defined in **DOE 10 CFR 431.302**, shall meet the requirements of **Tables C403.12.2.1(1), C403.12.2.1(2), and C403.12.2.1(3)**.

C403.11.2.1 C403.12.2.1 Performance standards. Walk-in coolers and walk-in freezers shall meet the requirements of **Tables C403.12.2.1(1), C403.12.2.1(2) and C403.12.2.1(3)**.

Staff Classification	Correlates Directly	Energy Standard	Over lap
	x		
Action	AS	AS/IC	SI
	x		SI/IC

CE#208 Renumbers Table C403.11.2.1(1). Renumbers Table C403.11.2.1(2).

Related Mods:
FBC -
C403.2.1.4

~~TABLE C403.11.2.1(1)~~ ~~TABLE C403.12.2.1(1)~~

WALK-IN COOLER AND FREEZER DISPLAY DOOR EFFICIENCY REQUIREMENTS^a

CLASS DESCRIPTOR	CLASS	MAXIMUM ENERGY CONSUMPTION (kWh/day) ^a	TEST PROCEDURE
Display door, medium temperature	DD, M	$0.04 \times A_{dd} + 0.41$	10 CFR 431
Display door, low temperature	DD, L	$0.10 \times A_{dd} + 0.29$	10 CFR 431

a. A_{dd} is the surface area of the display door.

~~TABLE C403.11.2.1(2)~~ ~~TABLE C403.12.2.1(2)~~

WALK-IN COOLER AND FREEZER NONDISPLAY DOOR EFFICIENCY REQUIREMENTS^a

a. A_{nd} is the surface area of the nondisplay door.

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		
Action	AS	AS/IC	SI
	x		SI/IC

CE#209 Adds new Table C403.11.2.1(3).

Related Mods:
CED1-156-22
FBC
C403.2.1.4

~~TABLE C403.12.2.1(3)~~

WALK-IN COOLER AND FREEZER REFRIGERATION SYSTEM EFFICIENCY REQUIREMENTS

CLASS DESCRIPTOR	CLASS	MINIMUM ANNUAL WALK-IN ENERGY FACTOR (AWEF) (Btu/W-h) ^a	TEST PROCEDURE
Dedicated condensing, medium temperature, indoor system	DC.M.I	5.61	
Dedicated condensing, medium temperature, outdoor system	DC.M.O	7.60	
Dedicated condensing, low temperature, indoor system, net ^{capacity (q_{net}) < 6,500 Btu/h}	DC.L.I < 6,500	$9.091 \times 10^{-5} \times q_{net} + 1.81$	
Dedicated condensing, low temperature, indoor system, net ^{capacity (q_{net}) ≥ 6,500 Btu/h}	DC.L.I ≥ 6,500	2.40	

CLASS DESCRIPTOR	CLASS	MAXIMUM ENERGY CONSUMPTION (kWh/day) ^a	TEST PROCEDURE
Passage door, medium temperature	PD, M	$0.05 \times A_{nd} + 1.7$	10 CFR 431
Passage door, low temperature	PD, L	$0.14 \times A_{nd} + 4.8$	10 CFR 431
Freight door, medium temperature	FD, M	$0.04 \times A_{nd} + 1.0$	10 CFR 431
Freight door, low temperature	FD, L	$0.12 \times A_{nd} + 5.6$	10 CFR 431

	Dedicated condensing, low temperature, outdoor system, net ^{capacity (q_{net}) < 6,500 Btu/h}	DC.L.O < 6,500	$6.522 \times 10^{-5} \times q_{net} + 2.73$	AHRI 1250
	Dedicated condensing, low temperature, outdoor system, net ^{capacity (q_{net}) ≥ 6,500 Btu/h}	DC.L.O ≥ 6,500	3.15	
	Unit cooler, medium	UC.M	9.00	
	Unit cooler, low temperature, net ^{capacity (q_{net}) < 15,500 Btu/h}	UC.L < 15,500	$1.575 \times 10^{-5} \times q_{net} + 3.91$	
	Unit cooler, low temperature, net ^{capacity (q_{net}) ≥ 15,500 Btu/h}	UC.L ≥ 15,500	4.15	

CE#210 Renumbers Section C403.11.3. Renumbers subsection C403.11.3.1. Renumbers subsection C403.11.3.2 and replaces referenced "Table C403.12.3" with "Table C403.13.3(1) or C403.13.3(2)."

Related Mods:
CEPI-79- 21

C403.11.3 C403.12.3 Refrigeration systems. Refrigerated display cases, walk-in coolers or walk-in freezers that are served by remote compressors and remote condensers not located in a condensing unit, shall comply with **Sections C403.12.3.2**.
Exception: Systems where the working fluid in the refrigeration cycle goes through both subcritical and super-critical states (transcritical) or that use ammonia refrigerant are exempt.

		≥200,000 Btu/h	≥4,000 Btu/h/gal and ≥10 gal	80% E_r ✗	ANSI Z2 1-10.3
Storage water heater s, oil	≤105,000 Btu/h	≥20 gal and ≤50 gal lans	0.68—0.0019V, EF	DOE-10 CFR Part 430	
	≥105,000 Btu/h	≤4,000 Btu/h/gal	80% E_r ✗	ANSI Z2 1-10.3	
Instantaneous water- heaters, oil	≤210,000 Btu/h	≥4,000 Btu/h/gal and ≤2 gal	0.69—0.0019V, EF	DOE-10 CFR Part 430	
	≥210,000 Btu/h	≥4,000 Btu/h/gal and ≤10 gal	80% E_r	ANSI Z2 1-10.3	
	≥210,000 Btu/h	≥4,000 Btu/h/gal and ≥10 gal	78% E_r ✗		
Hot water supply-boil ers, gas and oil	≥300,000 Btu/h and ≤12 ,500,000 Btu/h	≥4,000 Btu/h/gal and ≤10 gal	80% E_r	ANSI Z2 1-10.3	
Hot water supply-boil ers, gas	≥300,000 Btu/h and ≤12 ,500,000 Btu/h	≥4,000 Btu/h/gal and ≥10 gal	80% E_r ✗		
	Hot water supply-boil ers, oil	≥300,000 Btu/h and ≤12,500,000 Btu/h	≥4,000 Btu/h/gal and ≥10 gal	78% E_r ✗	
	Pool heaters, gas and oil	All	—	80% E_r	ASHRAE 146
	Heat pump pool heat ers	All	—	4.0 COP	AHRI 1160
	Unfi red- stor ana	All	—	Minimum insulation requirement R- 12.5 (h × ft ² × °F)/Btu	(none)

For SI: 1 foot = 304.8 mm; 1 square foot = 0.0929 m²; °C = [(°F) − 32]/1.8; 1 British thermal unit per hour = 0.2931 W; 1 gallon = 3.785 L; 1 British thermal unit per hour per gallon = 0.078 W/L.

a. Energy factor (EF) and thermal efficiency (Et) are minimum requirements. In the EF equation, V is the rated volume in gallons.

b. Standby loss (SL) is the maximum Btu/h based on a nominal 70°F temperature difference between stored water and ambient requirements.

In the SL equation, Q is the nameplate input rate in Btu/h. In the equations for electric water heaters, V is the rated volume in gallons and V_m is the measured volume in gallons. In the SL equation for oil and gas water heaters and boilers, V is the rated volume in gallons.

c. Instantaneous water heaters with input rates below 200,000 Btu/h shall comply with these requirements where the water heater is designed to heat water to temperatures 180°F or higher.

d. Electric water heaters with an input rating of 12 kW (40,950 Btu/h) or less that are designed to heat water to temperatures of 180°F or greater shall comply with the requirements for electric water heaters that have an input rating greater than 12 kW (40,950 Btu/h).

e. A tabletop water heater is a water heater that is enclosed in a rectangular cabinet with a flat top surface not more than 3 feet in height.

f. A grid-enabled water heater is an electric resistance water heater that meets all of the following:

- Has a rated storage tank volume of more than 75 gallons.
- Was manufactured on or after April 16, 2015.
- Is equipped at the point of manufacture with an activation lock.
- Bears a permanent label applied by the manufacturer that complies with all of the following, following:
 - Is made of material not adversely affected by water.
 - Is attached by means of nonwater-soluble adhesive.
 - Advises purchasers and end users of the intended and appropriate use of the product with the following notice printed in 16.5 point Arial Narrow Bold font: "IMPORTANT INFORMATION: This water heater is intended only for use as part of

TABLE C404.2
MINIMUM PERFORMANCE OF WATER-HEATING EQUIPMENT

TABLE C404.2
MINIMUM PERFORMANCE OF WATER-HEATING EQUIPMENT

EQUIPMENT TYPE	SIZE CATEGORY	SUBCATEGORY OR RATING CONDITION	DRAW PATTERN	PERFORMANCE REQUIRED ^a	TEST PROCEDURE ^b
Electric tabletop water heaters ^c	≤ 12 kW	≥ 20 gal ≤ 120 gal ^d	Very small Low Medium High	UEF ≥ 0.8323 − (0.0058 × V _r) UEF ≥ 0.9188 − (0.0031 × V _r) UEF ≥ 0.9577 − (0.0023 × V _r) UEF ≥ 0.9804 − (0.0016 × V _r)	DOE 10 CFR Part 430 App. E
Electric storage water heaters ^e resistance and heat pump	≤ 12 kW	≥ 20 gal ≤ 55 gal ^d	Very small Low Medium High	UEF ≥ 0.8808 − (0.0038 × V _r) UEF ≥ 0.9354 − (0.0033 × V _r) UEF ≥ 0.9307 − (0.0002 × V _r) UEF ≥ 0.9349 − (0.0001 × V _r)	DOE 10 CFR Part 430 App. E
	≤ 12 kW	> 55 gal ≤ 120 gal ^d	Very small Low Medium High	UEF ≥ 1.0238 − (0.0011 × V _r) UEF ≥ 2.0440 − (0.0011 × V _r) UEF ≥ 2.1171 − (0.0011 × V _r) UEF ≥ 2.2418 − (0.0011 × V _r)	DOE 10 CFR Part 430 App. E
Electric storage water heaters ^e	> 12 kW	—	—	(0.3 + 27/V _m ^{1/3}), %h	DOE 10 CFR 431.106
Grid-enabled water heaters ^f	—	> 75 gal ^d	Very small Low Medium High	UEF ≥ 1.0136 − (0.0028 × V _r) UEF ≥ 0.9984 − (0.0014 × V _r) UEF ≥ 0.9853 − (0.0010 × V _r) UEF ≥ 0.9720 − (0.0007 × V _r)	DOE 10 CFR 430 App. E
Electric instantaneous water heaters ^g	≤ 12 kW	< 2 gal ^d	Very small Low Medium High	UEF ≥ 0.91 UEF ≥ 0.91 UEF ≥ 0.91 UEF ≥ 0.92	DOE 10 CFR Part 430
	> 12 kW & ≤ 58.6 kW	≤ 2 gal & ≤ 180°F	All	UEF ≥ 0.80	DOE 10 CFR Part 430
Gas storage water heaters ^h	≤ 75,000 Btu/h	≥ 20 gal & ≤ 55 gal ^d	Very small Low Medium High	UEF ≥ 0.3458 − (0.0020 × V _r) UEF ≥ 0.5902 − (0.0019 × V _r) UEF ≥ 0.6483 − (0.0017 × V _r) UEF ≥ 0.6920 − (0.0013 × V _r)	DOE 10 CFR Part 430 App. E
	≤ 75,000 Btu/h	> 55 gal & ≤ 100 gal ^d	Very small Low Medium High	UEF ≥ 0.8470 − (0.0006 × V _r) UEF ≥ 0.7693 − (0.0005 × V _r) UEF ≥ 0.7897 − (0.0004 × V _r) UEF ≥ 0.8072 − (0.0003 × V _r)	DOE 10 CFR Part 430 App. E
	> 75,000 Btu/h and ≤ 105,000 Btu/h ⁱ	≤ 120 gal & ≤ 180°F	Very small Low Medium High	UEF ≥ 0.2674 − (0.0009 × V _r) UEF ≥ 0.3362 − (0.0012 × V _r) UEF ≥ 0.6002 − (0.0011 × V _r) UEF ≥ 0.6597 − (0.0009 × V _r)	DOE 10 CFR Part 430 App. E
	> 105,000 Btu/h ⁱ	—	—	80% E_r SL ≤ (Q/800 + 110√V), Btu/h	DOE 10 CFR 431.106

Gas instantaneous water heaters ^a	> 50,000 Btu/h and < 200,000 Btu/h ^a	< 2 gal ^b	Very small Low Medium High	$UEF \geq 0.80$ $UEF \geq 0.81$ $UEF \geq 0.81$ $UEF \geq 0.81$ $80\% E_t$	DOE 10 CFR Part 430 App. E
	$\geq 200,000$ Btu/h ^a	< 10 gal	—	$80\% E_t$	DOE 10 CFR 431.106
Oil storage water heaters ^{a, c}	$\leq 105,000$ Btu/h	≤ 50 gal ^b	Very small Low Medium High	$UEF = 0.2508 - (0.0012 \times V_r) UEF = 0.5330 - (0.0016 \times V_r) UEF = 0.6078 - (0.0016 \times V_r) UEF = 0.6815 - (0.0014 \times V_r)$	DOE 10 CFR Part 430
	> 105,000 Btu/h and $\leq 140,000$ Btu/h ^a	≤ 120 gal & $\leq 180^\circ\text{F}$	Very small Low Medium High	$UEF = 0.2932 - (0.0015 \times V_r) UEF = 0.5598 - (0.0018 \times V_r) UEF = 0.6194 - (0.0016 \times V_r) UEF = 0.6740 - (0.0013 \times V_r)$	DOE 10 CFR Part 430 App. E
	> 140,000 Btu/h	All	—	$80\% E_t$	DOE 10 CFR 431.106
				$SL \leq (Q/800 + 110\sqrt{V}), \text{ Btu/h}$	
Oil instantaneous water heaters ^a	$\leq 210,000$ Btu/h	< 2 gal	—	$80\% E_t$	DOE 10 CFR Part 430 App. E
	> 210,000 Btu/h	< 10 gal	—	$80\% E_t$	DOE 10 CFR 431.106
	> 210,000 Btu/h	≥ 10 gal	—	$78\% E_t$	DOE 10 CFR 431.106
				$SL \leq (Q/800 + 110\sqrt{V}), \text{ Btu/h}$	
Hot water supply boilers, gas and oil ^d	$\geq 300,000$ Btu/h and < 12,500,000 Btu/h	< 10 gal	—	$80\% E_t$	DOE 10 CFR 431.106
Hot water supply boilers, gas ^e	$\geq 300,000$ Btu/h and < 12,500,000 Btu/h	≥ 10 gal	—	$80\% E_t$	DOE 10 CFR 431.106
				$SL \leq (Q/800 + 110\sqrt{V}), \text{ Btu/h}$	
Hot water supply boilers, oil ^e	$\geq 300,000$ Btu/h and < 12,500,000 Btu/h	≥ 10 gal	—	$78\% E_t$	DOE 10 CFR 431.106
				$SL \leq (Q/800 + 110\sqrt{V}), \text{ Btu/h}$	
Pool heaters, gas ^f	All	— ^g	—	$82\% E_t$	DOE 10 CFR Part 430 App. P
Heat pump pool heaters	All	50°F db and 44.2°F wb outdoor air 80.0°F entering water	—	4.0 COP	DOE 10 CFR Part 430 App. P
Unfired storage tanks	All	—	—	Minimum insulation requirement R-12.5 (h × ft × °F)/Btu	(non e)

For SI: 1 foot = 304.8 mm, 1 square foot = 0.0929 m², °C = (°F – 32)/1.8, 1 British thermal unit per hour = 0.2931 W, 1 gallon = 3.785 L, 1 British thermal unit per hour per gallon = 0.078 W/L.

a. Thermal efficiency (E_t) is a minimum requirement, while standby loss is a maximum requirement. In the standby loss equation, V is the rated volume in gallons and Q is the nameplate input rate in Btu/h. V_m is the measured volume in the tank in gallons. Standby loss for electric water heaters is in terms of %/h and denoted by the term “S,” and standby loss for gas and oil water heaters is in terms of Btu/h and denoted by the term “SL.” Draw pattern (DP) refers to the water draw profile in the Uniform Energy Factor (UEF) test. UEF and Energy Factor (EF) are minimum requirements. In the UEF standard equations, V_r refers to the rated volume in gallons.

b. Chapter 6 contains a complete specification, including the year version, of the referenced test procedure.

c. A tabletop water heater is a storage water heater that is enclosed in a rectangular cabinet with a flat top surface not more than 3 feet in height and has a ratio of input capacity (Btu/h) to tank volume (gal) < 4,000.

d. Water heaters or gas pool heaters in this category are regulated as consumer products by the US DOE, as defined in 10 CFR 430.

e. Storage water heaters have a ratio of input capacity (Btu/h) to tank volume (gal) < 4,000.

f. Efficiency requirements for electric storage water heaters ≤ 12 kW apply to both electric-resistance and heat pump water heaters. There are no minimum efficiency requirements for electric heat pump water heaters greater than 12 kW or for gas heat pump water heaters.

g. A grid-enabled water heater is an electric-resistance water heater that meets all of the following:

- Has a rated storage tank volume of more than 75 gallons.
- Is manufactured on or after April 16, 2015.
- Is equipped at the point of manufacture with an activation lock.
- Bears a permanent label applied by the manufacturer that complies with all of the following:
 - Is made of material not adversely affected by water.
 - Is attached by means of nonwater soluble adhesive.

4.3. Advises purchasers and end users of the intended and appropriate use of the product with the following notice printed in 16.5 point Arial Narrow Bold font: “IMPORTANT INFORMATION: This water heater is intended only for use as a part of an electric thermal storage or demand response program. It will not provide adequate hot water unless enrolled in such a program and activated by your utility company or another program operator. Confirm the availability of a program in your local area before purchasing or installing this product.”

h. Instantaneous water heaters and hot water supply boilers have an input capacity (Btu/h) divided by storage volume (gal) $\geq 4,000$ (Btu/h)/gal.

i. Electric instantaneous water heaters with input capacity >12 kW and ≤ 58.6 kW that (1) have a storage volume > 2 gallons, (2) are designed to provide outlet hot water at temperatures greater than 180°F, or (3) use three-phase power have no efficiency standard.

j. Gas storage water heaters with input capacity > 75,000 Btu/h and $\leq 105,000$ Btu/h must comply with the requirements for the > 105,000 Btu/h if the water heater (1) has a storage volume > 120 gallons, (2) is designed to provide outlet hot water at temperatures greater than 180°F, or (3) uses three-phase power.

k. Refer to Section C404.2.1 for additional requirements for gas storage and instantaneous water heaters and gas hot water supply boilers. Oil storage water heaters with input capacity > 105,000 Btu/h and $\leq 140,000$ Btu/h must comply with the requirements for the > 140,000 Btu/h if the water heater either (1) has a storage volume > 120 gallons, (2) is designed to provide outlet hot water at temperatures greater than 180°F, or (3) uses three-phase power.

l. Water heaters and hot water supply boilers with more than 140 gallons of storage capacity need not meet the standby loss requirement where: (1) the tank surface area is thermally insulated to R-12.5 or more, (2) there is no standing pilot light, and (3) for gas- or oil-fired storage water heaters, the heater is equipped with a fire damper or fan-assisted combustion.

Staff Classification	Correlates Directly	Energy Standard Needed	Other Info
	x		
Author	SL	SL-DC	SL-DC
	x		

CE#221 Revised the Section provision and the exceptions for clarity.

Related Mods: CEPI- 128-21, CECD1- 14-22	<div>C404.2.1 High-input service water-heating systems. Gas-fired water-heating equipment <i>water heaters</i> installed in new buildings shall be in compliance with this section. Where a singular piece of water-heating equipment serves the entire building and the where the <u>total input capacity provided by high-capacity gas-fired water heaters</u> rating of the equipment is is <u>4,000,000 Btu/h (233 kW) or greater</u>, such equipment shall have a thermal efficiency, E_t, of not less than 92 percent. Where multiple pieces of water-heating equipment serve the building, and the combined input rating of the water-heating equipment is is <u>4,000,000 Btu/h (233 kW) or greater</u>, the combined input capacity-weighted average thermal efficiency, $E_{t,w}$, shall be not less than 90 percent. shall comply with either or both of the following requirements:</div> <div><div><div>1. Where a singular piece of a high-capacity gas-fired water heater is installed, the water heater shall have a thermal efficiency, E_t, of not less than 92 percent.</div><div>2. Where multiple pieces of high-capacity gas-fired water heaters are connected to the same service water-heating system, the combined input capacity-weighted average thermal efficiency, $E_{t,w}$, shall be not less than 90 percent, and a minimum of 30 percent of the input to the high-capacity gas-fired water heaters in the service water-heating system shall have an E_t of not less than 92 percent.</div></div><div>Exceptions:</div><div><div>1. Where not less than 25 percent of the annual service water-heating requirement is provided by on-site renewable energy or site- <u>recovered energy</u>, the minimum thermal efficiency requirements of this section shall not apply. The input rating of water heaters installed in individual dwelling units shall not be required to be included in the total input rating of service water-heating equipment for a building.</div><div>2. The input rating of water heaters installed in individual dwelling units shall not be required to be included in the total input rating of service water-heating equipment for a building. The input rating of water heaters with an input rating of not greater than 105,000 Btu/h (30.8 kW) shall not be required to be included in the total input rating of service water-heating equipment for a building.</div><div>3. The input rating of water heaters with an input rating of not greater than 100,000 Btu/h (29.3 kW) shall not be required to be included in the total input rating of service water-heating equipment for a building. Where not less than 25 percent of the annual service water-heating requirement is provided by on-site renewable energy, or site-recovered energy, the minimum thermal efficiency requirements of this section shall not apply.</div></div><div>C405.15.1 or C406.3.1 shall not be used to meet this exception.</div></div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Modified</td><td>Overlap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/NC</td><td>DN</td></tr><tr><td></td><td></td><td>x</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Modified	Overlap		x			Action	AS	AS/NC	DN			x	
Staff Classification	Correlates Directly	Energy Standard Modified	Overlap														
	x																
Action	AS	AS/NC	DN														
		x															
CE#222	<div>This section renames the Section title, revises the code language for clarity, and adds an equation for insulation thickness update for alternate equivalent insulation material. It also revises the existing exceptions for tubular insulation and adds a new exception for piping not heated with fossil fuel or electricity.</div>																
Related Mods: CEPI- 130-21	<div>C404.</div> <div>Insulation of piping—Service water-heating system piping insulation. Piping from a water heater to the termination of the heated water fixture supply pipe shall be insulated in accordance with Table C403.13.3. On both the inlet and outlet piping of a storage water heater or heated water storage tank, the piping to a heat trap or the first 8 feet (2438 mm) of piping, whichever is less, shall be insulated. Piping that is heat traced shall be insulated in accordance with Table C403.13.3 or the heat trace manufacturer's instructions. Tubular pipe insulation shall be installed in accordance with the insulation manufacturer's instructions. Pipe insulation shall be continuous except where the piping passes through a framing member. The minimum insulation thickness requirements of this section shall not supersede any greater insulation thickness requirements necessary for the protection of piping from freezing temperatures or the protection of personnel against external surface temperatures on the insulation. Service water-heating system piping shall be surrounded by uncompressed insulation. The wall thickness of the insulation shall be not less than the thickness shown in Table C404.4.1. Where the insulation thermal conductivity is not within the range in the table, the following equation shall be used to calculate the minimum insulation thickness:</div> <div>Equation 4-8 $t_{alt} = t \times [(1 + t_{table}/t)k_{alt}/k_{upper} - 1]$ where: t_{alt} = Minimum insulation thickness of the alternate material (in) (mm). t = Actual outside radius of the pipe (in) (mm). t_{table} = Insulation thickness listed in this table for applicable fluid temperature and pipe size. k_{alt} = Thermal conductivity of the alternate material at mean rating temperature indicated for the applicable fluid temperature [Btu × in/h × ft² × °F] [W(m × °C)]. k_{upper} = The upper value of the thermal conductivity range listed in this table for the applicable fluid temperature [Btu × in/h × ft² × °F] [W(m × °C)].</div> <div>For nonmetallic piping thicker than Schedule 80 and having thermal resistance greater than that of steel pipe, reduced insulation thicknesses are permitted if documentation is provided showing that the pipe with the proposed insulation has no more heat transfer per foot (meter) than a steel pipe of the same size with the insulation thickness shown in the table.</div> <div>Exception: Tubular pipe insulation shall not be required on the following:</div> <div><div>1. The tubing from the connection at the termination of the fixture supply piping to a plumbing fixture or plumbing appliance. Factory-installed piping within water heaters and hot water storage tanks.</div><div>2. Valves, pumps, strainers and threaded unions in piping that is 1 inch (25 mm) or less in nominal diameter.</div><div>3. Piping that conveys hot water that has not been heated through the use of fossil fuels or electricity.</div><div>4. Piping from user-controlled shower and bath mixing valves to the water outlets.</div><div>5. Cold water piping of a demand-recirculation water system.</div><div>6. Tubing from a hot drinking water heating unit to the water outlet. Piping in existing buildings where alterations are made to existing service water-heating systems where there is insufficient space or access to meet the requirements.</div><div>7. Piping at locations where a vertical support of the piping is installed.</div><div>8. Piping surrounded by building insulation with a thermal resistance (R-value) of not less than R-3. Where piping passes through a framing member if it requires increasing the size of the framing member.</div></div> <div>Original text of mod is not consistent with that of the 2023 FBC-EC.</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Modified</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>AS/NC</td><td>DN</td></tr><tr><td></td><td></td><td>x</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Modified	Overlap				x	Action	AS	AS/NC	DN			x	
Staff Classification	Correlates Directly	Energy Standard Modified	Overlap														
			x														
Action	AS	AS/NC	DN														
		x															
CE#223	<div>Adds a new Section C404.4.1.</div>																
Related Mods: CEPI- 130-21	<div>C404.4.1 Installation requirements. The following piping shall be insulated per the requirements of this section:</div> <div><div>1. Recirculating system piping, including the supply and return piping.</div><div>2. The first 8 feet (2.4 m) of outlet piping from:<div><div>2.1. Storage water heaters.</div><div>2.2. Hot water storage tanks.</div></div></div><div>2.3. Any water heater and hot water supply boiler containing not less than 10 gallons (37.9 L) of water heated by a direct heat source, an indirect heat source, or both a direct heat source and an indirect heat source.</div><div>3. The first 8 feet (2.4 m) of branch piping connecting to recirculated, heat traced or impedance-heated piping.</div><div>4. The makeup water inlet piping between heat traps and the storage water heaters and the storage tanks they are serving, in a nonrecirculating service water heating storage system.</div><div>5. Hot water piping between multiple water heaters, between multiple hot water storage tanks, and between water heaters and hot water storage tanks.</div><div>6. Piping that is externally heated (such as heat trace or impedance heating).</div><div>7. For direct-buried service water heating system piping, reduction of these thicknesses by 1 1/2 inches (38.1 mm) shall be permitted (before thickness adjustment required in Section C404.4) but not to thicknesses less than 1 inch (25.4 mm).</div></div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Modified</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/NC</td><td>DN</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Modified	Overlap					Action	AS	AS/NC	DN		x		
Staff Classification	Correlates Directly	Energy Standard Modified	Overlap														
Action	AS	AS/NC	DN														
	x																
CE#224	<div>Adds a new Table C404.4.1 instead of referencing from a different section. The insulation efficiency levels did not change.</div>																
Related Mods: CEPI- 130-21	<div>TABLE C404.4.1 MINIMUM PIPING INSULATION THICKNESS FOR SERVICE WATER HEATING SYSTEMS^a</div> <div><table><tr><th>INSULATION THERMAL CONDUCTIVITY</th><th>NOMINAL PIPE OR TUBE SIZE (inches)</th></tr></table></div>	INSULATION THERMAL CONDUCTIVITY	NOMINAL PIPE OR TUBE SIZE (inches)														
INSULATION THERMAL CONDUCTIVITY	NOMINAL PIPE OR TUBE SIZE (inches)																

CECD1- 21-22, CECD1- 23-22, CED1-65- 22	<p>2.3.—For each control strategy, configuration and reconfiguration of performance parameters including: bright and dim setpoints, timeouts, dimming fade rates, sensor sensitivity adjustments, and wireless zoning configurations.</p> <p>Exceptions: Lighting controls are not required for the following:</p> <ol style="list-style-type: none">1. Areas designated as security or emergency areas that are required to be continuously lighted. <i>Spaces where an automatic shutoff could endanger occupant safety or security.</i>2. Interior exit stairways, interior exit ramps and exit passageways.3. Emergency egress lighting that is normally off. <i>Emergency lighting that is automatically off during normal operations.</i>4. Emergency lighting required by the <i>International Building Code</i> in exit access components that are not provided with fire alarm systems.5. Up to 0.02 watts per square foot (0.22 W/m²) of lighting in exit access components that are provided with fire alarm	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Required</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td>X</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Required	Over lap		X			Action	AS	AS/EC	D	D/EC		X			
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																	
	X																			
Action	AS	AS/EC	D	D/EC																
	X																			
CE#229	<p>This amendment adds four new space types to an existing space list requiring occupancy sensor lighting controls: a computer room, a data center, a medical supply room in a health care facility, a Laundry/washer area, and a telemedicine room in a health care facility. This change may increase the construction cost by expanding the occupancy sensor requirements to new space types but is a cost-effective measure. Replaces the text "warehouse" with "warehouse storage areas" for clarity.</p>																			
Related Mods: CECD1- 3-22, CE2D-39- 23. CECD1- 3-22	<p>C405.2.1 Occupant sensor controls. Occupant sensor controls shall be installed to control lights in the following space types:</p> <ol style="list-style-type: none">1. Classrooms/lecture/training rooms.2. <i>Computer room , datacenter.</i>2.3- Conference/meeting/multipurpose rooms.3.4- Copy/print rooms.4.5- Lounges/breakrooms.6. <i>Medical supply room in a health care facility.</i>6.7- Enclosed offices.8. <i>Laundry/washing area.</i>6.9- Open-plan office areas.7.10- Restrooms.8.14- Storage rooms.12. <i>Telemedicine room in a health care facility.</i>9.13- Locker rooms.10.14- Corridors.14.15- Warehouse storage areas.12.16- Other spaces 300 square feet (28 m²) or less that are enclosed by floor-to-ceiling height partitions.																			
	<p>Exception: Luminaires that are required to have specific application controls in accordance with Section C405.2.5.</p> <p>C405.2.1.1 Occupant sensor control function. Occupant sensor controls in warehouses warehouse storage areas shall comply with Section C405.2.1.2. Occupant sensor controls in open-plan office areas shall comply with Section C405.2.1.3. Occupant sensor controls in corridors shall comply with Section C405.2.1.4. Occupant sensor controls for all other spaces specified in Section C405.2.1 shall comply with the following:</p> <ol style="list-style-type: none">1. They shall automatically turn off lights within 20 minutes after all occupants have left the space.2. They shall be manual on or controlled to automatically turn on the lighting to not more than 50 percent power.3. They shall incorporate a manual control to allow occupants to turn off lights.	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Required</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Required	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																	
	X																			
Action	AS	AS/EC	D	D/EC																
			X																	
CE#230	<p>Deletes three exceptions and modifies an existing exception in Section C405.2 as a substitute. No change in the code stringency.</p>																			
Related Mods: CEPI- 152-21	<p>C405.2.2 Time-switch controls. Each area of the <i>building</i> that is not provided with <i>occupant sensor controls</i> complying with Section C405.2.1.1 shall be provided with <i>time-switch controls</i> complying with Section C405.2.2.1.</p> <p>Exceptions:</p> <ol style="list-style-type: none">1. Luminaires that are required to have specific application controls in accordance with Section C405.2.4.2. Spaces where patient care is directly provided.3. <i>Spaces where an automatic shutoff would endanger occupant safety or security.</i>4. <i>Lighting intended for continuous operation.</i>5. <i>Shop and laboratory classrooms.</i>	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Required</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td>X</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Required	Over lap		X			Action	AS	AS/EC	D	D/EC		X			
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																	
	X																			
Action	AS	AS/EC	D	D/EC																
	X																			
CE#231	<p>Replaces the text "Automatically" with " Programmed to automatically" for clarity.</p> <p>Adds a new requirement that says, "For spaces where schedules are not available, time switch controls are programmed to a schedule that turns off lights not less than 12 hours per day." Improves compliance enforcement when the schedule is not available but no impact on construction costs.</p>																			
Related Mods:	<p>C405.2.2.1 Time-switch control function. <i>Time-switch controls</i> shall comply with all of the following:</p> <ol style="list-style-type: none">1. Automatically Programmed to automatically turn off lights when the space is scheduled to be unoccupied.2. Have a minimum 7-day clock.3. Be capable of being set for seven different day types per week.4. Incorporate an automatic holiday "shutoff" feature, which turns off all controlled lighting loads for not fewer than 24 hours and then resumes normally scheduled operations.5. Have program backup capabilities, which prevent the loss of program and time settings for not fewer than 10 hours, if power is interrupted.6. Include an override switch that complies with the following:<ol style="list-style-type: none">6.1. The override switch shall be a <i>manual</i> control.6.2. The override switch, when initiated, shall permit the controlled lighting to remain on for not more than 2 hours.6.3. Any individual override switch shall control the lighting for an area not larger than 5,000 square feet (465 m²).7. For spaces where schedules are not available, <i>time switch controls</i> are programmed to a schedule that turns off lights not less than 12 hours per day.	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Required</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Required	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																	
	X																			
Action	AS	AS/EC	D	D/EC																
			X																	
CE#232	<p>Renames the Section title, revises the section code provision, lists space types where dimming controls are required for general lighting, and removes the existing exceptions but adds a new exception for special application lighting.</p>																			

Related Mods:	<p>C405.2.3 Light-reduction controls-Dimming controls. Where not provided with occupant sensor controls complying with Section C405.2.1.1, <i>general lighting</i> shall be provided with light-reduction controls complying with Section C405.2.3.1. Dimming controls complying with Section C405.2.3.1 are required for general lighting in the following space types:</p> <ol style="list-style-type: none">1. Classroom/lecture hall/training room.2. Conference/multipurpose/meeting room.3. In a dining area for bar/lounge or leisure, family dining.4. Laboratory.5. Lobby.6. Lounge/break room.7. Offices.8. Gymnasium/fitness center.9. Library reading room.10. In a health care facility for imaging rooms, exam rooms, nursery and nurses' station.11. Spaces not provided with occupant sensor controls complying with Section C405.2.1.1. <p>Exception: Luminaires controlled by special application controls complying with Section C405.2.5.</p> <p>Exceptions:</p> <ol style="list-style-type: none">1—Luminaires controlled by daylight responsive controls complying with Section C405.2.4.2—Luminaires controlled by special application controls complying with Section C405.2.5.																
	<p>3—Where provided with <i>manual</i> control, the following areas are not required to have light-reduction control:</p> <p>3.1—Spaces that have only one luminaire with a rated power of less than 60 watts.</p> <p>3.2—Spaces that use less than 0.45 watts per square foot (4.9 W/m²).</p> <p>3.3—Corridors, lobbies, electrical rooms and/or mechanical rooms:</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>DS</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	AS/EC	DS				X
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap														
	X																
Action	AS	AS/EC	DS														
			X														
CE#233	<p>Renames the Section title, revises the section code provision, and reduces the dimming limit to 10% of full power output from 20% for dimming controls and from 30% for switchable controls. Adds two new exceptions from manual dimming control requirements for spaces with high-end trim lighting controls.</p>																
Related Mods: CEPI- 156-21, CECD1- 4-22	<p>C405.2.3.1 Light-reduction-Dimming control function. Spaces required to have light-reduction controls dimming control shall have a be provided with manual control that allows the occupant to reduce the connected lighting load by not less than 50 percent in — a reasonably uniform illumination pattern with an intermediate step in addition to full-on or off, or with continuous dimming control, using one of the following or another <i>approved</i> method: controls that allow lights to be dimmed from full output to 10 percent of full power or lower with continuous dimming, as well as turning off lights. Manual control shall be provided within each room to dim lights.</p> <ol style="list-style-type: none">1—Continuous dimming of all luminaires from full output to less than 20 percent of full power.2—Switching all luminaires to a reduced output of not less than 30 percent and not more than 70 percent of full power.3—Switching alternate luminaires or alternate rows of luminaires to achieve a reduced output of not less than 30 percent and not more than 70 percent of full power. <p>Exceptions: Manual dimming control is not required in spaces where high-end trim lighting controls are provided that comply with the following:</p> <ol style="list-style-type: none">1. The calibration adjustment equipment is located for ready access only by authorized personnel.2. Lighting controls with ready access for users cannot increase the lighting power above the maximum level established by the high-end trim controls. <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>DS</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	AS/EC	DS				X
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap														
	X																
Action	AS	AS/EC	DS														
			X														
CE#234	<p>Reduces the interior lights connected to the load threshold for daylighting responsive controls. Primary sidelit area and toplit areas lighting connected load were reduced to 75W from 150W, and combined primary and secondary sidelit areas were reduced from 300 W to 150 W.</p> <p>Also revises exception item #3 and deletes equation 4-9 to simplify the compliance process.</p>																
Related Mods: CEPI- 161-21, 161-21,	<p>C405.2.4 Daylight-responsive controls. Daylight-responsive controls complying with Section C405.2.4.1 shall be provided to control the <i>general lighting</i> within daylight zones in the following spaces:</p>																
CEPI- 164-21	<ol style="list-style-type: none">1. Spaces with a total of more than 150 75 watts of general lighting within primary sidelit daylight zones complying with Section C405.2.4.2.2. Spaces with a total of more than 300 150 watts of general lighting within sidelit daylight zones complying with Section C405.2.4.2.3. Spaces with a total of more than 150 75 watts of general lighting within toplit daylight zones complying with Section C405.2.4.3. <p>Exceptions: Daylight responsive controls are not required for the following:</p> <ol style="list-style-type: none">1. Spaces in health care facilities where patient care is directly provided.2. Sidelit daylight zones on the first floor above grade in Group A-2 and Group M occupancies.3. <p>New buildings where the total connected lighting power calculated in accordance with Section C405.3.1 is not greater ^{than the adjusted interior lighting power allowance (AILA) calculated in accordance with Equation 4-9 (Equation 4-9)} office spaces less than 250 square feet (23.2 m²).</p> <p>where:</p> <p>$AILA_{adj}$ = Adjusted building interior lighting power allowance in watts.</p> <p>(Equation 4-9)</p> <p>$AILA_{adj}$ = Normal building lighting power allowance in watts calculated in accordance with Section C405.3.2 and reduced in accordance with Section C406.3 where Option 2 of Section C406.1 is used to comply with the requirements of Section C406.</p> <p>$UDZFA$ = Uncontrolled daylight-zone floor area is the sum of all sidelit and toplit zones, calculated in accordance with Sections C405.2.4.2 and C405.2.4.3, that do not have daylight-responsive controls.</p> <p>$TBFA$ = Total building floor area is the sum of all floor areas included in the lighting power allowance calculation in Section C405.3.2.</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Overlap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>DS</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap		X			Action	AS	AS/EC	DS				X
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap														
	X																
Action	AS	AS/EC	DS														
			X														
CE#235	<p>Replaces the text "sidelit daylight zone" with "primary sidelit daylight zone" in requirement items #1 and #2 for code clarity.</p> <p>Adds a clarifying text "Where the fenestration is located in a wall" for item #3 and removes the secondary sidelit daylighting zone calculation requirement.</p>																
Related Mods: CEPI- 167-21,	<p>C405.2.4.2 Sidelit daylight zone. The sidelit daylight zone is the floor area adjacent to vertical <i>fenestration</i> that complies with all of the following:</p> <ol style="list-style-type: none">1. Where the <i>fenestration</i> is located in a wall, the primary sidelit daylight zone shall extend laterally to the nearest full-height wall, or up to 1.0 times the height from the floor to the top of the <i>fenestration</i>, and longitudinally from the edge																

CEPI- 166-21	<p>of the <i>fenestration</i> to the nearest full-height wall, or up to 0.5 times the height from the floor to the top of the <i>fenestration</i> , whichever is less, as indicated in Figure C405.2.4.2(1).</p> <p>2. Where the <i>fenestration</i> is located in a <i>rooftop monitor</i> , the <i>primary</i> sidelit daylight zone shall extend laterally to the nearest obstruction that is taller than 0.7 times the ceiling height, or up to 1.0 times the height from the floor to the bottom of the <i>fenestration</i> , whichever is less, and longitudinally from the edge of the <i>fenestration</i> to the nearest obstruction that is taller than 0.7 times the ceiling height, or up to 0.25 times the height from the floor to the bottom of the <i>fenestration</i> , whichever is less, as indicated in Figures C405.2.4.2(2) and C405.2.4.2(3).</p> <p>3. Where the <i>fenestration</i> is located in a wall, the secondary sidelit daylight zone is directly adjacent to the primary sidelit daylight zone and shall extend laterally to 2.0 times the height from the floor to the top of the <i>fenestration</i> or to the nearest full height wall, whichever is less, and longitudinally from the edge of the <i>fenestration</i> to the nearest full height wall, or up to 0.5 times the height from the floor to the top of the <i>fenestration</i> , whichever is less, as indicated in Figure C405.2.4.2(1). The area of secondary sidelit zones shall not be considered in the calculation of the daylight zones in Section C402.6.1.4.</p> <p>4. The area of the <i>fenestration</i> is not less than 24 square feet (2.23 m²).</p> <p>5. The distance from the <i>fenestration</i> to any building or geological formation that would block access to daylight is greater than one-half of the height from the bottom of the <i>fenestration</i> to the top of the building or geologic formation.</p> <p>than 1.5 for all other orientations.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th></tr><tr><td></td><td>X</td><td></td><td>DEC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	EC		X		DEC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
	X																
Action	AS	AS/EC	EC														
	X		DEC														
CE#236	Revises the provision for clarity, removes sleeping and dwelling units lighting requirements from this section, and adds a new requirement, "lighting integrated into range hoods and exhaust fans must be controlled independently of fans."																
Related Mods: CEPI- 168-21, CEPI- 169-21, CEPI- 135-21, CECD1- 1-22, CED1-27- 22	<p>C405.2.5 Specific application controls. Specific application controls shall be provided for the following:</p> <p>1. The following lighting shall be controlled by an occupant sensor complying with Section C405.2.1.1 or a <i>time-switch control</i> complying with Section C405.2.2.1. In addition, a <i>manual</i> control shall be provided to control such lighting separately from the <i>general lighting</i> in the space:</p> <p>1.1. Luminaires for which additional lighting power is claimed in accordance with Section C405.3.2.2.1.</p> <p>1.2. Display and accent, including lighting in display cases.</p> <p>1.3. Lighting in display cases.</p> <p>1.4. Supplemental task lighting, including permanently installed under-shelf or under-cabinet lighting.</p> <p>1.5. Lighting equipment that is for sale or demonstration in lighting education.</p> <p>1.6. Display lighting for exhibits in galleries, museums and monuments that is in addition to <i>general lighting</i> .</p>																

	<p>2. <i>Sleeping units</i> shall have control devices or systems that are configured to automatically switch off all permanently installed luminaires and switched receptacles within 20 minutes after all occupants have left the unit.</p> <p>Exceptions:</p> <p>1—Lighting and switched receptacles controlled by card key controls;</p> <p>2—Spaces where patient care is directly provided;</p> <p>3—Permanently installed luminaires within <i>dwelling units</i> shall be provided with controls complying with Section C405.2.1.1 or C405.2.2.1.</p> <p>4.2—Lighting for nonvisual applications, such as plant growth and food warming, shall be controlled by a <i>time switch control</i> complying with Section C405.2.2.1 that is independent of the controls for other lighting within the room or space.</p> <p>5.3—Task lighting for medical and dental purposes that is in addition to <i>general lighting</i> shall be provided with a <i>manual control</i> .</p> <p>4. Lighting integrated into range hoods and exhaust fans shall be controlled independently of fans.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>EC</td></tr><tr><td></td><td>X</td><td></td><td>DEC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	EC		X		DEC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	EC															
	X		DEC															
CE#237	Edits the language for clarity. Edits the code language for clarity. Edits the code language for clarity, and reduces parking lot luminaire's total wattage threshold to 40 W from 78 W. This change increases the stringency but is cost-effective.																	
Related Mods: CECD1- 23-22, CEPI- 172-21	<p>C405.2.7 Exterior lighting controls. Exterior lighting systems shall be provided with controls that comply with Sections C405.2.7.1 through C405.2.7.4.</p> <p>Exceptions:</p> <p>1. Lighting for covered vehicle entrances and exits from to buildings and parking structures where required for eye adaptation;</p> <p>2. Lighting controlled from within <i>dwelling units</i> .</p> <p>C405.2.7.1 Daylight shutoff. Lights shall be automatically turned off when daylight is present and satisfies the lighting needs.</p> <p>C405.2.7.2 Building facade and landscape lighting. Building facade and landscape lighting shall automatically shut off from not later than 1 hour after <i>building</i> or business closing to not earlier than 1 hour before <i>building</i> or business opening.</p> <p>C405.2.7.3 Lighting setback. Lighting that is not controlled in accordance with Section C405.2.7.2 shall comply with the following:</p> <p>1. Be controlled so that the total wattage of such lighting is automatically reduced by not less than 50 percent by selectively switching off or dimming luminaires at one of the following times:</p>																	
	<p>1.1. From not later than midnight to not earlier than 6 a.m.</p> <p>1.2. From not later than 1 hour after <i>building</i> or business closing to not earlier than 1 hour before <i>building</i> or business opening.</p> <p>1.3. During any time where activity has not been detected for 15 minutes or more.</p> <p>2. Luminaires serving <i>exterior outdoor parking areas</i> and having a rated input wattage of greater than 78 40 watts and a mounting height of 24 feet (7 315 mm) or less above the ground shall be controlled so that the total wattage of such lighting is automatically reduced by not less than 50 percent during any time where activity has not been detected for 15 minutes or more. Not more than 1,500 watts of lighting power shall be controlled together.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>EC</td></tr><tr><td></td><td>X</td><td></td><td>DEC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	EC		X		DEC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap															
	X																	
Action	AS	AS/EC	EC															
	X		DEC															
CE#238	New reserved Section. This reserved Section must have a title and requirement compatible with its sub-section. It looks like an incomplete code modification.																	

Related Mods: CEPI- 176-21, CECD1- 5-22, CE2D-44- 23, CE2D-45- 23, CECD1- 23-22	C405.2.8 Reserved.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Reached</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		X			Action	AS	AS/EC	D	D/EC			X			
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap																		
	X																				
Action	AS	AS/EC	D	D/EC																	
		X																			
CE#239	It adds a new Section C405.2.8.1: Simplifies the code by limiting the demand responsive lighting controls requirements to B, E, M, and S building occupancies group. Adds an exception for storage rooms and warehouse spaces from dimming control; instead, use 25% or more switch-off control for general lighting. Decreases the code stringency.																				
Related Mods:	C405.2.8.1 Demand responsive lighting controls function. Demand responsive controls for lighting shall be capable of the following:																				
CE2D-45- 23, CECD1- 5-22	<div>1. Automatically reducing the output of controlled lighting to 80 percent or less of full power or light output upon receipt of a demand response signal .</div> <div>2. Where high-end trim has been set, automatically reducing the output of controlled lighting to 80 percent or less of the high-end trim setpoint upon receipt of a demand response signal .</div> <div>3. Dimming controlled lights gradually and continuously over a period of not longer than 15 minutes to achieve their demand response setpoint.</div> <div>4. Returning controlled lighting to its normal operational settings at the end of the demand response period.</div> <div>Exception: Storage rooms and warehouse storage areas shall be permitted to switch off 25 percent or more of general lighting power rather than dimming.</div> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Reached</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td>X</td><td></td><td></td></tr></table>			Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		X			Action	AS	AS/EC	D	D/EC			X		
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap																		
	X																				
Action	AS	AS/EC	D	D/EC																	
		X																			
CE#240	Renumbers Section C405.2.8 renames the title and edits the text for clarity.																				
Related Mods: CECD1- 23-22	<div>C405.2.8-C405.2.9 Parking garage-interior-parking-area lighting control. Parking-interior-parking-area garage lighting shall be controlled by an occupant sensor complying with Section C405.2.1.1 or a time-switch control complying with Section C405.2.2.1. Additional lighting controls shall be provided as follows:</div> <div>1. Lighting power of each luminaire shall be automatically reduced by not less than 30 percent when there is no activity detected within a lighting zone for 20 minutes. Lighting zones for this requirement shall be not larger than 3,600 square feet (334.5 m²).</div> <div>Exception: Lighting zones provided with less than 1.5 footcandles of illumination on the floor at the darkest point with all lights on are not required to have automatic light-reduction controls.</div> <div>2. Where lighting for eye adaptation is provided at covered vehicle entrances and exits from to buildings and parking structures, such lighting shall be separately controlled by a device that automatically reduces lighting power by at least 50 percent from sunset to sunrise.</div> <div>3. The power to luminaires within 20 feet (6096 mm) of perimeter wall openings shall automatically reduce in response to daylight by at least 50 percent.</div> <div>Exceptions:</div> <div>1. Where the opening-to-wall ratio is less than 40 percent as viewed from the interior and encompassing the vertical distance from the driving surface to the lowest structural element.</div> <div>2. Where the distance from the opening to any exterior daylight blocking obstruction is less than one-half the height from the bottom of the opening or fenestration to the top of the obstruction.</div> <div>3. Where openings are obstructed by permanent screens or architectural elements restricting daylight entering the interior space.</div>																				
	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Reached</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td>X</td><td></td><td></td></tr></table>			Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		X			Action	AS	AS/EC	D	D/EC			X		
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap																		
	X																				
Action	AS	AS/EC	D	D/EC																	
		X																			
CE#241	<div>Adds new Section C405.2.10 requiring sleeping and dwelling units to be provided with lighting controls and switched receptacles, instead of occupancy sensor based lighting and receptacle controls. This change simplifies the requirements for dwelling and sleeping units. Thus decreases the stringency.</div> <div>Adds new subsection C405.2.10.1. Requires a switched receptacle and occupant sensor lighting controls.</div> <div>Automatic shutoff is not required where captive key override controls all lighting and switched receptacles in units with five or fewer permanently installed lights and switched receptacles.</div> <div>Adds new subsection C405.2.10.2.</div> <div>Requires bathroom lighting to be controlled by an occupant sensor control that can turn-off lighting automatically within 20 minutes not occupied and a manual lighting control at the entrance of each unit that can turn-off lighting and switched receptacle in the unit, except for lighting in bathrooms and kitchens.</div>																				
Related Mods: CE2D-40- 23, CED1-27- 22, CE2D-41- 23	<div>C405.2.10 Sleeping unit and dwelling unit lighting and switched receptacle controls.</div> <div>Sleeping units and dwelling units shall be provided with lighting controls and switched receptacles as specified in Sections C405.2.10.1 and C405.2.10.2.</div> <div>C405.2.10.1 Sleeping units and dwelling units in hotels, motels and vacation timeshare properties. Sleeping units and dwelling units in hotels, motels and vacation timeshare properties shall be provided with the following:</div> <div>1. Not less than two 125V, 15- and 20- amp switched receptacles in each room, except for bathrooms, kitchens, foyers, hallways and closets.</div> <div>2. Lighting controls that automatically turn off all lighting and switched receptacles within 20 minutes after all occupants have left the unit.</div> <div>Exception: Automatic shutoff is not required where captive key override controls all lighting and switched receptacles in units with five or fewer permanently installed lights and switched receptacles.</div> <div>C405.2.10.2 Sleeping units in congregate living facilities. Sleeping units in congregate living facilities shall be provided with the following controls:</div> <div>1. Lighting in bathrooms shall be controlled by an occupant sensor control that automatically turns off lights within 20 minutes after all occupants have left the space.</div> <div>2. Each unit shall have a manual control by the entrance that turns off all lighting and switched receptacles in the unit, except for lighting in bathrooms and kitchens. The manual control shall be marked to indicate its function.</div>																				
	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Reached</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td>X</td><td></td><td></td></tr></table>			Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		X			Action	AS	AS/EC	D	D/EC			X		
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap																		
	X																				
Action	AS	AS/EC	D	D/EC																	
		X																			
CE#242	Renumbers Equation 4-10 and revises the list of lighting equipment and applications not included in calculating total connected lighting power.																				

Related Mods: CEPI- 177-21, CEPI- 135-21, CEPI- 187-21, CE2D-47- 23	<p>C405.3 Interior lighting power requirements. A <i>building</i> complies with this section where its total connected interior lighting power calculated under Section C405.3.1 is not greater than the interior lighting power allowance calculated under Section C405.3.2. <i>Sleeping units and dwelling units</i> shall comply with Section C405.3.3.</p> <p>C405.3.1 Total connected interior lighting power. The total connected interior lighting power shall be determined in accordance with Equation 4-9.</p> <p>Equation 4- 9: 9 where: TCLP = Total connected lighting power (watts). LVL = For luminaires with lamps connected directly to building power, such as line voltage lamps, the rated wattage of the lamp. BLL = For luminaires in TCLP = [LVL + BLL + LED + TRK + Other] last or transformer when operating that lamp. LED = For light-emitting diode luminaires with either integral or remote drivers, the rated wattage of the luminaire. TRK = For lighting track, cable conductor, rail conductor, and plug-in busway systems that allow the addition and relocation of luminaires without rewiring, the wattage shall be one of the following: 1. The specified wattage of the luminaires, but not less than 8 W per linear foot (25 W/lin m). 2. The wattage limit of the permanent current-limiting devices protecting the system. 3. The wattage limit of the transformer supplying the system. Other = The wattage of all other luminaires and lighting sources not covered previously and associated with interior lighting verified by data supplied by the manufacturer or other approved sources.</p> <p>The connected power associated with the following lighting equipment and applications is not included in calculating total connected lighting power. 1- Television-broadcast lighting for playing areas in sports arenas. 2- Emergency lighting automatically off during normal building operation. 3- Lighting in spaces specifically designed for use by occupants with special lighting needs, including those with visual impairment and other medical and age-related issues. 4- Casino gaming areas. 5- Mirror lighting in makeup or dressing rooms, areas used for video broadcasting, video or film recording, or live theatrical and music performance. 6- Task lighting for medical and dental purposes that is in addition to general lighting. 7- Display lighting for exhibits in galleries, museums and monuments that is in addition to general lighting. 8- Lighting for theatrical purposes, including performance, stage, film production and video production, in any location</p>																																																																		
	<p>that is specifically used for video broadcasting, video or film recording, or live theatrical and music performance.</p> <p>9- Lighting for photographic processes. 10- Lighting integral to equipment or instrumentation and installed by the manufacturer. 11- Task lighting for plant growth or maintenance. 12. 10. Advertising signage or directional signage. 13. 11. Lighting for food warming. 14. 12. Lighting equipment that is for sale. 15. 13. Lighting demonstration equipment in lighting education facilities. 16. 14. Lighting approved because of safety considerations. 17. 15. Lighting in retail display windows, provided that the display area is enclosed by ceiling- height partitions. 18. 16. Furniture-mounted supplemental task lighting that is controlled by automatic shutoff. 19. 17. Exit signs. 20. 18. Antimicrobial lighting used for the sole purpose of disinfecting a space. 19. Lighting in <i>sleeping units and dwelling units</i> . 20. For exit access and exit stairways, including landings, where the applicable code requires an illuminance of 10 footcandles or more on the walking surface, the power in excess of the allowed power calculated according to Section C405.3.2.2 is</p> <p>not included.</p> <table><tr><td>Diff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over time</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Actions</td><td>AS</td><td>ASAC</td><td>OS</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	Diff Classification	Correlates Directly	Energy Standard Needed	Over time		x			Actions	AS	ASAC	OS		x																																																				
Diff Classification	Correlates Directly	Energy Standard Needed	Over time																																																																
	x																																																																		
Actions	AS	ASAC	OS																																																																
	x																																																																		
CE#243	<p>Updates the LPD values in Table C405.3.2(1) based on improved lighting technologies and other requirements. The LPD values were mostly reduced. The measure is based on improved technology with little to no impact on the construction cost.</p>																																																																		
Related Mods:	<p>TABLE C405.3.2(1) INTERIOR LIGHTING POWER ALLOWANCES: BUILDING AREA METHOD</p> <table><tr><th>BUILDING AREA TYPE</th><th>LPD (w/ft²)</th></tr><tr><td>Automotive facility</td><td>0.75</td></tr><tr><td>Convention center</td><td>0.64</td></tr><tr><td>Courthouse</td><td>0.79</td></tr><tr><td>Dining- bar lounge/leisure</td><td>0.80</td></tr><tr><td>Dining- cafeteria/fast-food</td><td>0.76</td></tr><tr><td>Dining- family</td><td>0.74</td></tr><tr><td>Dormitory^{a, b}</td><td>0.63</td></tr><tr><td>Exercise center</td><td>0.72</td></tr><tr><td>Fire station^a</td><td>0.56</td></tr><tr><td>Gymnasium</td><td>0.76</td></tr><tr><td>Health care clinic</td><td>0.84</td></tr><tr><td>Hospital^a</td><td>0.96</td></tr><tr><td>Hotel/Motel^{a, b}</td><td>0.56</td></tr><tr><td>Library</td><td>0.83</td></tr><tr><td>Manufacturing facility</td><td>0.82</td></tr><tr><td>Motion picture theater</td><td>0.44</td></tr><tr><td>Multiple-family^a</td><td>0.45</td></tr><tr><td>Museum</td><td>0.55</td></tr><tr><td>Office</td><td>0.64</td></tr><tr><td>Parking garage</td><td>0.48</td></tr><tr><td>Penitentiary</td><td>0.69</td></tr><tr><td>Performing arts theater</td><td>0.84</td></tr><tr><td>Police station</td><td>0.66</td></tr><tr><td>Post office</td><td>0.66</td></tr><tr><td>Religious building</td><td>0.67</td></tr><tr><td>Retail</td><td>0.84</td></tr><tr><td>School/university</td><td>0.72</td></tr><tr><td>Sports arena</td><td>0.76</td></tr><tr><td>Town hall</td><td>0.69</td></tr><tr><td>Transportation</td><td>0.60</td></tr><tr><td>Warehouse</td><td>0.45</td></tr><tr><td>Workshop</td><td>0.94</td></tr></table>	BUILDING AREA TYPE	LPD (w/ft ²)	Automotive facility	0.75	Convention center	0.64	Courthouse	0.79	Dining- bar lounge/leisure	0.80	Dining- cafeteria/fast-food	0.76	Dining- family	0.74	Dormitory ^{a, b}	0.63	Exercise center	0.72	Fire station ^a	0.56	Gymnasium	0.76	Health care clinic	0.84	Hospital ^a	0.96	Hotel/Motel ^{a, b}	0.56	Library	0.83	Manufacturing facility	0.82	Motion picture theater	0.44	Multiple-family ^a	0.45	Museum	0.55	Office	0.64	Parking garage	0.48	Penitentiary	0.69	Performing arts theater	0.84	Police station	0.66	Post office	0.66	Religious building	0.67	Retail	0.84	School/university	0.72	Sports arena	0.76	Town hall	0.69	Transportation	0.60	Warehouse	0.45	Workshop	0.94
BUILDING AREA TYPE	LPD (w/ft ²)																																																																		
Automotive facility	0.75																																																																		
Convention center	0.64																																																																		
Courthouse	0.79																																																																		
Dining- bar lounge/leisure	0.80																																																																		
Dining- cafeteria/fast-food	0.76																																																																		
Dining- family	0.74																																																																		
Dormitory ^{a, b}	0.63																																																																		
Exercise center	0.72																																																																		
Fire station ^a	0.56																																																																		
Gymnasium	0.76																																																																		
Health care clinic	0.84																																																																		
Hospital ^a	0.96																																																																		
Hotel/Motel ^{a, b}	0.56																																																																		
Library	0.83																																																																		
Manufacturing facility	0.82																																																																		
Motion picture theater	0.44																																																																		
Multiple-family ^a	0.45																																																																		
Museum	0.55																																																																		
Office	0.64																																																																		
Parking garage	0.48																																																																		
Penitentiary	0.69																																																																		
Performing arts theater	0.84																																																																		
Police station	0.66																																																																		
Post office	0.66																																																																		
Religious building	0.67																																																																		
Retail	0.84																																																																		
School/university	0.72																																																																		
Sports arena	0.76																																																																		
Town hall	0.69																																																																		
Transportation	0.60																																																																		
Warehouse	0.45																																																																		
Workshop	0.94																																																																		

For SI: 1 watt per square foot = 10.76 w/m².

a. Where sleeping units are excluded from lighting power calculations by application of **Section R404.1**, neither the area of the sleeping units nor the wattage of lighting in the sleeping units is counted.

b. Where dwelling units are excluded from lighting power calculations by application of **Section R404.1**, neither the area of the dwelling units nor the wattage of lighting in the dwelling units is counted.

c. Dwelling units are excluded. Neither the area of the dwelling units nor the wattage of lighting in the dwelling units is counted.

TABLE C405.3.2(1)

INTERIOR LIGHTING POWER ALLOWANCES: BUILDING AREA METHOD

BUILDING AREA TYPE	LPD (watts/ft ²)
Automotive facility	0.73
Convention center	0.64
Courthouse	0.75
Dining: bar lounge/leisure	0.74
Dining: cafeteria/fast food	0.70
Dining: family	0.65
Dormitory	0.52
Exercise center	0.72
Fire station	0.56
Gymnasium	0.75
Health care clinic	0.77
Hospital	0.92
Hotel/Motel	0.53
Library	0.83
Manufacturing facility	0.82
Motion picture theater	0.43
Multiple-family	0.46
Museum	0.56
Office	0.62
Parking garage	0.17
Penitentiary	0.65
Performing arts theater	0.82
Police station	0.62
Post office	0.64
Religious building	0.66

Retail	0.78
School/university	0.70
Sports arena	0.73
Town hall	0.67
Transportation	0.56
Warehouse	0.45
Workshop	

0.86

For SI: 1 watt per square foot = 10.76 watts per square meter

FSEC – Anticipated energy impact on FBC-EC – Decrease

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap	
	X			
Action	AS	AS/IC	D	D/IC
			*	

CE#244 Updates the LPD values in Table C405.3.2(2) based on improved lighting technologies and other requirements. The LPD values were mostly reduced. The measure is based on improved technology with little to no impact on the construction cost.

Related Mods:
CED1-9- 22,
CED1-75- 22,
CECP1-7- 21,
CEPI-
135-21

Delete entire table

TABLE C405.3.2(2)

INTERIOR LIGHTING POWER ALLOWANCES: SPACE-BY-SPACE METHOD

For SI: 4 foot = 304.8 mm, 1 watt per square foot = 10.76 w/m².

a. In cases where both a common space type and a building area specific space type are listed, the building area specific space type shall apply.

b. A 'Facility for the Visually Impaired' is a facility that is licensed or will be licensed by local or state authorities for senior long-term care, adult daycare, senior support or people with special visual needs.

c. Where sleeping units are excluded from lighting power calculations by application of **Section R404.1**, neither the area of the sleeping units nor the wattage of lighting in the sleeping units is counted.

d. Where dwelling units are excluded from lighting power calculations by application of **Section R404.1**, neither the area of the dwelling units nor the wattage of lighting in the dwelling units is counted.

e. Class I facilities consist of professional facilities; and semiprofessional, collegiate, or club facilities with seating for 5,000 or more spectators.

f. Class II facilities consist of collegiate and semiprofessional facilities with seating for fewer than 5,000 spectators; club facilities with seating for between 2,000 and 5,000 spectators; and amateur league and high school facilities with seating for more than 2,000 spectators.

g. Class III facilities consist of club, amateur league and high school facilities with seating for 2,000 or fewer spectators.

h. Class IV facilities consist of elementary school and recreational facilities; and amateur league and high school facilities without provision for spectators.

	<p>TABLE C405.3.2(2) INTERIOR LIGHTING POWER ALLOWANCES: SPACE-BY-SPACE METHOD Please see attached For SI: 1 foot = 304.8 mm, 1 watt per square foot = 10.76 w/m².</p> <p>a. In cases where both a common space type and a building area specific space type are listed, the building area specific space type shall apply.</p> <p>b. A 'facility for the Visually Impaired' is a facility that is licensed or will be licensed by local or state authorities for senior long-term care, adult day care, senior support or people with special visual needs.</p> <p>c. Class I facilities consist of professional facilities; and semiprofessional, collegiate or club facilities with seating for 5,000 or more spectators.</p> <p>d. Class II facilities consist of collegiate and semiprofessional facilities with seating for fewer than 5,000 spectators, club facilities with seating for between 2,000 and 5,000 spectators, and amateur league and high school facilities with seating for more than 2,000 spectators.</p> <p>e. Class III facilities consist of club, amateur league and high school facilities with seating for 2,000 or fewer spectators.</p> <p>f. Class IV facilities consist of elementary school and recreational facilities; and amateur league and high school facilities without</p>													
	<p>provision for spectators. FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	<table border="1"> <tr> <th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr> <tr> <td></td><td>X</td><td></td><td></td></tr> <tr> <td>Action</td><td>AS</td><td>SLC</td><td>SLC</td></tr> </table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	SLC	SLC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap											
	X													
Action	AS	SLC	SLC											
CE#245	Adds a clarifying statement that sleeping and dwelling units are excluded from lighting power allowance calculations by applying a new Section C405.3.3, and their floor area is not included in the calculation.													
Related Mods: CEPI- 135-21, CECD1- 21-22	<p>C405.3.2.1 Building Area Method. For the Building Area Method, the interior lighting power allowance is calculated as follows:</p> <ol style="list-style-type: none"> For each building area type inside the <i>building</i>, determine the applicable building area type and the allowed lighting power density for that type from Table C405.3.2(1). For building area types not listed, select the building area type that most closely represents the use of that area. For the purposes of this method, an "area" shall be defined as all contiguous spaces that accommodate or are associated with a single building area type. Determine the floor area for each building area type listed in Table C405.3.2(1) and multiply this area by the applicable value from Table C405.3.2(1) to determine the lighting power (watts) for each building area type. <i>Sleeping units and dwelling units are excluded from lighting power allowance calculations by application of Section C405.3.3. The area of sleeping units and dwelling units is not included in the calculation.</i> The total interior lighting power allowance (watts) for the entire <i>building</i> is the sum of the lighting power from each building area type. 	<table border="1"> <tr> <th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr> <tr> <td></td><td>X</td><td></td><td></td></tr> <tr> <td>Action</td><td>AS</td><td>SLC</td><td>SLC</td></tr> </table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	SLC	SLC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap											
	X													
Action	AS	SLC	SLC											
CE#246	A clarifying statement was added that sleeping and dwelling units are excluded from lighting power allowance calculations by applying a new Section C405.3.3, and their area is not included in the calculation. Also, the total connected lighting power maximum allowance for unfinished spaces reduced to 0.10 W/ft ² from 0.20 W/ft ² .													
Related Mods: CEPI- 135-21, CEPI- 181-21, CECD1- 21-22,	<p>C405.3.2.2 Space-by-Space Method. Where a <i>building</i> has unfinished spaces, the lighting power allowance for the unfinished spaces shall be the total connected lighting power for those spaces, or 0.20 watts per square foot (10.76 W/m²), whichever is less. For the Space-by-Space Method, the interior lighting power allowance is calculated as follows:</p> <ol style="list-style-type: none"> For each space enclosed by partitions that are not less than 80 percent of the ceiling height, determine the applicable space type from Table C405.3.2(2). For space types not listed, select the space type that most closely represents the proposed use of the space. Where a space has multiple functions, that space may be divided into separate spaces. Determine the total floor area of all the spaces of each space type and multiply by the value for the space type in Table C405.3.2(2) to determine the <i>allowed</i> lighting power (watts) for each space type. <i>Sleeping units and dwelling units are excluded from lighting power allowance calculations by application of Section C405.3.3. The area of sleeping units and dwelling units is not included in the calculation.</i> The total interior lighting power allowance (watts) shall be the sum of the lighting power allowances for all space types. 	<table border="1"> <tr> <th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr> <tr> <td></td><td>X</td><td></td><td></td></tr> <tr> <td>Action</td><td>AS</td><td>SLC</td><td>SLC</td></tr> </table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	SLC	SLC
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap											
	X													
Action	AS	SLC	SLC											
CE#247	Revises the code language for clarifications.													
Related Mods: CECPI-7- 21, CED1-76- 22	<p>C405.3.2.2.1 Additional interior lighting power. Where using the Space-by-Space Method, an increase in the interior lighting power allowance is permitted for specific lighting functions. Additional power shall be permitted only where the specified lighting is installed and controlled in accordance with Section C405.2.5. This—These additional power allowances shall be used only for the specified luminaires serving—the specific lighting function and shall not be used for any other purpose. An increase in the interior lighting power allowance is permitted in the following cases:</p> <ol style="list-style-type: none"> For lighting equipment to be installed in sales areas specifically to highlight merchandise, the additional lighting power shall be determined in accordance with Equation 4-11; allowance shall be the connected lighting power of the luminaires specifically highlighting merchandise, calculated in accordance with Equation 4-9, or the additional power allowance calculated in accordance with Equation 4-10, whichever is less. 													
	<p>Equation 4-10 Additional lighting power allowance = 750 W + (Retail Area 1 × 0.40 W/ft²) + (Retail Area 2 × 0.40 W/ft²) + (Retail Area 3 × 0.40 W/ft²) + (Retail Area 4 × 0.40 W/ft²) + (Retail Area 5 × 0.40 W/ft²) + (Retail Area 6 × 0.40 W/ft²) + (Retail Area 7 × 0.40 W/ft²) + (Retail Area 8 × 0.40 W/ft²) + (Retail Area 9 × 0.40 W/ft²) + (Retail Area 10 × 0.40 W/ft²) + (Retail Area 11 × 0.40 W/ft²) + (Retail Area 12 × 0.40 W/ft²) + (Retail Area 13 × 0.40 W/ft²) + (Retail Area 14 × 0.40 W/ft²) + (Retail Area 15 × 0.40 W/ft²) + (Retail Area 16 × 0.40 W/ft²) + (Retail Area 17 × 0.40 W/ft²) + (Retail Area 18 × 0.40 W/ft²) + (Retail Area 19 × 0.40 W/ft²) + (Retail Area 20 × 0.40 W/ft²) + (Retail Area 21 × 0.40 W/ft²) + (Retail Area 22 × 0.40 W/ft²) + (Retail Area 23 × 0.40 W/ft²) + (Retail Area 24 × 0.40 W/ft²) + (Retail Area 25 × 0.40 W/ft²) + (Retail Area 26 × 0.40 W/ft²) + (Retail Area 27 × 0.40 W/ft²) + (Retail Area 28 × 0.40 W/ft²) + (Retail Area 29 × 0.40 W/ft²) + (Retail Area 30 × 0.40 W/ft²) + (Retail Area 31 × 0.40 W/ft²) + (Retail Area 32 × 0.40 W/ft²) + (Retail Area 33 × 0.40 W/ft²) + (Retail Area 34 × 0.40 W/ft²) + (Retail Area 35 × 0.40 W/ft²) + (Retail Area 36 × 0.40 W/ft²) + (Retail Area 37 × 0.40 W/ft²) + (Retail Area 38 × 0.40 W/ft²) + (Retail Area 39 × 0.40 W/ft²) + (Retail Area 40 × 0.40 W/ft²) + (Retail Area 41 × 0.40 W/ft²) + (Retail Area 42 × 0.40 W/ft²) + (Retail Area 43 × 0.40 W/ft²) + (Retail Area 44 × 0.40 W/ft²) + (Retail Area 45 × 0.40 W/ft²) + (Retail Area 46 × 0.40 W/ft²) + (Retail Area 47 × 0.40 W/ft²) + (Retail Area 48 × 0.40 W/ft²) + (Retail Area 49 × 0.40 W/ft²) + (Retail Area 50 × 0.40 W/ft²) + (Retail Area 51 × 0.40 W/ft²) + (Retail Area 52 × 0.40 W/ft²) + (Retail Area 53 × 0.40 W/ft²) + (Retail Area 54 × 0.40 W/ft²) + (Retail Area 55 × 0.40 W/ft²) + (Retail Area 56 × 0.40 W/ft²) + (Retail Area 57 × 0.40 W/ft²) + (Retail Area 58 × 0.40 W/ft²) + (Retail Area 59 × 0.40 W/ft²) + (Retail Area 60 × 0.40 W/ft²) + (Retail Area 61 × 0.40 W/ft²) + (Retail Area 62 × 0.40 W/ft²) + (Retail Area 63 × 0.40 W/ft²) + (Retail Area 64 × 0.40 W/ft²) + (Retail Area 65 × 0.40 W/ft²) + (Retail Area 66 × 0.40 W/ft²) + (Retail Area 67 × 0.40 W/ft²) + (Retail Area 68 × 0.40 W/ft²) + (Retail Area 69 × 0.40 W/ft²) + (Retail Area 70 × 0.40 W/ft²) + (Retail Area 71 × 0.40 W/ft²) + (Retail Area 72 × 0.40 W/ft²) + (Retail Area 73 × 0.40 W/ft²) + (Retail Area 74 × 0.40 W/ft²) + (Retail Area 75 × 0.40 W/ft²) + (Retail Area 76 × 0.40 W/ft²) + (Retail Area 77 × 0.40 W/ft²) + (Retail Area 78 × 0.40 W/ft²) + (Retail Area 79 × 0.40 W/ft²) + (Retail Area 80 × 0.40 W/ft²) + (Retail Area 81 × 0.40 W/ft²) + (Retail Area 82 × 0.40 W/ft²) + (Retail Area 83 × 0.40 W/ft²) + (Retail Area 84 × 0.40 W/ft²) + (Retail Area 85 × 0.40 W/ft²) + (Retail Area 86 × 0.40 W/ft²) + (Retail Area 87 × 0.40 W/ft²) + (Retail Area 88 × 0.40 W/ft²) + (Retail Area 89 × 0.40 W/ft²) + (Retail Area 90 × 0.40 W/ft²) + (Retail Area 91 × 0.40 W/ft²) + (Retail Area 92 × 0.40 W/ft²) + (Retail Area 93 × 0.40 W/ft²) + (Retail Area 94 × 0.40 W/ft²) + (Retail Area 95 × 0.40 W/ft²) + (Retail Area 96 × 0.40 W/ft²) + (Retail Area 97 × 0.40 W/ft²) + (Retail Area 98 × 0.40 W/ft²) + (Retail Area 99 × 0.40 W/ft²) + (Retail Area 100 × 0.40 W/ft²) + (Retail Area 101 × 0.40 W/ft²) + (Retail Area 102 × 0.40 W/ft²) + (Retail Area 103 × 0.40 W/ft²) + (Retail Area 104 × 0.40 W/ft²) + (Retail Area 105 × 0.40 W/ft²) + (Retail Area 106 × 0.40 W/ft²) + (Retail Area 107 × 0.40 W/ft²) + (Retail Area 108 × 0.40 W/ft²) + (Retail Area 109 × 0.40 W/ft²) + (Retail Area 110 × 0.40 W/ft²) + (Retail Area 111 × 0.40 W/ft²) + (Retail Area 112 × 0.40 W/ft²) + (Retail Area 113 × 0.40 W/ft²) + (Retail Area 114 × 0.40 W/ft²) + (Retail Area 115 × 0.40 W/ft²) + (Retail Area 116 × 0.40 W/ft²) + (Retail Area 117 × 0.40 W/ft²) + (Retail Area 118 × 0.40 W/ft²) + (Retail Area 119 × 0.40 W/ft²) + (Retail Area 120 × 0.40 W/ft²) + (Retail Area 121 × 0.40 W/ft²) + (Retail Area 122 × 0.40 W/ft²) + (Retail Area 123 × 0.40 W/ft²) + (Retail Area 124 × 0.40 W/ft²) + (Retail Area 125 × 0.40 W/ft²) + (Retail Area 126 × 0.40 W/ft²) + (Retail Area 127 × 0.40 W/ft²) + (Retail Area 128 × 0.40 W/ft²) + (Retail Area 129 × 0.40 W/ft²) + (Retail Area 130 × 0.40 W/ft²) + (Retail Area 131 × 0.40 W/ft²) + (Retail Area 132 × 0.40 W/ft²) + (Retail Area 133 × 0.40 W/ft²) + (Retail Area 134 × 0.40 W/ft²) + (Retail Area 135 × 0.40 W/ft²) + (Retail Area 136 × 0.40 W/ft²) + (Retail Area 137 × 0.40 W/ft²) + (Retail Area 138 × 0.40 W/ft²) + (Retail Area 139 × 0.40 W/ft²) + (Retail Area 140 × 0.40 W/ft²) + (Retail Area 141 × 0.40 W/ft²) + (Retail Area 142 × 0.40 W/ft²) + (Retail Area 143 × 0.40 W/ft²) + (Retail Area 144 × 0.40 W/ft²) + (Retail Area 145 × 0.40 W/ft²) + (Retail Area 146 × 0.40 W/ft²) + (Retail Area 147 × 0.40 W/ft²) + (Retail Area 148 × 0.40 W/ft²) + (Retail Area 149 × 0.40 W/ft²) + (Retail Area 150 × 0.40 W/ft²) + (Retail Area 151 × 0.40 W/ft²) + (Retail Area 152 × 0.40 W/ft²) + (Retail Area 153 × 0.40 W/ft²) + (Retail Area 154 × 0.40 W/ft²) + (Retail Area 155 × 0.40 W/ft²) + (Retail Area 156 × 0.40 W/ft²) + (Retail Area 157 × 0.40 W/ft²) + (Retail Area 158 × 0.40 W/ft²) + (Retail Area 159 × 0.40 W/ft²) + (Retail Area 160 × 0.40 W/ft²) + (Retail Area 161 × 0.40 W/ft²) + (Retail Area 162 × 0.40 W/ft²) + (Retail Area 163 × 0.40 W/ft²) + (Retail Area 164 × 0.40 W/ft²) + (Retail Area 165 × 0.40 W/ft²) + (Retail Area 166 × 0.40 W/ft²) + (Retail Area 167 × 0.40 W/ft²) + (Retail Area 168 × 0.40 W/ft²) + (Retail Area 169 × 0.40 W/ft²) + (Retail Area 170 × 0.40 W/ft²) + (Retail Area 171 × 0.40 W/ft²) + (Retail Area 172 × 0.40 W/ft²) + (Retail Area 173 × 0.40 W/ft²) + (Retail Area 174 × 0.40 W/ft²) + (Retail Area 175 × 0.40 W/ft²) + (Retail Area 176 × 0.40 W/ft²) + (Retail Area 177 × 0.40 W/ft²) + (Retail Area 178 × 0.40 W/ft²) + (Retail Area 179 × 0.40 W/ft²) + (Retail Area 180 × 0.40 W/ft²) + (Retail Area 181 × 0.40 W/ft²) + (Retail Area 182 × 0.40 W/ft²) + (Retail Area 183 × 0.40 W/ft²) + (Retail Area 184 × 0.40 W/ft²) + (Retail Area 185 × 0.40 W/ft²) + (Retail Area 186 × 0.40 W/ft²) + (Retail Area 187 × 0.40 W/ft²) + (Retail Area 188 × 0.40 W/ft²) + (Retail Area 189 × 0.40 W/ft²) + (Retail Area 190 × 0.40 W/ft²) + (Retail Area 191 × 0.40 W/ft²) + (Retail Area 192 × 0.40 W/ft²) + (Retail Area 193 × 0.40 W/ft²) + (Retail Area 194 × 0.40 W/ft²) + (Retail Area 195 × 0.40 W/ft²) + (Retail Area 196 × 0.40 W/ft²) + (Retail Area 197 × 0.40 W/ft²) + (Retail Area 198 × 0.40 W/ft²) + (Retail Area 199 × 0.40 W/ft²) + (Retail Area 200 × 0.40 W/ft²) + (Retail Area 201 × 0.40 W/ft²) + (Retail Area 202 × 0.40 W/ft²) + (Retail Area 203 × 0.40 W/ft²) + (Retail Area 204 × 0.40 W/ft²) + (Retail Area 205 × 0.40 W/ft²) + (Retail Area 206 × 0.40 W/ft²) + (Retail Area 207 × 0.40 W/ft²) + (Retail Area 208 × 0.40 W/ft²) + (Retail Area 209 × 0.40 W/ft²) + (Retail Area 210 × 0.40 W/ft²) + (Retail Area 211 × 0.40 W/ft²) + (Retail Area 212 × 0.40 W/ft²) + (Retail Area 213 × 0.40 W/ft²) + (Retail Area 214 × 0.40 W/ft²) + (Retail Area 215 × 0.40 W/ft²) + (Retail Area 216 × 0.40 W/ft²) + (Retail Area 217 × 0.40 W/ft²) + (Retail Area 218 × 0.40 W/ft²) + (Retail Area 219 × 0.40 W/ft²) + (Retail Area 220 × 0.40 W/ft²) + (Retail Area 221 × 0.40 W/ft²) + (Retail Area 222 × 0.40 W/ft²) + (Retail Area 223 × 0.40 W/ft²) + (Retail Area 224 × 0.40 W/ft²) + (Retail Area 225 × 0.40 W/ft²) + (Retail Area 226 × 0.40 W/ft²) + (Retail Area 227 × 0.40 W/ft²) + (Retail Area 228 × 0.40 W/ft²) + (Retail Area 229 × 0.40 W/ft²) + (Retail Area 230 × 0.40 W/ft²) + (Retail Area 231 × 0.40 W/ft²) + (Retail Area 232 × 0.40 W/ft²) + (Retail Area 233 × 0.40 W/ft²) + (Retail Area 234 × 0.40 W/ft²) + (Retail Area 235 × 0.40 W/ft²) + (Retail Area 236 × 0.40 W/ft²) + (Retail Area 237 × 0.40 W/ft²) + (Retail Area 238 × 0.40 W/ft²) + (Retail Area 239 × 0.40 W/ft²) + (Retail Area 240 × 0.40 W/ft²) + (Retail Area 241 × 0.40 W/ft²) + (Retail Area 242 × 0.40 W/ft²) + (Retail Area 243 × 0.40 W/ft²) + (Retail Area 244 × 0.40 W/ft²) + (Retail Area 245 × 0.40 W/ft²) + (Retail Area 246 × 0.40 W/ft²) + (Retail Area 247 × 0.40 W/ft²) + (Retail Area 248 × 0.40 W/ft²) + (Retail Area 249 × 0.40 W/ft²) + (Retail Area 250 × 0.40 W/ft²) + (Retail Area 251 × 0.40 W/ft²) + (Retail Area 252 × 0.40 W/ft²) + (Retail Area 253 × 0.40 W/ft²) + (Retail Area 254 × 0.40 W/ft²) + (Retail Area 255 × 0.40 W/ft²) + (Retail Area 256 × 0.40 W/ft²) + (Retail Area 257 × 0.40 W/ft²) + (Retail Area 258 × 0.40 W/ft²) + (Retail Area 259 × 0.40 W/ft²) + (Retail Area 260 × 0.40 W/ft²) + (Retail Area 261 × 0.40 W/ft²) + (Retail Area 262 × 0.40 W/ft²) + (Retail Area 263 × 0.40 W/ft²) + (Retail Area 264 × 0.40 W/ft²) + (Retail Area 265 × 0.40 W/ft²) + (Retail Area 266 × 0.40 W/ft²) + (Retail Area 267 × 0.40 W/ft²) + (Retail Area 268 × 0.40 W/ft²) + (Retail Area 269 × 0.40 W/ft²) + (Retail Area 270 × 0.40 W/ft²) + (Retail Area 271 × 0.40 W/ft²) + (Retail Area 272 × 0.40 W/ft²) + (Retail Area 273 × 0.40 W/ft²) + (Retail Area 274 × 0.40 W/ft²) + (Retail Area 275 × 0.40 W/ft²) + (Retail Area 276 × 0.40 W/ft²) + (Retail Area 277 × 0.40 W/ft²) + (Retail Area 278 × 0.40 W/ft²) + (Retail Area 279 × 0.40 W/ft²) + (Retail Area 280 × 0.40 W/ft²) + (Retail Area 281 × 0.40 W/ft²) + (Retail Area 282 × 0.40 W/ft²) + (Retail Area 283 × 0.40 W/ft²) + (Retail Area 284 × 0.40 W/ft²) + (Retail Area 285 × 0.40 W/ft²) + (Retail Area 286 × 0.40 W/ft²) + (Retail Area 287 × 0.40 W/ft²) + (Retail Area 288 × 0.40 W/ft²) + (Retail Area 289 × 0.40 W/ft²) + (Retail Area 290 × 0.40 W/ft²) + (Retail Area 291 × 0.40 W/ft²) + (Retail Area 292 × 0.40 W/ft²) + (Retail Area 293 × 0.40 W/ft²) + (Retail Area 294 × 0.40 W/ft²) + (Retail Area 295 × 0.40 W/ft²) + (Retail Area 296 × 0.40 W/ft²) + (Retail Area 297 × 0.40 W/ft²) + (Retail Area 298 × 0.40 W/ft²) + (Retail Area 299 × 0.40 W/ft²) + (Retail Area 300 × 0.40 W/ft²) + (Retail Area 301 × 0.40 W/ft²) + (Retail Area 302 × 0.40 W/ft²) + (Retail Area 303 × 0.40 W/ft²) + (Retail Area 304 × 0.40 W/ft²) + (Retail Area 305 × 0.40 W/ft²) + (Retail Area 306 × 0.40 W/ft²) + (Retail Area 307 × 0.40 W/ft²) + (Retail Area 308 × 0.40 W/ft²) + (Retail Area 309 × 0.40 W/ft²) + (Retail Area 310 × 0.40 W/ft²) + (Retail Area 311 × 0.40 W/ft²) + (Retail Area 312 × 0.40 W/ft²) + (Retail Area 313 × 0.40 W/ft²) + (Retail Area 314 × 0.40 W/ft²) + (Retail Area 315 × 0.40 W/ft²) + (Retail Area 316 × 0.40 W/ft²) + (Retail Area 317 × 0.40 W/ft²) + (Retail Area 318 × 0.40 W/ft²) + (Retail Area 319 × 0.40 W/ft²) + (Retail Area 320 × 0.40 W/ft²) + (Retail Area 321 × 0.40 W/ft²) + (Retail Area 322 × 0.40 W/ft²) + (Retail Area 323 × 0.40 W/ft²) + (Retail Area 324 × 0.40 W/ft²) + (Retail Area 325 × 0.40 W/ft²) + (Retail Area 326 × 0.40 W/ft²) + (Retail Area 327 × 0.40 W/ft²) + (Retail Area 328 × 0.40 W/ft²) + (Retail Area 329 × 0.40 W/ft²) + (Retail Area 330 × 0.40 W/ft²) + (Retail Area 331 × 0.40 W/ft²) + (Retail Area 332 × 0.40 W/ft²) + (Retail Area 333 × 0.40 W/ft²) + (Retail Area 334 × 0.40 W/ft²) + (Retail Area 335 × 0.40 W/ft²) + (Retail Area 336 × 0.40 W/ft²) + (Retail Area 337 × 0.40 W/ft²) + (Retail Area 338 × 0.40 W/ft²) + (Retail Area 339 × 0.40 W/ft²) + (Retail Area 340 × 0.40 W/ft²) + (Retail Area 341 × 0.40 W/ft²) + (Retail Area 342 × 0.40 W/ft²) + (Retail Area 343 × 0.40 W/ft²) + (Retail Area 344 × 0.40 W/ft²) + (Retail Area 345 × 0.40 W/ft²) + (Retail Area 346 × 0.40 W/ft²) + (Retail Area 347 × 0.40 W/ft²) + (Retail Area 348 × 0.40 W/ft²) + (Retail Area 349 × 0.40 W/ft²) + (Retail Area 350 × 0.40 W/ft²) + (Retail Area 351 × 0.40 W/ft²) + (Retail Area 352 × 0.40 W/ft²) + (Retail Area 353 × 0.40 W/ft²) + (Retail Area 354 × 0.40 W/ft²) + (Retail Area 355 × 0.40 W/ft²) + (Retail Area 356 × 0.40 W/ft²) + (Retail Area 357 × 0.40 W/ft²) + (Retail Area 358 × 0.40 W/ft²) + (Retail Area 359 × 0.40 W/ft²) + (Retail Area 360 × 0.40 W/ft²) + (Retail Area 361 × 0.40 W/ft²) + (Retail Area 362 × 0.40 W/ft²) + (Retail Area 363 × 0.40 W/ft²) + (Retail Area 364 × 0.40 W/ft²) + (Retail Area 365 × 0.40 W/ft²) + (Retail Area 366 × 0.40 W/ft²) + (Retail Area 367 × 0.40 W/ft²) + (Retail Area 368 × 0.40 W/ft²) + (Retail Area 369 × 0.40 W/ft²) + (Retail Area 370 × 0.40 W/ft²) + (Retail Area 371 × 0.40 W/ft²) + (Retail Area 372 × 0.40 W/ft²) + (Retail Area 373 × 0.40 W/ft²) + (Retail Area 374 × 0.40 W/ft²) + (Retail Area 375 × 0.40 W/ft²) + (Retail Area 376 × 0.40 W/ft²) + (Retail Area 377 × 0.40 W/ft²) + (Retail Area 378 × 0.40 W/ft²) + (Retail Area 379 × 0.40 W/ft²) + (Retail Area 380 × 0.40 W/ft²) + (Retail Area 381 × 0.40 W/ft²) + (Retail Area 382 × 0.40 W/ft²) + (Retail Area 383 × 0.40 W/ft²) + (Retail Area 384 × 0.40 W/ft²) + (Retail Area 385 × 0.40 W/ft²) + (Retail Area 386 × 0.40 W/ft²) + (Retail Area 387 × 0.40 W/ft²) + (Retail Area 388 × 0.40 W/ft²) + (Retail Area 389 × 0.40 W/ft²) + (Retail Area 390 × 0.40 W/ft²) + (Retail Area 391 × 0.40 W/ft²) + (Retail Area 392 × 0.40 W/ft²) + (Retail Area 393 × 0.40 W/ft²) + (Retail Area 394 × 0.40 W/ft²) + (Retail Area 395 × 0.40 W/ft²) + (Retail Area 396 × 0.40 W/ft²) + (Retail Area 397 × 0.40 W/ft²) + (Retail Area 398 × 0.40 W/ft²) + (Retail Area 399 × 0.40 W/ft²) + (Retail Area 400 × 0.40 W/ft²) + (Retail Area 401 × 0.40 W/ft²) + (Retail Area 402 × 0.40 W/ft²) + (Retail Area 403 × 0.40 W/ft²) + (Retail Area 404 × 0.40 W/ft²) + (Retail Area 405 × 0.40 W/ft²) + (Retail Area 406 × 0.40 W/ft²) + (Retail Area 407 × 0.40 W/ft²) + (Retail Area 408 × 0.40 W/ft²) + (Retail Area 409 × 0.40 W/ft²) + (Retail Area 410 × 0.40 W/ft²) + (Retail Area 411 × 0.40 W/ft²) + (Retail Area 412 × 0.40 W/ft²) + (Retail Area 413 × 0.40 W/ft²) + (Retail Area 414 × 0.40 W/ft²) + (Retail Area 415 × 0.40 W/ft²) + (Retail Area 416 × 0.40 W/ft²) + (Retail Area 417 × 0.40 W/ft²) + (Retail Area 418 × 0.40 W/ft²) + (Retail Area 419 × 0.40 W/ft²) + (Retail Area 420 × 0.40 W/ft²) + (Retail Area 421 × 0.40 W/ft²) + (Retail Area 422 × 0.40 W/ft²) + (Retail Area 423 × 0.40 W/ft²) + (Retail Area 424 × 0.40 W/ft²) + (Retail Area 425 × 0.40 W/ft²) + (Retail Area 426 × 0.40 W/ft²) + (Retail Area 427 × 0.40 W/ft²) + (Retail Area 428 × 0.40 W/ft²) + (Retail Area 429 × 0.40 W/ft²) + (Retail Area 430 × 0.40 W/ft²) + (Retail Area 431 × 0.40 W/ft²) + (Retail Area 432 × 0.40 W/ft²) + (Retail Area 433 × 0.40 W/ft²) + (Retail Area 434 × 0.40 W/ft²) + (Retail Area 435 × 0.4</p>													

Related Mods: CE2D-48- 23, CECD1- 21-22, CECD1- 1-22	<p>C405.3.3 Lighting power for sleeping units and dwelling units. <i>Sleeping units</i> in Group I-2 occupancies that are patient rooms shall comply with Sections C405.3.1 and C405.3.2. For all other <i>sleeping units</i> and <i>dwelling units</i>, permanently installed lighting, including lighting integrated into range hoods and exhaust fans, shall be provided by lamps capable of operating with an efficacy of not less than 65 lumens per watt or luminaires capable of operating with an efficacy of not less than 45 lumens per watt.</p> <p>Exceptions:</p> <ol style="list-style-type: none">1. Lighting integral to other appliances.2. Antimicrobial lighting used for the sole purpose of disinfecting.3. Luminaires with an input rating of less than 3 watts.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Reached</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap																	
	X																			
Action	AS	AS/EC	D	D/EC																
			X																	
CE#249	It renames the section title, edits the code language, and increases the photon efficiency. This change may slightly increase construction costs but saves more energy costs due to the improved efficiency requirement. It increases the stringency but is cost-effective.																			
Related Mods: FBC – C405.9	<p>C405.4 Lighting for plant growth and maintenance. Horticultural lighting. Not less than 95 percent of the permanently installed luminaires used for plant growth and maintenance shall have a photon efficiency of not less than 1.6 $\mu\text{mol}/\text{J}\cdot\text{s}$ as defined in accordance with ANSI/ASABE S640. Permanently installed luminaires shall have a photosynthetic photon efficacy of not less than 1.7 micromoles per joule ($\mu\text{mol}/\text{J}$) for horticultural lighting in greenhouses and not less than 1.9 $\mu\text{mol}/\text{J}$ for all other horticultural lighting. Luminaires for horticultural lighting in greenhouses shall be controlled by a device that automatically turns off the luminaire when sufficient daylight is available. Luminaires for horticultural lighting shall be controlled by a device that automatically turns off the luminaire at specific programmed times.</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Reached</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap																	
	X																			
Action	AS	AS/EC	D	D/EC																
			X																	
CE#250	Renames the Section title, edits the code language and existing exception items #7 and #14 for clarity, and adds a new exception item #15. No change in code stringency. Revises the code language of exterior lighting power allowance to include "building site lighting for which the building owner is responsible." This change improves the code clarity.																			
Related Mods: FBC – C405.4.1	<p>C405.5 Exterior lighting power requirements. The total connected exterior lighting power calculated in accordance with Section C405.5.1 shall be not greater than the exterior lighting power allowance calculated in accordance with Section C405.5.2.</p> <p>C405.5.1 Total connected exterior building exterior lighting power. The total exterior connected lighting power shall be the total maximum rated wattage of all exterior lighting that is powered through the energy service for the building and building site lighting for which the building owner is responsible.</p> <p>Exception: Lighting used for the following applications shall not be included.</p> <ol style="list-style-type: none">1. Lighting approved because of safety considerations.2. Emergency lighting automatically off during normal business operation.3. Exit signs.4. Specialized signal, directional and marker lighting associated with transportation.5. Advertising signage or directional signage.6. Integral to equipment or instrumentation and installed by its manufacturer.7. Theatrical purposes, including performance, stage, film production and video production. Lighting in any location that is specifically used for video broadcasting, video or film recording, or live theatrical and music performances.8. Athletic playing areas.9. Temporary lighting.10. Industrial production, material handling, transportation sites and associated storage areas.11. Theme elements in theme/amusement parks.12. Used to highlight features of art, public monuments and the national flag.13. Lighting for water features and swimming pools.	<p>Section C405.5.1 shall be not greater than the exterior lighting power allowance calculated in accordance with Section C405.5.2.</p> <p>C405.5.1 Total connected exterior building exterior lighting power. The total exterior connected lighting power shall be the total maximum rated wattage of all exterior lighting that is powered through the energy service for the building and building site lighting for which the building owner is responsible.</p> <p>Exception: Lighting used for the following applications shall not be included.</p> <ol style="list-style-type: none">1. Lighting approved because of safety considerations.2. Emergency lighting automatically off during normal business operation.3. Exit signs.4. Specialized signal, directional and marker lighting associated with transportation.5. Advertising signage or directional signage.6. Integral to equipment or instrumentation and installed by its manufacturer.7. Theatrical purposes, including performance, stage, film production and video production. Lighting in any location that is specifically used for video broadcasting, video or film recording, or live theatrical and music performances.8. Athletic playing areas.9. Temporary lighting.10. Industrial production, material handling, transportation sites and associated storage areas.11. Theme elements in theme/amusement parks.12. Used to highlight features of art, public monuments and the national flag.13. Lighting for water features and swimming pools.																		
	<p>14. Lighting controlled from within <i>sleeping units</i> and <i>dwelling units</i>, where the lighting complies with Section R404.1.</p> <p>15. Lighting of the exterior means of egress as required by the International Building Code.</p> <p>C405.5.2 Exterior lighting power allowance. The exterior lighting power allowance (watts) is calculated as follows:</p> <ol style="list-style-type: none">1. Determine the Lighting Zone (LZ) for the building according to Table C405.5.2(1), unless otherwise specified by the code official.2. For each exterior area that is to be illuminated by lighting that is powered through the energy service for the building and building site lighting for which the building owner is responsible, determine the applicable area type from Table C405.5.2(2). For area types not listed, select the area type that most closely represents the proposed use of the area.3. Determine the total area or length of each area type and multiply by the value for the area type in Table C405.5.2(2) to determine the lighting power (watts) allowed for each area type.4. The total exterior lighting power allowance (watts) is the sum of the base site allowance determined according to Table C405.5.2(2), plus the watts from each area type.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Reached</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Reached	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Reached	Over lap																	
	X																			
Action	AS	AS/EC	D	D/EC																
			X																	
CE#251	Updates the exterior lighting power allowance values in Table C405.5.2(2). Reduces the lighting power allowances based on advances in lighting technology and aligns with ASHRAE 90.1 requirements.																			
Related Mods: CECD1- 23-22, CEPI- 189-21,CEPI- 254-21 FBC – C405.4.2	<p>Delete Table TABLE C405.5.2(2) LIGHTING POWER ALLOWANCES FOR BUILDING EXTERIORS For Site: 1 foot = 304.8 mm, 1 watt per square foot = W/0.0929 m², W = watts TABLE C405.5.2(2) LIGHTING POWER ALLOWANCES FOR BUILDING EXTERIORS</p>	<table><tr><th colspan="5">LIGHTING ZONES</th></tr><tr><th></th><th>Zone 1</th><th>Zone 2</th><th>Zone 3</th><th>Zone 4</th></tr><tr><td>Base Site Allowance</td><td>160 W</td><td>280 W</td><td>400 W</td><td>560 W</td></tr></table>		LIGHTING ZONES						Zone 1	Zone 2	Zone 3	Zone 4	Base Site Allowance	160 W	280 W	400 W	560 W		
LIGHTING ZONES																				
	Zone 1	Zone 2	Zone 3	Zone 4																
Base Site Allowance	160 W	280 W	400 W	560 W																

Parking area, exterior	0.015 W/ft ²	0.026 W/ft ²	0.037 W/ft ²	0.052 W/ft ²
Walkways and ramps less	0.50 W/linear foot	0.50 W/linear foot	0.55 W/linear foot	0.60 W/linear foot
Plaza areas	0.026 W/ft ²	0.049 W/ft ²	0.070 W/ft ²	0.098 W/ft ²
Dining areas	0.156 W/ft ²	0.273 W/ft ²	0.390 W/ft ²	0.546 W/ft ²
Stairways	Exempt	Exempt	Exempt	Exempt
Pedestrian tunnels	0.063 W/ft ²	0.110 W/ft ²	0.157 W/ft ²	0.220 W/ft ²
Landscaping	0.014 W/ft ²	0.025 W/ft ²	0.036 W/ft ²	0.050 W/ft ²
Pedestrian and vehicular entrances and exits	5.6 W/linear foot of opening	9.8 W/linear foot of opening	14 W/linear foot of opening	19.6 W/linear foot of opening
Entry canopies	0.072 W/ft ²	0.126 W/ft ²	0.180 W/ft ²	0.252 W/ft ²
Loading docks	0.104 W/ft ²	0.182 W/ft ²	0.260 W/ft ²	0.364 W/ft ²

Free-standing and attached	0.20 W/ft ²	0.35 W/ft ²	0.50 W/ft ²	0.70 W/ft ²
Open areas (including vehicle sales lots)	0.072 W/ft ²	0.126 W/ft ²	0.180 W/ft ²	0.252 W/ft ²
Street frontage for vehicle sales lots in addition to "open area" allowance	No allowance	7.2 W/linear foot	10.3 W/linear foot	14.4 W/linear foot

For SI: 1 foot = 304.8 mm, 1 watt per square foot = 10.76 W/m², W = Watt.

Staff Classification	Correlates Directly	Energy Standard Needed	Over top
AS	x		
AS/IC			
D			
ESC			

FSEC – Anticipated energy impact on FBC-EC – Decrease

CE#252 Updates the individual exterior lighting power allowance values in Table C405.5.2(3). Reduces the individual lighting power allowances based on advances in lighting technology and aligns with ASHRAE 90.1 requirements. It increases the stringency but has no impact on the construction cost.

Related Mods:
CEPI- 189-21,
CEPI- 254-21,
CECD1- 23-22
FBC –
C405.4.2

Delete entire Table
TABLE C405.5.2(3)
INDIVIDUAL LIGHTING POWER ALLOWANCES FOR BUILDING EXTERIORS
TABLE C405.5.2(3)
INDIVIDUAL LIGHTING POWER ALLOWANCES FOR BUILDING EXTERIORS
LIGHTNING ZONES

	Zone 1	Zone 2	Zone 3	Zone 4
Building facades	No allowance	0.075 W/ft ² of gross above-grade wall area	0.113 W/ft ² of gross above-grade wall area	0.15 W/ft ² of gross above-grade wall area
Automated teller machines (ATM) and night depositories	90 W per location plus 35W per additional ATM per location			
Uncovered entrances and gatehouse inspection stations at guarded facilities	0.144 W/ft ² of area	0.252 W/ft ² of area	0.360 W/ft ² of area	0.504 W/ft ² of area
Uncovered loading areas for law enforcement, fire, ambulance and other emergency service vehicles	0.104 W/ft ² of area	0.182 W/ft ² of area	0.260 W/ft ² of area	0.364 W/ft ² of area
Drive-up windows and doors	53 W per drive-through	92 W per drive-through	132 W per drive-through	185 W per drive-through
Parking area near 24-hour retail entrances	80 W per main entry	140 W per main entry	200 W per main entry	280 W per main entry

For SI: 1 watt per square foot = 10.76 W/m², W = Watts.
FSEC – Anticipated energy impact on FBC-EC – Decrease

Staff Classification	Correlates Directly	Energy Standard Needed	Over top
	x		
AS			
AS/IC			
D			
ESC			

CE#253 Revises the exception per the DOE definition of Distribution Transformers found in 10 CFR 431.192.

Related Mods: FBC – C405.6	<p>C405.7 Electrical transformers. Low-voltage dry-type distribution electric transformers shall meet the minimum efficiency requirements of Table C405.7 as tested and rated in accordance with the test procedure <i>listed in DOE 10 CFR 431</i>. The efficiency shall be verified through certification under an <i>approved</i> certification program or, where a certification program does not exist, the equipment efficiency ratings shall be supported by data furnished by the transformer manufacturer.</p> <p>Exceptions: The following transformers are exempt <i>in accordance with the DOE definition of Distribution Transformers found in 10 CFR 431.192</i>:</p> <p>1—Transformers that meet the <i>Energy Policy Act of 2005—exclusions based on the—DOE—10 CFR 431 definition of special purpose applications</i>;</p> <p>2—Transformers that meet the <i>Energy Policy Act of 2005—exclusions that are not to be used in general purpose applications based on information provided in DOE 10 CFR 431</i>;</p> <p>3—1—Transformers that meet the <i>Energy Policy Act of 2005—exclusions with multiple voltage taps where the highest tap is not less than 20 percent more than the lowest tap—with a tap range of 20 percent or more</i>;</p> <p>4—2—Drive (<i>isolation</i>) transformers;</p> <p>5—3—Rectifier transformers;</p> <p>6—4—Auto transformers;</p> <p>7—5—Uninterruptible power system transformers;</p> <p>8—6—Impedance <i>Special impedance</i> transformers;</p> <p>9—7—Regulating transformers;</p> <p>10—8—Sealed and nonventilating <i>transformers</i>;</p> <p>11—9—Machine tool (<i>control</i>) transformers;</p> <p>12—10—Welding transformers;</p> <p>13—11—Grounding transformers;</p> <p>14—12—Testing transformers;</p> <p>13. Nonventilated transformers.</p>
----------------------------------	---

Staff Classification	Correlates Directly	Energy Standard Needed	Over top
AS	x		
AS/IC			
D			
ESC			

CE#254 Adds a new footnote and renumbers the existing ones for clarification. No impact on the stringency and construction cost.

Related Mods: CEPI- 192-21 FBC --	TABLE C405.7			
	MINIMUM NOMINAL EFFICIENCY LEVELS FOR DOE 10 CFR 431 LOW-VOLTAGE TRANSFORMERS DRY-TYPE DISTRIBUTION			
	SINGLE-PHASE		THREE-PHASE TRANSFORMERS ^a	
	kVA ^a	Efficiency (%) ^{b, c}	kVA ^{a, b}	Efficiency (%) ^{b, c}
C405.6	15	97.70	15	97.89
	25	98.00	30	98.23
	37.5	98.20	45	98.40
	50	98.30	75	98.60
	75	98.50	112.5	98.74
	100	98.60	150	98.83
	167	98.70	225	98.94

	<table><tr><td>250</td><td>98.80</td><td>300</td><td>99.02</td></tr><tr><td>333</td><td>98.90</td><td>500</td><td>99.14</td></tr><tr><td>—</td><td>—</td><td>750</td><td>99.23</td></tr><tr><td>—</td><td>—</td><td>1000</td><td>99.28</td></tr></table> <p>a. kiloVolt-Amp rating—A low-voltage dry-type distribution transformer with a kVA rating not listed in the table shall have its minimum efficiency level determined by linear interpolation of the kVA and efficiency values listed in the table immediately above and below its kVA rating. Extrapolation shall not be used below the minimum values or above the maximum values shown for single-phase transformers and three-phase transformers.</p> <p>b. kiloVolt-Amp rating.</p> <p>b-e. Nominal efficiencies shall be established in accordance with the DOE 10 CFR 431 test procedure for low-voltage dry-type transformers.</p>	250	98.80	300	99.02	333	98.90	500	99.14	—	—	750	99.23	—	—	1000	99.28	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>ASDC</td><td>ASDC</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ASDC	ASDC		x		
250	98.80	300	99.02																															
333	98.90	500	99.14																															
—	—	750	99.23																															
—	—	1000	99.28																															
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																															
	x																																	
Action	AS	ASDC	ASDC																															
	x																																	
CE#255	Adds a new exception, item #6, that says, "Definite-purpose machines within the scope of ANSI/NEMA MG 1, Part 18." This new exception prevents the construction increase.																																	
Related Mods: FBC – C405.7	<p>C405.8 Electric motors. Electric motors shall meet the minimum efficiency requirements of Tables C405.8(1) through C405.8(4) when tested and rated in accordance with the DOE 10 CFR 431. The efficiency shall be verified through certification under an approved certification program or, where a certification program does not exist, the equipment efficiency ratings shall be supported by data furnished by the motor manufacturer.</p> <p>Exception: The standards in this section shall not apply to the following exempt electric motors:</p> <ol style="list-style-type: none">1. Air-over electric motors.2. Component sets of an electric motor.3. Liquid-cooled electric motors.4. Submersible electric motors.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>ASDC</td><td>ASDC</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ASDC	ASDC		x																		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																															
	x																																	
Action	AS	ASDC	ASDC																															
	x																																	
	<ol style="list-style-type: none">5. Inverter-only electric motors.6. Definite-purpose machines within the scope of ANSI/NEMA MG 1, Part 18.																																	
CE#256	<p>It adds a new Section C405.9 by moving the provision from Section C405.1 and aligns the requirement with the ASHRAE Standard 90.4 for computer rooms. This change may increase the stringency of computer room requirements and hence the construction cost.</p> <p>It adds a new subsection C405.9.1 for data centers by moving data center requirements from Section C405.1. No impact on the stringency.</p> <p>It adds a new Section C405.9.2 for computer rooms that aligns with ASHRAE Standard 90.4. This change increases the stringency of computer rooms code provision; hence, the construction cost of computer rooms.</p>																																	
Related Mods: CEPI- 134-21, CED1-78- 22	<p>C405.9 Data centers and computer rooms. Electrical equipment in data centers and computer rooms shall comply with this section.</p> <p>C405.9.1 Data centers. Transformers, uninterruptible power supplies, motors and electrical power processing equipment in data centers shall comply with Section 8 of ASHRAE 90.4 in addition to this code.</p> <p>C405.9.2 Computer rooms. Uninterruptible power supplies in computer rooms shall comply with the requirements in Tables 8.5 and 8.6 of ASHRAE 90.4 in addition to this code.</p> <p>Exception: AC-output UPS that utilizes standardized NEMA 1-15P or NEMA 5-15P input plug, as specified in ANSI/NEMA WD-6</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>ASDC</td><td>ASDC</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ASDC	ASDC		x																		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																															
	x																																	
Action	AS	ASDC	ASDC																															
	x																																	
CE#257	Renumbers Section C405.9. C405.9.1, C405.9.2. Renumbers C405.11. C405.12. C405.12.1.																																	
Related Mods:	<p>C405.9-C405.10 Vertical and horizontal transportation systems and equipment.</p> <p>C405.9.1-C405.10.1 Elevator cabs:</p> <p>C405.9.2-C405.10.2 Escalators and moving walks.</p> <p>C405.9.2.1-C405.10.2.1 Energy recovery.</p> <p>C405.10-C405.11 Voltage drop:</p> <p>C405.11-C405.12 Automatic receptacle control:</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>ASDC</td><td>ASDC</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ASDC	ASDC		x																		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																															
	x																																	
Action	AS	ASDC	ASDC																															
	x																																	
	C405.11.1-C405.12.1 Automatic receptacle control function																																	
CE#258	<p>Renumbers Section C405.12. Reduces the building floor area threshold for energy monitoring from 25,000 ft2 to 10,000 ft2, makes editorial changes, updates referenced code section, and adds a new exceptions for dwelling units. Increases the stringency by reducing the floor area threshold but exempts all residential unit, which may reduce the stringency. Therefore, the stringency may increase depending on the building occupancy group but is a cost- effective change.</p> <p>Renumbers subsection C405.12.1. Renumbers subsection C405.12.2 and replaces the text "measured load" with "design load."</p>																																	
Related Mods: CEPI- 138-21, CEPI- 203-21, CED1-31- 22, CED1-30- 22, CE2D-29- 23, CE2D-33- 23	<p>C405.12-C405.13 Energy monitoring. New buildings with a gross conditioned floor area of 25,000 square feet (2322 m²) or larger not less than 10,000 square feet (929 m²) shall be equipped to measure, monitor, record and report energy consumption data in compliance accordance with Sections C405.13.1 through C405.13.6 for load categories indicated in Table C405.13.2 and Sections C405.13.7 through C405.13.11 for end-use categories indicated in Table C405.13.8. Exception: R-2 occupancies and individual tenant spaces are not required to comply with this section provided that the space has its own utility services and meters and has less than 5,000 square feet (464.5 m2) of conditioned floor area:</p> <p>Exceptions:</p> <ol style="list-style-type: none">1. Dwelling units in R-2 occupancies.2. Individual tenant spaces are not required to comply with this section provided that the space has its own utility services and meters and has less than 5,000 square feet (464.5 m²) of conditioned floor area. <p>C405.12.1-C405.13.1 Electrical energy metering. For all electrical energy supplied to the building and its associated site, including but not limited to site lighting, parking, recreational facilities and other areas that serve the building and its occupants, meters or other measurement devices shall be provided to collect energy consumption data for each end-use category required by Section C405.13.2.</p> <p>C405.12.2-C405.13.2 End-use electric metering categories. Meters or other approved measurement devices shall be provided to collect energy use data for each end-use category indicated in Table C405.13.2. Where multiple meters are used to measure any end-use category, the data acquisition system shall total all of the energy used by that category. Not more than 5 percent of the measured design load for each of the end-use categories indicated in Table C405.13.2 shall be permitted to be from a load that is not within that category.</p> <p>Exceptions:</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>ASDC</td><td>ASDC</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <p>Original text of mod is not consistent with that of the 2023 FBC – EC.</p>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ASDC	ASDC		x																		
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																															
	x																																	
Action	AS	ASDC	ASDC																															
	x																																	

		FSEC – Anticipated energy impact on FBC-EC – Decrease																																
CE#259	Renumbers Table C405.12.2, renames the title, edits texts for clarity, and adds “Electric hot water heating for uses other than space conditioning” as a new energy use category.																																	
Related Mods: CE2D-33- 23, CED1-30- 22, CED1-36- 22, CEAPP- 01-24	<div>TABLE C405.12.2-TABLE C405.13.2 ELECTRICAL ENERGY-USE CATEGORIES</div> <div>DESCRIPTION OF ENERGY USE</div> <table><tr><td>Total HVAC system</td><td>Heating, cooling and ventilation, including but not limited to fans, pumps, boilers, chillers and water heating. Energy used by 120-volt equipment, or by 208/ 120-volt equipment that is located in a building where the main service is 480/ 277-volt power, is permitted to be excluded from total HVAC system energy use.</td></tr><tr><td>Interior lighting</td><td>Lighting systems located within the building.</td></tr><tr><td>Exterior lighting</td><td>Lighting systems located on the building site but not within the building.</td></tr><tr><td>Plug loads</td><td>Devices, appliances and equipment connected to convenience receptacle outlets.</td></tr><tr><td>Process load</td><td>Any single load that is not included in an HVAC, lighting or plug load category and that exceeds 5 percent of the peak connected load of the whole building, including but not limited to data centers, manufacturing equipment and commercial kitchens.</td></tr><tr><td>Building operations and other miscellaneous loads</td><td>The remaining loads not included elsewhere in this table, including but not limited to vertical transportation systems, automatic doors, motorized shading systems, ornamental fountains, ornamental fireplaces, swimming pools, in-ground spas and snow-melt systems.</td></tr><tr><td>Electric hot water heating for uses other</td><td>Electricity used to generate hot water. Exception: Electric water heating with design capacity that is less than 10 percent of the building service rating.</td></tr></table> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Required</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DEC</td></tr><tr><td></td><td></td><td></td><td>*</td><td></td></tr></table></div>		Total HVAC system	Heating, cooling and ventilation, including but not limited to fans, pumps, boilers, chillers and water heating. Energy used by 120-volt equipment, or by 208/ 120-volt equipment that is located in a building where the main service is 480/ 277-volt power, is permitted to be excluded from total HVAC system energy use.	Interior lighting	Lighting systems located within the building.	Exterior lighting	Lighting systems located on the building site but not within the building.	Plug loads	Devices, appliances and equipment connected to convenience receptacle outlets.	Process load	Any single load that is not included in an HVAC, lighting or plug load category and that exceeds 5 percent of the peak connected load of the whole building, including but not limited to data centers, manufacturing equipment and commercial kitchens.	Building operations and other miscellaneous loads	The remaining loads not included elsewhere in this table, including but not limited to vertical transportation systems, automatic doors, motorized shading systems, ornamental fountains, ornamental fireplaces, swimming pools, in-ground spas and snow-melt systems.	Electric hot water heating for uses other	Electricity used to generate hot water. Exception: Electric water heating with design capacity that is less than 10 percent of the building service rating.	Staff Classification	Correlates Directly	Energy Standard Required	Over lap					Action	AS	AS/EC	D	DEC				*	
Total HVAC system	Heating, cooling and ventilation, including but not limited to fans, pumps, boilers, chillers and water heating. Energy used by 120-volt equipment, or by 208/ 120-volt equipment that is located in a building where the main service is 480/ 277-volt power, is permitted to be excluded from total HVAC system energy use.																																	
Interior lighting	Lighting systems located within the building.																																	
Exterior lighting	Lighting systems located on the building site but not within the building.																																	
Plug loads	Devices, appliances and equipment connected to convenience receptacle outlets.																																	
Process load	Any single load that is not included in an HVAC, lighting or plug load category and that exceeds 5 percent of the peak connected load of the whole building, including but not limited to data centers, manufacturing equipment and commercial kitchens.																																	
Building operations and other miscellaneous loads	The remaining loads not included elsewhere in this table, including but not limited to vertical transportation systems, automatic doors, motorized shading systems, ornamental fountains, ornamental fireplaces, swimming pools, in-ground spas and snow-melt systems.																																	
Electric hot water heating for uses other	Electricity used to generate hot water. Exception: Electric water heating with design capacity that is less than 10 percent of the building service rating.																																	
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																															
Action	AS	AS/EC	D	DEC																														
			*																															
CE#260	Renumbers Section C405.12.3, renames the title and edits the code language for clarity. Renumbers Section C405.12.4, renames the title and edits the code language for clarity. Renumbers Section C405.12.5 and edits the code language for clarity.																																	
Related Mods: CEPI- 203-21,	C405.12.3 C405.13.3 Meters- Electrical meters- Meters or other measurement devices required by this section shall be configured to automatically communicate energy consumption data to the data acquisition system required by Section C405.13.4. Source e-meters shall be allowed to be any digital-type meter. Lighting, HVAC or other building systems that can																																	
CE2D-33- 23, CED1-30- 22	<p>self-monitor their energy consumption shall be permitted instead of meters. Current sensors shall be permitted, provided that they have a tested accuracy of ±2 percent. Required metering systems and equipment shall have the capability to provide at least hourly data that is fully integrated into the data acquisition system and graphical energy report in accordance with Sections C405.13.4 and C405.13.5. Nonintrusive load monitoring (NILM) packages that extract energy consumption data from detailed electric waveform analysis shall be permitted to substitute for individual meters if the equivalent data is available for collection in Section C405.13.4 and reporting in Section C405.13.5.</p> <p>C405.12.4 C405.13.4 Data-Electrical energy data acquisition system.- A data acquisition system shall have the capability to store the data from the required meters and other sensing devices for a minimum of 36 months. The data acquisition system shall have the capability to store real-time energy consumption data and provide hourly, daily, monthly and yearly logged data for each end-use category required by Section C405.13.2. The data acquisition system shall have the capability of providing building total peak electric demand and the time(s) of day and time(s) per month at which the peak occurs. Peak demand shall be integrated over the same time period as the underlying whole-building meter reading rate.</p> <p>C405.12.5 C405.13.5 Graphical energy report.- A permanent and readily accessible available reporting mechanism shall be provided in the building that is accessible for access by building operation and management personnel. The reporting mechanism shall have the capability to graphically provide the energy consumption for each end-use category required by Section C405.13.2 at least not less than every hour, day, month and year for the previous 36 months</p> <p>Original text of mod is not consistent with that of the 2023 FBC – EC.</p>																																	
CE#261	Adds a new subsection C405.13.6. Adds a new subsection C405.13.7. Adds a new subsection C405.13.8. Adds a new Table C405.13.8. Adds a new subsection C405.13.9. Adds a new subsection C405.13.10. Adds a new subsection C405.13.11.																																	
Related Mods: CE2D-33- 23	<p>C405.13.6 Renewable energy. On-site renewable energy sources shall be metered with no less frequency than nonrenewable energy systems in accordance with Section C405.13.3.</p> <p>C405.13.7 Nonelectrical energy submetering. For all nonelectrical energy supplied to the building and its associated site that serves the building and its occupants, submeters or other measurement devices shall be provided to collect energy consumption data for each end-use category required by Section C405.13.8.</p> <p>Exceptions:</p> <ol style="list-style-type: none">1. HVAC and water heating equipment serving only an individual dwelling unit shall not require end-use submetering.2. End-use submetering shall not be required for fire pumps, stairwell pressurization fans or any system that operates only during testing or emergency.3. End-use submetering shall not be required for an individual tenant space having a floor area not greater than 2,500 square feet (232 m²) where a dedicated source meter complying with Section C405.13.9 is provided.4. Equipment powered primarily by solid fuels serving loads other than building heating and service water heating loads.																																	
	<div>TABLE C405.13.8</div> <div>DESCRIPTION OF ENERGY USE</div> <table><tr><td>Total HVAC system</td><td>Heating, cooling and ventilation, including but not limited to fans, pumps, boilers, chillers and water heating. Energy used by 120-volt equipment, or by 208/ 120-volt equipment that is located in a building where the main service is 480/ 277-volt power, is permitted to be excluded from total HVAC system energy use.</td></tr><tr><td>Interior lighting</td><td>Lighting systems located within the building.</td></tr><tr><td>Exterior lighting</td><td>Lighting systems located on the building site but not within the building.</td></tr><tr><td>Plug loads</td><td>Devices, appliances and equipment connected to convenience receptacle outlets.</td></tr><tr><td>Process load</td><td>Any single load that is not included in an HVAC, lighting or plug load category and that exceeds 5 percent of the peak connected load of the whole building, including but not limited to data centers, manufacturing equipment and commercial kitchens.</td></tr><tr><td>Building operations and other miscellaneous loads</td><td>The remaining loads not included elsewhere in this table, including but not limited to vertical transportation systems, automatic doors, motorized shading systems, ornamental fountains, ornamental fireplaces, swimming pools, in-ground spas and snow-melt systems.</td></tr><tr><td>Electric hot water heating for uses other</td><td>Electricity used to generate hot water. Exception: Electric water heating with design capacity that is less than 10 percent of the building service rating.</td></tr></table> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Required</td><td>Over lap</td></tr><tr><td></td><td></td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DEC</td></tr><tr><td></td><td></td><td></td><td>*</td><td></td></tr></table></div>		Total HVAC system	Heating, cooling and ventilation, including but not limited to fans, pumps, boilers, chillers and water heating. Energy used by 120-volt equipment, or by 208/ 120-volt equipment that is located in a building where the main service is 480/ 277-volt power, is permitted to be excluded from total HVAC system energy use.	Interior lighting	Lighting systems located within the building.	Exterior lighting	Lighting systems located on the building site but not within the building.	Plug loads	Devices, appliances and equipment connected to convenience receptacle outlets.	Process load	Any single load that is not included in an HVAC, lighting or plug load category and that exceeds 5 percent of the peak connected load of the whole building, including but not limited to data centers, manufacturing equipment and commercial kitchens.	Building operations and other miscellaneous loads	The remaining loads not included elsewhere in this table, including but not limited to vertical transportation systems, automatic doors, motorized shading systems, ornamental fountains, ornamental fireplaces, swimming pools, in-ground spas and snow-melt systems.	Electric hot water heating for uses other	Electricity used to generate hot water. Exception: Electric water heating with design capacity that is less than 10 percent of the building service rating.	Staff Classification	Correlates Directly	Energy Standard Required	Over lap					Action	AS	AS/EC	D	DEC				*	
Total HVAC system	Heating, cooling and ventilation, including but not limited to fans, pumps, boilers, chillers and water heating. Energy used by 120-volt equipment, or by 208/ 120-volt equipment that is located in a building where the main service is 480/ 277-volt power, is permitted to be excluded from total HVAC system energy use.																																	
Interior lighting	Lighting systems located within the building.																																	
Exterior lighting	Lighting systems located on the building site but not within the building.																																	
Plug loads	Devices, appliances and equipment connected to convenience receptacle outlets.																																	
Process load	Any single load that is not included in an HVAC, lighting or plug load category and that exceeds 5 percent of the peak connected load of the whole building, including but not limited to data centers, manufacturing equipment and commercial kitchens.																																	
Building operations and other miscellaneous loads	The remaining loads not included elsewhere in this table, including but not limited to vertical transportation systems, automatic doors, motorized shading systems, ornamental fountains, ornamental fireplaces, swimming pools, in-ground spas and snow-melt systems.																																	
Electric hot water heating for uses other	Electricity used to generate hot water. Exception: Electric water heating with design capacity that is less than 10 percent of the building service rating.																																	
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																															
Action	AS	AS/EC	D	DEC																														
			*																															

Related Mods: CECPI-2- 21, CED1-50- 22, CED1-55- 22, CED1-56- 22	<p>C405.15.2.1 Off-site procurement. The building owner, as defined in the <i>International Building Code</i>, shall procure and be credited for the total amount of off-site renewable electrical energy, not less than required in accordance with Equation 4-11, with one or more of the following:</p> <ol style="list-style-type: none">1. <i>Physical renewable energy power purchase agreement.</i>2. <i>Financial renewable energy power purchase agreement.</i>3. <i>Community renewable energy facility.</i>4. <i>Off-site renewable energy system owned by the building property owner.</i>5. <i>Renewable energy investment fund.</i>6. <i>Green retail tariff.</i> <p>The generation source shall be located where the energy can be delivered to the</p>																												
	<p>building site by any of the following:</p> <ol style="list-style-type: none">1. Direct connection to the off-site renewable energy facility.2. The local utility or distribution entity.3. An interconnected electrical network where energy delivery capacity between the generator and the building site is available. <p>C405.15.2.2 Off-site contract. The renewable energy shall be delivered or credited to the building site under an energy contract with a duration of not less than 10 years. The contract shall be structured to survive a partial or full transfer of ownership of the building property.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>x</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	D			x	D/EC												
Staff Classification	Correlates Directly	Energy Standard	Over lap																										
	x																												
Action	AS	AS/EC	D																										
		x	D/EC																										
CE#265	Adds a new Table C405.15.2.																												
Related Mods:	<p>TABLE C405.15.2 ANNUAL OFF-SITE RENEWABLE ENERGY REQUIREMENTS</p> <table><tr><th></th><th>CLIMATE ZONE</th><th>ANNUAL OFF-SITE RENEWABLE ELECTRICAL ENERGY (kWh/ W)</th></tr><tr><td></td><td>1A, 2B, 3B, 3C, 4B and 5B</td><td>1.75</td></tr><tr><td></td><td>0A, 0B, 1B, 2A, 3A and 6B</td><td>1.55</td></tr><tr><td></td><td>4A, 4C, 5A, 5C, 6A and 7</td><td>1.35</td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>x</td><td>D/EC</td></tr></table>		CLIMATE ZONE	ANNUAL OFF-SITE RENEWABLE ELECTRICAL ENERGY (kWh/ W)		1A, 2B, 3B, 3C, 4B and 5B	1.75		0A, 0B, 1B, 2A, 3A and 6B	1.55		4A, 4C, 5A, 5C, 6A and 7	1.35	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	D			x	D/EC
	CLIMATE ZONE	ANNUAL OFF-SITE RENEWABLE ELECTRICAL ENERGY (kWh/ W)																											
	1A, 2B, 3B, 3C, 4B and 5B	1.75																											
	0A, 0B, 1B, 2A, 3A and 6B	1.55																											
	4A, 4C, 5A, 5C, 6A and 7	1.35																											
Staff Classification	Correlates Directly	Energy Standard	Over lap																										
	x																												
Action	AS	AS/EC	D																										
		x	D/EC																										
CE#266	Adds a new subsection C405.15.3. Adds a new subsection C405.15.4.																												
Related Mods:	<p>C405.15.3 Renewable energy certificate (REC) documentation. The property owner or owner's authorized agent shall demonstrate that where renewable energy certificates (RECs) or energy attribute certificates (EACs) are associated with on-site</p>																												
CECPI-2- 21, CED1-50- 22	<p>and off-site renewable energy production required by Sections C405.15.1 and C405.15.2, all of the following criteria for RECs and EACs shall be met:</p> <ol style="list-style-type: none">1. The RECs and EACs are retained and retired by or on behalf of the property owner or tenant for a period of not less than 15 years or the duration of the contract in Section C405.15.2.2, whichever is less.2. The RECs and EACs are created within a 12-month period of the use of the REC.3. The RECs and EACs are from a generating asset placed in service not more than 5 years before the issuance of the certificate of occupancy. <p>C405.15.4 Renewable energy certificate purchase. A building that qualifies for one or more of the exceptions to Section C405.15.1, and where it can be demonstrated to the code official that the requirements of Section C405.15.2 cannot be met, the building owner shall contract the purchase of renewable electricity products before the certificate of occupancy is issued. The purchase of renewable electricity products shall comply with the Green-e Energy National Standard for renewable electricity products equivalent to five times the amount of total off-site renewable energy calculated in accordance with Equation 4-11.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>x</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	D			x	D/EC												
Staff Classification	Correlates Directly	Energy Standard	Over lap																										
	x																												
Action	AS	AS/EC	D																										
		x	D/EC																										
CE#267	Adds a new Section C405.16. This change slightly increase stringency and hence the construction cost but is cost-effective.																												
Related Mods: CEPI- 142-21	<p>C405.16 Inverters. Direct-current-to-alternating-current inverters serving on-site renewable energy systems or on-site electrical energy storage systems (ESS) shall be compliant with IEEE 1547 and UL 1741.</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>x</td><td>D/EC</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	D			x	D/EC												
Staff Classification	Correlates Directly	Energy Standard	Over lap																										
	x																												
Action	AS	AS/EC	D																										
		x	D/EC																										
CE#268	Deletes the existing Section C406 and replaces it with an expanded scope Section C406 measures to choose from and renames the title. Separate new measures for renewable energy and load management requirements. Increased the number of energy efficiency measures to 32 from 11 that provide design flexibility.																												
Related Mods: CEPI- 193-21	<p>SECTION C406 ADDITIONAL EFFICIENCY, RENEWABLE AND LOAD MANAGEMENT REQUIREMENTS</p> <p>C406.1 Additional energy efficiency credit requirements. New buildings shall achieve a total of 10 credits from Tables C406.1(1) through C406.1(5) where the table is selected based on the use group of the building and from credit calculations as</p>																												

	<p>specified in relevant subsections of Section C406. Where a building contains multiple use groups, credits from each use group shall be weighted by floor area of each group to determine the weighted average building credit. Credits from the tables or calculation shall be achieved where a building complies with one or more of the following:</p> <p>1—More efficient HVAC performance in accordance with Section C406.2;</p> <p>2—Reduced lighting power in accordance with Section C406.3;</p> <p>3—Enhanced lighting controls in accordance with Section C406.4;</p> <p>4—On-site supply of renewable energy in accordance with Section C406.5;</p> <p>5—Provision of a dedicated outdoor air system for certain HVAC equipment in accordance with Section C406.6;</p> <p>6—High efficiency service water heating in accordance with Section C406.7;</p> <p>7—Enhanced envelope performance in accordance with Section C406.8;</p> <p>8—Reduced air infiltration in accordance with Section C406.9;</p> <p>9—Where not required by Section C405.13, include an energy monitoring system in accordance with Section C406.10;</p> <p>10—Where not required by Section C403.2.3, include a fault detection and diagnostics (FDD) system in accordance with Section C406.11;</p> <p>11—Efficient kitchen equipment in accordance with Section C406.12.</p> <p>C406.1.1 Tenant spaces. Tenant spaces shall comply with sufficient options from Tables C406.1(1) through C406.1(5) to achieve a minimum number of 5 credits, where credits are selected from Section C406.2, C406.3, C406.4, C406.6, C406.7 or C406.10. Where the entire building complies using credits from Section C406.5, C406.8 or C406.9, tenant spaces shall—be deemed to comply with this section.</p> <p>Exception: Previously occupied tenant spaces that comply with this code in accordance with Section C501.</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><td>Action</td><td>AS</td><td>SLC</td><td>D</td><td>DLC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	SLC	D	DLC				x																																																								
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																																																																								
			x																																																																								
Action	AS	SLC	D	DLC																																																																							
			x																																																																								
CE#269	Deletes Tables C406.1(1) through C406.1(5)																																																																										
Related Mods: CEPI- 193-21, CED1- 190-22	Delete entire tables: TABLE C406.1(1) ADDITIONAL ENERGY EFFICIENCY CREDITS FOR GROUP B OCCUPANCIES TABLE C406.1(2) ADDITIONAL ENERGY EFFICIENCY CREDITS FOR GROUP R AND I OCCUPANCIES TABLE C406.1(3) ADDITIONAL ENERGY EFFICIENCY CREDITS FOR GROUP E OCCUPANCIES																																																																										
	TABLE C406.1(4) ADDITIONAL ENERGY EFFICIENCY CREDITS FOR GROUP M OCCUPANCIES TABLE C406.1(5) ADDITIONAL ENERGY EFFICIENCY CREDITS FOR OTHER OCCUPANCIES	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr></table> <table><tr><td>Action</td><td>AS</td><td>SLC</td><td>D</td><td>DLC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	SLC	D	DLC				x																																																								
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																																																																								
			x																																																																								
Action	AS	SLC	D	DLC																																																																							
			x																																																																								
CE#270	This amendment renames the title and rearranges the subsection for on-site renewable energy generation and load management requirements. It moves some of the section content to a new subsection, C406.1.1. It adds a new subsection, C406.1.1, that specifies the energy credit requirements by building occupancy group and climate zones. The building occupancy group has been increased, and efficiency measures have been expanded, which provides design flexibility by better matching the measures with building occupancy group. Most of the new measures may increase the stringency but are cost-effective.																																																																										
Related Mods: CEPI- 193-21, CED1- 185-22, CED1- 187-22, CED1- 190-22, CE2D- 51- 23	<p>C406.1 Compliance. Buildings shall comply as follows:</p> <p>1. Buildings with greater than 2,000 square feet (186 m²) of conditioned floor area shall comply with Section C406.1.1.</p> <p>2. Buildings with greater than 5,000 square feet (465 m²) of conditioned floor area shall comply with Sections C406.1.1 and C406.1.2.</p> <p>3. Build-out construction greater than 1,000 square feet (93 m²) of conditioned floor area that does not have final lighting or final HVAC systems installed under a prior building permit shall comply with Section C406.1.1.2.</p> <p>Exceptions: Core and shell buildings where not less than 20 percent of the net floor area is without final lighting or final HVAC that comply with all of the following:</p> <p>1. Buildings with greater than 5,000 square feet (465 m²) of conditioned floor area shall comply with Section C406.1.2.</p> <p>2. Portions of the building where the net floor area is without final lighting or final HVAC shall comply with Section C406.1.1.2.</p> <p>3. Portions of the building where the net floor area has final lighting and final HVAC systems shall comply with Section C406.1.1.</p> <p>C406.1.1 Additional energy efficiency credit requirements. Buildings shall comply with measures from Section C406.2 to achieve not less than the number of required efficiency credits from Table C406.1.1(1) based on building occupancy group and climate zone. Where a project contains multiple occupancies, the total required energy credits from each building occupancy shall be weighted by the gross conditioned floor area to determine the weighted-average project energy credits required.</p> <p>Accessory occupancies shall be included with the primary occupancy group for the purposes of Section C406.</p> <p>Exceptions:</p> <p>1. Portions of buildings devoted to manufacturing or industrial use.</p> <p>2. Where a building achieves more renewable and load management credits in Section C406.3 than are required in Section C406.1.2, surplus credits shall be permitted to reduce the required energy efficiency credits as follows:</p>																																																																										
	<p>(Equation 4-12)</p> <p>where:</p> $EEC_{red} = EEC_{tbl} - \{ \text{the lesser of: } [SLRM_{lim}, SLRM_{adj}] \times (RLM_{ach} - RLM_{req}) \}$ <p>EEC_{red} = Reduced required energy efficiency credits;</p> <p>EEC_{tbl} = Required energy efficiency credits from Table C406.1.1(1);</p> <p>$SLRM_{lim}$ = Surplus renewable and load management credit limit from Table C406.1.1(2);</p> <p>$SLRM_{adj}$ = 1.0 for all-electric or all-renewable buildings (excluding emergency generation); 0.7 for buildings with fossil fuel equipment (excluding emergency generation);</p> <p>RLM_{ach} = Achieved renewable and load management credits from Section C406.3; RLM_{req} = Required renewable and load management credits from Section C406.1.2</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td>x</td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>SLC</td><td>D</td><td>DLC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap			x		Action	AS	SLC	D	DLC				x																																																								
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																																																																								
		x																																																																									
Action	AS	SLC	D	DLC																																																																							
			x																																																																								
CE#271	It adds a new Table, C406.1.1(1), specifying the energy credit requirements by building occupancy group and climate zones. Increased the number of measures to 32 from 11 and expanded the building occupancy group that provides design flexibility.																																																																										
Related Mods: CEPI- 193-21, CED1- 190-22	TABLE C406.1.1(1) ENERGY CREDIT REQUIREMENTS BY BUILDING OCCUPANCY GROUP	<table><tr><th rowspan="2">BUILDING OCCUPANCY GROUP</th><th colspan="16">CLIMATE ZONE</th></tr><tr><th>0A</th><th>0B</th><th>1A</th><th>1B</th><th>2A</th><th>2B</th><th>3A</th><th>3B</th><th>3C</th><th>4A</th><th>4B</th><th>4C</th><th>5A</th><th>5B</th><th>5C</th><th>6A</th><th>6B</th><th>7</th></tr><tr><td>R-2, R-4 and I-1</td><td>65</td><td>66</td><td>67</td><td>77</td><td>80</td><td>86</td><td>80</td><td>81</td><td></td><td>86</td><td>88</td><td>90</td><td>86</td><td>90</td><td>90</td><td>70</td><td>68</td><td>60</td></tr><tr><td>I-2</td><td>43</td><td>42</td><td>38</td><td>37</td><td>36</td><td>38</td><td>32</td><td>32</td><td></td><td>36</td><td>34</td><td>35</td><td>43</td><td>43</td><td>44</td><td>46</td><td>47</td><td>50</td></tr></table>	BUILDING OCCUPANCY GROUP	CLIMATE ZONE																0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	R-2, R-4 and I-1	65	66	67	77	80	86	80	81		86	88	90	86	90	90	70	68	60	I-2	43	42	38	37	36	38	32	32		36	34	35	43	43	44	46	47	50
BUILDING OCCUPANCY GROUP	CLIMATE ZONE																																																																										
	0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7																																																									
R-2, R-4 and I-1	65	66	67	77	80	86	80	81		86	88	90	86	90	90	70	68	60																																																									
I-2	43	42	38	37	36	38	32	32		36	34	35	43	43	44	46	47	50																																																									

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

C406.2 Additional energy efficiency credits achieved. Each energy efficiency credit measure used to meet credit requirements for the project shall have efficiency that is greater than the requirements in Sections C402 through C405. Measures installed in the project that meet the requirements in Sections C406.2.1 through C406.2.6 shall achieve the base credits listed for the measure and occupancy type in Tables C406.2(1) through C406.2(9), or where calculations required by Sections C406.2.1 through C406.2.6 create or modify the table credits, the credits achieved shall be based on the calculations. Energy credits achieved for measures shall be determined by one of the following, as applicable:

1. The measure's energy credit shall be the base energy credit from Tables C406.2(1) through C406.2(9) for the measure where no adjustment factor or calculation is included in the description of the measure in Section C406.2.
2. The measure's energy credit shall be the base energy credit for the measure adjusted by _____ a factor or equation as stated in the description of the measure in Section C406.2. Where adjustments are applied, each measure's energy credit shall be rounded to the nearest whole number.
3. The measure's energy credit shall be calculated as stated in the measure's description _____ in Section C406.2, where each individual measure credit shall be rounded to the nearest whole number.

Energy credits achieved for the project shall be the sum of the individual measure's energy credits. Credits are available for the measures listed in this section. Where a project contains multiple building occupancy groups:

1. Credits achieved for each occupancy group shall be summed and then weighted by the conditioned floor area of each occupancy group to determine the weighted average project energy credits achieved.
2. Improved envelope efficiency (E01 through E06), HVAC performance (H01) and lighting reduction (L06) measure credits shall be determined for the building or permitted conditioned floor area as a whole. Credits for other measures shall be determined for each occupancy separately. Credits shall be taken from applicable tables or calculations for each occupancy and weighted by the building occupancy group floor area.

Staff Classification	Correlates Directly	Energy Standard Needed	Step Up
			A
Active AS	AS/AC	D	0/0C
			A

Original text of mod is not consistent with that of the 2023 FBC – EC.

CE#278 Table C406.1(1) has been renamed, renumbered and rearranged. The measures have been expanded to 32 from 11, and the achievable energy credits have been updated.

Related Mods:
CEPI- 193-21,
CECD1-
6-22,
TABLE C406.2(1)
BASE ENERGY CREDITS FOR GROUP R-2, R-4 AND I-1 OCCUPANCIES*

ID	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE															
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A
E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1															

CECD1- 185-22, **E01** Envelope performance **C406.2.1.1** Determined in accordance with Section C406.2.1.1

		H05	DOAS/fan control	C406.2.2.5	41	41	40	40	42	36	42	37	39	49	40	46	56	46	61	65	68	82	93																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W01	SHW preheat recovery	C406.2.3.1 a	4	4	4	4	5	5	5	5	6	6	6	6	6	6	6	5	5	5	5																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W02	Heat pump water heater	C406.2.3.1 b	2	2	2	2	2	2	3		3	3	3	3	3			3		3	3																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W03	Efficient gas water heater	C406.2.3.1 c	2	2	2	2	2	3	3	3	3	3	3	3	3			3	3	3	3																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W04	SHW pipe insulation	C406.2.3.2	1	1	1	1	1	1	1	1	1	1	1	1	1	1		1	1	1	1																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W05	Point of use water heaters	C406.2.3.3 a	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	1	1	1	1	1	1	1		1	1	1	1																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W07	SHW heat trace system	C406.2.3.3 c	1	1	2	2	2	2	2	2	2	2	2	2	2	2		1	1	1	1																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W09	SHW flow reduction	C406.2.3.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		W10	Shower heat recovery	C406.2.3.6	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1																																																																																																																																																																																																																																																																																																																																																																																																																																																
		P01	Energy monitoring	C406.2.4	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3																																																																																																																																																																																																																																																																																																																																																																																																																																																
		L01	Lighting performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		L02	Lighting dimming & tuning	C406.2.5.2	5	5	5	5	5	6	5	6	6	5	6	6	5	5	5	4	4	3	2																																																																																																																																																																																																																																																																																																																																																																																																																																																
		L03	Increase occp. sensor	C406.2.5.3	5	5	5	5	5	5	5	5	6	5	5	6	5	5	5	4	4	3	2																																																																																																																																																																																																																																																																																																																																																																																																																																																
		L04	Increase daylight area	C406.2.5.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		L06	Light power reduction	C406.2.5.6	7	7	7	7	7	7	7	9	7	7	8	6	7	7	5	5	4	3																																																																																																																																																																																																																																																																																																																																																																																																																																																	
		Q01	Efficient elevator	C406.2.6.1	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	1	1																																																																																																																																																																																																																																																																																																																																																																																																																																																	
		Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																
		Q04	Fault detection	C406.2.6.4	3	3	3	3	3	3	3	3	2	3	3	2	3	3	3	3	3	4																																																																																																																																																																																																																																																																																																																																																																																																																																																	
		DOAS = Dedicated Outside Air System; HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water; UA = U - Factor x Area.																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
		a. "x" indicates credit is not available in that climate zone for that measure.																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
		<table><tr><td rowspan="2">Staff Classification</td><td rowspan="2">Correlates Directly</td><td rowspan="2">Energy Standard</td><td rowspan="2">Over lap</td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table>																							Staff Classification	Correlates Directly	Energy Standard	Over lap					x																																																																																																																																																																																																																																																																																																																																																																																																																																						
Staff Classification	Correlates Directly	Energy Standard	Over lap																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
	x																																																																																																																																																																																																																																																																																																																																																																																																																																																																						
		<table><tr><td rowspan="2">Action</td><td rowspan="2">AS</td><td rowspan="2">AS/AC</td><td rowspan="2">D</td><td rowspan="2">E/C</td></tr><tr><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>																							Action	AS	AS/AC	D	E/C							x																																																																																																																																																																																																																																																																																																																																																																																																																																			
Action	AS	AS/AC	D	E/C																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
			x																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
CE#280		Table C406.1(3) has been renamed, renumbered and rearranged. The measures have been expanded to 32 from 11, and the achievable energy credits have been updated.																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
Related Mods: CEPI- 193-21, CECD1- 6-22, CED1- 185-22, CED1- 194-22		<table><tr><th colspan="23">TABLE C406.2(3) BASE ENERGY CREDITS FOR GROUP R-1 OCCUPANCIES</th></tr><tr><th rowspan="2">ID</th><th rowspan="2">ENERGY CREDIT MEASURE</th><th rowspan="2">SECTION</th><th colspan="16">CLIMATE ZONE</th></tr><tr><th>0A</th><th>0B</th><th>1A</th><th>1B</th><th>2A</th><th>2B</th><th>3A</th><th>3B</th><th>3C</th><th>4A</th><th>4B</th><th>4C</th><th>5A</th><th>5B</th><th>5C</th><th>6</th><th>6B</th><th>7</th></tr><tr><td>E01</td><td>Envelope performance</td><td>C406.2.1.1</td><td colspan="16">Determined in accordance with Section C406.2.1.1</td></tr><tr><td>E02</td><td>UA reduction (15%)</td><td>C406.2.1.2</td><td>2</td><td>3</td><td>1</td><td>2</td><td>1</td><td>3</td><td>3</td><td>2</td><td>1</td><td>5</td><td>2</td><td>2</td><td>7</td><td>4</td><td>2</td><td>9</td><td>7</td><td>9</td><td>11</td></tr><tr><td>E03</td><td>Reduced air leakage</td><td>C406.2.1.3</td><td>15</td><td>9</td><td>12</td><td>8</td><td>6</td><td>16</td><td>7</td><td>5</td><td>10</td><td>14</td><td>3</td><td>1</td><td>19</td><td>5</td><td>1</td><td>28</td><td>16</td><td>28</td><td>18</td></tr><tr><td>E04</td><td>Add roof insulation</td><td>C406.2.1.4</td><td>1</td><td>1</td><td>1</td><td>2</td><td>2</td><td>1</td><td>2</td><td>1</td><td>1</td><td>2</td><td>1</td><td>2</td><td>2</td><td>1</td><td>2</td><td>3</td><td>2</td><td>2</td><td></td></tr><tr><td>E05</td><td>Add wall insulation</td><td>C406.2.1.5</td><td>18</td><td>26</td><td>11</td><td>25</td><td>3</td><td>4</td><td>5</td><td>3</td><td>1</td><td>6</td><td>2</td><td>4</td><td>7</td><td>4</td><td>4</td><td>8</td><td>6</td><td>8</td><td></td></tr><tr><td>E06</td><td>Improve fenestration</td><td>C406.2.1.6</td><td>2</td><td>2</td><td>1</td><td>2</td><td>2</td><td>3</td><td>5</td><td>3</td><td>1</td><td>6</td><td>3</td><td>4</td><td>9</td><td>7</td><td>6</td><td>13</td><td>8</td><td>6</td><td></td></tr><tr><td>H01</td><td>HVAC performance</td><td>C406.2.2.1</td><td>21</td><td>20</td><td>17</td><td>18</td><td>16</td><td>13</td><td>12</td><td>12</td><td>11</td><td>11</td><td>11</td><td>8</td><td>11</td><td>11</td><td>8</td><td>13</td><td>11</td><td>14</td><td>16</td></tr><tr><td>H02</td><td>Heating efficiency</td><td>C406.2.2.2</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>1</td><td>1</td><td>6</td><td>2</td><td>1</td><td>1</td><td>3</td><td>2</td><td>2</td><td>6</td><td>4</td><td>8</td><td>11</td></tr><tr><td>H03</td><td>Cooling efficiency</td><td>C406.2.2.3</td><td>7</td><td>6</td><td>4</td><td>4</td><td>3</td><td>2</td><td>1</td><td>2</td><td>1</td><td>1</td><td>2</td><td>1</td><td>1</td><td>1</td><td>1</td><td>x</td><td>x</td><td>x</td><td></td></tr><tr><td>H04</td><td>Residential HVAC control</td><td>C406.2.2.4</td><td>x</td><td>x</td><td></td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td></td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td></td></tr><tr><td>H05</td><td>DOAS/fan control</td><td>C406.2.2.5</td><td>32</td><td>30</td><td>26</td><td>28</td><td>25</td><td>23</td><td>24</td><td>22</td><td>28</td><td>26</td><td>22</td><td>20</td><td>30</td><td>26</td><td>19</td><td>41</td><td>34</td><td>48</td><td>62</td></tr><tr><td>W01</td><td>SHW preheat recovery</td><td>C406.2.3.1 a</td><td>18</td><td>19</td><td>22</td><td>22</td><td>25</td><td>27</td><td>31</td><td>21</td><td>32</td><td>34</td><td>34</td><td>38</td><td>37</td><td>36</td><td>40</td><td>36</td><td>37</td><td>36</td><td>35</td></tr><tr><td>W02</td><td>Heat pump water heater</td><td>C406.2.3.1 b</td><td>14</td><td>15</td><td>18</td><td>17</td><td>20</td><td>22</td><td>25</td><td>25</td><td>27</td><td>29</td><td>29</td><td>32</td><td>31</td><td>31</td><td>34</td><td>30</td><td>32</td><td>31</td><td>30</td></tr><tr><td>W03</td><td>Efficient gas water heater</td><td>C406.2.3.1 c</td><td>11</td><td>12</td><td>14</td><td>14</td><td>16</td><td>17</td><td>19</td><td>19</td><td>20</td><td>21</td><td>21</td><td>24</td><td>23</td><td>23</td><td>25</td><td>22</td><td>23</td><td>23</td><td>22</td></tr><tr><td>W04</td><td>SHW pipe insulation</td><td>C406.2.3.2</td><td>3</td><td>3</td><td>4</td><td>3</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>4</td><td>3</td></tr><tr><td>W05</td><td>Point of use water heaters</td><td>C406.2.3.3 a</td><td>x</td><td>x</td><td></td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td></td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td><td>x</td></tr><tr><td>W06</td><td>Thermostatic bal. valves</td><td>C406.2.3.3 b</td><td>1</td><td>1</td><td>1</td><td>1</td><td>1</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>2</td><td>1</td><td>1</td></tr></table>																							TABLE C406.2(3) BASE ENERGY CREDITS FOR GROUP R-1 OCCUPANCIES																							ID	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE																0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6	6B	7	E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																E02	UA reduction (15%)	C406.2.1.2	2	3	1	2	1	3	3	2	1	5	2	2	7	4	2	9	7	9	11	E03	Reduced air leakage	C406.2.1.3	15	9	12	8	6	16	7	5	10	14	3	1	19	5	1	28	16	28	18	E04	Add roof insulation	C406.2.1.4	1	1	1	2	2	1	2	1	1	2	1	2	2	1	2	3	2	2		E05	Add wall insulation	C406.2.1.5	18	26	11	25	3	4	5	3	1	6	2	4	7	4	4	8	6	8		E06	Improve fenestration	C406.2.1.6	2	2	1	2	2	3	5	3	1	6	3	4	9	7	6	13	8	6		H01	HVAC performance	C406.2.2.1	21	20	17	18	16	13	12	12	11	11	11	8	11	11	8	13	11	14	16	H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	1	1	6	2	1	1	3	2	2	6	4	8	11	H03	Cooling efficiency	C406.2.2.3	7	6	4	4	3	2	1	2	1	1	2	1	1	1	1	x	x	x		H04	Residential HVAC control	C406.2.2.4	x	x		x	x	x	x	x	x	x	x		x	x	x	x	x	x		H05	DOAS/fan control	C406.2.2.5	32	30	26	28	25	23	24	22	28	26	22	20	30	26	19	41	34	48	62	W01	SHW preheat recovery	C406.2.3.1 a	18	19	22	22	25	27	31	21	32	34	34	38	37	36	40	36	37	36	35	W02	Heat pump water heater	C406.2.3.1 b	14	15	18	17	20	22	25	25	27	29	29	32	31	31	34	30	32	31	30	W03	Efficient gas water heater	C406.2.3.1 c	11	12	14	14	16	17	19	19	20	21	21	24	23	23	25	22	23	23	22	W04	SHW pipe insulation	C406.2.3.2	3	3	4	3	4	4	4	4	4	4	4	4	4	4	4	4	4	4	3	W05	Point of use water heaters	C406.2.3.3 a	x	x		x	x	x	x	x	x	x	x		x	x	x	x	x	x	x	W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	2	2	2	2	2	2	2	2	2	2	2	2	1	1
TABLE C406.2(3) BASE ENERGY CREDITS FOR GROUP R-1 OCCUPANCIES																																																																																																																																																																																																																																																																																																																																																																																																																																																																							
ID	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6	6B	7																																																																																																																																																																																																																																																																																																																																																																																																																																																			
E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
E02	UA reduction (15%)	C406.2.1.2	2	3	1	2	1	3	3	2	1	5	2	2	7	4	2	9	7	9	11																																																																																																																																																																																																																																																																																																																																																																																																																																																		
E03	Reduced air leakage	C406.2.1.3	15	9	12	8	6	16	7	5	10	14	3	1	19	5	1	28	16	28	18																																																																																																																																																																																																																																																																																																																																																																																																																																																		
E04	Add roof insulation	C406.2.1.4	1	1	1	2	2	1	2	1	1	2	1	2	2	1	2	3	2	2																																																																																																																																																																																																																																																																																																																																																																																																																																																			
E05	Add wall insulation	C406.2.1.5	18	26	11	25	3	4	5	3	1	6	2	4	7	4	4	8	6	8																																																																																																																																																																																																																																																																																																																																																																																																																																																			
E06	Improve fenestration	C406.2.1.6	2	2	1	2	2	3	5	3	1	6	3	4	9	7	6	13	8	6																																																																																																																																																																																																																																																																																																																																																																																																																																																			
H01	HVAC performance	C406.2.2.1	21	20	17	18	16	13	12	12	11	11	11	8	11	11	8	13	11	14	16																																																																																																																																																																																																																																																																																																																																																																																																																																																		
H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	1	1	6	2	1	1	3	2	2	6	4	8	11																																																																																																																																																																																																																																																																																																																																																																																																																																																		
H03	Cooling efficiency	C406.2.2.3	7	6	4	4	3	2	1	2	1	1	2	1	1	1	1	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																			
H04	Residential HVAC control	C406.2.2.4	x	x		x	x	x	x	x	x	x	x		x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																			
H05	DOAS/fan control	C406.2.2.5	32	30	26	28	25	23	24	22	28	26	22	20	30	26	19	41	34	48	62																																																																																																																																																																																																																																																																																																																																																																																																																																																		
W01	SHW preheat recovery	C406.2.3.1 a	18	19	22	22	25	27	31	21	32	34	34	38	37	36	40	36	37	36	35																																																																																																																																																																																																																																																																																																																																																																																																																																																		
W02	Heat pump water heater	C406.2.3.1 b	14	15	18	17	20	22	25	25	27	29	29	32	31	31	34	30	32	31	30																																																																																																																																																																																																																																																																																																																																																																																																																																																		
W03	Efficient gas water heater	C406.2.3.1 c	11	12	14	14	16	17	19	19	20	21	21	24	23	23	25	22	23	23	22																																																																																																																																																																																																																																																																																																																																																																																																																																																		
W04	SHW pipe insulation	C406.2.3.2	3	3	4	3	4	4	4	4	4	4	4	4	4	4	4	4	4	4	3																																																																																																																																																																																																																																																																																																																																																																																																																																																		
W05	Point of use water heaters	C406.2.3.3 a	x	x		x	x	x	x	x	x	x	x		x	x	x	x	x	x	x																																																																																																																																																																																																																																																																																																																																																																																																																																																		
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	2	2	2	2	2	2	2	2	2	2	2	2	1	1																																																																																																																																																																																																																																																																																																																																																																																																																																																		

W07	SHW heat trace system	C406.2.3.3 c	5	6	6	6	6	7	7	7	7	7	7	8	7	7	8	7	7	6	6
W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W09	SHW flow reduction	C406.2.3.5	6	7	8	8	9	10	11	11	12	13	13	14	14	13	15	13	14	14	13
W10	Shower heat recovery	C406.2.3.6	4	5	5	5	6	7	8	8	8	9	9	10	10	9	10	9	10	10	9
P01	Energy monitoring	C406.2.4	3	3	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
L01	Lighting performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

DOAS = Dedicated Outside Air System; HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water; UA = U - Factor x Area.

a. "x" indicates credit is not available in that climate zone for that measure.

Staff Classification	Correlates Directly	Energy Standard	Over lap
Actions	AS	AS/EC	EC

CE#281 Table C406.1(4) has been renamed, renumbered and rearranged. The measures have been expanded to 32 from 11, and the achievable energy credits have been updated.

Related Mods:
CEPI- 193-21,
CED1- 185-22,
CED1- 194-22

TABLE C406.2(4)																					
ID	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE																		
			0 A	0B	1A	1B	2A	2 B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	
E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																		
E02	UA reduction (15%)	C406.2.1.2	7	8	3	6	5	3	7	3	1	13	4	8	21	15	11	13	24	37	43
E03	Reduced air leakage	C406.2.1.3	5	3	4	2	2	2	5	1	x	8	x	2	13	4	x	18	9	18	7
E04	Add roof insulation	C406.2.1.4	2	2	2	2	2	2	3	2	1	3	1	2	3	2	2	3	3	2	3
E05	Add wall insulation	C406.2.1.5	13	14	8	11	4	4	7	4	1	5	2	4	6	4	3	9	7	10	8
E06	Improve fenestration	C406.2.1.6	5	5	4	5	7	7	8	2	1	8	2	4	10	5	1	21	17	10	9
H01	HVAC performance	C406.2.2.1	22	22	19	20	17	17	15	15	11	15	15	11	16	15	11	19	17	18	20
H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	1	1	1	3	2	2	5	4	3	9	7	8	12
H03	Cooling efficiency	C406.2.2.3	7	6	4	5	3	3	1	2	1	1	2	1	1	1	1	x	x	x	x
H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H05	DOAS/fan control	C406.2.2.5	31	31	27	29	25	25	28	26	18	35	28	28	47	38	29	64	53	58	74
W01	SHW preheat recovery	C406.2.3.1 a	8	9	10	9	11	11	12	12	14	13	13	14	13	13	15	12	13	14	14
W02	Heat pump water heater	C406.2.3.1 b	3	3	3	3	4	4	5	4	5	5	5	6	5	5	6	5	5	6	6
W03	Efficient gas water heater	C406.2.3.1 c	5	5	6	6	7	7	8	7	8	8	8	9	8	8	9	8	8	9	8
W04	SHW pipe insulation	C406.2.3.2	3	3	4	4	4	4	4	4	5	4	4	5	4	4	5	4	4	4	4
W05	Point of use water heaters	C406.2.3.3 a	12	15	17	16	18	18	19	19	22	20	20	22	20	20	22	18	19	20	19
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
W07	SHW heat trace system	C406.2.3.3 c	4	4	4	4	5	5	5	5	6	5	5	6	5	5	6	5	5	5	5
W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W09	SHW flow reduction	C406.2.3.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W10	Shower heat recovery	C406.2.3.6	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
P01	Energy monitoring	C406.2.4	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
L01	Lighting performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	5	5	6	6	6	6	6	6	7	6	6	6	5	5	6	4	5		2
L03	Increase occp. sensor	C406.2.5.3	5	6	6	6	6	6	6	6	8	6	6	6	5	5	6	4	5		3

L04	Increase daylight area	C406.2.5.4	7	7	8	8	8	8	8	9	6	7	7	6	6	6	6	5
L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L06	Light power reduction	C406.2.5.6	7	7	8	8	8	8	8	9	7	8	8	6	7	8	5	3
Q01	Efficient elevator	C406.2.6.1	4	4	4	4	5	5	5	5	5	5	5	5	5	5	4	4
Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q04	Fault detection	C406.2.6.4	3	3	3	3	3	2	2	2	2	2	2	2	2	3	3	3

DOAS = Dedicated Outside Air System; HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water; UA = U - Factor × Area.

a. "x" indicates credit is not available in that climate zone for that measure.

Staff Classification	Correlates Directly	Energy Standard Reached	Over lap
	x		
Action	AS	AS/CE	CE
			x

CE#282 Table C406.1(S) has been renamed, renumbered and rearranged. The measures have been expanded to 32 from 11, and the achievable energy credits have been updated.

Related
Measures:

CEPI- 193-21,

CECD1-
6-22, CED1-
185-22, CED1-
194-22

TABLE C406.2(5) BASE ENERGY CREDITS FOR GROUP A-2 OCCUPANCIES ^a																						
I D	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE																			
			0 A	0B	1A	1B	2A	2 B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	8	
E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																			
E02	UA reduction (15%)	C406.2.1.2	1	1	1	1	13	1	3	2	1	4	4	5	5	5	6	6	6	6	6	
E03	Reduced air leakage	C406.2.1.3	2	1	1	1	2	3	11	2	1	24	4	6	33	9	3	42	29	36	16	
E04	Add roof insulation	C406.2.1.4	1	1	x	1	1	1	2	1	1	1	1	1	2	2	1	2	2	1		
E05	Add wall insulation	C406.2.1.5	1	1	x	1	1	2	3	3	1	2	1	1	2	2	2	2	2	2		
E06	Improve fenestration	C406.2.1.6	1	1	1	1	1	1	2	2	1	1	2	2	3	2	1	4	4	1	1	
H01	HVAC performance	C406.2.2.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
H02	Heating efficiency	C406.2.2.2	x	x	x	x	1	1	6	3	3	10	6	8	15	11	10	19	15	23	28	
H03	Cooling efficiency	C406.2.2.3	6	5	3	4	3	2	1	1	1	1	1	1	1	1	1	x	x	x	x	
H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
H05	DOAS/fan control	C406.2.2.5	29	27	20	25	24	21	36	27	15	51	35	38	67	53	45	84	70	97	115	
W01	SHW preheat recovery	C406.2.3.1 a	24	26	31	29	33	35	37	38	45	38	41	44	37	40	44	34	38	33	30	
W02	Heat pump water heater	C406.2.3.1 b	15	16	19	18	21	23	25	25	29	26	28	30	26	28	31	25	27	24	22	
W03	Efficient gas water heater	C406.2.3.1 c	15	16	19	18	21	22	23	24	28	24	25	27	23	25	27	21	24	21	18	
W04	SHW pipe insulation	C406.2.3.2	2	3	3	3	3	3	3	3	3	3	3	3	2	3	3	2	2	2	2	
W05	Point of use water heaters	C406.2.3.3 a	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
W07	SHW heat trace system	C406.2.3.3 c	3	4	4	4	4	4	4	4	4	4	4	4	3	4	4	3	3	3	3	
W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
W09	SHW flow reduction	C406.2.3.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
W10	Shower heat recovery	C406.2.3.6	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
P01	Energy monitoring	C406.2.4	2	2	2	2	2	1	2	1	1	2	1	1	2	2	1	2	2	2	3	
L01	Lighting performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
L02	Lighting dimming & tuning	C406.2.5.2	2	2	2	2	2	2	2	2	2	2	2	2	1	2	1	1	1	1	x	
L03	Increase occp. sensor	C406.2.5.3	2	2	2	2	2	2	2	2	2	1	1	1	1	1	1	1	1	1	x	
L04	Increase daylight area	C406.2.5.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
L06	Light power reduction	C406.2.5.6	3	3	3	3	3	3	3	3	3	2	2	2	2	2	2	1	2	1	1	
Q01	Efficient elevator	C406.2.6.1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
Q02	Commercial kitchen equip.	C406.2.6.2	24	26	28	27	28	29	27	29	32	26	28	29	24	26	28	21	23	19	17	
Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
Q04	Fault detection	C406.2.6.4		2	2	2	2	2	2	2	1	2	2	1	2	2	2	3	2		4	

DOAS = Dedicated Outside Air System; HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water; UA = U -Factor

× Area.
a. "x" indicates credit is not available in that climate zone for that measure.

Self Classification	Correlates Directly	Energy Standard Required	Overlap
	x		
Action	MS	MS/CE	MS/CE
		x	

CE#283 Adds a new base energy credits Table C406.2(6) for group M occupancies with 32 measures.

Related Mods:
CEPI- 193-21,
CED1- 185-22,

TABLE C406.2(6) BASE ENERGY CREDITS FOR GROUP M OCCUPANCIES*																				
ID	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE																	
			0 A	0 B	1A	1B	2 A	3A	3B	3 C	4A	4B	4C 5 A	5B	5C	6A	6B	7	8	
E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																	
E02	UA reduction (15%)	C406.2.1.2	14	14	8	13	7	9	20	15	1	35	18	28	37	40	43	44	46	31
E03	Reduced air leakage	C406.2.1.3	3	3	2	2	3	3	19	3	1	44	6	11	13	6	64	44	43	19
E04	Add roof insulation	C406.2.1.4	8	6	5	7	7	7	18	16	4	19	18	20	22	23	24	26	24	30
E05	Add wall insulation	C406.2.1.5	64	18	48	62	19	15	23	18	4	27	21	27	24	25	23	24	24	16
E06	Improve fenestration	C406.2.1.6	4	3	3	3	4	4	6	5	2	7	5	7	7	5	10	10	3	3
H01	HVAC performance	C406.2.2.1	31	28	28	28	21	21	23	20	2	27	21	22	25	23	32	28	30	33
H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	10	3	1	19	8	15	17	18	29	24	27	31
H03	Cooling efficiency	C406.2.2.3	10	9	7	7	5	4	2	2	1	1	2	1	1	1	x	x	x	x
H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
H05	DOAS/fan control	C406.2.2.5	48	48	42	47	48	38	66	46	31	98	61	82	120	91	90	134	115	141
W01	SHW preheat recovery	C406.2.3.1 a	12	18	16	15	18	20	19	21	14	17	21	21	16	19	21	13	16	13
W02	Heat pump water heater	C406.2.3.1 b	3	3	4	3	4	5	5	5	7	5	6	6	5	6	4	4	4	4
W03	Efficient gas water heater	C406.2.3.1 c	6	7	8	8	10	10	10	11	14	9	11	11	10	11	7	8	7	7
W04	SHW pipe insulation	C406.2.3.2	3	3	4	4	4	4	4	4	5	4	4	5	4	5	4	4	4	4
W05	Point of use water heaters	C406.2.3.3 a	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
W07	SHW heat trace system	C406.2.3.3 c	4	4	4	4	5	5	5	5	6	5	5	6	5	6	5	5	5	5
W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W09	SHW flow reduction	C406.2.3.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
W10	Shower heat recovery	C406.2.3.6	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
P01	Energy monitoring	C406.2.4	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
L01	Lighting performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L02	Lighting dimming & tuning	C406.2.5.2	9	9	11	10	14	13	11	13	14	9	12	11	9	10	5	7	3	3
L03	Increase occp. sensor	C406.2.5.3	9	9	11	10	14	13	12	13	14	10	12	11	10	11	6	8	4	4
L04	Increase daylight area	C406.2.5.4	12	14	15	14	18	17	15	16	18	11	14	13	12	11	8	10	10	8
L05	Residential light control	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
L06	Light power reduction	C406.2.5.6	12	14	14	14	18	16	12	15	18	8	12	9	10	7	6	7	5	5
Q01	Efficient elevator	C406.2.6.1	3	3	4	3	4	4	4	4	5	3	4	4	4	4	3	3	3	3
Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
Q04	Fault detection	C406.2.6.4	3	2	2	2	2	2	2	2	1	2	2	1	2	2	3	2	3	3

DOAS = Dedicated Outside Air System; HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water; UA = U- Factor x Area

a. "x" indicates credit is not available in that climate zone for that measure

Self Classification	Correlates Directly	Energy Standard Required	Overlap
	x		
Action	MS	MS/CE	MS/CE
		x	

CE#284 Adds new based energy credits Table C406.2(7) for group E occupancies with 32 measures.

Related Mods:

TABLE C406.2(7) BASE ENERGY CREDITS FOR GROUP E OCCUPANCIES ^a																				
ID	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE																	
			0 A	0B	1A	1B	2A	2 B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7
E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																	
E02	UA reduction (15%)	C406.2.1.2		18	7	19	12	13	20	17	11	24	20	17	33	32	29	40	38	46
E03	Reduced air leakage	C406.2.1.3		3	3	3	2	5	2	1	1	1	1	1	1	1	1	2	1	1

		E04	Add roof insulation	C406.2.1.4				8	4	9	5	7	16	7	1	14	7	10	18	13	13	23	25	22																		
		E05	Add wall insulation	C406.2.1.5				7	4	8	3	6	8	6	2	6	3	6	5	5	6	7	6	7																		
		E06	Improve fenestration	C406.2.1.6				10	6	9	11	11	15	9	1	16	8	15	22	18	19	33	29	19																		
		H01	HVAC performance	C406.2.2.1	30	28	25	26	23	21	20	18	15	19	18	17	19	20	15	23	20	25	29																			
		H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	4	3	3	5	5	10	9	11	6	15	11	18	26																			
		H03	Cooling efficiency	C406.2.2.3	9	8	6	7	5	4	2	2	1	1	1	1	1	1	1	x	x	x	x																			
		H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																			
		H05	DOAS/fan control	C406.2.2.5	45	42	37	41	36	34	41	39	30	43	46	58	57	65	40	79	63	88	117																			
		W01	SHW preheat recovery	C406.2.3.1 a	7	7	9	8	10	11	13	13	15	14	15	15	15	14	17	13	15	14	12																			
		W02	Heat pump water heater	C406.2.3.1 b	4	4	6	5	7	7	9	9	10	10	10	11	11	10	12	10	11	10	9																			
		W03	Efficient gas water heater	C406.2.3.1 c	4	4	6	5	6	7	8	8	9	9	9	10	9	9	11	8	10	9	7																			
		W04	SHW pipe insulation	C406.2.3.2	3	3	4	4	4	4	4	5	6	5	5	6	5	5	7	4	5	4	4																			
		W05	Point of use water heaters	C406.2.3.3 a	3	4	4	4	4	5	5	5	6	5	5	5	5	5	6	4	5	4	3																			
		W06	Thermostatic bal. valves	C406.2.3.3 b	1	1	1	1	1	1	1	2	2	2	2	2	2	2	2	1	2	1	1																			
		W07	SHW heat trace system	C406.2.3.3 c	4	4	4	4	5	5	5	6	7	6	6	7	6	6	8	5	7	5	5																			
		W08	SHW submeters	C406.2.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																			
		W09	SHW flow reduction	C406.2.3.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																			
		W10	Shower heat recovery	C406.2.3.6	2	2	2	2	3	3	3	3	4	3	3	4	3	3	4	3	3	3	3																			
		P01	Energy monitoring	C406.2.4	a	4	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	4																			
		L01	Lighting performance	C406.2.5.1	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																			
		L02	Lighting dimming & tuning	C406.2.5.2	5	5	5	6	6	6	5	6	7	6	6	6	5	5	6	4	4	3																				
		L03	Increase occp. sensor	C406.2.5.3	4	4	5	5	5	6	6	6	7	6	6	5	4	4	5	3	4	3																				
		L04	Increase daylight area	C406.2.5.4	6	6	7	7	7	7	7	7	8	6	6	6	5	5	6	5	5	5																				
		L05	Residential light	C406.2.5.5	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																			
		L06	Light power	C406.2.5.6	6	7	7	7	8	8	8	8	10	7	8	7	6	7	8	5	6	4																				
		Q01	Efficient	C406.2.6.1	3	4	4	4	4	5	5	5	5	5	5	5	5	5	4	5	4																					
		Q02	Commercial kitchen equip.	C406.2.6.2	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																			
		Q03	Residential kitchen equip.	C406.2.6.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x																			
		Q04	Fault detection	C406.2.6.4	4	4	4	4	3	3	3	3	2	3	3	3	3	2	4	3	4																					
		DOAS = Dedicated Outside Air System; HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water; UA																																								
		= U-Factor x Area																																								
		a. "x" indicates measure is not available in that climate zone for that measure.																																								
		<table><tr><td>Start Classification</td><td>Generate Directly</td><td>Energy Standard Reached</td><td>Overlap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/AC</td><td>0</td></tr><tr><td></td><td></td><td>x</td><td>0/0</td></tr></table>																									Start Classification	Generate Directly	Energy Standard Reached	Overlap		x			Action	AS	AS/AC	0			x	0/0
Start Classification	Generate Directly	Energy Standard Reached	Overlap																																							
	x																																									
Action	AS	AS/AC	0																																							
		x	0/0																																							
CE#285	Adds a new base energy credits Table C406.2(8) for group S-1 and S-2 occupancies with 32 measures.																																									
Related Models: CED1- 194-22	TABLE C406.2(8) BASE ENERGY CREDITS FOR GROUP S-1 AND S-2 OCCUPANCIES*																																									
	ID	ENERGY CREDIT MEASURE	SECTION	CLIMATE ZONE																																						
				0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C		5B	5C	6A	6B	7																					
	E01	Envelope performance	C406.2.1.1	Determined in accordance with Section C406.2.1.1																																						
	E02	UA reduction (15%)	C406.2.1.2	14	14	1	12	1	9	27	16	2	37	29	39	44	47	50	43	52	55	74																				
	E03	Reduced air leakage	C406.2.1.3	2	2	1	2	1	3	31	3	1	77	14	17	92	25	8	95	71	69	26																				
	E04	Add roof insulation	C406.2.1.4	13	12	10	11	10	11	18	17	7	14	19	18	14	20	22	10	14	12	19																				
	E05	Add wall insulation	C406.2.1.5	19	23	13	21	7	10	15	12	3	10	12	13		12	12	7	9	8	8																				
	E06	Improve fenestration	C406.2.1.6	7	5	8	7	6	6	2	4	2	4	1	6		1	7	3	4	4	7																				
	H01	HVAC performance	C406.2.2.1	x	x	x	x	x	x	x	x	x	x	x	x		x	x	x	x	x	x																				
	H02	Heating efficiency	C406.2.2.2	x	x	x	x	x	x	16	3	1	33	17	22	41	31	21	44	38	43	43																				
	H03	Cooling efficiency	C406.2.2.3	7	7	4	5	3	3	1	1	1	1	1	1		1	1	x	x	x	x																				
	H04	Residential HVAC control	C406.2.2.4	x	x	x	x	x	x	x	x	x	x	x	x		x	x	x	x	x	x																				
	H05	DOAS/fan control	C406.2.2.5	35	37	26	33	24	27	77	35	14	141	83	96	168	132	90	180	157	177	178																				
	W01	SHW preheat recovery	C406.2.3.1 a	8	7	9	8	10	10	8	10	12	5	8	8		6	9	3	4	3	3																				

[illegible]

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

	FSEC – Anticipated energy impact on FBC-EC – Decrease																																																				
CE#288	Adds new Table C406.2.1.6. Decreases the U-Factor and the SHGC hence it increases the stringency.																																																				
Related Mods: CEPI- 193-21, CED1- 194-22	<div>TABLE C406.2.1.6 VERTICAL FENESTRATION REQUIREMENTS FOR ENERGY CREDIT E06</div> <table><tr><th rowspan="2">APPLICABLE CLIMATE ZONE</th><th colspan="2">MAXIMUM U-FACTOR</th><th rowspan="2">MAXIMUM SHGC</th><th rowspan="2">MINIMUM VT</th></tr><tr><th>Fixed</th><th>Operable</th></tr><tr><td>0-2</td><td>0.45</td><td>0.52</td><td>0.21</td><td>0.28</td></tr><tr><td>3</td><td>0.33</td><td>0.44</td><td>0.23</td><td>0.30</td></tr><tr><td>4-5</td><td>0.31</td><td>0.38</td><td>0.34</td><td>0.41</td></tr><tr><td>6-7</td><td>0.26</td><td>0.32</td><td>0.38</td><td>0.44</td></tr><tr><td>8</td><td>0.24</td><td>0.28</td><td>0.38</td><td>0.44</td></tr></table> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Modified</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>SLC</td><td>IN</td><td>A</td><td>SLC</td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td></tr></table></div>	APPLICABLE CLIMATE ZONE	MAXIMUM U-FACTOR		MAXIMUM SHGC	MINIMUM VT	Fixed	Operable	0-2	0.45	0.52	0.21	0.28	3	0.33	0.44	0.23	0.30	4-5	0.31	0.38	0.34	0.41	6-7	0.26	0.32	0.38	0.44	8	0.24	0.28	0.38	0.44	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap		X			Action	AS	SLC	IN	A	SLC						
APPLICABLE CLIMATE ZONE	MAXIMUM U-FACTOR		MAXIMUM SHGC	MINIMUM VT																																																	
	Fixed	Operable																																																			
0-2	0.45	0.52	0.21	0.28																																																	
3	0.33	0.44	0.23	0.30																																																	
4-5	0.31	0.38	0.34	0.41																																																	
6-7	0.26	0.32	0.38	0.44																																																	
8	0.24	0.28	0.38	0.44																																																	
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap																																																		
	X																																																				
Action	AS	SLC	IN	A	SLC																																																
CE#289	Added new Section C406.2.2 for achieving credits with improved HVAC equipment. It increases the stringency but is cost-effective. Adds new subsection C406.2.2.1. Adds new subsection C406.2.2.2 by expanding an existing measure. It increases the stringency but is cost-effective. Adds new subsection C406.2.2.3 by expanding an existing measure. It increases the stringency but is cost-effective. Adds new subsection C406.2.2.4. Requires centralized HVAC setback control in multi-family buildings. It increase the stringency but is cost effective. Adds new subsection C406.2.2.5 by modifying																																																				
Related Mods: CEPI- 193-21, CED1- 185-22, CED1- 198-22, CE20-61- 23, CED1- 173-22	<p>C406.2.2 More efficient HVAC equipment performance. All heating and cooling systems shall meet the minimum requirements of Section C403 and efficiency improvements shall be referenced to minimum efficiencies listed in tables referenced by Section C403.3.2. Where multiple efficiency requirements are listed, equipment shall meet the seasonal or part-load efficiencies including SEER, integrated energy efficiency ratio (IEER), <i>integrated part load value</i> (IPLV) or AFUE. Equipment that is larger than the maximum capacity range indicated in tables referenced by Section C403.3.2 shall utilize the values listed for the largest capacity equipment for the associated equipment type shown in the table. Where multiple individual heating or cooling systems serve the project, the improvement shall be the weighted-average improvement based on individual system capacity. Systems are permitted to achieve HVAC energy credits by meeting the requirements of one of the following:</p> <ol style="list-style-type: none">C406.2.2.1 H01.C406.2.2.2 H02.C406.2.2.3 H03.																																																				
	<p>4. C406.2.2.4 H04.</p> <p>5. C406.2.2.5 H05.</p> <p>6. Any combination of H02, H03, H04 and H05.</p> <p>7. The combination of H01 and H04.</p> <p>C406.2.2.1 H01 HVAC Total System Performance Ratio (TSPR). H01 energy credits shall be earned where systems are permitted to use Section C409 and where the savings (TSPR_g) based on the proposed TSPR (TSPR_p) compared to the target¹ TSPR is 5 percent or more. If savings are greater than 5 percent, determine H01 earned credits using Equation 4-15. Energy credits for H01 shall not be combined with energy credits from HVAC measures H02, H03 or H05.</p> <p>Equation 4-15</p> $EC_{TSPR} = EC_{BASE} \times AREA_{TSPR} \times \frac{TSPR_g}{0.05} \quad \text{Eq. 4-15(1) through C406.2(9)}$ <p>¹EC_{TSPR} = Energy credits achieved for H01</p> <p>TSPR_g = The lesser of 0.20 and $(1 - (TSPR_p / TSPR_t))$, where:</p> <p>$AREA_{TSPR}$ = (floor area served by systems included in TSPR)/total building conditioned floor area)</p> <p>TSPR_p = HVAC TSPR of the proposed design calculated in accordance with Sections C409.4, C409.5 and C409.6.</p> <p>TSPR_t = TSPR_r / MPF.</p> <p>TSPR_r = HVAC TSPR of the reference building design calculated in accordance with Sections C409.4, C409.5 and C409.6.</p> <p>MPF = Mechanical performance factor from Table C409.4 based on climate zone and building use type. Where a building has multiple building use types, MPF shall be area weighted in accordance with Section C409.4.</p> <p>C406.2.2.2 H02 More efficient HVAC equipment heating performance. In accordance with Section C406.1.1, not less than 90 percent of the total HVAC cooling capacity serving the total conditioned floor area of the entire building or tenant space shall comply with the requirements of this section.</p> <ol style="list-style-type: none">Equipment installed shall be types that have their efficiency listed in tables referenced by Section C403.3.2. Electric resistance heating capacity shall be limited to 20 percent of system capacity, with the exception of heat pump supplemental heating.Equipment shall exceed the minimum heating efficiency requirements listed in tables referenced by Section C403.3.2 by not less than 5 percent. Where equipment exceeds the minimum annual heating efficiency requirements by more than 5 percent, energy efficiency credits for heating shall be determined using Equation 4-16, rounded to the nearest whole number. <p>Equation 4-16</p> <p>where:</p> <p>EEC_{HEH} = Energy efficiency credits for heating efficiency improvement.</p> <p>EEC_{H5} = Section C406.2.2.2 credits from Tables C406.2(1) through C406.2(9).</p> <p>HEI = The lesser of the improvement above minimum heating efficiency requirements, expressed as a fraction, or 20 percent (0.20). Where heating equipment with different minimum efficiencies are included in the building, a heating</p>																																																				

	<p>capacity weighted-average improvement shall be used. Where electric resistance primary heating or reheat is included in the building, it shall be included in the weighted-average improvement with an HEI of 0. Supplemental gas and electric heat for heat pump systems shall be excluded from the weighted HEI. For heat pumps rated at multiple ambient temperatures, the efficiency at 47°F (8.3°C) shall be used. For metrics that increase as efficiency increases, HEI shall be calculated as follows:</p> $HEI = (HEI_{DES} / HEI_{MIN}) - 1$ <p>where: HEI_{DES} = Design heating efficiency metric, part-load or annualized where available. HEI_{MIN} = Minimum required heating efficiency metric, part-load or annualized where available from Section C403.3.2.</p> <p>Exception: In low-energy spaces complying with Section C402.1.1, not less than 90 percent of the installed heating capacity is provided by electric infrared or gas-fired radiant heating equipment for localized heating applications. Such spaces shall achieve base energy credits only for EEC_{HEC}.</p> <p>C406.2.2.3 H03 More efficient HVAC cooling equipment and fan performance. In accordance with Section C406.1.1, not less than 90 percent of the total HVAC cooling capacity serving the total conditioned floor area of the entire building or tenant space shall comply with all of the requirements of this section.</p> <p>1. Equipment installed shall be types that are listed in tables referenced by Section C403.3.2.</p> <p>2. Equipment shall exceed the minimum cooling efficiency requirements listed in tables referenced by Section C403.3.2 by not less than 5 percent. For water-cooled chiller plants, heat-rejection equipment performance in Table C403.3.2[7] shall also be increased by at least the chiller efficiency improvement. Where equipment exceeds both the minimum annual cooling efficiency and heat-rejection efficiency requirements by more than 5 percent, energy efficiency credits for cooling shall be determined using Equation 4-17, rounded to the nearest whole number.</p> <p>Where fan energy is not included in the packaged equipment rating or it is and the fan size has been increased from the as-rated equipment condition, fan power or horsepower shall be less than 95 percent of the allowed fan power in Section C403.8.1.</p> <p>Equation 4-17</p> $EEC_{HEC} = EEC_{HEC} + EEC_{HEC}$ <p>EEC_{HEC} = Energy efficiency credits for cooling efficiency improvement. EEC_{HEC} = Section C406.2.2.3 base energy credits from Tables C406.2(1) through C406.2(9).</p> <p>CEI = The lesser of the improvement above minimum cooling efficiency and heat-rejection performance requirements, expressed as a fraction, or 20 percent (0.20). Where cooling equipment with different minimum efficiencies is included in the building, a cooling capacity weighted-average improvement shall be used. Where multiple cooling efficiency or performance requirements are provided, the equipment shall exceed the annualized energy or part-load requirement. Meeting both part-load and full-load efficiencies is not required. For metrics $EEC_{HEC} = EEC_{HEC} \times (CEI/0.05)$ses, CEI shall be calculated as follows:</p> $CEI = (CEI_{DES} / CEI_{MIN}) - 1$ <p>where: CEI_{DES} = Design cooling efficiency metric, part-load or annualized where available. CEI_{MIN} = Minimum required cooling efficiency metric, part-load or annualized where available from Section C403.3.2. For data centers using ASHRAE Standard 90.4, CEI shall be calculated as follows:</p> $CEI = (AMLC_{DES} / AMLC_{MAX}) \times (AMLC_{DES} / AMLC_{MAX}) - 1$																		
	<p>where: $AMLC_{DES}$ = As-designed annualized mechanical load component calculated in accordance with ASHRAE Standard 90.4, Section 6.5. $AMLC_{MAX}$ = Maximum annualized mechanical load component from ASHRAE Standard 90.4, Table 6.5.</p> <p>C406.2.2.4 H04 Residential HVAC control. HVAC systems serving dwelling units or sleeping units shall be controlled to automatically activate a setback at least 5°F (3°C) for both heating and cooling. The temperature controller shall be configured to provide setback during occupied sleep periods. The unoccupied setback mode shall be configured to operate in conjunction with one of the following:</p> <p>1. A manual main control device by each dwelling unit main entrance that initiates setback and nonventilation mode for all HVAC units in the dwelling unit and is clearly identified as "Heating/Cooling Master Setback."</p> <p>2. Occupancy sensors in each room of the dwelling unit combined with a door switch to initiate setback and nonventilation mode for all HVAC units in the dwelling within 20 minutes of all spaces being vacant immediately after a door switch operation. Where separate room HVAC units are used, an individual occupancy sensor on each unit that is configured to provide setback shall meet this requirement.</p> <p>3. An advanced learning thermostat or controller that recognizes occupant presence and automatically creates a schedule for occupancy and provides a dynamic setback schedule based on when the spaces are generally unoccupied.</p> <p>4. An automated control and sensing system that uses geographic fencing connected to the dwelling unit occupants' cell phones and initiates the setback condition when all occupants are away from the building.</p> <p>C406.2.2.5 H05 Dedicated outdoor air system. Credits for this measure are allowed only where single-zone HVAC units are not required to have multi-speed or variable-speed fan control in accordance with Section C403.8.6.1. HVAC controls and ventilation systems shall include all of the following:</p> <p>1. Zone controls shall cycle the heating/cooling unit fans off when not providing required heating and cooling or shall limit fan power to 0.12 watts/cfm (0.056 w/l/s) of zone supplyair.</p> <p>2. Outdoor air shall be supplied by an independent ventilation system designed to provide not more than 130 percent of the minimum outdoor air to each individual occupied zone, as specified by the International Mechanical Code.</p> <p>Exception: Outdoor airflow is permitted to increase during emergency or economizer operation, implemented as described in Item 4.</p> <p>3. The ventilation system shall have energy recovery with an enthalpy recovery ratio of 65 percent or more at heating design conditions in Climate Zones 3 through 8 and an enthalpy recovery ratio of 65 percent or more at cooling design conditions in Climate Zones 0, 1, 2, 3A, 3B, 4A, 4B, 5A and 6A. In "A" climate zones, energy recovery shall include latent recovery. Where no humidification is provided, heating energy recovery effectiveness is permitted to be based on sensible energy recovery ratio. Where energy recovery effectiveness is less than the 65 percent required for full credit, adjust the credits from Section C406.2 by the factors in Table C406.2.2.5.</p> <p>4. Where the ventilation system serves multiple zones and the system is not in a latent recovery outside air dehumidification mode, partial economizer cooling through an outdoor air bypass or wheel speed control shall automatically do one of the following:</p> <p>4.1. Set the energy recovery leaving-air temperature 55°F (13°C) or 100 percent outdoor air bypass when a majority of zones require cooling and outdoor air temperature is below 70°F (21°C).</p> <p>4.2. The HVAC ventilation system shall include supply-air temperature controls that automatically reset the supply-air temperature in response to representative building loads, or to outdoor air temperatures. The controls shall</p>																		
CE#290	<p>reset the supply-air temperature not less than 25 percent of the difference between the design supply-air temperature and the design room-air temperature.</p> <p>5. Ventilation systems providing mechanical dehumidification shall use recovered energy for reheat within the limits of Item 4. This shall not limit the use of latent energy recovery for dehumidification.</p> <p>Where only a portion of the building is permitted to be served by constant air volume units or the enthalpy recovery ratio or sensible energy recovery ratio is less than 65 percent, the base energy credits shown in Section C406.2 shall be prorated as follows:</p> <p>Equation 4-18</p> <p>where: EC_{DOAS} = Energy credits achieved for H05. EC_{BASE} = H05 base energy credits in Section C406.2. $FLOOR_{CAV}$ = Fraction of whole-project $EC_{DOAS} = EC_{BASE} \times FLOOR_{CAV} \times ERE_{ADJ}$ fan airflow control in accordance with Section C403.8.6. ERE_{ADJ} = The energy recovery adjustment from Table C406.2.2.5 based on the lower of actual cooling or heating enthalpy recovery ratio or sensible energy recovery ratio where required for the climate zone. Where recovery ratios vary, use a weighted average by supply airflow.</p> <div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><th>Action</th><th>AS</th><th>REC</th><th>D</th><th>DEC</th></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table><p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	REC	D	DEC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	REC	D	DEC															
			x																

Related Mods: CEPI- 193-21, CED1- 185-22	TABLE C406.2.2.5 DOAS ENERGY RECOVERY ADJUSTMENTS																																
	<div>ERRadj BASED ON LOWER OF ACTUAL HEATING OR COOLING ENERGY RECOVERY EFFECTIVENESS WHERE REQUIRED</div> <table><tr><th>Cooling ERR is at least</th><th>Heating enthalpy recovery ratio or sensible energy recovery ratio is at least</th><th>Energy recovery effectiveness adjustment (ERRadj)</th></tr><tr><td>65%</td><td>65%</td><td>1.00</td></tr><tr><td>60%</td><td>60%</td><td>0.67</td></tr><tr><td>55%</td><td>55%^a</td><td>0.33</td></tr><tr><td>50%</td><td>50%^a</td><td>0.25</td></tr></table> <p>a. In climate zones where heating recovery is required in Section C403, a heating recovery effectiveness below 60 percent is not allowed for dwelling units.</p> <div><div>FSEC – Anticipated energy impact on FBC-EC – Decrease</div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>DS</th></tr><tr><td></td><td></td><td></td><td>X</td></tr></table></div>			Cooling ERR is at least	Heating enthalpy recovery ratio or sensible energy recovery ratio is at least	Energy recovery effectiveness adjustment (ERRadj)	65%	65%	1.00	60%	60%	0.67	55%	55% ^a	0.33	50%	50% ^a	0.25	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	AS/EC	DS			
Cooling ERR is at least	Heating enthalpy recovery ratio or sensible energy recovery ratio is at least	Energy recovery effectiveness adjustment (ERRadj)																															
65%	65%	1.00																															
60%	60%	0.67																															
55%	55% ^a	0.33																															
50%	50% ^a	0.25																															
Staff Classification	Correlates Directly	Energy Standard	Over lap																														
	X																																
Action	AS	AS/EC	DS																														
			X																														
CE#291	Adds new Section C406.2.3. Achieving energy credits by reducing water heating energy for SWH. Adds new subsection C406.2.3.1 based on existing requirements. Adds new subsection C406.2.3.1.1 based on the existing code C406.7.2. No change on stringency. Adds new subsection C406.2.3.1.2 by modifying an existing measure. Adds new subsection C406.2.3.1.3 based on the existing code C406.7.3. No change on stringency. Adds new subsection C406.2.3.1.4. It increases the stringency but is a cost-effective measure.																																
Related Mods: CEPI- 193-21, CED1- 185-22	<p>C406.2.3 Reduced energy use in service water heating. For projects with service water heating equipment that serves the whole building, a building <i>addition</i> or a tenant space shall achieve credits through compliance with the requirements of this section. Systems are permitted to achieve energy credits by meeting the requirements of one of the following:</p> <ol style="list-style-type: none">1. Section C406.2.3.1 by selecting one allowed measure W01, W02, W03 or a combination in accordance with Section C406.2.3.1.4.2. Section C406.2.3.2 W04.3. Section C406.2.3.3 by selecting one allowed measure: W05, W06 or W07.4. Section C406.2.3.4 W08.5. Section C406.2.3.5 W09.6. Section C406.2.3.6 W10.7. Any combination of measures in Sections C406.2.3.1 through C406.2.3.6 as long as not more than one allowed measure from Sections C406.2.3.1 and C406.2.3.3 are selected. <p>C406.2.3.1 Service water heating system efficiency. A project is allowed to achieve energy credits from only one of Sections C406.2.3.1.1 through C406.2.3.1.4.</p> <p>C406.2.3.1.1 W01 Recovered or renewable water heating. The building service water-heating system shall have one or more of the following that are sized to provide not less than 30 percent of the building's annual hot water requirements, or sized to provide not less than 70 percent of the building's annual hot water requirements if the <i>building</i> is required to comply with Section C403.11.5:</p> <ol style="list-style-type: none">1. Waste heat recovery from service hot water, heat recovery chillers, building equipment or process equipment																																
	<p>2.A water-to-water heat pump that precools chilled water return for building cooling while heating SHW</p> <p>3.On-site renewable energy water heating systems</p> <p>C406.2.3.1.2 W02 Heat pump water heater. Air-source heat pump <i>water heaters</i> shall be installed according to the manufacturer's instructions and at least 30 percent of design end-use <i>service water heating</i> requirements shall be met using only heat pump heating at an ambient condition of 67.5°F (19.7°C), db without supplemental electric resistance or fossil fuel heating. For a heat pump <i>water heater</i> with supplemental electric resistance heating, the heat pump-only capacity shall be deemed at 40 percent of first-hour draw. Where the heat pump-only capacity exceeds 50 percent of the design end-use load, excluding recirculating system losses, the credits from the Section C406.2 tables shall be prorated as follows:</p> <p>Equation 4-19</p> <p>where:</p> <p>EC_{HPWH} = Energy credits achieved for W02.</p> <p>EC_{base} = W02 base energy credits from Tables C406.2(1) through C406.2(9). Endload = End-use peak hot water load, excluding load for heat trace or recirculation, Btu/h or kW.</p> <p>$EC_{HPWH} = (EC_{base}/0.5) \times ((CAP_{HPWH})/(\text{Endload}[\text{not greater than } 2]))_{\text{without supplemental electric resistance or fossil fuel heat, Btu/h or kW.}}$</p> <p>The heat pump service water heating system shall comply with the following requirements:</p> <ol style="list-style-type: none">1. For systems with an installed total output capacity of more than 100,000 Btu/h (29 kW) at an ambient condition of 67.5°F (19.7°C) db, a preheat storage tank with greater than or equal to 0.75 gallons per 1,000 Btu/h (≥ 9.7 L/kW) of design end-use service water-heating requirements shall be heated only with a heat pump heating when the ambient temperature is greater than 45°F (7.2°C).2. For systems with piping temperature maintenance, either a heat trace system or a separate <i>water heater</i> in series for recirculating system and final heating shall be installed.3. Heat pump <i>water heater</i> efficiency shall meet or exceed one of the following:<ol style="list-style-type: none">3.1. Output-capacity-weighted-average UEF of 3.0 in accordance with 10 CFR 430 Appendix E.3.2. Output-capacity-weighted-average COP of not less than 4.0 tested at 50°F (10°C) entering air and 70°F (21°C) entering potable water in accordance with ANSI/AHRI 1300. <p>C406.2.3.1.3 W03 Efficient fossil fuel water heater. The combined input-capacity- weighted-average equipment rating of all gas <i>water heating equipment in the building</i> shall be not less than 95 percent E_{eff} or 0.93 UEF. Adjustments shall apply as follows:</p> <ol style="list-style-type: none">1. Where the <i>service water heating</i> system is required to comply with Section C404.2.1, this measure shall achieve 30 percent of the listed base W03 energy credits in Tables C406.2(1) through C406.2(9).2. Where the installed building <i>service water heating</i> capacity is less than 200,000 Btu/h (59 kW) and weighted UEF is less than 0.93 UEF and not less than 0.82, this measure shall achieve 25 percent of the base W03 credit in Tables C406.2(1) through C406.2(9).																																
	<p>C406.2.3.1.4 Combination service water heating systems. Combination <i>service water heating</i> systems shall achieve credits using one of the measure combinations as follows:</p> <ol style="list-style-type: none">1. (W01 + W02) Where <i>service water heating</i> employs both energy recovery and heat pump water heating, W01 may be combined with W02 and receive the sum of both credits.2. (W01 + W03) Where <i>service water heating</i> employs both energy recovery and efficient gas water heating, W01 may be combined with W03 and receive the sum of the W01 credit and the portion of the W03 credit based on Item 4.3. (W02 + W03) Where <i>service water heating</i> employs both heat pump water heating and efficient gas water heating, W02 may be combined with W03 and receive the sum of the W02 credit and the portion of the W03 credit based on Item 4.4. For Items 2 and 3, the achieved W03 credit shall be the Section C406.2.3.1.3 W03 credit multiplied by the fractional share of total water-heating installed capacity served by gas water heating that is not less than 95 percent E_{eff} or 0.93 UEF. In no case shall the achieved W03 credit exceed 60 percent of the W03 credit in the Section C406.2 tables. In buildings that have a service water heating design generating capacity greater than 900,000 Btu/h (264 kW), that proportioned W03 credit shall be further multiplied by 30 percent.																																
	<div><div>FSEC – Anticipated energy impact on FBC-EC – Decrease</div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table></div>			Staff Classification	Correlates Directly	Energy Standard	Over lap		X																								
Staff Classification	Correlates Directly	Energy Standard	Over lap																														
	X																																

		<table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DI/EC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Action	AS	AS/EC	D	DI/EC				x									
Action	AS	AS/EC	D	DI/EC																
			x																	
CE#292	Adds new subsection C406.2.3.2. It increases the stringency but is a cost-effective measure. Adds new subsection C406.2.3.3. It increases the stringency but is a cost-effective measure. 1. W05 Point of use water heaters. It increases the stringency but is a cost-effective measure. 2. W06 Thermostatic balancing valves. It increases the stringency but is a cost-effective measure. 3. W07 Heat trace system. It increases the stringency but is a cost-effective measure. Adds new subsection C406.2.3.4. It increases the stringency but is a cost-effective measure. Adds new subsection C406.2.3.5. It increases the stringency but is a cost-effective measure. Adds new subsection C406.2.3.6. It increases the stringency but is a cost-effective measure.																			
Related Mods: CEPI- 193-21, CED1- 185-22, CED1- 174-22	C406.2.3.2 W04 Service hot water piping insulation increase. Where service hot water is provided by a central water-heating system, the hot water pipe insulation thickness shall be at least 1.5 times the thickness required in Section C404.4. All service hot water piping shall be insulated from the hot water source to the fixture shutoff. Where 50 percent or more of hot water piping does not have increased insulation due to installation in partitions, the credit shall be prorated as a percentage of lineal feet of piping with increased insulation. C406.2.3.3 Service water-heating distribution temperature maintenance. A project is allowed to claim energy credits from only one of the following SHW distribution temperature maintenance measures. 1. W05 Point of use water heaters . Credits are available for Group B or E buildings larger than 5,000 square feet (465 m ²) where service water heating systems meet the following requirements: 1.1. Fixtures requiring hot water shall be supplied from a local water heater with no recirculating system or heat trace piping. Exception: Commercial kitchens or showers in locker rooms shall be permitted to have a local recirculating system or heat trace piping where water heaters are located not more than 50 lineal feet (15 m) from the farthest fixture served. 1.2. Supply piping from the water heater to the termination of the fixture supply pipe shall be insulated to the levels shown in Table C404.4.1. Exceptions: 1. Piping at locations where a vertical support of the piping is installed. 2. Where piping passes through a framing member and insulation requires increasing the size of the framing member. 1.3. The water volume in the piping from the water heater to the termination of any individual fixture shall be limited as follows: 1.3.1. Nonresidential public lavatory faucets that are available for use by members of the general public: not more than 2 ounces (59 mL). 1.3.2. Commercial kitchens or showers in locker rooms with recirculating systems or heat trace piping: not more than 24 ounces (710 mL) from the recirculating system or heat trace piping. 1.3.3. All other plumbing fixtures or appliances: not more than 16 ounces (473 mL). 2. W06 Thermostatic balancing valves. Credits are available where service water heating is provided centrally and distributed throughout the building with a recirculating system. Each recirculating system branch return connection to the main SHW supply piping shall have an automatic thermostatic balancing valve set to a minimal return water flow when the branch return temperature is greater than 120°F (49°C). 3. W07 Heat trace system. Credits are available for projects with gross floor area greater than 10,000 square feet (929m ²) and a central water-heating system. The energy credits achieved shall be from Tables C406.2(1) through C406.2(9). This system shall include self-regulating electric heat cables, connection kits and electronic controls. The cable shall be installed directly on the hot water supply pipes underneath the insulation to replace standby losses. C406.2.3.4 W08 Water-heating system submeters. Each individual dwelling unit in a Group R-2 occupancy served by a central service water-heating system shall be provided with a service hot water meter connected to a reporting system that provides individual dwelling unit reporting of actual domestic hot water use. Preheated water serving the cold water inlet to showers need not be metered. C406.2.3.5 W09 Service hot water flow reduction. Dwelling unit , sleeping unit and guestroom plumbing fixtures that are connected to the service water-heating system shall have a flow or consumption rating less than or equal to the values shown in Table C406.2.3.5. C406.2.3.6 W10 Shower drain heat recovery. Cold water serving building showers shall be preheated by shower drain																			
	<p>heat recovery units that comply with Section C404.7. The efficiency of drain heat recovery units shall be 54 percent or greater measured in accordance with CSA B55.1. Full credits are applicable to the following building uses: I-2, I-4, R-1, R-2 and also Group E where there are more than eight showers. Partial credits are applicable to buildings where all but ground floor showers are served where the base energy credit from Section C406.2 is adjusted by Equation 4-20.</p> <p style="text-align: right;">Equation 4-20</p> $W10 \text{ credit} = W10 \text{ base energy credit} \times (\text{showers with drain heat recovery}/\text{total showers in building})$ <p style="text-align: right;">FSEC – Anticipated energy impact on FBC-EC – Decrease</p>																			
		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DI/EC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	D	DI/EC				x	
Staff Classification	Correlates Directly	Energy Standard	Over lap																	
	x																			
Action	AS	AS/EC	D	DI/EC																
			x																	
CE#293	Adds new Table C406.2.3.5.																			
Related Mods: CEPI- 193-21	TABLE C406.2.3.5 MAXIMUM FLOW RATING FOR RESIDENTIAL PLUMBING FIXTURES WITH HEATED WATER <table><tr><th>PLUMBING</th><th>MAXIMUM FLOW RATE</th></tr><tr><td>Faucet for private lavatory,^a hand sinks, or bar sinks</td><td>1.2 gpm at 60 psi</td></tr><tr><td>Faucet for residential kitchen sink^{a, b, c}</td><td>1.8 gpm at 60 psi</td></tr><tr><td>Shower head (including hand-held shower spray)^{a, b, d}</td><td>1.8 gpm at 80 psi</td></tr></table> <p>For SI: 1 gallon per minute = 3.785 L/min, 1 pound per square inch = 6.89 kPa. a. Showerheads, lavatory faucets and kitchen faucets are subject to US federal requirements listed in 10 CFR 430.32(o)–(p). b. Maximum flow allowed is less than required by flow rates listed in 10 CFR 430.32(o)–(p) for showerheads and kitchen faucets. c. Residential kitchen faucets may temporarily increase the flow above the maximum rate, but not above 2.2 gallons per minute at 60 psi (8.3 L/min at 414 kPa), and must default to the maximum flow rate listed. d. Where a shower is served by multiple shower heads, the combined flow rate of all shower heads controlled by a single valve shall not exceed the maximum flow rate listed or the shower shall be designed to allow only one shower head to operate at a</p> <p style="text-align: right;">time.</p>			PLUMBING	MAXIMUM FLOW RATE	Faucet for private lavatory, ^a hand sinks, or bar sinks	1.2 gpm at 60 psi	Faucet for residential kitchen sink ^{a, b, c}	1.8 gpm at 60 psi	Shower head (including hand-held shower spray) ^{a, b, d}	1.8 gpm at 80 psi									
PLUMBING	MAXIMUM FLOW RATE																			
Faucet for private lavatory, ^a hand sinks, or bar sinks	1.2 gpm at 60 psi																			
Faucet for residential kitchen sink ^{a, b, c}	1.8 gpm at 60 psi																			
Shower head (including hand-held shower spray) ^{a, b, d}	1.8 gpm at 80 psi																			
		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DI/EC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	D	DI/EC				x	
Staff Classification	Correlates Directly	Energy Standard	Over lap																	
	x																			
Action	AS	AS/EC	D	DI/EC																
			x																	
CE#294	Adds new Section C406.2.4 based on an existing measure. Achieving energy credits using an energy monitoring system.																			
Related Mods: CEPI- 193-21	C406.2.4 P01 Energy monitoring. A project not required to comply with Section C405.13 can achieve energy credits for installing an energy monitoring system that complies with all the requirements of Sections C405.13.1 through C405.13.5. <p style="text-align: right;">FSEC – Anticipated energy impact on FBC-EC – Decrease</p>																			
		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>DI/EC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		x			Action	AS	AS/EC	D	DI/EC				x	
Staff Classification	Correlates Directly	Energy Standard	Over lap																	
	x																			
Action	AS	AS/EC	D	DI/EC																
			x																	

CE#295	Adds new Section C406.2.5. Achieving energy credits by enhancing lighting performance. C406.2.5.1 Reserves for future use. Adds new Section C406.2.5.2 by modifying an existing lighting control measure. Adds new Section C406.2.5.3. It increases the stringency but is a cost-effective measure. Adds new subsection C406.2.5.3.1. Adds new subsection C406.2.5.3.2. Adds new subsection C406.2.5.3.3.																					
Related Mods: CEPI- 193-21, CED1-81- 22, CECD1- 3-22, CECD1- 4-22,	<p>C406.2.5 Energy savings in lighting systems. Projects are permitted to achieve energy credits for increased lighting system performance by meeting the requirements of one of the following:</p> <ol style="list-style-type: none">1. Section C406.2.5.2 L02.2. Section C406.2.5.3 L03.3. Section C406.2.5.4 L04.4. Section C406.2.5.5 L05.5. Section C406.2.5.6 L06.6. Any combination of L03, L04, L05 and L06.7. Any combination of L02, L03 and L04. <p>C406.2.5.1 L01 Lighting system performance (reserved). Reserved for future use.</p> <p>C406.2.5.2 L02 High-end trim lighting controls. Measure credits shall be achieved where qualifying spaces are not less than 50 percent of the project interior floor area exclusive of <i>dwelling and sleeping units</i> . Qualifying spaces are those where <i>general lighting</i> is controlled by high-end trim lighting controls complying with the following:</p> <ol style="list-style-type: none">1. The calibration adjustment equipment is located for ready access only by authorized personnel.2. Lighting controls with ready access for users cannot increase the lighting power above the maximum level established by the high-end trim controls.3. <i>Construction documents</i> shall state that maximum light output or power of <i>general lighting</i> in spaces contributing the qualifying floor area shall be not greater than 85 percent of full power or light output.4. High-end trim lighting controls shall be tested in accordance with Section C408.3.1.5. <p>The base credits from Tables C406.2(1) through C406.2(9) shall be prorated as follows:</p>																					
	<p><i>HET</i> × [Base energy credits for C406.2.5.2]/50% where: <i>HET</i> = Floor area of qualifying spaces where <i>general lighting</i> is provided with high-end trim lighting controls complying with this section, expressed as a percentage of total interior floor area, excluding <i>dwelling and sleeping units</i> .</p> <p>C406.2.5.3 L03 Increase occupancy sensor. Lighting controls shall comply with Sections C406.2.5.3.1, C406.2.5.3.2 and C406.2.5.3.3.</p> <p>C406.2.5.3.1 Occupant sensor controls. Occupant sensor controls shall be installed to control lights in the following space types:</p> <ol style="list-style-type: none">1. Food preparation area.2. Laboratory.3. Elevator lobby.4. Pharmacy area.5. Vehicular maintenance area.6. Workshop.7. Recreation room in a facility for the visually impaired.8. Exercise area in a fitness center.9. Playing area in a fitness center.10. Exam/treatment room in a health care facility.11. Imaging room in a health care facility.12. Physical therapy room in a health care facility.13. Library reading area.14. Library stacks.15. Detailed manufacturing area.16. <i>Equipment room</i> in a manufacturing facility.17. Low-bay area in a manufacturing facility.18. Post office sorting area.19. Religious fellowship hall.20. Hair salon.21. Nail salon.22. Banking activity area.23. Museum restoration room. <p>C406.2.5.3.2 Occupant sensor control function. Occupant sensors in library stacks and laboratories shall comply with Section C405.2.1.2. Occupant sensors in elevator lobbies shall comply with Section C405.2.1.4. All other occupant sensors required by Section C406.2.5.3.1 shall comply with Section C405.2.1.1.</p> <p>Exception: In spaces where an <i>automatic</i> shutoff could endanger occupant safety or security, occupant sensor controls shall uniformly reduce lighting power to not more than 20 percent of full power within 10 minutes after all occupants have left the space. Time-switch controls complying with Section C405.2.2.1 shall automatically</p>																					
	<p>turn off lights.</p> <p>C406.2.5.3.3 Occupant sensor time delay and setpoint. Occupant sensor controls installed in accordance with Sections C405.2.1.1, C405.2.1.2, C405.2.1.3 and C405.2.1.4 shall automatically turn off lights or reduce lighting power within 10 minutes after all occupants have left the space. Occupant sensor controls installed in accordance with Section C405.2.1.2 shall have an unoccupied setpoint of not greater than 20 percent of full power.</p>																					
		<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Overlap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AL/EC</th><th>DS</th><th>OL/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>			Staff Classification	Correlates Directly	Energy Standard	Overlap		X			Action	AS	AL/EC	DS	OL/EC				X	
Staff Classification	Correlates Directly	Energy Standard	Overlap																			
	X																					
Action	AS	AL/EC	DS	OL/EC																		
			X																			
	FSEC – Anticipated energy impact on FBC-EC – Decrease																					
CE#296	Adds new subsection C406.2.5.4. It may lightly increases the stringency but is a cost-effective measure.																					
Related Mods: CEPI- 193-21, CED1- 185-22, CECD1- 6-22	<p>C406.2.5.4 L04 Increased daylight area. The total daylight area of the <i>building</i></p> <p>(DLA_{BLDG}) determined by Equation 4-21 shall be at least 5 percent greater than the typical daylight area (DLA_{TYP}) from Table C406.2.5.4. Credits for measure L04 shall be determined by Equation 4-22 or Equation 4-23, whichever is less:</p> <p>Equation 4-21</p> $DLA_{BLDG} = DLZ/LFA$ <p>where: DLZ = The total building floor area located within sidelit and toplit daylight zones complying with Section C405.2.4.2 or C405.2.4.3 and provided with daylight-responsive controls complying with Section C405.2.4.1, ft² or m².</p> <p>LFA = The total building floor area used to determine the lighting power allowance in Section C405.3.2, ft² or m².</p> <p>Equation 4-22</p> $EC_{DL} = EC_{DLIS} \times 20 \times (DLA_{BLDG} - DLA_{TYP})$ <p>where: EC_{DL} = The lesser of actual area of daylight zones in the building with continuous daylight dimming, ft² or m² and (DLZ/LFA × DLA_{TYP}); see Table C406.2.5.4. Daylight zones shall meet the criteria in Sections C405.2.4.2 and C405.2.4.3 for primary sidelit daylight zones, secondary sidelit daylight zones and toplit daylight zones.</p> <p>DLA_{TYP} = Typical percent of building area with daylight control (as a fraction) from Table C406.2.5.4.</p> <p>EC_{DLIS} = Section C406.2.5.4 L04 base energy credits from Section C406.2.</p> <p>Equation 4-23</p> $EC_{DL} = EC_{DLIS} \times 20 \times (DLA_{MAX} - DLA_{TYP})$ <p>where: EC_{DL} = The number of credits achieved by this measure.</p>																					

	<p>FBC_{EC} = Section C406.2.5.4 L04 base energy credits from Section C406.2 and Tables C406.2(4), C406.2(6), C406.2(7) and C406.2(8).</p> <p>DLA_{TYP} = Typical percent of building floor area with daylight control (as a fraction) from Table C406.2.5.4.</p> <p>DLA_{MAX} = Maximum percent of building floor area with daylight control that can be counted for compliance with this measure, from Table C406.2.5.4.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Required</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Required	Over lap		X			Action	AS	AS/EC	D	D/EC				X																									
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																																								
	X																																										
Action	AS	AS/EC	D	D/EC																																							
			X																																								
CE#297	Adds new Table C406.2.5.4.																																										
Related Mods: CEPI- 193-21, CECD1- 6-22	<p>TABLE C406.2.5.4 ADDED DAYLIGHTING PARAMETERS</p> <table><tr><th>BUILDING-USE</th><th>DLA_{TYP}</th><th>DLA_{MAX}</th></tr><tr><td>Group B; $\leq 5,000 \text{ ft}^2$ (460 m^2)</td><td>10%</td><td>20%</td></tr><tr><td>Group B; $> 5,000 \text{ ft}^2$ (460 m^2)</td><td>21%</td><td>31%</td></tr><tr><td>Group M; with $\leq 1,000 \text{ ft}^2$ (900 m^2) roof area</td><td>0%</td><td>20%</td></tr><tr><td>Group M; with $> 1,000 \text{ ft}^2$ (900 m^2) roof area</td><td>60%</td><td>80%</td></tr><tr><td>Group E; education</td><td>42%</td><td>52%</td></tr><tr><td>Groups S-1 and S-2; warehouse</td><td>50%</td><td>70%</td></tr><tr><td>Groups S-1 and S-2; other than warehouse</td><td>NA</td><td>NA</td></tr></table> <p>NA = Not available.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Required</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	BUILDING-USE	DLA_{TYP}	DLA_{MAX}	Group B; $\leq 5,000 \text{ ft}^2$ (460 m^2)	10%	20%	Group B; $> 5,000 \text{ ft}^2$ (460 m^2)	21%	31%	Group M; with $\leq 1,000 \text{ ft}^2$ (900 m^2) roof area	0%	20%	Group M; with $> 1,000 \text{ ft}^2$ (900 m^2) roof area	60%	80%	Group E; education	42%	52%	Groups S-1 and S-2; warehouse	50%	70%	Groups S-1 and S-2; other than warehouse	NA	NA	Staff Classification	Correlates Directly	Energy Standard Required	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
BUILDING-USE	DLA_{TYP}	DLA_{MAX}																																									
Group B; $\leq 5,000 \text{ ft}^2$ (460 m^2)	10%	20%																																									
Group B; $> 5,000 \text{ ft}^2$ (460 m^2)	21%	31%																																									
Group M; with $\leq 1,000 \text{ ft}^2$ (900 m^2) roof area	0%	20%																																									
Group M; with $> 1,000 \text{ ft}^2$ (900 m^2) roof area	60%	80%																																									
Group E; education	42%	52%																																									
Groups S-1 and S-2; warehouse	50%	70%																																									
Groups S-1 and S-2; other than warehouse	NA	NA																																									
Staff Classification	Correlates Directly	Energy Standard Required	Over lap																																								
	X																																										
Action	AS	AS/EC	D	D/EC																																							
			X																																								
CE#298	Adds new subsection C406.2.5.5. This is simpler lighting control strategy. It does impact the stringency since lighting control is required elsewhere in the code. Adds new subsection C406.2.5.6 by expanding an existing measure.																																										
Related Mods:																																											

CEPI- 193-21,
CE2D-64- 23,
CECD1- 16-
22, CE2D-64-
23, CECD1- 7-
22

C406.2.5.5 L05 Residential light control. In buildings with Group R-2 occupancy spaces, interior lighting systems shall comply with the following:

- In *common areas*, the following space types shall have occupant sensor controls that comply with the requirements of **Section C405.2.1.1**:
 - Laundry/washing areas.
 - Dining areas.
 - Food preparation areas.
 - Seating areas.
 - Exercise areas.
 - Massage spaces.
- In *dwelling units*, not less than one receptacle in each living room and each sleeping room shall be controlled by a switch in that room.
- Lights and switched receptacles in bathrooms and kitchens shall be controlled by an occupant sensor complying with **Section C405.2.1.1**. All other lights and switched receptacles in each *dwelling unit* shall be controlled by a switch at the main entrance. The switch shall be marked to indicate its function.

Exception: Lighting and switched receptacles controlled by an occupant sensor complying with **Section C405.2.1.1** are not required to be controlled by the switch at the main entrance.

C406.2.5.6 L06 Reduced lighting power. Interior lighting within all building areas shall comply with this section.

- The connected interior lighting power (LP) determined in accordance with **Section C405.3.1** shall be 95 percent or less than the interior lighting power allowance (LPA) determined in accordance with **Section C405.3.2** using the same method used to comply with **Section C405.3**. Energy credits shall not be greater than four times the L06 base credit from **Section C406.2** and shall be determined using **Equation 4-24**.
- All permanently installed lighting serving *dwelling units* and *sleeping units*, including ceiling fan light kits and lighting integrated into range hoods and exhaust fans shall be provided by lamps with an efficacy of not less than 90 lumens per watt or by luminaires that have an efficacy of not less than 65 lumens per watt.

Exceptions:

- Lighting integral to other appliances.
- Antimicrobial lighting used for the sole purpose of disinfecting.

$$EC_{LPA} = EC_5 \times 20 \times (LPA - LP) / LPA_{EC}$$

where:
 LPA_{EC} = Additional energy credit for lighting power reduction.

Equation 4-24

LP = Connected interior lighting power calculated in accordance with **Section C405.3.1**, watts.
 LPA = Interior lighting power allowance calculated in accordance with the requirements of **Section C405.3.2**, watts.

EC_5 = L06 base credit from

Staff Classification	Correlates directly	Energy Standard Required	Over lap
	X		
Action	AS	AS/EC	D D/EC
			X

	<p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>
CE#299	<p>Adds new Section C406.2.6.</p> <p>Adds new subsection C406.2.6.1. The measure requires the installation of higher-efficiency elevator equipment. Thus, it increases the stringency but is cost-effective measure.</p> <p>Adds new subsection C406.2.6.2 based on an existing measure. No change in stringency.</p> <p>Adds new subsection C406.2.6.3. Requires the installation of higher efficiency or the highest Energy Star refrigerators in apartment and hotel guestrooms. It slightly increases the stringency but is a cost-effective measure.</p> <p>Adds new subsection C406.2.6.4 based on an existing measure. No change in stringency.</p>
Related Mods: CEPI- 193-21, CED1- 185-22, CED1- 175-22	<p>C406.2.6 Efficient equipment credits. Projects are permitted to achieve energy credits using any combination of Efficient Equipment Credits Q01 through Q04.</p> <p>C406.2.6.1 Q01 Efficient elevator equipment. Qualifying elevators in the <i>building</i> shall be energy efficiency class A per ISO 25745-2, Table 7. Only buildings three or more floors above grade may use this credit. Credits shall be prorated based on</p> <p>Equation 4-25, rounded to the nearest whole credit. Projects with a compliance ratio below 0.5 do not qualify for this credit.</p> <p>Equation 4-25</p> <p>where: EC_9 = Elevator energy credit achieved for the building. EC_1 = Q01 base energy credit from applicable Table C406.2(1) through Table C406.2(9). CR_e = Compliance ratio = FA / FB. FA = Sum of floors served by class A elevators. FB = Sum of floors served by all building elevators and escalators.</p>

	<p>C406.2.6.2 Q02 Efficient commercial kitchen equipment. For buildings and spaces designated as Group A-2, or facilities whose primary business type involves the use of a commercial kitchen where at least one gas or electric fryer is installed before the issuance of the certificate of occupancy, all fryers, dishwashers, steam cookers and ovens installed before the issuance of the certificate of occupancy shall comply with all of the following:</p> <ol style="list-style-type: none">1. Achieve performance levels in accordance with the equipment specifications listed in Tables C406.2.6.2(1) through C406.2.6.2(4) where rated in accordance with the applicable test procedure.2. Have associated performance levels listed on the <i>construction documents</i> submitted for permitting. <p>C406.2.6.3 Q03 Efficient residential kitchen equipment. For projects with Group R-1 and R-2 occupancies, energy credits shall be achieved where all dishwashers, refrigerators and freezers comply with all of the following:</p> <ol style="list-style-type: none">1. Achieve the Energy Star Most Efficient 2021 label in accordance with the specifications current as of:<ol style="list-style-type: none">1.1. Refrigerators and freezers 5.0, 9/15/2014.1.2. Dishwashers 6.0, 1/29/2016.2. Be installed before the issuance of the certificate of occupancy.																																																			
	<p>For Group R-1 where only some guestrooms are equipped with both refrigerators and dishwashers, the table credits shall be prorated as follows:</p> <p>Equation 4-26</p> <p>C406.2.6.4 Q04 Fault detection and diagnostics system. A project not required to comply with Section C403.2.3 can achieve energy credits for installing a fault detection and diagnostics system to: $[\text{Section C406.2 base credits}] \times [\text{floor area of guestrooms with kitchens}] / [\text{total guestroom floor area}]$ with Items 1 through 6 in Section C403.2.3.</p>																																																			
		<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>MS/EC</td><td>D</td><td>OS</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	MS/EC	D	OS				X																																	
Staff Classification	Correlates Directly	Energy Standard	Over lap																																																	
	X																																																			
Action	AS	MS/EC	D	OS																																																
			X																																																	
CE#300	Adds new Table C406.2.6.2(1) based on an existing Table C406.12(1). No change in stringency.																																																			
Related Mods: CEPI- 193-21	TABLE C406.2.6.2(1) MINIMUM EFFICIENCY REQUIREMENTS: COMMERCIAL FRYERS																																																			
	<table><tr><td></td><td>HEAVY-LOAD COOKING ENERGY EFFICIENCY</td><td>IDLE ENERGY RATE</td><td>TEST PROCEDURE</td></tr><tr><td>Standard open deep-fat gas fryers</td><td>≥ 50%</td><td>≤ 9,000 Btu/h</td><td rowspan="2">ASTM F1361</td></tr><tr><td>Standard open deep-fat electric fryers</td><td>≥ 83%</td><td>≤ 800 watts</td></tr><tr><td>Large vat open deep-fat gas fryers</td><td>≥ 50%</td><td>≤ 12,000 Btu/h</td><td rowspan="2">ASTM F2144</td></tr><tr><td>Large vat open deep-fat electric fryers</td><td>≥ 80%</td><td>≤ 1,100 watts</td></tr></table> <p>For SI: 1 British thermal unit per hour = 0.293 watts.</p>		HEAVY-LOAD COOKING ENERGY EFFICIENCY	IDLE ENERGY RATE	TEST PROCEDURE	Standard open deep-fat gas fryers	≥ 50%	≤ 9,000 Btu/h	ASTM F1361	Standard open deep-fat electric fryers	≥ 83%	≤ 800 watts	Large vat open deep-fat gas fryers	≥ 50%	≤ 12,000 Btu/h	ASTM F2144	Large vat open deep-fat electric fryers	≥ 80%	≤ 1,100 watts	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>MS/EC</td><td>D</td><td>OS</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	MS/EC	D	OS				X															
	HEAVY-LOAD COOKING ENERGY EFFICIENCY	IDLE ENERGY RATE	TEST PROCEDURE																																																	
Standard open deep-fat gas fryers	≥ 50%	≤ 9,000 Btu/h	ASTM F1361																																																	
Standard open deep-fat electric fryers	≥ 83%	≤ 800 watts																																																		
Large vat open deep-fat gas fryers	≥ 50%	≤ 12,000 Btu/h	ASTM F2144																																																	
Large vat open deep-fat electric fryers	≥ 80%	≤ 1,100 watts																																																		
Staff Classification	Correlates Directly	Energy Standard	Over lap																																																	
	X																																																			
Action	AS	MS/EC	D	OS																																																
			X																																																	
CE#301	Adds new Table C406.2.6.2(2) based on an existing Table C406.12(2). No change in stringency.																																																			
Related Mods: CEPI- 193-21	TABLE C406.2.6.2(2) MINIMUM EFFICIENCY REQUIREMENTS: COMMERCIAL STEAM COOKERS																																																			
	<table><tr><td></td><td>PAN CAPACITY</td><td>COOKING ENERGY EFFICIENCY^a</td><td>IDLE ENERGY RATE</td><td>TEST PROCEDURE</td></tr><tr><td rowspan="4"></td><td>3-pan</td><td>50%</td><td>400 watts</td><td rowspan="8">ASTM F1484</td></tr><tr><td>4-pan</td><td>50%</td><td>530 watts</td></tr><tr><td>5-pan</td><td>50%</td><td>670 watts</td></tr><tr><td>6-pan and larger</td><td>50%</td><td>800 watts</td></tr><tr><td rowspan="4"></td><td>3-pan</td><td>38%</td><td>6,250 Btu/h</td></tr><tr><td>4-pan</td><td>38%</td><td>8,350 Btu/h</td></tr><tr><td>5-pan</td><td>38%</td><td>10,400 Btu/h</td></tr><tr><td>6-pan and larger</td><td>38%</td><td>12,500 Btu/h</td></tr></table> <p>For SI: 1 British thermal unit per hour = 0.293 watts.</p> <p>a.. Cooking energy efficiency is based on heavy-load (potato) cooking capacity.</p>		PAN CAPACITY	COOKING ENERGY EFFICIENCY^a	IDLE ENERGY RATE	TEST PROCEDURE		3-pan	50%	400 watts	ASTM F1484	4-pan	50%	530 watts	5-pan	50%	670 watts	6-pan and larger	50%	800 watts		3-pan	38%	6,250 Btu/h	4-pan	38%	8,350 Btu/h	5-pan	38%	10,400 Btu/h	6-pan and larger	38%	12,500 Btu/h	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>MS/EC</td><td>D</td><td>OS</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard	Over lap		X			Action	AS	MS/EC	D	OS				X	
	PAN CAPACITY	COOKING ENERGY EFFICIENCY^a	IDLE ENERGY RATE	TEST PROCEDURE																																																
	3-pan	50%	400 watts	ASTM F1484																																																
	4-pan	50%	530 watts																																																	
	5-pan	50%	670 watts																																																	
	6-pan and larger	50%	800 watts																																																	
	3-pan	38%	6,250 Btu/h																																																	
	4-pan	38%	8,350 Btu/h																																																	
	5-pan	38%	10,400 Btu/h																																																	
	6-pan and larger	38%	12,500 Btu/h																																																	
Staff Classification	Correlates Directly	Energy Standard	Over lap																																																	
	X																																																			
Action	AS	MS/EC	D	OS																																																
			X																																																	
CE#302	Adds new Table C406.2.6.2(3) based on an existing Table C406.12(3). No change in stringency.																																																			
Related Mods: CEPI- 193-21	TABLE C406.2.6.2(3) MINIMUM EFFICIENCY REQUIREMENTS: COMMERCIAL DISHWASHERS																																																			
	<table><tr><td></td><td colspan="3">HIGH-TEMPERATURE EFFICIENCY REQUIREMENTS</td><td colspan="3">LOW-TEMPERATURE EFFICIENCY REQUIREMENTS</td><td>TEST PROCEDURE</td></tr><tr><td></td><td>Idle Energy Rate^a</td><td>Washing Energy</td><td>Water Consumption^b</td><td>Idle Energy Rate^a</td><td>Washing Energy</td><td>Water Consumption^b</td><td></td></tr><tr><td>Under counter</td><td>≤ 0.30 kW</td><td>≤ 0.35 kWh/ rack</td><td>≤ 0.86 GPR (≤ 3.3 LPR)</td><td>≤ 0.25 kW</td><td>≤ 0.15 kWh/ rack</td><td>≤ 1.19 GPR ≤ 4.5 LPR</td><td></td></tr><tr><td>Stationary single-tank door</td><td>≤ 0.55 kW</td><td>≤ 0.35 kWh/ rack</td><td>≤ 0.89 GPR (≤ 3.4 LPR)</td><td>≤ 0.30 kW</td><td>≤ 0.15 kWh/ rack</td><td>≤ 1.18 GPR ≤ 4.47 LPR</td><td></td></tr><tr><td>Pot, pan and utensil</td><td></td><td>kWh/ rack ≤ 0.55 + 0.05 x $\frac{c}{sf_{rack}}$ ¹⁵</td><td>≤ 0.58 GPSF (≤ 2.2 LPSM)</td><td>NA</td><td>NA</td><td>NA</td><td></td></tr></table>		HIGH-TEMPERATURE EFFICIENCY REQUIREMENTS			LOW-TEMPERATURE EFFICIENCY REQUIREMENTS			TEST PROCEDURE		Idle Energy Rate^a	Washing Energy	Water Consumption^b	Idle Energy Rate^a	Washing Energy	Water Consumption^b		Under counter	≤ 0.30 kW	≤ 0.35 kWh/ rack	≤ 0.86 GPR (≤ 3.3 LPR)	≤ 0.25 kW	≤ 0.15 kWh/ rack	≤ 1.19 GPR ≤ 4.5 LPR		Stationary single-tank door	≤ 0.55 kW	≤ 0.35 kWh/ rack	≤ 0.89 GPR (≤ 3.4 LPR)	≤ 0.30 kW	≤ 0.15 kWh/ rack	≤ 1.18 GPR ≤ 4.47 LPR		Pot, pan and utensil		kWh/ rack ≤ 0.55 + 0.05 x $\frac{c}{sf_{rack}}$ ¹⁵	≤ 0.58 GPSF (≤ 2.2 LPSM)	NA	NA	NA												
	HIGH-TEMPERATURE EFFICIENCY REQUIREMENTS			LOW-TEMPERATURE EFFICIENCY REQUIREMENTS			TEST PROCEDURE																																													
	Idle Energy Rate^a	Washing Energy	Water Consumption^b	Idle Energy Rate^a	Washing Energy	Water Consumption^b																																														
Under counter	≤ 0.30 kW	≤ 0.35 kWh/ rack	≤ 0.86 GPR (≤ 3.3 LPR)	≤ 0.25 kW	≤ 0.15 kWh/ rack	≤ 1.19 GPR ≤ 4.5 LPR																																														
Stationary single-tank door	≤ 0.55 kW	≤ 0.35 kWh/ rack	≤ 0.89 GPR (≤ 3.4 LPR)	≤ 0.30 kW	≤ 0.15 kWh/ rack	≤ 1.18 GPR ≤ 4.47 LPR																																														
Pot, pan and utensil		kWh/ rack ≤ 0.55 + 0.05 x $\frac{c}{sf_{rack}}$ ¹⁵	≤ 0.58 GPSF (≤ 2.2 LPSM)	NA	NA	NA																																														

CE#303	Adds new Table C406.2.6.2(4) based on an existing Table C406.12(4). No change in stringency.				
Related Mods:	TABLE C406.2.6.2(4) MINIMUM EFFICIENCY REQUIREMENTS: COMMERCIAL OVENS				
CEPI- 193-21	FUEL	CLASSIFICATION	IDLE RATE	COOKING ENERGY	TEST PROCEDURE
	Gas	Full-size	$\leq 12,000 \text{ Btu/h}$	≥ 46	ASTM F1496
	Electric	Half-size	$\leq 1.0 \text{ kW}$	≥ 71	
	Electric	Full-size	$\leq 1.60 \text{ kW}$		
	Gas	Steam mode	$\leq 200 \text{ P}^a + 6,511 \text{ Btu/h}$	≥ 41	ASTM F2861
		Convection mode	$\leq 150 \text{ P}^a + 5,425 \text{ Btu/h}$	≥ 56	
	Electric	Steam mode	$\leq 0.133 \text{ P}^a + 0.6400 \text{ kW}$	≥ 55	
		Convection mode	$\leq 0.080 \text{ P}^a + 0.4989 \text{ kW}$	≥ 76	
	Gas	Single	$\leq 25,000 \text{ Btu/h}$	≥ 48	ASTM F2093
		Double	$\leq 30,000 \text{ Btu/h}$	≥ 52	

For SI: 1 British thermal unit per hour = 0.293 watts.
a. P = Pan capacity: the number of steam table pans the combination oven is able to accommodate in accordance with ASTM F1495.

Test Classification	Corrosive Directly	Energy Standard Needed	Over Size
	X		
Action	AS	ASAC	D
		X	200°

CE#304	Adds new Section C406.3. Achieving energy credits for renewable and load management measures. It increase the stringency but is cost-effective measure.
Related Models: CEPI- 193-21, CED1- 175-22	<p>C406.3 Reduced lighting power. Buildings shall comply with Section C406.3.1 or C406.3.2, and dwelling units and sleeping units within the building shall comply with Section C406.3.3.</p> <p>C406.3.1 Reduced lighting power by more than 10 percent. The total connected interior lighting power calculated in accordance with Section C405.3.1 shall be less than 90 percent of the total lighting power allowance calculated in accordance with Section C405.3.2.</p> <p>C406.3.2 Reduced lighting power by more than 15 percent. Where the total connected interior lighting power calculated in accordance with Section C405.3.1 is less than 85 percent of the total lighting power allowance calculated in accordance with Section C405.3.2, additional energy efficiency credits shall be determined based on Equation 4-13, rounded to the nearest whole number.</p> <p>(Equation 4-13)</p> <p>where:</p> <p>$AEEC = \frac{LPA}{LPD}$ — Section C406.3.3 additional energy efficiency credits.</p> <p>$AEEC = \frac{LPA}{LPD}$ — Section C406.3.1 credits from Tables C406.1(1) through C406.1(5).</p> <p>LPA = Total lighting power allowance calculated in accordance with Section C405.3.2.</p> <p>LPD = Total connected interior lighting power calculated in accordance with Section C405.3.1.</p> <p>C406.3.3 Lamp efficacy. Not less than 95 percent of the permanently installed lighting, excluding kitchen appliance light fixtures, serving dwelling units and sleeping units shall be provided by lamps with an efficacy of not less than 65 lumens per watt or luminaires with an efficacy of not less than 45 lumens per watt.</p> <p>C406.3 Renewable and load management credits achieved. Renewable energy and load management measures shall achieve credits as follows:</p> <ol style="list-style-type: none"> General measure requirements. Credits are achieved for measures installed in the building that comply with Sections C406.3.1 through C406.3.8.

	<p>2. Achieved credits are determined as follows:</p> <p>2.1. Measure credits achieved shall be determined in one of two ways, depending on the measure:</p> <p>2.1.1. The measure credit shall be the base credit listed by occupancy group and <i>climate zone</i> for the measure in Tables C406.3(1) through C406.3(9) where no adjustment factor or formula is shown in the description of the measure in Section C406.3.</p> <p>2.1.2. The measure credit shall be the base energy credit for the measure adjusted by a factor or formula as stated in the description of the measure in Section C406.3. Where adjustments are applied, each energy credit shall be rounded to the nearest whole number.</p> <p>2.2. Load management and renewable credits achieved for the project shall be the sum of credits for individual measures included in the project. Credits are available for the measures listed in this section.</p> <p>2.3. Where a project contains multiple building use groups, credits achieved for each building use group shall be summed and then weighted by the gross floor area of each building use group to determine the weighted-average project energy credits achieved.</p> <p>3. Load management control requirements. The load management measures in Sections C406.3.2 (G01) through C406.3.7 (G06) require load management control sequences that are capable of and configured to automatically provide the load management operation specified based on indication of a peak period related to high short-term electric prices, grid condition or peak building load. Such a peak period shall, where possible, be initiated by a <i>demand response signal</i> from the controlling entity, such as a utility or service operator. Where communications are disabled or unavailable, all demand-responsive controls shall continue backup demand response based on a local schedule or building-demand monitoring. The local building schedule shall be adjustable without programming and reflect the electric rate peak period dates and times. The load management control sequences shall be activated for peak period control by one of the following:</p> <p>3.1. A certified OpenADR 2.0a or OpenADR 2.0b Virtual End Node (VEN), as specified under Clause 11, Conformance, in the applicable OpenADR 2.0 Specification.</p> <p>3.2. A device certified by the manufacturer as being capable of responding to a <i>demand response signal</i> from a certified OpenADR 2.0b VEN by automatically implementing the control functions requested by the VEN for the equipment it controls.</p> <p>3.3. The physical configuration and communication protocol of CTA-2045-A or CTA-2045-B.</p> <p>3.4. For air conditioners and heat pumps with two or more stages of control and cooling capacity of less than 65,000 Btu/h (19 kW), <i>thermostats</i> with a <i>demand responsive control</i> that complies with the communication and performance requirements of AHRI 1380.</p> <p>3.5. A device that complies with IEC 62746-10-1, an international standard for the open automated demand response system interface between the appliance, system, or energy management system and the controlling entity.</p> <p>3.6. An interface that complies with the communication protocol required by a controlling entity to participate in an automated demand response program.</p> <p>3.7. Where the controlling entity does not have a <i>demand response signal</i> available for the building type and size, local load management control shall be provided based on either:</p> <p>3.7.1. Building demand management controls that monitor building electrical demand and initiate controls to minimize monthly or peak time period demand charges.</p> <p>3.7.2. A local building schedule that reflects the electric rate peak period dates and times where buildings are less than 25,000 gross square feet (2322 m²).</p>																
	<div><div>Original text of mod is not consistent with that of the 2023 FBC – EC.</div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th></tr><tr><td></td><td></td><td>x</td><td></td></tr></table></div> <div>FSEC – Anticipated energy impact on FBC-EC – Decrease</div>	Staff Classification	Correlates Directly	Energy Standard	Over lap				x	Action	AS	AS/EC	EC			x	
Staff Classification	Correlates Directly	Energy Standard	Over lap														
			x														
Action	AS	AS/EC	EC														
		x															

CE#305 Adds new Tables C406.3(1) through Table C406.3(9). Adds new Table C406.3(6). It slightly increase the stringency.

Related Mods:
CEPI- 193-21

TABLE C406.3(1)		RENEWABLE AND LOAD MANAGEMENT CREDITS FOR GROUP R-2, R-4 AND I-1 OCCUPANCIES																				
ID	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																			
			0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8	
R01	Renewable energy	C406.3.1	9	15	11	17	18	20	19	21	13	10	13	9	9	11	10	9	10	9	7	
G01	Lighting load management	C406.3.2	16	7	9	12	12	16	11	14	12	11	16	14	8	11	14	5	7	7	11	
G02	HVAC load management	C406.3.3	42	41	21	35	23	37	30	28	28	17	33	24	20	22	23	10	13	15	17	
G03	Automated shading	C406.3.4	11	x	7	18	10	13	5	13	12	2	14	7	10	13	11	1	8	8	16	
G04	Electric energy storage	C406.3.5	10	10	10	11	10	13	13	14	17	16	13	17	14	13	17	14	14	14	15	
G05	Cooling energy storage	C406.3.6	28	6	31	13	22	21	21	37	11	12	22	11	9	17	9	7	17	2	3	
G06	SHW energy storage	C406.3.7	17	17	19	18	19	19	20	20	22	19	19	21	19	19	20	18	19	18	17	
G07	Building thermal mass	C406.3.8	7	2	11	5	16	28	22	27	60	19	43	46	32	58	37	27	45	40	19	
HVAC =Heating, Ventilation and Air Conditioning; SHW =Service Hot Water. x = Credits excluded from this building use type and climate zone.																						
TABLE C406.3(2)		RENEWABLE AND LOAD MANAGEMENT CREDITS FOR GROUP I-2 OCCUPANCIES																				
ENERGY		CLIMATE ZONE																				
ID	CREDIT ABBREVIATED TITLE	SECTION	0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8	
R01	Renewable energy	C406.3.1	6	6	6	6	6	8	7	9	8	6	8	6	6	7	7	6	7	5	4	
G01	Lighting load management	C406.3.2	11	12	13	13	13	12	12	12	6	13	16	12	13	14	15	14	14	12	12	
G02	HVAC load management	C406.3.3	10	11	10	10	8	21	10	10	13	11	18	11	12	14	13	12	11	9	7	
G03	Automated shading	C406.3.4	1	1	1	1	x	x	x	x	x	2	x	x	2	x	x	1	1	x	x	
G04	Electric energy storage	C406.3.5	13	13	13	13	14	15	14	15	15	14	15	15	14	15	15	13	14	13	12	
G05	Cooling energy storage	C406.3.6	25	6	33	14	25	19	27	37	27	16	22	19	14	18	11	11	20	2	3	
G06	SHW energy storage	C406.3.7	4	4	4	4	4	4	4	4	4	4	5	4	4	4	4	4	4	4	4	
G07	Building thermal mass	C406.3.8	6	2	10	4	16	25	20	24	57	18	39	44	31	53	33	25	40	34	14	

HVAC =Heating, Ventilation and Air Conditioning; SHW =Service Hot Water. x = Credits excluded from this building use type and climate zone.

TABLE C406.3(3)
RENEWABLE AND LOAD MANAGEMENT CREDITS FOR GROUP R-1 OCCUPANCIES

ID	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																		
			0A	0B	1A	1B	2 A	2B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	8
R01	Renewable energy	C406.3.1	9	8	12	9	11	11	10	12	13	9	12	8	9	11	9	8	9	7	5
G01	Lighting load management	C406.3.2	12	12	11	12	12	14	14	13	15	14	13	11	10	11	14	9	11	8	8
G02	HVAC load management	C406.3.3	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
G03	Automated shading	C406.3.4	2	2	2	3	1	2	3	2	4	3	2	1	1	1	3	1	2	1	1
G04	Electric energy storage	C406.3.5	9	9	10	10	9	13	13	15	13	14	13	14	14	12	16	13	12	12	13
G05	Cooling energy storage	C406.3.6	31	7	38	17	29	24	31	44	26	18	26	16	15	21	11	12	24	2	4
G06	SHW energy storage	C406.3.7	25	25	28	26	28	29	29	30	31	29	30	31	28	29	31	26	28	25	24
G07	Building thermal mass	C406.3.8	6	1	10	4	14	24	19	23	53	17	38	41	30	52	33	26	42	37	17

HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water. x = Credits excluded from this building use type and climate zone

TABLE C406.3(4)
RENEWABLE AND LOAD MANAGEMENT CREDITS FOR GROUP B OCCUPANCIES

I D	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																		
			0A	0B	1A	1B	2 A	2B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	8
R01	Renewable energy	C406.3.1	14	14	17	15	17	19	18	22	24	17	22	16	14	18	18	14	17	14	11
G01	Lighting load management	C406.3.2	10	11	11	12	11	11	11	12	9	10	11	10	10	11	10	10	11	10	9
G02	HVAC load management	C406.3.3	x	10	10	9	9	3	8	12	7	12	8	11	9	10	12	8	9	10	2
G03	Automated shading	C406.3.4	4	7	7	8	7	8	5	6	6	4	6	5	4	5	5	5	5	4	7
G04	Electric energy storage	C406.3.5	14	15	14	14	16	16	17	16	18	17	16	18	17	17	18	16	15	17	18
G05	Cooling energy storage	C406.3.6	28	7	36	16	27	24	28	45	27	17	27	15	15	20	9	12	25	2	4
G06	SHW energy storage	C406.3.7	5	5	6	6	6	6	7	7	8	7	7	7	7	7	8	6	7	6	6
G07	Building thermal mass	C406.3.8	3	1	5	2	6	9	6	7	14	4	11	8	9	15	5	8	12	15	7

HVAC =Heating, Ventilation and Air Conditioning; SHW =Service Hot Water. x = Credits excluded from this building use type and climate zone.

TABLE C406.3(5)
RENEWABLE AND LOAD MANAGEMENT CREDITS FOR A-2 OCCUPANCIES

ID	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																		
			0A	0B	1A	1B	2 A	2B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	8
R01	Renewable energy	C406.3.1	2	2	2	2	2	2	2	3	4	2	3	2	2	3	2	2	2	2	1
G01	Lighting load management	C406.3.2	4	4	5	5	4	5	5	5	5	4	5	5	4	4	5	4	5	4	1
G02	HVAC load management	C406.3.3	32	26	37	28	31	26	27	22	23	20	17	14	19	14	10	16	14	14	1
G03	Automated shading	C406.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
G04	Electric energy storage	C406.3.5	4	4	4	4	5	5	5	5	4	4	4	4	3	4	4	4	3	3	2
G05	Cooling energy storage	C406.3.6	15	4	17	8	12	10	10	16	6	5	7	3	3	4	1	2	4	x	x
G06	SHW energy storage	C406.3.7	13	13	15	14	15	16	16	17	19	16	17	19	16	17	18	15	16	14	13
G07	Building thermal mass	C406.3.8	3	1	5	2	7	12	8	10	21	6	15	14	8	18	10	6	12	8	3

HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water. x = Credits excluded from this building use type and climate zone

TABLE C406.3(6)
RENEWABLE AND LOAD MANAGEMENT CREDITS FOR GROUP M OCCUPANCIES

I D	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																		
			0A	0B	1A	1B	2 A	2B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	8
R01	Renewable energy	C406.3.1	8	8	12	9	11	12	12	17	17	11	13	9	10	11	10	9	10	9	6
G01	Lighting load management	C406.3.2	16	16	18	19	17	19	19	21	17	18	21	21	18	21	22	18	22	18	16
G02	HVAC load management	C406.3.3	x	15	16	15	15	6	15	21	13	23	15	23	17	19	26	14	17	18	3

G03	Automated shading	C406.3.4	7	11	11	12	11	13	10	11	11	7	11	11	8	10	11	8	9	8	12
G04	Electric energy storage	C406.3.5	8	10	8	10	11	12	11	10	14	11	10	12	10	11	12	11	9	10	8
G05	Cooling energy storage	C406.3.6	40	9	51	22	35	31	34	53	21	17	28	10	11	19	4	9	18	2	2
G06	SHW energy storage	C406.3.7	3	3	4	3	4	4	4	4	5	4	4	5	4	4	5	4	4	4	3
G07	Building thermal mass	C406.3.8	5	1	6	3	8	12	10	10	20	7	17	15	14	24	10	13	20	24	12

HVAC =Heating, Ventilation and Air Conditioning; SHW =Service Hot Water. x = Credits excluded from this building use type and climate zone.

TABLE C406.3(7)
RENEWABLE AND LOAD MANAGEMENT CREDITS FOR GROUP E OCCUPANCIES

ID	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																		
			0A	0B	1A	1B	2 A	2B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	8
R01	Renewable energy	C406.3.1	10	11	13	12	13	16	15	21	22	15	19	15	14	17	16	13	16	12	10
G01	Lighting load management	C406.3.2	7	12	12	13	13	15	14	16	13	12	16	16	10	14	18	16	13	14	14
G02	HVAC load management	C406.3.3	18	22	32	23	25	31	26	26	20	23	31	24	20	31	12	18	27	16	9
G03	Automated shading	C406.3.4	7	13	16	12	18	17	17	18	13	12	17	17	10	15	13	14	10	16	17
G04	Electric energy storage	C406.3.5	16	16	18	17	19	21	21	23	26	22	24	24	23	24	24	20	22	19	19
G05	Cooling energy storage	C406.3.6	36	9	46	21	36	32	39	62	39	24	37	22	20	28	13	16	31	3	4
G06	SHW energy storage	C406.3.7	5	5	6	5	6	6	7	7	8	7	7	8	7	7	8	7	7	7	6
G07	Building thermal mass	C406.3.8	7	2	11	5	17	28	23	27	63	21	44	48	37	60	38	31	50	47	21

HVAC =Heating, Ventilation and Air Conditioning; SHW =Service Hot Water. x = Credits excluded from this building use type and climate zone.

TABLE C406.3(8)
RENEWABLE AND LOAD MANAGEMENT CREDITS FOR GROUP S-1 AND S-2 OCCUPANCIES

I D	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																		
			0A	0B	1A	1B	2 A	2B	3A	3B	3C	4A	4B	4 C	5A	5B	5C	6 A	6B	7	8
R01	Renewable energy	C406.3.1	38	37	55	45	53	53	49	58	66	36	56	38	29	41	36	24	32	23	16
G01	Lighting load management	C406.3.2	13	26	32	28	32	35	36	33	36	31	27	37	32	23	28	36	22	25	22
G02	HVAC load management	C406.3.3	18	46	37	37	28	36	29	26	22	23	17	12	16	13	5	14	8	10	3
$EC_2 = EC_{1,0} \times (1.44 \times SR + 0.71)/2.15$	Automated shading	C406.3.4	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	Electric energy storage	C406.3.5	40	40	47	41	47	44	40	44	42	30	38	31	21	31	26	24	29	23	21
	Cooling energy storage	C406.3.6	20	5	21	11	14	14	11	21	5	5	9	2	2	5	1	1	3	x	x

$$EC_s = EC_{1.0} \times (1.44 \times SR + 0.71) / 2.15$$

G06	SHW energy storage	C406.3.7	3	3	3	3	4	3	4	4	4	3	4	3	4	2	2	2	2	2	2
G07	Building thermal mass	C406.3.8	7	2	12	5	17	29	23	28	66	18	44	47	39	56	37	20	39	29	13

HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water.
x indicates measure is not available for building occupancy in that climate zone.

TABLE C406.3(9)
RENEWABLE AND LOAD MANAGEMENT CREDITS FOR OTHER^a OCCUPANCIES

HVAC = Heating, Ventilation and Air Conditioning; SHW = Service Hot Water.
a. Other occupancy groups include all Groups except for Groups A-2, B, E, I, M and R.

Staff Classification	Contains Directly	Energy Standard Headed	Over lap
	x		
Action	AS	AL/EC	DI
		x	

I D	ENERGY CREDIT ABBREVIATED TITLE	SECTION	CLIMATE ZONE																		
			0 A	0B	1A	1B	2A	2B	3 A	3B	3C	4 A	4B	4C	5 A	5B	5C	6A	6B	7	8
R01	Renewable energy	C406.3.1	12	13	16	14	16	18	17	20	21	13	18	13	14	15	14	11	13	10	8
G01	Lighting load management	C406.3.2	11	13	14	14	14	16	15	16	14	14	16	16	15	14	16	14	13	12	12
G02	HVAC load management	C406.3.3	24	24	23	22	20	23	21	21	18	18	20	17	18	18	14	13	14	13	6
G03	Automated shading	C406.3.4	5	6	7	9	8	9	7	9	8	5	9	7	5	8	7	5	6	6	9
G04	Electric energy storage	C406.3.5	14	15	16	15	16	17	17	18	19	16	17	17	16	16	17	14	15	14	14
G05	Cooling energy storage	C406.3.6	28	7	34	15	25	22	25	39	20	14	22	12	11	17	7	9	18	2	3
G06	SHW energy storage	C406.3.7	9	9	11	10	11	11	11	12	13	11	12	13	11	11	12	10	11	10	9
G07	Building thermal mass	C406.3.8	6	2	9	4	13	21	16	20	44	14	31	33	26	42	25	20	33	29	13

CE#306
Related
 Adds new Section C406.3.1 by expanding an existing additional energy efficiency measure. Increases the renewable energy generation capacity by at least 0.1 watts per gross square foot (1.08 W/m²) of building area or securing off-site renewable energy. This change may increase the code stringency but provides simpler compliance verification alternative.
Modis:
 Adds new Section C406.3.2. Lighting dimming reduces lighting levels and power. The lighting dimming control requires integration with automated controls that interface with utility signals or local building demand monitoring software. Thus, it increases the stringency but is a cost-effective measure.
 CEP1- 193-21, CECD1- 5-22, CED1- 161-22, CED1- 141-22, CED1- 185-22, CED1- 176-22, CED1- 92-22
 Adds new Section C406.3.3. Requires thermostats to be reset during peak price periods or a gradual pre-cooling set-point adjustment control sequence, as well as integration with automated controls that interface with utility signals or local building demand monitoring software. Thus, it increases the stringency but is cost-effective measure.
 Adds new Section C406.3.4. The measure requires an automated external exterior roller, movable blind, or movable shutter shading devices to reduce solar gain through fenestration during peak price hours. Thus, it increases the stringency but is cost-effective measure.
 Adds new Section C406.3.5. Batteries or other electric energy storage devices are required, as is integration with automated controls that interface with utility signals or local building demand monitoring software. Thus, it increases the stringency but is cost-effective measure.
 Adds new Section C406.3.6. Ice or chilled water cooling energy storage is required, as is integration with automated controls that interface with utility signals or local building demand monitoring software. Thus, it increases the stringency but is cost-effective measure.
 Adds new Section C406.3.7. Requires integration with automated controls that interface with utility signals or local building demand monitoring software. Thus, it increases the stringency but is cost-effective measure.
 Adds new Section C406.3.8. Requires integration with automated controls that interface with utility signals or local building demand monitoring software. Thus, it increases the stringency but is cost-effective measure.
C406.3.1 R01 Renewable energy. Projects installing on-site renewable energy systems with a capacity of at least 0.1 watts per gross square foot (1.08 W/m²) of building area or securing off-site renewable energy shall achieve energy credits for this measure calculated as follows:
 Equation 4-27

where:
 EC_R = Section C406.3.1 R01 energy credits achieved for this project.
 $EC_{0.1}$ = Section C406.3.1 R01 base credits from Tables C406.3(1) through C406.3(9).
 R_t = Actual total rating of on-site renewable energy systems (W).
 R_{off} = Actual total equivalent rating of off-site renewable energy contracts (W), calculated as follows:
 $R_{off} = TRE / (REN + 20)$ $EC_R = EC_{0.1} \times (R_t + R_{off} - R_{ex}) / (0.1 \times PGFA)$
 where:
 TRE = Total off-site renewable electrical energy in kilowatt-hours (kWh) that is procured in accordance with Sections C405.15.2.1 through C405.15.4.
 REN = Annual off-site renewable electrical energy from Table C405.15.2, in units of kilowatt-hours per watt of array capacity.
 R_{ex} = Rating (W) of renewable energy resources capacity excluded from credit calculated as follows:
 $R_{ex} = RR_s + RR_x + RR_c$
 where:
 RR_s = Rating of on-site renewable energy systems required by Section C405.15.1, without exception (W).
 RR_x = Rating of renewable energy resources used to meet any exceptions of this code (W).
 RR_c = Rating of renewable energy resources used to achieve other energy credits in Section C406 (W).
 $PGFA$ = Project gross floor area, ft². Where renewable requirements, exceptions or credits are expressed in annual kWh or Btu rather than watts of output capacity, they shall be converted as 3413 Btu = 1 kWh and converted to W equivalent capacity as follows:
 $RR_{ex} = TRE_{ex} / (REN + PGFA)$
 $RR_{ex} = TRE_{ex} / (REN + PGFA)$

	<p>where: TRE_{ex} = Total renewable energy in kilowatt-hours (kWh) that is excluded from R01 energy credits.</p> <p>C406.3.2 G01 Lighting load management. A project not required to comply with Section C405.2.8 can achieve energy credits for installing demand-responsive lighting controls for interior <i>general lighting</i> that comply with Section C405.2.8.1. The demand- responsive lighting controls shall automatically reduce the light output or power of controlled lighting to not more than 80 percent of full output, or 80 percent of the high-end trim setpoint, whichever is less. Energy credits can be earned where demand- responsive lighting controls are installed for the following:</p> <ol style="list-style-type: none"> Not less than 10 percent of the interior floor area in <i>Group R</i> or <i>I</i> occupancies. Not less than 50 percent of the interior floor area in all other occupancies. <p>G01 credits shall be prorated using Equation 4-28 with not more than 75 percent of the interior floor area being counted. [interior floor area with lighting load management, %] x [table credits for C406.3.2]/75% Equation 4-28</p> <p>C406.3.3 G02 HVAC load management. <i>Automatic</i> load management controls shall be configured as follows:</p> <ol style="list-style-type: none"> Cooling temperature shift: Where electric cooling is in use, controls shall gradually increase the cooling setpoint by at least 3°F (1.7°C) over a minimum of 3 hours or reduce effective cooling capacity to 60 percent of installed capacity during the peak period or adjust the cooling temperature setpoint as described in Section C403.6.1. Heating temperature shift: Where electric heating is in use, controls shall gradually decrease the heating setpoint by at least 3°F (1.7°C) over a minimum of 3 hours or reduce effective heating capacity to 60 percent of installed capacity during the peak period or adjust the heating temperature setpoint as described in Section C403.6.1. Ventilation shift: Where HVAC systems serve multiple zones and have less than 70 percent outdoor air required, include controls that provide excess outdoor air preceding the peak period and reduce outdoor air by at least 30 percent during the peak period, in accordance with ASHRAE Standard 62.1 Section 6.2.5.2 or provisions for <i>approved</i> engineering analysis in Section 403.3.1.1 of the <i>International Mechanical Code</i>. <p>Credits achieved for measure G02 shall be calculated as follows: Equation 4-29 where: EC_{G02_ach} = Demand responsive control credit achieved for project. EC_{G02_base} = G02 base energy credit from Section C406.3 EC_{G02_adj} = Energy credit adjustment factor from Table C406.3.3</p> <p>C406.3.4 G03 Automated shading load management. Where <i>fenestration</i> on east, south and west exposures is greater than 20 percent of the wall area, load management credits shall be achieved as follows:</p> <ol style="list-style-type: none"> <i>Automatic</i> exterior shading devices or <i>dynamic glazing</i> that is capable of reducing solar gain through sunlit <i>fenestration</i> less than 50 percent when fully closed shall receive the full credits in Tables C406.3(1) through C406.3(9). The <p>$EC_{G02_ach} = EC_{G02_base} \times EC_{G02_adj}$</p>
--	--

	<p>exterior shades shall have fully open and fully closed solar heat gain coefficient (SHGC) determined in accordance with AERC 1.</p> <p>2. Automatic interior shading devices with a solar reflectance of not less than 0.50 for the surface facing the <i>fenestration</i> shall receive 40 percent of the credits in Tables C406.3(1) through C406.3(9).</p> <p>3. All shading devices, <i>dynamic glazing</i> or shading attachments shall:</p> <p>3.1. Provide not less than 90 percent coverage of the total <i>fenestration</i> on east, south and west exposures in the <i>building</i> to achieve the credits determined in Item 1 or 2. Alternatively, provide not less than 70 percent coverage of the total <i>fenestration</i> on the south and west exposures in the <i>building</i> to achieve 50 percent of the credits determined in Item 1 or 2.</p> <p>3.2. Be automatically controlled and shall modulate in multiple steps or continuously the amount of solar gain and light transmitted into the space in response to peak periods and either daylight levels or solar intensity.</p> <p>3.3. Include a <i>manual</i> override located in the same <i>enclosed space</i> as the shaded vertical <i>fenestration</i> that shall override operation of <i>automatic</i> controls for not longer than 4 hours. Such override shall be locked out during peak periods.</p> <p>For this section, directional exposures shall exclude <i>fenestration</i> that has an orientation deviating by more than 45 degrees of facing the cardinal direction. In the southern hemisphere, where the south exposure is referred to, it shall be replaced by the north exposure.</p> <p>C406.3.5 G04 Electric energy storage. Electric storage devices shall be charged and discharged by <i>automatic</i> load management controls to store energy during nonpeak periods and use stored energy during peak periods to reduce building demand. Electric storage devices shall have a minimum capacity of 1.5 watt-hours per square foot (Wh/ft²) (16 Wh/m²) of gross building area. Base credits in Tables C406.3(1) through C406.3(9) are based on installed electric storage of 5 Wh/ft² (54 Wh/m²) and shall be prorated for actual installed storage capacity between 1.5 and 15 Wh/ft² (16 to 161 Wh/m²), as follows:</p> <p>Equation 4-30</p> <p>Larger energy storage shall be permitted; however, credits are limited to the range of 1.5 to 15 Wh/ft² (16 to 161 Wh/m²).</p> <p>C406.3.5 G05 Cooling energy storage. <i>Automatic</i> load management controls shall be capable of activating ice or chilled water storage equipment to reduce demand during summer peak periods. Storage tank standby loss shall be demonstrated through analysis to be not more than 2 percent of storage capacity over a 24-hour period for the cooling design day. Base credits in Section C406.3 are based on storage capacity of the design peak hour cooling load with a 1.15 sizing factor. Credits shall be prorated for installed storage systems sized between 0.5 and 4.0 times the design day peak hour cooling load, rounded to the nearest whole credit. Larger storage shall be permitted but the associated credit shall be prorated for installed electric storage capacity, Wh/ft² (Wh/m²)/5 (54) × [C406.3.5 credits from tables]</p> <p>range provided in this section. Energy credits shall be determined as follows:</p> <p>Equation 4-31</p> <p>where:</p> <p>EC_{G04} = Cooling storage credit achieved for project.</p>																																																				
	<p>EC_{G05} = G05 base energy credit for building use type and climate zone based on 1.0 ton-hours storage per design day ton (kWh/kW) of cooling load.</p> <p>SR = Storage ratio in ton-hours storage per design day ton (kWh/kW) of cooling load where $0.5 \leq SR \leq 4.0$.</p> <p>C406.3.7 G06 Service hot water energy storage. Where service hot water (SHW) is heated by electricity, <i>automatic</i> load management controls complying with ANSI/CTA-2045-B shall preheat stored SHW before the peak period and suspend electric water heating during the peak period. Storage capacity shall be provided by either:</p> <p>1. Preheating water above 140°F (60°C) delivery temperature with at least 1.34 kWh of energy storage per kW of water-heating capacity. Tempering valves shall be provided at the water heater delivery location.</p> <p>2. Providing additional heated water tank storage capacity above peak SHW demand with equivalent peak storage capacity to Item 1.</p> <p>Credits earned for measure G06 shall be calculated using Equation 4-32:</p> <p>Equation 4-32</p> <p>where:</p> <p>EC_{G06_ach} = SHW energy storage credit achieved for project. EC_{G06_base} = G06 Base energy credit</p> <div>$EC_{G06_ach} = EC_{G06_base} \times EC_{G06_adj}$<p>from Section C406.3 EC_{G06_adj} = Energy credit adjustment factor from Table C406.3.7</p><p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p></div> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Addressed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>DS</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Addressed	Over lap		X			Action	AS	AS/EC	DS			X																																					
Staff Classification	Correlates Directly	Energy Standard Addressed	Over lap																																																		
	X																																																				
Action	AS	AS/EC	DS																																																		
		X																																																			
CE#307	Adds new Table C406.3.3																																																				
Related Mods: CEPI- 193-21, CED1- 161-22	<p>TABLE C406.3.3 ENERGY CREDIT ADJUSTMENT BASED ON USE OF VENTILATION SHIFT OR DEMAND RESPONSE</p> <table><tr><th>DEMAND RESPONSE SIGNAL AVAILABLE^a</th><th>DEMAND RESPONSE REQUIRED BY SECTION C403.4.6.1^b</th><th>INCLUDES VENTILATION SHIFT^c</th><th>EC_{G06_adj}</th></tr><tr><td>No</td><td>No</td><td>Yes</td><td>100%</td></tr><tr><td>No</td><td>Yes</td><td>Yes</td><td>80%</td></tr><tr><td>Yes</td><td>No</td><td>Yes</td><td>80%</td></tr><tr><td>Yes</td><td>Yes</td><td>Yes</td><td>40%</td></tr><tr><td>No</td><td>No</td><td>No</td><td>70%</td></tr></table> <table><tr><td>No</td><td>Yes</td><td>No</td><td>50%</td></tr><tr><td>Yes</td><td>No</td><td>No</td><td>50%</td></tr><tr><td>Yes</td><td>Yes</td><td>No</td><td>0%</td></tr></table> <p>a. "Demand Response Signal Available" is "Yes" where a controlling entity other than the owner makes a demand response signal available to the building.</p> <p>b. Where the exception is invoked in Section C403.4.6.1 for buildings that comply with Load Management measure G02, then "Demand Response Required" is "Yes."</p> <p>c. Ventilation shift controls in accordance with Section C406.3.3, item 3.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Addressed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>DS</td></tr><tr><td></td><td></td><td>X</td><td></td></tr></table>	DEMAND RESPONSE SIGNAL AVAILABLE ^a	DEMAND RESPONSE REQUIRED BY SECTION C403.4.6.1 ^b	INCLUDES VENTILATION SHIFT ^c	EC_{G06_adj}	No	No	Yes	100%	No	Yes	Yes	80%	Yes	No	Yes	80%	Yes	Yes	Yes	40%	No	No	No	70%	No	Yes	No	50%	Yes	No	No	50%	Yes	Yes	No	0%	Staff Classification	Correlates Directly	Energy Standard Addressed	Over lap		X			Action	AS	AS/EC	DS			X	
DEMAND RESPONSE SIGNAL AVAILABLE ^a	DEMAND RESPONSE REQUIRED BY SECTION C403.4.6.1 ^b	INCLUDES VENTILATION SHIFT ^c	EC_{G06_adj}																																																		
No	No	Yes	100%																																																		
No	Yes	Yes	80%																																																		
Yes	No	Yes	80%																																																		
Yes	Yes	Yes	40%																																																		
No	No	No	70%																																																		
No	Yes	No	50%																																																		
Yes	No	No	50%																																																		
Yes	Yes	No	0%																																																		
Staff Classification	Correlates Directly	Energy Standard Addressed	Over lap																																																		
	X																																																				
Action	AS	AS/EC	DS																																																		
		X																																																			
CE#308	Adds new Table C406.3.7.																																																				
Related Mods: CEPI- 193-21, CED1- 176-22	<p>TABLE C406.3.7 ENERGY CREDIT ADJUSTMENT BASED ON USE OF HEAT PUMP WATER HEATER OR DEMAND RESPONSE</p> <table><tr><th>DEMAND RESPONSE READY PER SECTION C404.10</th><th>DEMAND RESPONSE SIGNAL AVAILABLE^a</th><th>HAS HPWH</th><th>EC_{G06_adj}^b</th></tr><tr><td>No</td><td>NA</td><td>No</td><td>100%</td></tr><tr><td>No</td><td>NA</td><td>Yes</td><td>33%</td></tr><tr><td>Yes</td><td>No</td><td>No</td><td>50%</td></tr><tr><td>Yes</td><td>No</td><td>Yes</td><td>17%</td></tr><tr><td>Yes</td><td>Yes</td><td>NA</td><td>0%</td></tr></table>	DEMAND RESPONSE READY PER SECTION C404.10	DEMAND RESPONSE SIGNAL AVAILABLE ^a	HAS HPWH	EC_{G06_adj} ^b	No	NA	No	100%	No	NA	Yes	33%	Yes	No	No	50%	Yes	No	Yes	17%	Yes	Yes	NA	0%																												
DEMAND RESPONSE READY PER SECTION C404.10	DEMAND RESPONSE SIGNAL AVAILABLE ^a	HAS HPWH	EC_{G06_adj} ^b																																																		
No	NA	No	100%																																																		
No	NA	Yes	33%																																																		
Yes	No	No	50%																																																		
Yes	No	Yes	17%																																																		
Yes	Yes	NA	0%																																																		

HPWH = Heat Pump Water Heater, NA = Not available.

a. "Demand Response Signal Available" is "Yes" where a controlling entity currently makes a demand response signal available to the building.

b. The lower values of *EC_{G06-P08}* in this column apply where not less than 67 percent of the whole-building design end use service water heating requirements are met using only heat pump heating at the conditions described in **Section C406.2.3.1.2**.

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	X		

Action	AS	AS/IC	D	D/IC
			X	

CE#309 Adds new Section C406.3.8. This measure is primarily an operational strategies change and the use of interior thermal mass. Has no impact on the stringency.

Related Mods:
CEPI- 193-21,
CED1-92- 22,
CED1- 185-22

C406.3.8 G07 Building thermal mass. The project shall have additional passive interior mass and a night flush control of the HVAC system. The credit is available to projects that have at least 80 percent of gross floor area unoccupied between midnight and 6:00 a.m. The project shall meet the following requirements:

- Interior to the building thermal envelope insulation, provide 10 pounds per foot (15 kg/ m) of project *conditioned floor area* of passive thermal mass in the building interior wall, the inside of the *exterior wall* or the interior floor construction. Mass construction shall have mass surfaces directly contacting the air in *conditioned spaces* with directly attached gypsum panels allowed. Mass with carpet or furred gypsum panels or exterior wall mass that is on the exterior of the insulation layer [e.g., the portion of concrete masonry unit (CMU) block on the exterior of insulation-filled cell cavities] shall not be included toward the building mass required.
- HVAC units for 80 percent or more of the supply airflow in the project shall be equipped with outdoor air economizers and fans that have variable or low speed capable of operating at 66 percent or lower airflow and be included in the night flush control sequence.
- Night flush controls shall be configured with the following sequence or another night flush strategy shall be permitted where demonstrated to be effective, avoids added morning heating and is *approved* by the authority having jurisdiction.

3.1. Summer mode shall be activated when outdoor air temperature exceeds 70°F (21°C) and shall continue uninterrupted until deactivated when outdoor air temperature falls below 45°F (7°C). During summer mode, the occupied cooling setpoint shall be set 1°F (0.6°C) higher than normal and the occupied heating setpoint shall be reset 2°F (1.1°C) lower than normal.

3.2. Where all the following conditions exist, night flush shall be activated:

3.2.1. Summer mode is active in accordance with Item 3.1.

3.2.2. Outdoor air temperature is 5°F (2.8°C) or more below indoor average *zone* temperature.

3.2.3. Indoor average *zone* temperature is greater than morning occupied heating setpoint.

3.2.4. In Climate Zones 0A, 1A, 2A and 3A, outdoor dewpoint is below 50°F (10°C) or outdoor air enthalpy is less than indoor air enthalpy.

3.2.5. Local time is between 10:00 p.m. and 6:00 a.m.

3.3. When night flush is active, *automatic* night flush controls shall operate outdoor air economizers at low fan speed not exceeding 66 percent during the unoccupied period with mechanical cooling and heating locked out.

FSEC – Anticipated energy impact on FBC-EC – Decrease

Staff Classification	Correlates Directly			
	X			
Action	AS	AS/EC	D	D/EC
			X	

CE#310 Deletes Sections C406.4, C406.5, C406.6, C406.7, C406.8, C406.9, C406.10, Table C406.10.2, C406.11, C406.12, C406.12(1), C406.12(2), C406.12(3), C406.12(4).

Related Mods:

C406.4 Enhanced digital lighting controls. Interior general lighting in the building shall have the following enhanced lighting controls that shall be located, scheduled and operated in accordance with **Sections C405.2.1** through **C405.2.3**:

- Luminaires shall be configured for continuous dimming.
- Luminaires shall be addressed individually. Where individual addressability is not available for the luminaire class type, a controlled group of not more than four luminaires shall be allowed.
- Not more than eight luminaires shall be controlled together in a *daylight zone*.
- Fixtures shall be controlled through a digital control system that includes the following function:

4.1—Control reconfiguration based on digital addressability;

4.2—Load shedding;

4.3—Occupancy sensors shall be capable of being reconfigured through the digital control system;

5—Construction documents shall include submittal of a Sequence of Operations, including a specification outlining each of the functions in item 4;

6—Functional testing of lighting controls shall comply with **Section C408**.

C406.5 On-site renewable energy. Buildings shall comply with **Section C406.5.1** or **C406.5.2**.

C406.5.1 Basic renewable credit. The total minimum ratings of on-site renewable energy systems, not including systems used for credits under **Sections C406.7.2**, shall be one of the following:

- Not less than 0.86 Btu/h per square foot (2.7 W/m²) or 0.25 watts per square foot (2.7 W/m²) of *conditioned floor area*;
- Not less than 2 percent of the annual energy used within the building for building mechanical and service water heating equipment and lighting regulated in **Section C405**.

C406.5.2 Enhanced renewable credit. Where the total minimum ratings of on-site renewable energy systems exceeds the rating in **Section C406.5.1**, additional energy efficiency credits shall be determined based on **Equation 4-14**, rounded to the nearest whole number.

(Equation 4-14)

where:

AS_{EC} = **Section C406.5.2** additional energy efficiency credits;

AS_{EC} = **Section C406.5** credits from Tables C406.5(4) through C406.5(5);

AS_{EC} = **Section C406.5** credits from Tables C406.5(4) through C406.5(5);

RR₀ = Actual total minimum ratings of on-site renewable energy systems (in Btu/h, watts per square foot or W/m²);

RR₀ = Minimum ratings of on-site renewable energy systems required by **Section C406.5.1** (in Btu/h, watts per square foot or W/m²).

C406.6 Dedicated outdoor air system. Buildings containing equipment or systems regulated by **Section C403.3.4.2**, **C403.4.3**, **C403.4.4**, **C403.4.5**, **C403.6**, **C403.8.4**, **C403.8.6**, **C403.8.6.1**, **C403.11.1**, **C403.11.2**, **C403.11.3** or **C403.11.4** shall be equipped with an independent ventilation system designed to provide not less than the minimum 100 percent outdoor air to each individual occupied space, as specified by the **International Mechanical Code**. The ventilation system shall be capable of total energy recovery. The HVAC system shall include supply air temperature controls that automatically reset the supply air temperature in

response to representative building loads or to outdoor air temperatures. The controls shall reset the supply air temperature not less than 25 percent of the difference between the design supply air temperature and the design room air temperature.

C406.7 Reduced energy use in service water heating. Buildings shall comply with **Section C406.7.1** and **Section C406.7.2**. **C406.7.3** or **C406.7.4**.

C406.7.1 Building type. To qualify for this credit, the building shall contain one of the following use groups, and the additional energy efficiency credit shall be prorated by conditioned floor area of the portion of the building comprised of the following use groups:

1—Group R-1: Boarding houses, hotels or motels;

2—Group I-2: Hospitals, psychiatric hospitals and nursing homes;

3—Group A-2: Restaurants and banquet halls or buildings containing food preparation areas;

4—Group F: Laundries;

5—Group R-2;

6—Group A-3: Health clubs and spas;

7—Group E: Schools with full-service kitchens or locker rooms with showers;

8—Buildings showing a service hot water load of 10 percent or more of total building energy loads, as shown with an energy analysis as described in **Section C406.7.2**.

C406.7.2 Recovered or renewable water heating. The building service water heating system shall have one or more of the following that are sized to provide not less than 30 percent of the building's annual hot water requirements, or sized to provide 70 percent of the building's annual hot water requirements if the building is required to comply with **Section C403.11.5**:

1—Waste heat recovery from service hot water, heat recovery chillers, building equipment or process equipment;

2—On-site renewable energy water-heating systems;

C406.7.3 Efficient fossil fuel water heater. The combined input-capacity weighted-average equipment rating of all fossil fuel water-heating equipment in the building shall be not less than 95 percent EF or 0.95 EF. This option shall receive only half the listed credits for buildings required to comply with **Section C404.2.4**.

C406.7.4 Heat pump water heater. Where electric resistance water heaters are allowed, all service hot water system heating requirements shall be met using heat pump technology with a combined input-capacity weighted-average EF of 3.0. Air-source heat pump water heaters shall not draw conditioned air from within the building, except exhaust air that would otherwise be exhausted to the exterior.

C406.8 Enhanced envelope performance. The total UA of the building thermal envelope, as designed, shall be not less than 15 percent below the total UA of the building thermal envelope, in accordance with **Section C402.1.4**.

C406.9 Reduced air infiltration. Air infiltration shall be verified by whole-

building pressurization testing conducted in accordance with **ASTM E779** or **ASTM E1827** by an independent third party. The measured air leakage rate of the building envelope shall not

exceed $0.25 \text{ cfm/ft}^2 (2.0 \text{ L/s} \times \text{m}^2)$ under a pressure differential of 0.3 inches water column (75 Pa), with the calculated surface area being the sum of the above- and below-grade building envelope. A report that includes the tested surface area, floor area, air by volume, stories above grade, and leakage rates shall be submitted to the code official and the building owner.

Exception: For buildings having over 250,000 square feet (25,000 m^2) of conditioned floor area, air leakage testing need not be conducted on the whole building where testing is conducted on representative above-grade sections of the building. Tested areas shall total not less than 25 percent of the conditioned floor area and shall be tested in accordance with this section.

C406.10 Energy monitoring. Buildings shall be equipped to measure, monitor, record and report energy consumption data in compliance with **Sections C406.10.1** through **C406.10.5**.

C406.10.1 Electrical energy metering. For all electrical energy supplied to the building and its associated site, including but not limited to site lighting, parking, recreational facilities, and other areas that serve the building and its occupants, meters or other measurement devices shall be provided to collect energy consumption data for each end-use category required by **Section C406.10.2**.

C406.10.2 End-

use metering categories. Meters or other approved measurement devices shall be provided to collect energy use data for each end-

use category listed in **Table 406.10.2**. These meters shall have the capability to collect energy consumption data for the whole building or for each separately metered portion of the building. Where multiple meters are used to measure any end-

use category, the data acquisition system shall total all of the energy used by that category. Not more than 5 percent of the measured load for each of the end-use categories listed in **Table 406.10.2** is permitted to be from a load not within the category.

Exceptions:

1—HVAC and water-heating equipment serving only an individual dwelling unit does not require end-use metering;

2—End-use metering is not required for fire pumps, stairwell pressurization fans or any system that operates only during testing or emergency.

C406.10.3 Meters. Meters or other measurement devices required by this section shall be configured to automatically communicate energy consumption data to the data acquisition system required by **Section C406.10.4**. Source meters shall be allowed to be any digital-type meter. Lighting, HVAC or other building systems that can monitor their energy consumption shall be permitted instead of meters. Current sensors shall be permitted, provided that they have a tested accuracy of ± 2 percent. Required metering systems and equipment shall have the capability to provide at least hourly data that is fully integrated into the data acquisition system and graphical energy report in accordance with **Sections C406.10.4** and **C406.10.6**.

C406.10.4 Data acquisition system. A data acquisition system shall have the capability to store the data from the required meters and other sensing devices for a minimum of 36 months. The data acquisition system shall have the capability to store real-

time energy consumption data and provide hourly, daily, monthly and yearly logged data for each end-use category required by **Section C406.10.2**.

C406.10.5 Graphical energy report. A permanent and readily accessible reporting mechanism shall be provided in the building that is accessible by building operation and management personnel. The reporting mechanism shall have the capability to graphically provide the energy consumption for each end-use category required by **Section C406.10.2** at least every hour, day, month and year for the previous 36 months.

C406.11 Fault detection and diagnostics system. A fault detection and diagnostics system shall be installed to monitor the HVAC

system's performance and automatically identify faults. The system shall do all of the following:

1—Include permanently installed sensors and devices to monitor the HVAC system's performance.

2—Sample the HVAC system's performance at least once every 15 minutes;

3—Automatically identify and report HVAC system faults;

4—Automatically notify authorized personnel of identified HVAC system faults;

5—Automatically provide prioritized recommendations for repair of identified faults based on analysis of data collected from the sampling of the HVAC system performance;

6—Be capable of transmitting the prioritized fault repair recommendations to remotely located authorized personnel.

C406.12 Efficient kitchen equipment. For buildings and spaces designated as Group A,

2 or facilities that include a commercial kitchen with at least one gas or electric fryer, all fryers, dishwashers, steam cookers and ovens shall comply with all of the following:

1—Achieve performance levels in accordance with the equipment specifications listed in **Tables C406.12(1)** through **C406.12(4)** when rated in accordance with the applicable test procedure.

2—Be installed prior to the issuance of the Certificate of Occupancy.

3—Have associated performance levels listed on the construction documents submitted for permitting.

Energy efficiency credits for efficient kitchen equipment shall be independent of climate zone and determined based on Equation 4-45, rounded to the nearest whole number.

(Equation 4-15)

where:

A_{EED} = Section C406.12 additional energy efficiency credits.

A_{FK} = Floor area of full-service kitchen (ft² or m²).

A_{FL} = Gross floor area of building (ft² or m²).

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
			x
Action	AS	AS/IC	D
			x

Related Mods: CEPI- 193-21, CEPI- 207-21, CEPI-24- 21 Part I, CED1- 185-22	<p>C407.2 Mandatory requirements. Compliance based on total simulated building performance requires that a proposed design meet all of the following:</p> <p>1. The requirements of the sections indicated within Table C407.2(1).</p> <p>2. An annual <i>energy cost</i> that is less than or equal to 80 percent the percentage of the annual energy cost (PAEC) of the standard reference design calculated in Equation 4-33 Energy prices shall be taken from a source approved by the code official; such as the Department of Energy, Energy Information Administration's <i>State Energy Data System Prices and Expenditures</i> reports. Code officials shall be permitted to require time-of-use pricing in energy cost calculations. The reduction in energy cost of the proposed design associated with on-site renewable energy shall be not more than 5 percent of the total energy cost. The amount of renewable energy purchased from off-site sources shall be the same in the standard reference design and the proposed design :</p>																				
	<p>Exceptions:</p> <p>1. Jurisdictions that require site energy (1 kWh = 3413 Btu) rather than <i>energy cost</i> as the metric of comparison.</p> <p>2. Where <i>energy use</i> based on source energy expressed in Btu or Btu per square foot of <i>conditioned floor area</i> is substituted for the <i>energy cost</i> , the <i>energy use</i> shall be calculated using source energy factors from Table C407.2(2). For electricity, US locations shall use values from eGRID subregions. Locations outside the United States shall use the value for "All other electricity" or locally derived values.</p> <p>Equation 4-33 where: PAEC = The percentage of the annual energy cost of the standard reference design. EC_r = Energy efficiency credits required for the building in accordance with Section C408.1 (do not include load management and</p> <p>PAEC = 100 × (0.80 + 0.025 – EC_r/1,000)</p> <p>renewable credits).</p> <p>Original text of mod is not consistent with that of the 2023 FBC – EC.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>			Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	D	D/EC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																		
			x																		
Action	AS	AS/EC	D	D/EC																	
			x																		
CE#313	Updated Table C407.2(1).																				
Related Mods: CEPI- 193-21, CEPI-24- 21 Part I, CED1- 92- 22 CEPI- 207-21	<p>Delete entire table TABLE C407.2 REQUIREMENTS FOR TOTAL BUILDING PERFORMANCE</p> <p>TABLE C407.2(1) REQUIREMENTS FOR SIMULATED BUILDING PERFORMANCE Please see attached PDF</p> <p>Original text of mod is not consistent with that of the 2023 FBC – EC.</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>			Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	D	D/EC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																		
			x																		
Action	AS	AS/EC	D	D/EC																	
			x																		
CE#314	Add new Table C407.2(2) for source energy conversion factors by fuel types.																				
Related Mods:	<p>TABLE C407.2(2)</p> <p>SOURCE ENERGY CONVERSION FACTORS FOR ELECTRICITY</p> <p>Please see attached PDF</p> <table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>x</td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>			Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				x	Action	AS	AS/EC	D	D/EC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																		
			x																		
Action	AS	AS/EC	D	D/EC																	
			x																		
CE#315	<p>Updates Table C407.4(1). Replaces the solar absorptance requirement with solar reflectance for roofs and above-grade walls. Updates the roof's emittance requirement. Adds thermal bridge requirement but climate zones 0 through 3 are exempted. Replaces "Mechanical ventilation" with "Outdoor airflow" and revises the standard reference design mechanical ventilation air requirements based on the system type. If the proposed building has natural ventilation, then use the same for the standard reference design. Adds "Energy recovery" as a new building component characteristic. If the proposed design specifies ventilation airflow, then use the same as the proposed; otherwise, if the proposed design has mechanical ventilation, use the same but with the standard reference design airflow. Adds "Fan power" as a new building component characteristic and requires modeling per Section C403.8. Adds "On-site renewable energy" as a new building component characteristic and has requirements.</p>																				
Related Mods: CECP1-2- 21, CECP1-4- 21, CEPI- 211-21, CEPI- 212, 21, CED1- 197-22	<p>TABLE C407.4.1(1) SPECIFICATIONS FOR THE STANDARD REFERENCE AND PROPOSED DESIGNS</p> <table><tr><th>BUILDING COMPONENT CHARACTERISTICS</th><th>STANDARD REFERENCE DESIGN</th><th>PROPOSED DESIGN</th></tr><tr><td>Space use classification</td><td>Same as proposed</td><td>The space use classification shall be chosen in accordance with Table C405.3.2(1) or C405.3.2(2) for all areas of the building covered by this permit. Where the space use classification for a building is not known, the building shall be categorized as an office building.</td></tr><tr><td></td><td>Type: insulation entirely above deck</td><td>As proposed</td></tr><tr><td></td><td>Gross area: same as proposed</td><td>As proposed</td></tr><tr><td></td><td>U-factor: as specified in Table C402.1.2</td><td>As proposed</td></tr></table>			BUILDING COMPONENT CHARACTERISTICS	STANDARD REFERENCE DESIGN	PROPOSED DESIGN	Space use classification	Same as proposed	The space use classification shall be chosen in accordance with Table C405.3.2(1) or C405.3.2(2) for all areas of the building covered by this permit. Where the space use classification for a building is not known, the building shall be categorized as an office building.		Type: insulation entirely above deck	As proposed		Gross area: same as proposed	As proposed		U-factor: as specified in Table C402.1.2	As proposed			
BUILDING COMPONENT CHARACTERISTICS	STANDARD REFERENCE DESIGN	PROPOSED DESIGN																			
Space use classification	Same as proposed	The space use classification shall be chosen in accordance with Table C405.3.2(1) or C405.3.2(2) for all areas of the building covered by this permit. Where the space use classification for a building is not known, the building shall be categorized as an office building.																			
	Type: insulation entirely above deck	As proposed																			
	Gross area: same as proposed	As proposed																			
	U-factor: as specified in Table C402.1.2	As proposed																			
	<p>Roofs</p> <table><tr><td>Solar absorptance: 0.75 Solar reflectance: 0.25, except as specified in Section C402.4 and Table C402.4 for Climate Zones 0, 1, 2 and 3</td><td>As proposed</td></tr><tr><td>Emittance: 0.90, except as specified in Section C402.4 and Table C402.4 for Climate Zones 0, 1, 2 and 3</td><td>As proposed</td></tr><tr><td>Type: same as proposed</td><td>As proposed</td></tr><tr><td>Gross area: same as proposed</td><td>As proposed</td></tr><tr><td>U-factor: as specified in Table C402.1.2</td><td>As proposed</td></tr></table>			Solar absorptance: 0.75 Solar reflectance: 0.25, except as specified in Section C402.4 and Table C402.4 for Climate Zones 0, 1, 2 and 3	As proposed	Emittance: 0.90, except as specified in Section C402.4 and Table C402.4 for Climate Zones 0, 1, 2 and 3	As proposed	Type: same as proposed	As proposed	Gross area: same as proposed	As proposed	U-factor: as specified in Table C402.1.2	As proposed								
Solar absorptance: 0.75 Solar reflectance: 0.25, except as specified in Section C402.4 and Table C402.4 for Climate Zones 0, 1, 2 and 3	As proposed																				
Emittance: 0.90, except as specified in Section C402.4 and Table C402.4 for Climate Zones 0, 1, 2 and 3	As proposed																				
Type: same as proposed	As proposed																				
Gross area: same as proposed	As proposed																				
U-factor: as specified in Table C402.1.2	As proposed																				

	Walls, above-grade	Thermal bridges: account for heat transfer consistent with compliant psi- and chi-factors from Table C402.1.4 for thermal bridges as identified in Section C402.7 that are present in the proposed design	As proposed; psi- and chi-factors for proposed thermal bridges shall be determined in accordance with requirements in Section C402.1.4 .
		Solar absorptance: 0.76 reflectance: 0.25	As proposed
		Emittance: 0.90	As proposed
	Walls, below-grade	Type: mass wall	As proposed
		Gross area: same as proposed	As proposed
	Schedules	Same as proposed Exception: Thermostat settings and schedules for HVAC systems that utilize radiant heating, radiant cooling and elevated air speed, provided that equivalent levels of occupant thermal comfort are demonstrated by means of equal Standard Effective Temperature as calculated in Normative Appendix B of ASHRAE Standard 55 .	Operating schedules shall include hourly profiles for daily operation and shall account for variations between weekdays, weekends, holidays and any seasonal operation. Schedules shall model the time-dependent variations in occupancy, illumination, receptacle loads, thermostat settings, mechanical ventilation, HVAC equipment availability, service hot water usage and any process loads. The schedules shall be typical of the proposed building type as determined by the designer and approved by the jurisdiction.
	Mechanical ventilation-Outdoor-airflow	Same as proposed. Where the proposed design specifies mechanical ventilation: 1. For systems 1–4 as specified in Tables C407.4.1(2) and C407.4.1(3) , the outdoor airflow rate shall be determined in accordance with Section C403.7 and <i>International Mechanical Code</i> Section 403.3.1.1.2.3.4, Equation 4-8 , using a system ventilation efficiency (E_v) of 0.75. 2. For systems 5–11 as specified in Tables C407.4.1(2) and C407.4.1(3) , the outdoor airflow rate shall be determined in accordance with Section C403.7 and <i>International Mechanical Code</i> Section 403.3 .	As proposed, in accordance with Section C403.2.2 .
	Heating systems	Where the proposed design specifies natural ventilation, as proposed.	
		Fuel type: same as proposed design	As proposed
		Equipment type ^b : as specified in Tables C407.4.1(2) and C407.4.1(3)	As proposed
	Energy recovery	Where the proposed design specifies mechanical ventilation, as specified in Section C403.7.4 based on the standard reference design airflows Where the proposed design specifies natural ventilation, as proposed	As proposed
	Fan power	As specified in Section C403.8 for the proposed design 1. Where the fan power of the proposed design is exempted from the requirements of Section C403.8 , as proposed. 2. Fan systems addressed by Section C403.8.1 : fan system BHP shall be as proposed or to the limits specified in Section C403.8.1 , whichever is smaller. If the limit is reached, the power of each fan shall be reduced proportionally until the limit is met. 3. Fan systems serving areas	As proposed
		system design of Section 403.2 of the <i>International Mechanical Code</i> shall not use the particulate filtration or air cleaner pressure drop adjustment available in Table C403.8.1(1) when calculating the fan system BHP limit for the portion of the airflow being	

	On-site renewable energy	<p>Where a system providing on-site renewable energy has been modeled in the proposed design, the same system shall be modeled identically in the standard reference design except the rated capacity shall meet the requirements of Section C405.15.1</p> <p>Where no system is designed or included in the proposed design, model an unshaded photovoltaic system with the following characteristics:</p> <p>Size: rated capacity per Section C405.15.1. Module type: crystalline silicon panel with glass cover, 19.1% nominal efficiency and temperature coefficient of -0.35%/°C. Performance shall be based on a reference temperature of 77°F (25°C), air mass of 1.5 atmosphere and irradiance of 317 Btu/h x ft² (1000 W/m²).</p> <p>Array type: rack-mounted array with installed nominal operating cell temperature (INOCT) of 103°F (45°C).</p>	As proposed																			
		Total system losses (DC output to AC output): 11.3%.																				
		Tilt: 0 degrees (mounted horizontally). Azimuth: 180 degrees.																				
				<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				X	Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																			
			X																			
Action	AS	AS/EC	D	D/EC																		
			X																			
CE#316	<p>Revises and reorganizes Section C407.5. Moves the software capability requirement under new subsection C407.5.1.1. Renames the "Specific approval" section and edits the code language for clarity.</p> <p>Created a new subsection by moving the software capability requirements from Section C407.5. Created new subsection C407.5.1.2.</p> <p>Requires compliance software vendors to test their software per ASHRAE Standard 140 and publish the results in publicly accessible web-site. No impact on construction cost.</p>																					
Related Mods:	<p>C407.5 Calculation software tools. Calculation procedures used to comply with Section C407 shall apply an approved version of a performance analysis software tool capable of calculating the annual energy consumption of all building elements that differ between the standard reference design and the proposed design. The same approved version of the performance analysis tool shall be used to calculate the proposed design and standard reference design.</p> <p>C407.5.1 Specific Software tool approval: Performance analysis tools complying with the applicable subsections of Section C407 and tested according to ASHRAE Standard 140 Any version of a performance analysis tool meeting the requirements of Sections C407.5.1.1 and C407.5.1.2 shall be permitted to be approved. Tools are permitted to be approved based on meeting a specified threshold for a jurisdiction. The code official shall be permitted to approve tools for a specified application or limited scope.</p> <p>C407.5 C407.5.1.1 Calculation software tools-Software tool capabilities: Calculation procedures used to comply with this section shall be software tools capable of calculating the annual energy consumption of all building elements that differ between the standard reference design and the proposed design and shall include the following capabilities: Approved software tools shall include the following capabilities:</p> <ol style="list-style-type: none">1. Building operation for a full calendar year (8,760 hours).2. Climate data for a full calendar year (8,760 hours) and shall reflect approved coincident hourly data for temperature, solar radiation, humidity and wind speed for the building location.3. Ten or more thermal zones.4. Thermal mass effects.5. Hourly variations in occupancy, illumination, receptacle loads, thermostat settings, mechanical ventilation, HVAC equipment availability, service hot water usage and any process loads.6. Part-load performance curves for mechanical equipment.7. Capacity and efficiency correction curves for mechanical heating and cooling equipment.																					
CECD1- 8-22, CE2D-10- 23 CEPI-24- 21 Part I	<p>8. Printed code official inspection checklist listing each of the proposed design component characteristics from Table C407.4.1(1) determined by the analysis to provide compliance, along with their respective performance ratings, including but not limited to R-value, U-factor, SHGC, HSPF, AFUE, SEER and EF.</p> <p>C407.5.1.2 Testing required by software vendors. Prior to approval, software tools shall be tested by the software vendor in accordance with ASHRAE Standard 140, except Sections 7 and 8. During testing, hidden inputs that are not normally available to the user shall be permitted to avoid introducing source code changes strictly used for testing. Software vendors shall publish, on a publicly available website, the following ASHRAE Standard 140 test results, input files and modeler reports for each tested version of a software tool:</p> <ol style="list-style-type: none">1. Test results that demonstrate the software tool was tested in accordance with ASHRAE Standard 140 and that meet or exceed the values for "The Minimum Number of Range Cases within the Test Group to Pass" for all test groups in ASHRAE Standard 140, Table A3-14.2. Test results of the performance analysis tool and input files used for generating the ASHRAE Standard 140 test cases along with the results of the other performance analysis tools included in ASHRAE Standard 140, Annexes B8 and B16.3. The modeler report in ASHRAE Standard 140, Annex A2, Attachment A2.7, Report Blocks A and G shall be completed for results exceeding the maximum or falling below the minimum of the reference values shown in ASHRAE Standard 140, Tables A3-1 through A3-13, and Report Blocks A and E shall be completed for any omitted results.																					
				<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table> <table><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td><td>D/EC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				X	Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																			
			X																			
Action	AS	AS/EC	D	D/EC																		
			X																			
CE#317	Creates new subsection C407.5.2.																					
Related Mods:	<p>C407.5.2 Algorithms not tested. Algorithms not tested in accordance with Section C407.5.1.2, including algorithms that are alternatives to those that were tested, and numerical settings not tested, such as time steps and tolerances, shall be permitted to be used where modeling the proposed design and standard reference design.</p> <p>Action AS AS/EC D D/EC X</p>																					
CECD1- 8-22, CE2D-10- 23 CEPI-24- 21 Part I																						
				<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Overlap</td></tr><tr><td></td><td></td><td></td><td>X</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Overlap				X										
Staff Classification	Correlates Directly	Energy Standard Needed	Overlap																			
			X																			

--

Staff Classification	Correlates Directly	Energy Standard Needed	Overlap
	X		

Action	AS	AS/IC	D	D/IC
			X	

CE2D-66- 23, CECD1- 5-22, CE2D-67- 23	<p>C408.3.1.5 High-end trim lighting control verification for L02 Additional Efficiency Credit. For the qualifying spaces associated with the project receiving the additional efficiency credits in Section C406.2.5.2, the following shall be documented while daylight responsive controls are not reducing lighting power:</p> <ol style="list-style-type: none">1. The maximum setting for power or light output for each control group of general lighting luminaires.2. The high-end trim setting for power or light output for each control group of general lighting luminaires.3. For projects with seven or fewer claimed qualifying spaces, the reduction in light output or reduction in power due to high-end trim shall be tested in all spaces and shown to reduce the general lighting power or light output to not greater than 85 percent of full power or light output. For projects with more than seven claimed qualifying spaces, reduction in light output or reduction in power due to high- end trim shall be tested in not less than 10 percent of spaces, and not less than seven spaces, and be shown to reduce general lighting power or light output to not greater than 85 percent of full power or light output. Where more than 30 percent of the tested spaces fail, the remaining qualifying spaces shall be tested.4. Summarize the reduction in general lighting power or light output resulting from the high-end trim setting for each qualifying space and the floor area of each qualifying space.5. Summarize the fraction of total floor area for spaces where high-end trim reduces general lighting power or light output to not greater than 85 percent of full power or light output. <p>C408.3.1.6 Demand responsive lighting controls G01. For spaces associated with the project receiving renewable and load management credits in Section C406.3.2, the following procedures shall be performed:</p> <ol style="list-style-type: none">1. Confirm the maximum setpoint upon receipt of the <i>demand response signal</i> has been established for each space.2. For projects with seven or fewer spaces with controls, each space shall be tested.3. For projects with more than seven spaces with controls, testing shall be done for each unique space type. Where multiple spaces of each space type exist, not less than 10 percent of each space type, and in no case fewer than one space, shall be tested unless the <i>code official</i> requires a higher percentage to be tested. Where 30 percent or more of the tested controls fail in a space type, all remaining identical space types shall be tested.4. For demand responsive controls to be tested, verify the following:<ol style="list-style-type: none">4.1. Where high-end trim controls are used, the high-end trim shall be set before testing.4.2. Turn off all nongeneral lighting in the space.4.3. Set <i>general lighting</i> to its maximum illumination level. Where high-end trim is set, this will be the maximum illumination level at the high-end trim setpoint.4.4. An illumination measurement shall be taken in an area of the space not controlled by daylight responsive controlled lighting. If there is not an area without daylight responsive controls, the daylight responsive controls shall be overridden from reducing the lighting level during the test.4.5. Measure and document the maximum illumination level of the space.5. Simulate a <i>demand response signal</i> and measure the illumination level at the same location as for the measurement in Section C408.3.1.6, Item 4.5. Verify the illumination level has been reduced to not greater than 80 percent of the maximum illumination level documented in Section C408.3.1.6, Item 4.5.6. Simulate the end of a demand event by turning off the <i>demand response signal</i>; confirm controls automatically return to their normal operational settings at the end of the demand response event. <table><tr><td>Staff Classification</td><td>Connects Directly</td><td>Energy Standard Number</td><td>Goal Type</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>SLC</td><td>SLC</td></tr></table>	Staff Classification	Connects Directly	Energy Standard Number	Goal Type		X			Action	AS	SLC	SLC
Staff Classification	Connects Directly	Energy Standard Number	Goal Type										
	X												
Action	AS	SLC	SLC										
CE#322	<p>Adds new Section C409. The TRSP method is an alternative to the prescriptive or performance compliance method and allowed in office, retail, hotel, motel, multifamily, dormitory, school, and library building use types only. The compliance method excludes system types listed in the new subsection C409.2.1. TRSP is an optional compliance path; hence has no construction cost impact but provides compliance method flexibility.</p> <p>Adds new Section C409.1 that defines when the TRSP method is used.</p> <p>Adds new Section C409.2 that defines the HVAC system type, building occupancy group and other limits of the method.</p> <p>Adds new Section C409.2.1 that specifies the HVAC system types not permitted to use the TRSP method. Check the reference to Section C403.1. Is it Section C409.3?</p> <p>It adds a new Section C409.3 that lists HVAC systems types required to comply with the TSPR method in addition to the requirements of Section C409.4.</p> <p>It adds a new Section C409.4 that introduces a procedure for calculating the target HVAC total system performance ratio (TSPR) based on the standard reference building design TSPR and Mechanical Performance Factor (MPF) from a new Table C409.4.</p> <p>Adds new Table C409.4.</p>												
Related Mods: CEPI-76- 21, CED1-	<p>SECTION C409</p> <p>CALCULATION OF THE HVAC TOTAL SYSTEM PERFORMANCE RATIO</p> <p>C409.1 Applicability. Use of the <i>HVAC total system performance ratio</i> (TSPR) method shall comply with this section.</p> <p>C409.2 Permitted uses. Only HVAC systems that serve building occupancies and uses in Table C409.4 and are not excluded by Section C409.2.1 shall be permitted to use the TSPR method.</p>												

198-22, CED1-182-22	<p>C409.2.1 Systems not permitted. The following HVAC systems are not permitted to use Section C403.1, Item 3:</p> <ol style="list-style-type: none"> 1. HVAC systems using: <ol style="list-style-type: none"> 1.1. District heating water, chilled water or steam. 1.2. Small-duct high-velocity air-cooled, space-constrained air-cooled, or single- package vertical air conditioner; single- package vertical heat pump; or double-duct air conditioner or double-duct heat pump, as defined in subpart F to 10 CFR Part 431. 1.3. Packaged terminal air conditioners and packaged terminal heat pumps that have a cooling capacity greater than 12,000 Btu/h (3.5 kW). 1.4. A common heating source serving both HVAC and <i>service water heating</i> equipment. 2. HVAC systems that provide recovered heat for <i>service water heating</i>. 3. HVAC systems not specified in Table C409.6.1.10.1. 4. HVAC systems specified in Table C409.6.1.10.1 with characteristics or parameters in Table C409.6.1.10.2(1), not identified as applicable to that HVAC system type. 5. HVAC systems with chilled water supplied by absorption chillers, heat recovery chillers, water-to-water heat pumps, air- to-water heat pumps, or a combination of air- and water- cooled chillers on the same chilled water loop. 6. HVAC systems served by heating water systems that include air-to-water or water-to- water heat pumps. 7. Underfloor air distribution and displacement ventilation HVAC systems. 8. Space-conditioning systems that do not include mechanical cooling. 9. HVAC systems serving laundry rooms, elevator rooms, mechanical rooms, <i>data centers</i> and <i>computer rooms</i>. 10. Buildings or areas of medical office buildings required to use ASHRAE Standard 170. 11. Buildings or areas that are required by regulation to have continuous air-handling unit operation. 12. HVAC systems serving laboratories with fume hoods. 13. Locker rooms with more than two showers. 14. Natatoriums and rooms with saunas. 15. Restaurants and commercial kitchens with a total cooking capacity greater than 100,000 Btu/h (29 kW). 16. Areas of buildings with commercial refrigeration equipment exceeding 100 kW of power input. 17. Cafeterias and dining rooms <p>C409.3 HVAC TSPR compliance. HVAC systems permitted to use TSPR shall comply with Section C409.4 and the following:</p> <ol style="list-style-type: none"> 1. HVAC systems shall comply with applicable requirements of Section C403 as follows: <ol style="list-style-type: none"> 1.1. Air economizers shall meet the requirements of Sections C403.5.3.4 and C403.5.5. 1.2. Variable-air-volume systems shall meet the requirements of Sections C403.6.5, C403.6.6 and C403.6.9. 1.3. Hydronic systems shall meet the requirements of Section C403.4.4. 1.4. Plants with multiple chillers or boilers shall meet the requirements of Section C403.4.5. 1.5. Hydronic (water loop) heat pumps and water-cooled unitary air conditioners shall meet the requirements of Section C403.4.3.3.
---------------------	--

- C409.4 Performance target.** For HVAC systems serving uses or portions of uses listed in **Section C409.2** that are not served by systems listed in **Section C409.2.1**, the *HVAC TSPR* of the *proposed design* shall be greater than or equal to the *HVAC TSPR* of the *standard reference design* divided by the mechanical performance factor (MPF) using **Equation 4-34**.

where:

$TSPR_{HVAC}$ = HVAC TSPR of the proposed design calculated in accordance with Sections C409.4, C409.5 and C409.6

TS_{PR} = HVAC TS_{PR} of the reference building design calculated in accordance with Sections C409.4, C409.5 and C409.6

MPF = Mechanical performance factor from Table C409.4 based on climate zone and building use type.

Equation 4-35

where:
 MPF_1, MPF_2 through MPF_n = Mechanical performance factors from Table C409.4 based on climate zone and building use types 1, 2 through n

C409.4.1 HVAC TSPR. HVAC TSPR is calculated according to Equation 4-36.

Equation 4-36

where:
Building HVAC system energy = Sum of the annual site energy consumption for heating, cooling, fans, energy recovery, pumps and heat rejection in thousands of Btu (kWh).
Heating and cooling load = Sum of the annual heating and cooling loads met by the building HVAC system in thousands of Btu (kWh).

$$MPF = (A_1 \times MPF_1 + A_2 \times MPF_2 + \dots + A_n \times MPF_n) / (A_1 + A_2 + \dots + A_n)$$

$$\text{HVAC TSPR} = \text{heating and cooling load/building HVAC system energy}$$

TABLE C409.4 MECHANICAL PERFORMANCE FACTORS
CLIMATE ZONE

BUILDING USE	OCCUPANCY GROUP	0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
Office (all other)*	B	0.72	0.715	0.70	0.705	0.685	0.65	0.71	0.68	0.645	0.805	0.79	0.78	0.845	0.765	0.805	0.865	0.835	0.875	0.895
Office (large)	B	0.83	0.83	0.84	0.84	0.79	0.82	0.72	0.81	0.77	0.67	0.78	0.63	0.71	0.72	0.83	0.73	0.71	0.71	0.71
Retail	M	0.60	0.57	0.50	0.55	0.46	0.46	0.43	0.51	0.40	0.46	0.57	0.68	0.46	0.58	0.67	0.50	0.45	0.44	0.38
Hotel/motel	R-1	0.63	0.62	0.63	0.63	0.62	0.68	0.61	0.71	0.73	0.46	0.59	0.52	0.38	0.47	0.51	0.35	0.38	0.31	0.26
Multi-family dormitory	R-2	0.64	0.63	0.67	0.63	0.65	0.64	0.58	0.72	0.55	0.53	0.69	0.44	0.54	0.47	0.38	0.55	0.50	0.51	0.47
School/education and libraries	E (A-3)	0.83	0.81	0.80	0.79	0.75	0.72	0.71	0.72	0.67	0.73	0.72	0.68	0.82	0.73	0.81	0.89	0.80	0.83	0.77

a. Large-office conditioned floor area greater than 150,000 square feet or more than five stories.

Staff Classification	Correlates Directly	Energy Standard Needed	Overlap
	X		

Action	AS	AS/IC	D	D/IC
			x	

CE#323	<p>Adds new Section C409.5 that defines the calculation procedure for the TSPR method.</p> <p>Adds new subsection C409.5.1 that specifies the simulation program capability requirements for TSPR method. Adds a new Section C409.5.2 that specifies the hourly 8760 climatic data requirements for the simulation.</p> <p>Adds a new Section C409.5.3 that specifies the submittal documentation requirements.</p> <p>Adds a new subsection C409.5.3.1 that specifies the building permit compliance report submittal requirements.</p>	
--------	--	--

Related Models:	<p>add a new subsection C409.5.3.1 that specifies the building thermal compliance report submission requirements.</p> <p>C409.5.3 General. Projects shall use the procedures of this section when calculating compliance with HVAC total system performance ratio.</p> <p>C409.5.1 Simulation program. Simulation tools used to calculate the HVAC TSPR of the standard reference design shall comply with the following:</p> <ol style="list-style-type: none"> 1. The simulation program shall calculate the HVAC TSPR based only on the input for the proposed design and the requirements of Section C409. The calculation procedure
-----------------	--

1. The simulation program shall calculate the *HVAC TSPR* based only on the input for the *proposed design* and the requirements of *Section 4.09*. The calculation procedure shall not allow the user to directly modify the building component characteristics of the *standard reference design*.
2. Performance analysis tools shall meet the applicable subsections of *Section C409* and be tested in accordance with *ASHRAE Standard 140*, except for Sections 7 and 8.
8. The required tests shall include the *building thermal envelope* and fabric load test (Sections 5.2.1, 5.2.2 and 5.2.3), ground-cooled slab-on-grade analytical verification tests (Section 5.2.4), space-cooling equipment performance tests (Section 5.3), space-heating equipment performance tests (Section 5.4), and air-side HVAC equipment analytical verification test (Section 5.5), along with the associated reporting (Section 6).
3. The test results and modeler reports shall be publicly available and shall include the test results of the simulation programs and input files used for generating the results along with the results of the other simulation programs included in *ASHRAE Standard 140*, Annexes B8 and B16. The modeler report in *ASHRAE Standard 140* Annex A2, Attachment A2.7.

ASHRAE Standard 140, Annexes B8 and B16. The modeler report in ASHRAE Standard 140 Annex A2 Attachment A2.7

	<p>shall be completed for results exceeding the maximum or falling below the minimum of the reference values and for omitted results.</p> <p>4. The simulation program shall have the ability to model part-load performance curves or other part-load adjustment methods based on manufacturer's part-load performance data for mechanical equipment.</p> <p>5. The <i>code official</i> shall be permitted to approve specific software deemed to meet these requirements in accordance with Section C101.4.1.</p> <p>C409.5.2 Climatic data. The simulation program shall perform the simulation using hourly values of climatic data for a full calendar year (8,760 hours) and shall reflect <i>approved</i> coincident hourly data for temperature, solar radiation, humidity and wind speed for the building location.</p> <p>C409.5.3 Documentation. Documentation or web links to documentation conforming to the provisions of this section shall be provided to the <i>code official</i>.</p> <p>C409.5.3.1 Compliance report. Building permit submittals shall include:</p> <ol style="list-style-type: none">1. A report produced by the simulation software that includes the following:<ol style="list-style-type: none">1.1. Address of the <i>building</i>.1.2. Name of the individual completing the compliance report.1.3. Name and version of the compliance software tool.1.4. The dimensions, floor heights and number of floors for each thermal block.1.5. By thermal block, the <i>U-factor</i>, <i>C-factor</i> or <i>F-factor</i> for each simulated opaque envelope component and the <i>U-factor</i> and SHGC for each fenestration component.1.6. By <i>thermal block</i> or by surface for each thermal block, the fenestration area.1.7. By <i>thermal block</i>, a list of the HVAC equipment simulated in the <i>proposed design</i>, including the equipment type, fuel type, equipment efficiencies and system controls.1.8. Annual site HVAC energy use by end use for the proposed and baseline building.1.9. Annual sum of heating and cooling loads for the baseline building.1.10. The HVAC TSPR for both the <i>standard reference design</i> and the <i>proposed design</i>.2. A mapping of the actual building HVAC component characteristics and those simulated in the <i>proposed design</i> showing how individual pieces of HVAC equipment identified in Item 1 have been combined into average inputs as required by Section C409.6.1.10, including:<ol style="list-style-type: none">2.1. Fans.2.2. Hydronic pumps.2.3. Air handlers.2.4. Packaged cooling equipment.2.5. Furnaces.2.6. Heat pumps.2.7. Boilers.2.8. Chillers.2.9. Heat rejection equipment (open- and closed-circuit cooling towers, dry coolers).																		
	<ol style="list-style-type: none">2.10. Electric resistance coils.2.11. Condensing units.2.12. Motors for fans and pumps.2.13. Energy recovery devices. <p>3. For each piece of equipment identified in Item 2, include the following, as applicable:</p> <ol style="list-style-type: none">3.1. Equipment name or tag consistent with that found on the design documents.3.2. Rated efficiency level.3.3. Rated capacity.3.4. Where not provided by the simulation program report in Item 1, documentation of the calculation of any weighted equipment efficiencies input into the program.3.5. Electrical input power for fans and pumps (before any speed or frequency control device) at design condition and calculation of input value (W/cfm or W/gpm) or W/gpm (W/Lps). <p>4. Floor plan of the <i>building</i>, identifying:</p> <ol style="list-style-type: none">4.1. How portions of the buildings are assigned to the simulated thermal blocks.4.2. Areas of the <i>building</i> that are not covered under the requirements of Section C403.1.1.																		
	<table><tr><td>Staff Classification</td><td>Considers Directly</td><td>Energy Standard Considered</td><td>Overlps</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALOC</td><td>IS</td><td>DOC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Considers Directly	Energy Standard Considered	Overlps		x			Action	AS	ALOC	IS	DOC				x	
Staff Classification	Considers Directly	Energy Standard Considered	Overlps																
	x																		
Action	AS	ALOC	IS	DOC															
			x																
CE#324	<p>Adds a new Section C409.6. Prescribes how the standard reference design and proposed design building models must be configured and analyzed. Adds a new subsection C409.6.1. Defines how the proposed design must be configured and analyzed.</p> <p>Adds a new subsection C409.6.1.1 that prescribes how the geometry of buildings must be configured using one or more thermal blocks. Adds a new subsection C409.6.1.1.1. Adds a new subsection C409.6.1.2. Adds a new subsection C409.6.1.2.1. Adds a new subsection C409.6.1.3. Adds a new subsection C409.6.1.3.1. Adds a new subsection C409.6.1.3.2. Adds a new subsection C409.6.1.4. Adds a new subsection C409.6.1.4.1. Adds a new subsection C409.6.1.4.2. Adds a new subsection C409.6.1.4.3. Adds a new subsection C409.6.1.4.4. Adds a new subsection C409.6.1.4.5. Adds a new subsection C409.6.1.4.6. Adds a new subsection C409.6.1.4.7. Adds a new subsection C409.6.1.4.8. Adds a new subsection C409.6.1.5. Adds a new subsection C409.6.1.6. Adds a new subsection C409.6.1.7.</p>																		
	<p>Adds a new subsection C409.6.1.8. Adds a new subsection C409.6.1.9. Adds a new subsection C409.6.1.10. Adds a new subsection C409.6.1.10.1. Adds a new Table C409.6.1.10.1. Adds a new subsection C409.6.1.10.2. Adds a new subsection C409.6.1.10.3. Adds a new subsection C409.6.1.10.3.</p>																		
Related Mods:	<p>C409.6 Calculation procedures. Except as specified by this section, the <i>standard reference design</i> and <i>proposed design</i> shall be configured and analyzed using identical methods and techniques.</p> <p>C409.6.1 Simulation of the proposed building design. The <i>proposed design</i> shall be configured and analyzed as specified in this section.</p> <p>C409.6.1.1 Thermal block geometry. The geometry of buildings shall be configured using one or more thermal blocks. Each <i>thermal block</i> shall define attributes, including <i>thermal block</i> dimensions, number of floors, floor-to-floor height and floor-to-ceiling height. Simulation software may allow the use of simplified shapes (such as rectangle, L-shaped, H-shaped, U-shaped or T-shaped) to represent thermal blocks. Where actual building shape does not match these predefined shapes, simplifications are permitted, provided that the following requirements are met:</p> <ol style="list-style-type: none">1. The <i>conditioned floor area</i> and volume of each thermal block shall match the <i>proposed design</i> within 10 percent.2. The area of each exterior envelope component from Table C402.1.4 is accounted for within 10 percent of the actual design.3. The area of vertical <i>fenestration</i> and skylights is accounted for within 10 percent of the actual design.4. The orientation of each component in Items 2 and 3 is accounted for within 45 degrees of the actual design. <p>The creation of additional thermal blocks may be necessary to meet these requirements. A more complex zoning of the <i>building</i> shall be allowed where all thermal zones in the reference and proposed models are the same, and rules related to thermal block geometry and HVAC system assignment to <i>thermal blocks</i> are met with appropriate assignment to thermal zones.</p> <p>Exception: Portions of the <i>building</i> that are unconditioned or served by systems not covered by the requirements of Section C403.1.1 shall be omitted.</p>																		
CEPI-76-21. CED1- 182-22, CED1- 198-22,																			

	<p>C409.6.1.1.1 Number of thermal blocks. One or more thermal blocks may be required per <i>building</i> based on the following restrictions:</p> <ol style="list-style-type: none">1. Each thermal block shall have not more than one <i>building</i> use.2. Each thermal block shall be served by not more than one type of HVAC system. A single block shall be created for each unique HVAC system and building use combination, and multiple HVAC units or components of the same type shall be combined in accordance with Section C409.6.1.10.2.3. Each thermal block shall have not more than a single defined floor-to-floor or floor-to-ceiling height. Where floor heights differ by more than 2 feet, separate thermal blocks shall be created.4. Each block shall include either above-grade or below-grade stories. For buildings with both above-grade and below-grade stories, separate blocks shall be created for each. Where blocks have <i>exterior walls</i> partially below
	<p>grade, if greater than 50 percent of the exterior wall surface is below grade, then simulate the block as below grade; otherwise, simulate as above grade.</p> <p>5. Where a block includes multiple stories, separate blocks shall be created, if needed, to comply with both the following fenestration modeling requirements:</p> <p>5.1. The product of the <i>proposed design U-factor</i> times the area of windows ($U \times A$) on a given story of each facade shall not differ by more than 15 percent of the average $U \times A$ for that modeled facade in each block.</p> <p>5.2. The product of the <i>proposed design SHGC</i> times the area of windows ($SHGC \times A$) on a given story of each facade shall not differ by more than 15 percent of the average $SHGC \times A$ for that modeled facade in each block.</p> <p>6. For a building model with multiple blocks, the blocks shall be configured together to have the same adjacencies as the actual building design.</p> <p>C409.6.1.2 Thermal zoning. Each story in a thermal block shall be modeled as follows:</p> <ol style="list-style-type: none">1. Below-grade stories shall be modeled as a single thermal zone.2. Where any facade in the block is less than 45 feet (13.7 m) in length, it shall be modeled as a single thermal zone per story.3. For stories not covered by Item 1 or Item 2, each story shall be modeled with five thermal zones. A perimeter zone shall be created, extending from each facade to a depth of 15 feet (4572 mm). Where facades intersect, the zone boundary shall be formed by a 45-degree angle with the two facades. The remaining area of each story shall be modeled as a core zone with no <i>exterior walls</i>. <p>C409.6.1.2.1 Core and shell, build-out and future system construction analysis. Where the building permit applies to only a portion of the HVAC system in a <i>building</i> and the remaining components will be designed under a future building permit or were previously installed, such components shall be modeled as follows:</p> <ol style="list-style-type: none">1. Blocks including existing or future HVAC <i>zone</i> served by independent systems and not part of the construction project shall not be modeled.2. Where the HVAC <i>zones</i> that do not include complete HVAC systems in the permit are intended to receive HVAC services from systems that are part of the construction project, their proposed zonal systems shall be modeled with equipment that meets, but does not exceed, the requirements of Section C403.3. Where existing HVAC systems serve permitted <i>zone</i> equipment, the existing systems shall be modeled with equipment matching the manufacturer's stated efficiency for the installed equipment or equipment that meets, but does not exceed, the requirements of Section C403.4. Where the central plant heating and cooling equipment is completely replaced and HVAC <i>zones</i> with existing systems receive HVAC services from systems in the permit, their proposed zonal systems shall be modeled with equipment that meets, but does not exceed, the requirements of Section C403.
	<p>C409.6.1.3 Occupancy. Building occupancies modeled in the <i>standard reference design</i> and the <i>proposed design</i> shall comply with the following requirements.</p> <p>C409.6.1.3.1 Occupancy type. The occupancy type for each thermal block shall be consistent with the building occupancy and uses specified in Table C409.4. Portions of the building occupancy and uses other than those specified in Table C409.4 shall not be included in the simulation. Surfaces adjacent to such <i>excluded building</i> portions shall be modeled as adiabatic in the simulation program.</p> <p>C409.6.1.3.2 Occupancy schedule, density and heat gain. The occupant density, heat gain and schedule shall be for multifamily, offices, retail spaces, libraries, hotels/ motels or schools as specified by ANSI/ASHRAE/IES 90.1, Normative Appendix C.</p> <p>C409.6.1.4 Building thermal envelope components. <i>Building thermal envelope</i> components modeled in the <i>standard reference design</i> and the <i>proposed design</i> shall comply with the requirements of this section.</p> <p>C409.6.1.4.1 Roofs. The roof <i>U-factor</i> and area shall be modeled as in the <i>proposed design</i>. If different roof thermal properties are present in a single thermal block, an area-weighted <i>U-factor</i> shall be used. Roofs shall be modeled with insulation above a steel roof deck, with a solar reflectance of 0.25 and an <i>emittance</i> of 0.90.</p> <p>Exception: For Climate Zones 0, 1, 2 and 3, solar reflectance and <i>emittance</i> shall be as specified in Section C402.4 and Table C402.4.</p> <p>C409.6.1.4.2 Above-grade walls. The <i>U-factor</i> and area of <i>above-grade walls</i> shall be modeled as in the <i>proposed design</i>. If different wall constructions exist on the facade of a thermal block, an area-weighted <i>U-factor</i> shall be used. Walls will be modeled as steel-frame construction.</p> <p>C409.6.1.4.3 Below-grade walls. The <i>C-factor</i> and area of below-grade walls shall be modeled as in the <i>proposed design</i>. If different below-grade wall constructions exist in a thermal block, an area-weighted <i>C-factor</i> shall be used.</p> <p>C409.6.1.4.4 Above-grade exterior floors. The <i>U-factor</i> and area of floors shall be modeled as in the <i>proposed design</i>. If different floor constructions exist in the thermal block, an area-weighted <i>U-factor</i> shall be used. Exterior floors shall be modeled as steel frame.</p> <p>C409.6.1.4.5 Slab-on-grade floors. The <i>F-factor</i> and perimeter of slab-on-grade floors shall be modeled as in the <i>proposed design</i>. If different slab-on-grade floor constructions exist in a thermal block, a perimeter-weighted <i>F-factor</i> shall be used.</p> <p>C409.6.1.4.6 Vertical fenestration. The window area and area-weighted <i>U-factor</i> and SHGC shall be modeled for each facade based on the <i>proposed design</i>. Each exterior surface in a thermal block must comply with Section C409.6.1.1.1, Item 5. Windows shall be combined into a single window centered on each facade based on the area and sill height input by the user. Where different <i>U-values</i>, SHGC or sill heights exist on a single facade in a block, the area-weighted average for each shall be input by the user.</p> <p>C409.6.1.4.7 Skylights. The skylight area and area-weighted <i>U-factor</i> and SHGC shall be modeled for each roof based on the <i>proposed design</i>. Skylights shall be combined into a single skylight centered on the roof of each zone based on the area input by the user.</p>

	<p>C409.6.1.4.8 Exterior shading. Permanent window overhangs shall be modeled. Where windows with and without overhangs or windows with different overhang projection factors exist on a facade, window width-weighted projection factors shall be input by the user as follows:</p> <p>Equation 4-37</p> <p>where:</p> <p>P_{avg} = Average overhang projection modeled in the simulation tool</p> <p>A = Distance measured horizontally from the farthest continuous extremity of any overhang, eave or permanently attached shading device to the vertical surface of the</p> $P_{avg} = (A_1 \times L_{o1} + A_2 \times L_{o2} \dots + A_n \times L_{on}) / (L_{w1} + L_{w2} \dots + L_{wn})$ <p>L_{wn} = Length of the window.</p> <p>C409.6.1.5 Lighting. Interior lighting power density shall be equal to the allowance in Table C405.3.2(1) for multifamily buildings, offices, retail spaces, libraries or schools. The lighting schedule shall be for multifamily buildings, offices, retail spaces, libraries or schools as specified by ANSI/ASHRAE/IES 90.1, Normative Appendix C. The impact of lighting controls is assumed to be captured by the lighting schedule and no explicit controls shall be modeled. Exterior lighting shall not be modeled.</p> <p>C409.6.1.6 Miscellaneous equipment. The miscellaneous equipment schedule and power shall be for multifamily buildings, offices, retail spaces, libraries or schools as specified by ANSI/ASHRAE/IES 90.1, Normative Appendix C. The impact of miscellaneous equipment controls is assumed to be captured by the equipment schedule and no explicit controls shall be modeled.</p> <p>Exceptions:</p> <ol style="list-style-type: none">1. Multiple-family dwelling units shall have a miscellaneous load density of 0.42 watts per square foot.2. Multiple-family <i>common areas</i> shall have a miscellaneous load density of 0 watts per square foot. <p>C409.6.1.7 Elevators. Elevators shall not be modeled.</p> <p>C409.6.1.8 Service water heating equipment. <i>Service water heating</i> shall not be modeled.</p> <p>C409.6.1.9 On-site renewable energy systems. On-site renewable energy systems shall not be modeled.</p> <p>C409.6.1.10 HVAC equipment. Where proposed or where reference system parameters are not specified in Section C409, HVAC systems shall be modeled to meet the minimum requirements of Section C403.</p> <p>C409.6.1.10.1 Supported HVAC systems. At a minimum, the HVAC systems shown in Table C409.6.1.10.1 shall be supported by the simulation program.</p>																
	<p>C409.6.1.10.2 Proposed building HVAC system simulation. The HVAC systems shall be modeled as in the <i>proposed design</i> at design conditions unless otherwise stated, with clarifications and simplifications as described in Tables C409.6.1.10.2(1) and C409.6.1.10.2(2). System parameters not described in the following sections shall be simulated to meet the minimum requirements of Section C403. All <i>zones</i> within a thermal block shall be served by the same HVAC system type as described in Section C409.6.1.1.1, Item 2. Heat loss from <i>ducts</i> and pipes shall not be modeled. The proposed building system parameters in Table C409.6.1.10.2(1) are based on input of full-load equipment efficiencies with adjustments using part-load curves integrated into the simulation program. Where other approaches to part-load adjustments are used, it is permitted for specific input parameters to vary. The simulation program shall model part-load HVAC equipment performance using one of the following:</p> <ol style="list-style-type: none">1. Full-load efficiency adjusted for fan power input that is modeled separately and typical part-load performance adjustments for the proposed equipment.2. Part-load adjustments based on input of both full-load and part-load metrics.3. Equipment-specific adjustments based on performance data provided by the equipment manufacturer for the proposed equipment. <p>Where multiple system components serve a thermal block, average values weighted by the appropriate metric as described in this section shall be used.</p> <ol style="list-style-type: none">1. Where multiple <i>fan systems</i> serve a single thermal block, fan power shall be based on a weighted average using the design supply air (cfm).2. Where multiple cooling systems serve a single thermal block, the coefficient of performance (COP) shall be based on a weighted average using cooling capacity. Direct expansion (DX) coils shall be entered as multistage if more than 50 percent of coil capacity serving the thermal block is multistage with staged controls.3. Where multiple heating systems serve a single thermal block, thermal efficiency or heating COP shall be based on a weighted average using heating capacity.4. Where multiple boilers or chillers serve a heating water or chilled water loop, efficiency shall be based on a weighted average for using heating or cooling capacity.5. Where multiple cooling towers serving a condenser water loop are combined, the cooling tower efficiency, cooling tower design approach and design range are based on a weighted average of the design water flow rate through each cooling tower.6. Where multiple pumps serve a heating water, chilled water or condenser water loop, pump power shall be based on a weighted average for using design water flow rate.7. Where multiple system types with and without economizers are combined, the economizer maximum outside air fraction of the combined system shall be based on the weighted average of 100 percent supply air for systems with economizers and design outdoor air for systems without economizers.8. Multiple systems with and without ERVs cannot be combined.9. Systems with and without supply-air temperature reset controls cannot be combined.10. Systems with different fan controls (constant volume, multispeed or VAV) for supply fans cannot be combined. <p>C409.6.1.10.3 Demand control ventilation. Demand control ventilation (DCV) shall be modeled using a simplified approach that adjusts the design outdoor supply airflow rate based on the floor area of the <i>building</i> that is covered by DCV. The simplified method shall accommodate both variable DCV and on/off DCV, giving on/off DCV one third of the effective floor control area of the variable DCV. Outdoor air reduction coefficients shall be as stated in Table C409.6.1.10.3.</p> <p>Exception: On/off DCV shall receive full effective area adjustment for R-1 and R-2 occupancies.</p> <table><tr><th>Staff Classification</th><th>Controls Directly</th><th>Energy Standard</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>ALUC</td><td>DCV</td></tr></table>	Staff Classification	Controls Directly	Energy Standard	Over lap					Action	AS	ALUC	DCV				
Staff Classification	Controls Directly	Energy Standard	Over lap														
Action	AS	ALUC	DCV														
CE#325	<p>Adds a new Table C409.6.1.10.1 Adds a new Table C409.6.1.10.2(1). Adds a new Table C409.6.1.10.2(2). Adds a new Table C409.6.1.10.3.</p>																
Related Mods: CEPI-76- 21, CED1- 198-22	<p>TABLE C409.6.1.10.1 PROPOSED BUILDING HVAC SYSTEMS SUPPORTED BY HVAC TSPR SIMULATION SOFTWARE</p> <table><tr><th></th><th>SYSTEM NAME</th></tr><tr><td>1</td><td>Packaged terminal air conditioner (with electric or hydronic heat)</td></tr><tr><td>2</td><td>Packaged terminal air heat pump</td></tr><tr><td>3</td><td>Packaged single-zone gas furnace^a and/or air-cooled air conditioner (includes split systems)^b</td></tr><tr><td>4</td><td>Packaged single-zone heat pump (air to air only)(includes split systems^b and electric or gas supplemental heat)</td></tr><tr><td>5</td><td>Variable refrigerant flow (air cooled only)</td></tr><tr><td>6</td><td>Four pipe fan coil</td></tr><tr><td>7</td><td>Water-source heat pump (water loop), water-source variable refrigerant flow system or water-source air conditioner</td></tr></table>		SYSTEM NAME	1	Packaged terminal air conditioner (with electric or hydronic heat)	2	Packaged terminal air heat pump	3	Packaged single-zone gas furnace ^a and/or air-cooled air conditioner (includes split systems) ^b	4	Packaged single-zone heat pump (air to air only)(includes split systems ^b and electric or gas supplemental heat)	5	Variable refrigerant flow (air cooled only)	6	Four pipe fan coil	7	Water-source heat pump (water loop), water-source variable refrigerant flow system or water-source air conditioner
	SYSTEM NAME																
1	Packaged terminal air conditioner (with electric or hydronic heat)																
2	Packaged terminal air heat pump																
3	Packaged single-zone gas furnace ^a and/or air-cooled air conditioner (includes split systems) ^b																
4	Packaged single-zone heat pump (air to air only)(includes split systems ^b and electric or gas supplemental heat)																
5	Variable refrigerant flow (air cooled only)																
6	Four pipe fan coil																
7	Water-source heat pump (water loop), water-source variable refrigerant flow system or water-source air conditioner																

8	Ground source heat pump
9	Packaged variable air volume (DX cooling) ^a
10	Variable air volume (hydronic cooling) ^a
11	Variable air volume with fan-powered terminal units
12	Dedicated outdoor air system (in conjunction with systems 1–8)

- a. Reheat or primary heat may be electric, hydronic or gas furnace.
b. Condensing units with DX air handlers are modeled as package furnaces with air conditioners or heat pumps.

TABLE C409.6.1.10.2(1) PROPOSED BUILDING SYSTEM PARAMETERS				
FIXED OR CATEGORY DEFINED	PARAMETER	USER	REQUIRED SYSTEMS	APPLICABLE
HVAC		User	Selected from Table C409.6.1.10.1	All
system type	System type defined			
Design day information	99.6% heating design and 1% dry-bulb and 1% wet-bulb cooling design			
Sizing factors used are 1.25 for				
Zone coil capacity sizing	Fixed heating equipment and 1.15 for		All System	cooling equipment
Based on a supply-air-to-room-air				
Fixed temperature setpoint difference of		1–11 20°F (11.2°C)		
Supply airflow				
Fixed Equal to required outdoor air				
ventilation		12		
Portion of supply air	Percentage of supply airflow subject to higher filtration (adjusts baseline		User	
with proposed filter			All	
As specified in ANSI/ASHRAE/IES 90.1, Normative Appendix C;				
airflow rate	adjusted for proposed DCV control		All	
Outdoor ventilation air				
Based on ASHRAE 62.1 Section 6.2.4.3, system ventilation efficiency				
Fixed (E _v) is 0.75		9–11		
Outdoor ventilation supply airflow rate	System ventilation efficiency (E _v) is			
adjustments	Fixed	1.0	1–8, 12	
Fixed Basis is 1.0 zone air distribution effectiveness		All		

System operation	Space temperature setpoints	Fixed	As specified in ANSI/ASHRAE/IES 90.1, Normative Appendix C, except: • Multiple-family, which shall use 68°F heating and 76°F cooling setpoints. • Hotel/motel setpoints, which shall be 70°F heating and 72°F cooling.	1–11
	Fan operation—occupied	User defined	Runs continuously during occupied hours or cycles to meet load. Multispeed fans reduce airflow related to thermal loads.	1–11
	Fan operation—occupied	Fixed	Fan runs continuously during occupied hours	12
	Fan operation—night cycle	Fixed	Fan cycles on to meet setback temperatures	1–11
Packaged equipment efficiency	DX cooling efficiency	User defined	Cooling COP without fan energy calculated in accordance with Section C409.6.1.10.2	1, 2, 3, 4, 5, 7, 8, 9, 11, 12
	DX coil number of stages	User defined	Single stage or multistage	3, 4, 9, 10, 11, 12
	Heat pump efficiency	User defined	Heating COP without fan energy calculated in accordance with Section C409.6.1.10.2	2, 4, 5, 7, 8, 12
	Furnace efficiency	User defined	Furnace thermal efficiency	3, 9, 11, 12
Heat pump supplemental heat	Heat source	User defined	Electric resistance or gas furnace	2, 4, 7, 8, 12
	Control	Fixed	Supplemental electric heat locked out above 40°F OAT. Runs as needed in conjunction with compressor between 40°F and 0°F. Gas heat operates in place of the heat pump when the heat pump cannot meet load.	2, 4, 7, 8, 12
System fan power and controls	Part-load fan controls ^b : • Constant volume. • Two speed or three speed. • VAV.	User defined	Static pressure reset included for VAV	1–8 (CAV, two or three speed), 9, 10, 11 (VAV), 12 (CAV and VAV)
	Design fan power (W/cfm)	User defined	Input electric power for all fans required to operate at fan system design conditions divided by the supply airflow rate. This is a wire-to-air value, including all drive, motor efficiency and other losses.	All

	Low-speed and medium-speed fan power	User defined	Low-speed input electric power for all fans required to operate at low-speed conditions divided by the low-speed supply airflow rate. This is a wire-to-air value, including all drive, motor efficiency and other losses. Also provide medium-speed values for three-speed fans.	1-8
	Supply air temperature (SAT) controls	User defined	If not SAT reset, then constant at 55°F. Options for reset based on OAT or warmest zone. If warmest zone, then the user can specify the minimum and maximum temperatures. If OAT reset, SAT is reset higher to 60°F at an outdoor low of 50°F. SAT is 55°F at an outdoor high of 70°F.	9, 10, 11
Variable air volume systems	Minimum terminal unit airflow percentage	User defined	Average minimum terminal unit airflow percentage for thermal block weighted by cfm or minimum required for outdoor air ventilation, whichever is higher.	9, 10, 11
	Terminal unit heating source	User defined	Electric or hydronic	9, 10, 11
	Dual setpoint minimum VAV damper position	User defined	Heating maximum airflow fraction	9, 10
	Fan-powered terminal unit (FPTU) type	User defined	Series or parallel FPTU	11
	Parallel FPTU fan	Fixed	Sized for 50% peak primary air at 0.35 W/cfm	11
	Series FPTU fan	Fixed	Sized for 50% peak primary air at 0.35 W/cfm	11
Economizer	Economizer presence	User defined	Yes or no	3, 4, 5, 6, 9, 10, 11
	Economizer control type	Fixed	Lockout on differential db temperature (OAT > RAT) in Climate Zones 5A, 6A, all B & C; fixed enthalpy > 28 Btu/lb (47kJ/kg) or fixed db OAT > 75°F (24°C) in Climate Zones 0A through 4A	3, 4, 5, 6, 9, 10, 11
Energy recovery	Sensible effectiveness	User defined	Heat exchanger sensible effectiveness at design heating and cooling conditions	3, 4, 9, 10, 11, 12
	Latent effectiveness	User defined	Heat exchanger latent effectiveness at design heating and cooling conditions	3, 4, 9, 10, 11, 12
	Economizer bypass	User defined	If ERV is bypassed or wheel rotation is slowed during economizer conditions (yes/no)	3, 4, 9, 10, 11, 12
	Economizer bypass active	Fixed	If there is a bypass, it will be active between 45°F and 75°F outside air temperature	3, 4, 9, 10, 11, 12
	Bypass SAT setpoint	User defined	If bypass, target SAT	3, 4, 9, 10, 11, 12
	Fan power reduction during bypass (W/cfm)	User defined	If ERV system includes bypass, static pressure setpoint and variable speed fan, fan power can be reduced during economizer conditions	3, 4, 9, 10, 11, 12
Demand control ventilation (DCV)	DCV application on/off	User defined	Percent of thermal block floor area under occupied standby controls, on/off only with occupancy sensor and no variable control	3, 4, 9, 10, 11, 12
	DCV application CO ₂	User defined	Percentage of thermal block floor area under variable DCV control (CO ₂) may include both variable and on/off controls	3, 4, 9, 10, 11, 12
DOAS	DOAS fan power W/cfm	User defined	Fan electrical input power in W/cfm of supply airflow	12
	DOAS supplemental heating and cooling	User defined	Heating source, cooling source, energy recovery and respective efficiencies	12
	Maximum SAT setpoint (cooling)	User defined	SAT setpoint if DOAS includes supplemental cooling	12
	Minimum SAT setpoint (heating)	User defined	SAT setpoint if DOAS includes supplemental heating	12
Heating plant	Boiler efficiency	User defined	Boiler thermal efficiency	1, 6, 7, 9, 10, 11, 12
	Heating water loop configuration	User defined	Constant flow primary only; variable flow primary only; constant flow primary/variable flow secondary; variable flow primary and secondary	1, 6, 7, 9, 10, 11, 12
	Heating water primary pump power (W/gpm)	User defined	Heating water primary pump input W/gpm heating water flow	1, 6, 7, 9, 10, 11, 12
	Heating water secondary pump power (W/gpm)	User defined	Heating water secondary pump input W/gpm heating water flow (if primary/secondary)	1, 6, 7, 9, 10, 11, 12
	Heating water loop temperature	User defined	Heating water supply and return temperatures, °F	1, 6, 9, 10, 11
	Heating water loop supply temperature reset	Fixed	Reset HWS by 27.3% of design delta-T (HWS-70°F space heating temperature setpoint) between 20°F and 50°F OAT	1, 6, 7, 9, 10, 11, 12

Chilled water plant	Boiler type	Fixed	Noncondensing boiler where input thermal efficiency is less than 86%; condensing boiler otherwise	1, 6, 7, 9, 10, 11, 12
	Chiller compressor type	User define	Screw/scroll, centrifugal or reciprocating	6, 10, 11, 12
	Chiller condenser type	User define	Air cooled or water cooled	6, 10, 11, 12
	Chiller full-load efficiency	User define	Chiller COP	6, 10, 11, 12
	Chilled water loop configuration	User defined	Variable flow primary only, constant flow primary/variable flow secondary, variable flow primary and secondary	6, 10, 11, 12
	Chilled water primary pump power (W/gpm)	User defined	Primary pump input W/gpm chilled water flow	6, 10, 11, 12
	Chilled water secondary pump power (W/gpm)	User defined	Secondary pump input W/gpm chilled water flow (if primary/ secondary)	6, 10, 11, 12
	Chilled water temperature reset included	User defined	Yes/no	6, 10, 11, 12
	Chilled water temperature reset schedule (if included)	Fixed	Outdoor air reset: CHW supply temperature of 44°F at 80°F (26.7°C) outdoor air db temperature and above, CHW supply temperature of 54°F at 60°F outdoor air db temperature and below, ramped linearly between	6, 10, 11, 12
	Condenser water pump power (W/gpm)	User defined	Pump input W/gpm condenser water flow	6, 7, 8, 10, 11, 12
	Condenser water pump control	User defined	Constant speed or variable speed	6, 7, 8, 10, 11, 12
	Heat rejection equipment efficiency	User define	Gpm/hp tower fan	6, 7, 10, 11, 12
	Heat rejection fan control	User define	Constant or variable speed	6, 7, 10, 11, 12
	Heat rejection approach and range	User define	Design cooling tower approach and range temperature	6, 7, 10, 11, 12
Heat pump loop	Loop flow and heat pump control valve	Fixed	Two-position valve with VFD on pump; loop flow at 3 gpm/ton	7, 8
	Heat pump loop minimum and maximum temperature control	User defined	User input: restrict to minimum 20°F and maximum 40°F temperature difference	7
GLHP well field	—	Fixed	Bore depth = 250 ft Bore length 200 ft/ton for the greater of cooling or heating load Bore spacing = 15 ft Bore diameter = 5 in ¾" (19 mm) polyethylene pipe Ground and grout conductivity = 4.8 Btu × in/h × ft² × °F	8

or SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm, °C = (°F – 32)/1.8, 1 British thermal unit per hour = 0.2931 W, 1 British thermal unit per pound = 2.33 kJ/kg, 1 cubic foot per minute = 0.4719 L/s, 1 cubic foot per minute/foot = 47.82 W, COP = (Btu/h × hp)/(2,550.7), 1 gallon per minute = 3.79 L/m.
 CHW = Chilled Water, db = dry bulb, DOAS = Dedicated Outdoor Air System, GLHP = Ground Loop Heat Pump, HWS = Hot Water Supply, OAT = Outdoor Air Temperature, SAT = Supply Air Temperature, VFD = Variable Frequency Drive, wb = wet bulb.
 a. Part-load fan power and pump power modified in accordance with **Table C409.6.1.10.2(2)**.

TABLE C409.6.1.10.2(2)

FAN AND PUMP POWER CURVE COEFFICIENTS

EQUATION TERM	FAN POWER COEFFICIENTS	PUMP POWER COEFFICIENTS	
	VSD + SP Reset	Ride Pump Curve	VSD + DP/Valve Reset
<i>b</i>	0.0408	0	0
<i>x</i>	0.088	3.2485	0.0205
<i>x</i> ²	-0.0729	-4.7443	0.4101
<i>x</i> ³	0.9437	2.5295	0.5753

TABLE C409.6.1.10.3

DCV OUTDOOR AIR REDUCTION CURVE COEFFICIENTS

EQUATION TERM	DCV OSA REDUCTION (γ) AS A FUNCTION OF EFFECTIVE DCV CONTROL FLOOR AREA (x)			
	Office	School	Hotel, Motel, Multiple-Family, Dormitory	Retail
<i>b</i>	0	0	0	0
<i>x</i>	0.4053	0.2676	0.5882	0.4623
<i>x</i> ²	-0.8489	0.7753	-1.0712	-0.848
<i>x</i> ³	1.0092	-1.5165	1.3565	1.1925
<i>x</i> ⁴	-0.4168	0.7136	-0.6379	-0.5895

Staff Classification	Correlates Directly	Energy Standard Method	Chair Top
	x		

OSA = Outside Air.

CE#326 Adds a new subsection C409.6.2. Adds a new subsection C409.6.2.1. Adds a new subsection C409.6.2.2. Adds a new subsection C409.6.2.3. Adds a new subsection C409.6.2.4. Adds a new subsection C409.6.2.5. Adds a new subsection C409.6.2.6. Adds a new subsection C409.6.2.7. Adds a new subsection C409.6.2.8. Adds a new subsection C409.6.2.9. Adds a new subsection C409.6.2.10. Adds a new subsection C409.6.2.11. Adds a new Table C409.6.2.11(1). Adds a new Table C409.6.2.11(2). Systems types for office and retail building occupancy groups. Adds a new Table C409.6.2.11(3). System types for hotel and multifamily building occupancy groups.

Related Mods:
CEPI-76- 21

C409.6.2 Simulation of the standard reference design. The *standard reference design* shall be configured and analyzed as specified in this section. **C409.6.2.1 Utility rates.** Same as the *proposed design* . **C409.6.2.2 Thermal blocks.** Same as the *proposed design* . **C409.6.2.3 Thermal zoning.** Same as the *proposed design* . **C409.6.2.4 Occupancy type, schedule, density and heat gain.** Same as the *proposed design* . **C409.6.2.5 Envelope components.** Same as the *proposed design* . **C409.6.2.6 Lighting.** Same as the *proposed design* . **C409.6.2.7 Miscellaneous equipment.** Same as the *proposed design* . **C409.6.2.8 Elevators.** Not modeled. Same as the *proposed design* . **C409.6.2.9 Service water heating equipment.** Not modeled. Same as the *proposed design* . **C409.6.2.10 On-site renewable energy systems.** Not modeled. Same as the *proposed design* . **C409.6.2.11 HVAC equipment.** The reference building design HVAC equipment consists of separate space conditioning systems as described in **Tables C409.6.2.11(1)** through **C409.6.2.11(3)** for the appropriate building use types. In these tables, "warm" refers to Climate Zones 0 through 2 and 3A, and "cold" refers to Climate Zones 3B, 3C and 4 through 8.

Action	AS	AS/IC	D	S	OSC

TABLE C409.6.2.11(1)

REFERENCE BUILDING DESIGN HVAC COMPLEX SYSTEMS

BUILDING TYPE

BUILDING TYPE

PARAMETER	Large Office (warm)	Large Office (cold)	Large Office (warm)	Large Office (cold)
VAV/RH	VAV/RH	VAV/RH	VAV/RH	VAV/RH
Water-cooled chiller	Water-cooled chiller	Water-cooled chiller	Water-cooled chiller	Water-cooled chiller
Electric reheat	Electric reheat	Electric reheat	Electric reheat	Electric reheat
Gas boiler	Gas boiler	Gas boiler	Gas boiler	Gas boiler
Fan control	Fan control	Fan control	Fan control	Fan control
Main fan power [W/cfm (W × s/L)] proposed ≥	1.165 (2.468)	1.165 (2.468)	1.165 (2.468)	1.165 (2.468)
MERV 13	MERV 13	MERV 13	MERV 13	MERV 13
Main fan power [W/cfm (W × s/L)] proposed <	1.066 (2.259)	1.066 (2.259)	1.066 (2.259)	1.066 (2.259)
Zonal fan power [W/cfm (W × s/L)]	0.35 (0.75)	0.35 (0.75)	0.35 (0.75)	0.35 (0.75)
Minimum zone airflow fraction	1.5 × Voz	1.5 × Voz	1.5 × Voz	1.5 × Voz
Heat/cool sizing factor	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15
Outdoor air economizer	Yes except 4A	Yes except 4A	Yes except 4A	Yes except 4A
Occupied OSA (= proposed)	Sum(Voz)/0.75	Sum(Voz)/0.75	Sum(Voz)/0.65	Sum(Voz)/0.65

Energy recovery ventilator efficiency ERR; ERV bypass SAT setpoint	NA	NA	50% No bypass	50% 60°F except 4A
DCV	No	No	No	No
Cooling source	(2) Water-cooled centrifugal chillers	(2) Water-cooled centrifugal chillers	(2) Water-cooled screw chillers	(2) Water-cooled screw chillers
Cooling COP (net of fan)	Path B for profile	Path B for profile	Path B for profile	Path B for profile
Heating source (reheat)	Electric resistance	Gas boiler	Electric resistance	Gas boiler
Furnace or boiler efficiency	1.0	75% E _f	1.0	80% E _f
Condenser heat rejection	Axial fan open circuit cooling tower			
Cooling tower efficiency [gpm/fan hp (L/s × fan kW)]	38.2	38.2	38.2	38.2
Tower turndown (> 300 ton (1060 kW))	50%	50%	50%	50%
Pump (constant flow/variable flow)	Constant flow; 10°F (5.6°C) range	Constant flow; 10°F (5.6°C) range	Constant flow; 10°F (5.6°C) range	Constant flow; 10°F (5.6°C) range
Tower approach	25.72 – (0.24 × wb), where wb is the 0.4% evaporation design wet-bulb temperature (°F)			
Cooling condenser pump power [W/gpm (W × s/L)]	19 (300)	19 (300)	19 (300)	19 (300)

Cooling primary pump power [W/gpm (W x s/L)]	9 (142)	9 (142)	9 (142)	9 (142)
Cooling secondary pump power [W/gpm (W x s/L)]	13 (205)	13 (205)	13 (205)	13 (205)
Cooling coil chilled water delta-T, °F (°C)	12 (6.7)	12 (6.7)	12 (6.7)	12 (6.7)
Design chilled water supply temperature, °F (°C)	44 (6.7)	44 (6.7)	44 (6.7)	44 (6.7)
Chilled water supply temperature (CHWST) reset setpoint vs. outside air temperature (OAT), °F (°C)	CHWST: 44-54/ OAT 80-60 (6.7-12.2/ 26.7-15.6)	CHWST: 44-54/ OAT 80-60 (6.7-12.2/ 26.7-15.6)	CHWST: 44-54/ OAT 80-60 (6.7-12.2/ 26.7-15.6)	CHWST: 44-54/ OAT 80-60 (6.7-12.2/ 26.7-15.6)
CHW cooling loop pumping control	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD
Heating pump power [W/ gpm (W x s/L)]	16.1 (254)	16.1 (254)	19 (300)	19 (300)
Heating oil HW dT, °F (°C)	50 (10)	50 (10)	50 (10)	50 (10)
Design hot water supply temperature (HWST), °F (°C)	180 (82.2)	180 (82.2)	180 (82.2)	180 (82.2)
HWST reset setpoint vs. OAT, °F (°C)	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)
Heat loop pumping control	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD

For SI: °C = (°F – 32)/1.8, 1 hp = 0.746 kW, 1 ton = 3.517 kW.
CHW = Chilled Water, ERR = Enthalpy Recovery Ratio, NA = Not Applicable, OSA = Outside Air, PIU = Parallel Powered Induction Unit, RH = Relative Humidity, SP = Static Pressure, Voz = Outdoor airflow to the zone, VSD = Variable Speed Drive.

TABLE C409.6.2.11(2)
TSPR REFERENCE BUILDING DESIGN HVAC SIMPLE SYSTEMS

BUILDING TYPE						
BUILDING TYPE PARAMETER	Medium Office (warm)	Medium Office (cold)	Small Office (warm)	Small Office (cold)	Retail (warm)	Retail (cold)
System type	Package VAV—electric reheat	Package VAV—hydronic reheat	PSZ-HP	PSZ-AC	PSZ-HP	PSZ-AC
Fan control	VSD (no SP reset)	VSD (no SP reset)	Constant volume	Constant volume	Constant volume	Constant volume
Main fan power [W/cfm (W x s/L)] proposed ≥ MERV 13	1.285 (2.723)	1.285 (2.723)	0.916 (1.941)	0.916 (1.941)	0.899 (1.905)	0.899 (1.905)
Main fan power [W/cfm (W x s/L)] proposed < MERV 13	1.176 (2.492)	1.176 (2.492)	0.850 (1.808)	0.850 (1.808)	0.835 (1.801)	0.835 (1.801)
Zonal fan power [W/ cfm (W x s/L)]	0.35 (0.75)	NA	NA	NA	NA	NA
Minimum zone airflow fraction	30%	30%	NA	NA	NA	NA
Heat/cool sizing factor	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15
Supplemental heating availability	NA	NA	< 40°F OAT	NA	< 40°F OAT	NA
Outdoor air economizer	No	Yes except 4A	No	Yes except 4A	No	Yes except 4A
Occupied OSA source	Packaged unit, occupied damper, all building use types					
Energy recovery ventilator	No	No	No	No	No	No
DCV	No	No	No	No	No	No
Cooling source	DX, multistage	DX, multistage	DX, 1 stage (heat pump)	DX, single stage	DX, 1 stage (heat pump)	DX, single stage
Cooling COP (net of fan)	3.40	3.40	3.00	3.00	3.40	3.50

Heating COP (net of fan)/furnace or boiler efficiency
1.0 3.40 3.40

For SI: °C = (°F – 32)/1.8.
NA = Not Applicable, OSA = Outside Air, RH = Relative Humidity, SP = Static Pressure, VSD = Variable Speed Drive.

TABLE C409.6.2.11(3)
TSPR REFERENCE BUILDING DESIGN HVAC SIMPLE SYSTEMS

BUILDING TYPE PARAMETER	BUILDING TYPE			
	Hotel (warm)	Hotel (cold)	Multifamily (warm)	Multifamily (cold)
System type	PTHP	PTAC	PTHP	PTAC
Fan control	Constant volume	Constant volume	Constant volume	Constant volume

	Main fan power [W/cfm (W x s/L)]		0.300 (0.636)	0.300 (0.636)	0.300 (0.636)	0.300 (0.636)																																		
	Heat/cool sizing factor		1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15																																		
	Supplemental heating availability		< 40°F	NA	< 40°F	NA																																		
	Outdoor air economizer		No	No	No	No																																		
	Occupied OSA source		Packaged unit, occupied damper	Packaged unit, occupied damper	Packaged unit, occupied damper	Packaged unit, occupied damper																																		
	Energy recovery ventilator		No	No	No	No																																		
	DCV		No	No	No	No																																		
Heating source		Electric resistance	Gas boiler	Heat pump	Furnace	Heat pump	Furnace																																	
Cooling source		DX, 1 stage (heat pump)	DX, 1 stage	DX, 1 stage (heat pump)	DX, 1 stage																																			
Cooling COP (net of fan)		3.10	3.20	3.10	3.20																																			
Heating source		PTHP	(2) Hydronic boiler	PTHP	(2) Hydronic boiler																																			
Heating COP (net of fan)/furnace or boiler efficiency		3.10	75% E _f	3.10	75% E _f																																			
Heating pump power [W/gpm (W x s/L)]		NA	19 (300)	NA	19 (300)																																			
Heating coil heating water delta-T, °F (°C)		NA	50 (27.8)	NA	50 (27.8)																																			
Design HWST, °F (°C)		NA	180 (82.2)	NA	180 (82.2)																																			
HWST reset setpoint vs. OAT, °F (°C)		NA	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	NA	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)																																			
Heat loop pumping control		NA	2-way valves & ride pump curve	NA	2-way valves & ride pump curve																																			
	For SI: °C = (°F – 32)/1.8. HWST = Hot Water Supply Temperature, NA = Not Applicable, OAT = Outdoor Air Temperature, OSA = Outside Air																																							
	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Applied</td><td>Over-Use</td></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Design</td><td>NA</td><td>NA/DC</td><td>DC</td></tr><tr><td></td><td></td><td>x</td><td></td></tr></table>						Staff Classification	Correlates Directly	Energy Standard Applied	Over-Use		x			Design	NA	NA/DC	DC			x																			
Staff Classification	Correlates Directly	Energy Standard Applied	Over-Use																																					
	x																																							
Design	NA	NA/DC	DC																																					
		x																																						
CE#327	Adds new Section C409.7. Defines the target systems are used for developing MPF values Adds a new Table C409.7(1). Target system types for large office and school building occupancy groups. These system types are used to develop mechanical performance factors (MPF) but not directly used with TSPR compliance procedure. Adds a new Table C409.7(2). Target system types for medium and small office and retail building occupancy groups. These system types are used to develop mechanical performance factors (MPF) but not directly used with TSPR compliance procedure. Adds a new Table C409.7(3).																																							
	Target system types for hotel and multifamily building occupancy groups. These system types are used to develop mechanical performance factors (MPF) but not directly used with TSPR compliance procedure.																																							
Related Mods: CEPI-76- 21	C409.7 Target design HVAC systems. Target system descriptions in Tables C409.7(1) through C409.7(3) are provided as reference for Section C403.1.1, Exception 10. The target systems are used for developing mechanical performance factors and do not need to be programmed into TSPR software TABLE C409.7(1) TARGET BUILDING DESIGN CRITERIA HVAC COMPLEX SYSTEMS																																							
	<table><tr><th rowspan="2">BUILDING TYPE PARAMETER</th><th colspan="4">BUILDING TYPE</th></tr><tr><th>Large Office (warm)</th><th>Large Office (cold)</th><th>School (warm)</th><th>School (cold)</th></tr><tr><td></td><td>VAV/RH</td><td>VAV/RH</td><td>VAV/RH</td><td>VAV/RH</td></tr><tr><td></td><td>Water-cooled chiller</td><td>Water-cooled chiller</td><td>Water-cooled chiller</td><td>Water-cooled chiller</td></tr><tr><td></td><td>Electric reheat (PIU)</td><td>Gas boiler</td><td>Electric reheat (PIU)</td><td>Gas boiler</td></tr><tr><td>Fan control</td><td>VSD (no SP reset)</td><td>VSD (no SP reset)</td><td>VSD (no SP reset)</td><td>VSD (no SP reset)</td></tr><tr><td>Main fan power [W/cfm (W x s/L)] Proposed ≥ MERV 13</td><td>1.127 (2.388)</td><td>1.127 (2.388)</td><td>1.127 (2.388)</td><td>1.127 (2.388)</td></tr></table>						BUILDING TYPE PARAMETER	BUILDING TYPE				Large Office (warm)	Large Office (cold)	School (warm)	School (cold)		VAV/RH	VAV/RH	VAV/RH	VAV/RH		Water-cooled chiller	Water-cooled chiller	Water-cooled chiller	Water-cooled chiller		Electric reheat (PIU)	Gas boiler	Electric reheat (PIU)	Gas boiler	Fan control	VSD (no SP reset)	VSD (no SP reset)	VSD (no SP reset)	VSD (no SP reset)	Main fan power [W/cfm (W x s/L)] Proposed ≥ MERV 13	1.127 (2.388)	1.127 (2.388)	1.127 (2.388)	1.127 (2.388)
BUILDING TYPE PARAMETER	BUILDING TYPE																																							
	Large Office (warm)	Large Office (cold)	School (warm)	School (cold)																																				
	VAV/RH	VAV/RH	VAV/RH	VAV/RH																																				
	Water-cooled chiller	Water-cooled chiller	Water-cooled chiller	Water-cooled chiller																																				
	Electric reheat (PIU)	Gas boiler	Electric reheat (PIU)	Gas boiler																																				
Fan control	VSD (no SP reset)	VSD (no SP reset)	VSD (no SP reset)	VSD (no SP reset)																																				
Main fan power [W/cfm (W x s/L)] Proposed ≥ MERV 13	1.127 (2.388)	1.127 (2.388)	1.127 (2.388)	1.127 (2.388)																																				

Zonal fan power [W/ CFM (W × s/ L)]	0.35 (0.75)	NA	0.35 (0.75)	NA
Minimum zone airflow fraction	1.5 × Voz	1.5 × Voz	1.2 × Voz	1.2 × Voz
Heat/cool sizing factor	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15
Outdoor air economizer	Yes except 0–1	Yes	Yes except 0–1	Yes
Occupied OSA (= proposed)	Sum(Voz)/0.75	Sum(Voz)/0.75	Sum(Voz)/0.65	Sum(Voz)/0.65
Energy recovery ventilator efficiency ERR	NA	NA	50%	50%
ERV bypass SAT setpoint	NA	NA	No bypass	60°F (15.6°C) except 4A
DCV	Yes	Yes	Yes	Yes
% Area variable control	15%	15%	70%	70%
% Area on/off control	65%	65%	20%	20%
Cooling source	(2) Water-cooled centrif chillers	(2) Water-cooled centrif chillers	(2) Water-cooled screw chillers	(2) Water-cooled screw chillers
Cooling COP (net of fan)	ASHRAE 90.1 Appendix G, Table G3.5.3	ASHRAE 90.1 Appendix G, Table G3.5.3	ASHRAE 90.1 Appendix G, Table G3.5.3	ASHRAE 90.1 Appendix G, Table G3.5.3
Heating source (reheat)	Electric resistance	Gas boiler	Electric resistance	Gas boiler
Furnace or boiler efficiency	1.0	90% E_f	1.0	90% E_f
Condenser heat rejection	Cooling tower	Cooling tower	Cooling tower	Cooling tower
Cooling tower efficiency [gpm/hp (L/s × kW)]—See ASHRAE 90.1 Appendix G, Section G3.1.3.11	40.2 (3.40)	40.2 (3.40)	40.2 (3.40)	40.2 (3.40)
Tower turndown (> 300 ton (1060 kW))	50%	50%	50%	50%
Pump (constant flow/variable flow)	Constant flow; 10°F (5.6°C) range	Constant flow; 10°F (5.6°C) range	Constant flow; 10°F (5.6°C) range	Constant flow; 10°F (5.6°C) range
Tower approach	ASHRAE 90.1 Appendix G, Table G3.1.3.11	ASHRAE 90.1 Appendix G, Table G3.1.3.11	ASHRAE 90.1 Appendix G, Table G3.1.3.11	ASHRAE 90.1 Appendix G, Table G3.1.3.11
Cooling condenser pump power [W/gpm (W·s/ L)]	19 (300)	19 (300)	19 (300)	19 (300)
Cooling primary pump power [W/ gpm (W·s/L)]	9 (142)	9 (142)	9 (142)	9 (142)
Cooling secondary pump power [W/gpm (W·s/ L)]	13 (205)	13 (205)	13 (205)	13 (205)
Cooling coil chilled water delta-T, °F (°C)	18 (10)	18 (10)	18 (10)	18 (10)
Design chilled water supply temperature, °F (°C)	42 (5.56)	42 (5.56)	42 (5.56)	42 (5.56)
Chilled water supply temperature (CHWST) reset setpoint vs. OAT, °F (°C)	CHWS 44-54/OAT 80-60 (6.7-12.2)/26.7-15.6)	CHWS 44-54/OAT 80-60 (6.7-12.2)/26.7-15.6)	CHWS 44-54/OAT 80-60 (6.7-12.2)/26.7-15.6)	CHWS 44-54/OAT 80- 60 (6.7-12.2)/26.7-15.6)
CHW cooling loop pumping control	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD
Heating pump power [W/ gpm (W·s/L)]	16.1 (254)	16.1 (254)	19 (254)	19 (254)
Heating HW delta-T, °F (°C)	50 (27.78)	20 (11.11)	50 (27.78)	20 (11.11)
Design hot water supply temperature (HWST), °F (°C)	180 (82)	140 (60)	180 (82)	140 (60)

Hot water supply temperature (HWST) range vs. outside air temperature (OAT) range	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)
Heat loop pumping control	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD	2-way valves & pump VSD

For SI: °C = (°F – 32)/1.8.

CHW = Chilled Water, ERR= Enthalpy Recovery Ratio, NA=Not Applicable, OSA = Outside Air, PIU= Parallel Powered Induction Unit, RH = Relative Humidity, SP = Static Pressure, Voz = Outdoor airflow to the zone, VSD = Variable Speed Drive.

TABLE C409.7(2)

TARGET BUILDING DESIGN CRITERIA HVAC SIMPLE SYSTEMS

BUILDING TYPE PARAMETER	BUILDING TYPE					
	Medium Office (warm)	Medium Office (cold)	Small Office (warm)	Small Office (cold)	Retail (warm)	Retail (cold)
System type	Package VAV—electric reheat	Package VAV—hydraulic reheat	PSZ-HP	PSZ-AC	PSZ-HP	PSZ-AC
Fan control	VSD (with SP reset)	VSD (with SP reset)	Constant volume	Constant volume	2-speed	2-speed
Main fan power [W/ cfm (W x s/L)] proposed ≥ MERV 13	0.634 (1.343)	0.634 (1.343)	0.486 (1.03)	0.486 (1.03)	0.585 (1.245)	0.585 (1.245)
Zonal fan power [W/ CFM (W x s/L)]	0.35 (5.53)	NA	NA	NA	NA	NA
Minimum zone airflow fraction	1.5 x Voz	1.5 x Voz	NA	NA	NA	NA
Heat/cool sizing factor	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15
Supplemental heating availability	NA	NA	< 40°F (< 4.4°C) OAT	NA	< 40°F (< 4.4°C) OAT	NA
Outdoor air economizer	Yes except 0–1	Yes	Yes except 0–1	Yes	Yes except 0–1	Yes
Occupied OSA source	Packaged unit, occupied damper, all building use types					
Energy recovery ventilator	No	No	No	No	Yes in 0A, 1A, 2A, 3A	Yes all A, 6,7,8 CZ
ERR					50%	50%
DCV	Yes	Yes	No	No	Yes	Yes
% Area variable control	15%	15%			80%	80%
% Area on/off control	65%	65%			0%	0%
Cooling source	DX, multistage	DX, multistage	DX, 1 stage (heat pump)	DX, single stage	DX, 2 stage (heat pump)	DX, 2 stage
Cooling COP (net of fan)	3.83	3.83	3.82	3.8248	3.765	3.765
Heating source	Electric resistance	Gas boiler	Heat pump	Furnace	Heat pump	Furnace
Heating COP (net of fan)/furnace or boiler efficiency	100%	81% E _f	3.81	81% E _f	3.536	81% E _f
Heating coil HW delta-T, °F (°C)	NA	20 (11.11)	NA	NA	NA	NA
Design HWST, °F (°C)	NA	140 (60)	NA	NA	NA	NA
HWST reset setpoint vs OAT, °F (°C)	NA	HWST: 180-150/ OAT 20-50 (82-65.6/-6.7-10)	NA	NA	NA	NA
Heat loop pumping control	NA	2-way valves & ride pump curve	NA	NA	NA	NA
Heating pump power [W/gpm (W s/L)]	NA	16.1	NA	NA	NA	NA

For SI: °C = (°F – 32)/1.8.

CHW = Chilled Water, ERR = Enthalpy Recovery Ratio, HWST = Hot Water Supply Temperature, NA = Not Applicable, OAT = Outside Air Temperature, OSA = Outside Air, SP = Static Pressure, Voz = Outdoor airflow to the zone, VSD = Variable Speed Drive.

TABLE C409.7(3)

TARGET BUILDING DESIGN CRITERIA HVAC SIMPLE SYSTEMS

BUILDING TYPE PARAMETER	BUILDING TYPE			
	Hotel (warm)	Hotel (cold)	Multifamily (warm)	Multifamily (cold)
System type	PTHP	PTAC with hydronic boiler	Split HP	Split AC
Fan control	Cycling	Cycling	Cycling	Cycling
Main fan power [W/ cfm (W x s/L)]	0.300 (0.638)	0.300 (0.638)	0.246 (0.523)	0.271 (0.576)
Heat/cool sizing factor	1.25/1.15	1.25/1.15	1.25/1.15	1.25/1.15
Supplemental heating availability	< 40°F (< 4.4°C)	NA	< 40°F (< 4.4°C)	NA

Outdoor air economizer	Only CZ 2, 3	No	No	No
Occupied OSA source	DOAS	DOAS	DOAS	DOAS except 3C
Energy recovery ventilator	NA	NA	Yes	Yes except 3C
ERR	NA	NA	60%	60%
DCV	Yes	Yes	No	No
% Area variable control	70%	70%		
% Area variable control	0%	0%		
Cooling source	DX, 1 stage (heat pump)	DX, 1 stage	DX, 1 stage (heat pump)	DX, 1 stage
Cooling COP (net of fan)	3.83	3.83	3.823	3.6504
Heating source	Heat	(2) Hydronic boiler	Heat pump	Furnace
Heating COP (net of fan)/furnace or boiler efficiency	3.44	81% η_f	3.86	80% AFUE
Heating pump power (W/ gpm (W·s/L))	NA	16.1	NA	NA

Heating coil heating water delta-T, °F (°C)	NA	20 (11.11)	NA	NA
Design HWST, °F (°C)	NA	140 (60)	NA	NA
HWST reset setpoint vs. OAT, °F (°C)	NA	HWST: 180-150/OAT 20-50 (82-65.6/ -6.7-10)	NA	NA
Heat loop pumping control	NA	2-way valves & ride pump curve	NA	NA

For SI: °C = (°F – 32)/1.8.

DOAS = Dedicated Outdoor Air System, ERR = Enthalpy Recovery Ratio, HWST = Hot Water Supply Temperature, NA = Not Applicable, OAT = Outdoor Air Temperature, OSA = Outside Air

Staff Classification	Correlates Directly	Energy Standard Reached	Over lap
	x		
Action	AS	AS/EC	EC
	x		

CE#328 Replaced the text "total building performance" with "simulated building performance."

Related Mods:
CEPI-24-21 Part I

C502.1 General. *Additions* to an existing building, building system or portion thereof shall conform to the provisions of this code as those provisions relate to new construction without requiring the unaltered portion of the existing building or building system to comply with this code. *Additions* shall not create an unsafe or hazardous condition or overload existing building systems. An *addition* shall be deemed to comply with this code if the *addition* alone complies or if the existing building and *addition* comply with this code as a single building.

C502.2 Change in space conditioning. Any nonconditioned or low-energy space that is altered to become *conditioned space* shall be required to comply with **Section C502**.

Exceptions:

- Where the component performance alternative in **Section C402.1.4** is used to comply with this section, the proposed UA shall be not greater than 110 percent of the target UA.
- Where the **total simulated building performance option in Section C407** is used to comply with this section, the annual energy cost of the proposed design shall be not greater than 110 percent of the annual energy cost otherwise permitted by **Section C407.2**.

Staff Classification	Correlates Directly	Energy Standard Reached	Over lap
	x		
Action	AS	AS/EC	EC
	x		

CE#329

Adds new Section C502.3.7.
Additional energy efficiency credit requirement for building additions.
There are five exceptions to this requirement based on building occupancy group, additions gross floor size less than 1000 ft² and less than 50% of existing conditioned floor size, HVAC equipment type, additions that don't increase the conditioned floor area, and compliance with Section C407. **Adds new Section C502.3.8.**
Additions must comply with renewable energy system requirements of new Section C405.15.

Related Mods:
CEPI- 217-21,
CE2D-51- 23

C502.3.7 Additional energy efficiency credit requirements. *Additions* shall comply with sufficient measures from **Sections C406.2** and **C406.3** to achieve not less than 50 percent of the number of required efficiency credits from **Table C406.1.1(1)** based on building occupancy group and climate zone. Where a project contains multiple occupancies, credits from **Table C406.1.1** for each building occupancy shall be weighted by the gross floor area to determine the project weighted average energy credits required. Accessory occupancies shall be included with the primary occupancy group for purposes of this section. *Alterations* to the existing building that are not part of the *addition*, but are permitted with an *addition*, shall be permitted to be used to achieve the required credits.

Exceptions:

- Buildings in Group U (Utility and Miscellaneous), Group S (Storage), Group F (Factory), Group H (High-Hazard).
- Additions* less than 1,000 square feet (93 m²) and less than 50 percent of existing floor area.
- Additions* that do not include the *addition* or replacement of equipment covered by **Tables C403.3.2(1) through C403.3.2(16)** or **Section C404.2**.
- Additions* that do not increase *conditioned space*.
- Where the *addition* alone or the existing building and *addition* together comply with **Section C407**.

C502.3.8 Renewable energy systems. *Additions* shall comply with **Section C405.15** for the *addition* alone.

Staff Classification	Correlates Directly	Energy Standard Reached	Over lap
	x		
Action	AS	AS/EC	EC
	x		

FSEC – Anticipated energy impact on FBC-EC – Decrease

CE#330 Revised of Section C503.1. Removes exception items #3 and #4 and adds two new exceptions.

Related Mods:
CED1-92-22, CEPI-221-21

SECTION C503 ALTERATIONS

C503.1 General. *Alterations* to any building or structure shall comply with the requirements of **Section C503**. *Alterations* shall be such

that the existing building or structure is not less conforming to the provisions of this code than the existing building or structure was prior to the *alteration*. *Alterations* to an existing building, building system or portion thereof shall conform to the provisions of this code as those provisions relate to new construction without requiring the unaltered portions of the existing building or building system to comply with this code. *Alterations* shall not create an unsafe or hazardous condition or overload existing building systems.

	<p>Exception: The following alterations need not comply with the requirements for new construction, provided that the energy use of the building is not increased:</p> <ol style="list-style-type: none">1. Storm windows installed over existing fenestration .2. Surface-applied window film installed on existing single-pane fenestration assemblies reducing solar heat gain, provided that the code does not require the glazing or fenestration to be replaced.3. Existing ceiling-wall or floor cavities exposed during construction, provided that these cavities are filled with insulation:4. Construction where the existing roof-wall or floor cavity is not exposed: <p>5.3- Roof-recover :</p> <ol style="list-style-type: none">4. Roof replacement where roof assembly insulation is integral to or located below the structural roof deck.6.5- Air barriers shall not be required for roof-recover and roof-replacement where the alterations or renovations to the building do not include alterations , renovations or repairs to the remainder of the building thermal envelope .6. An existing building undergoing alterations that complies with Section C407.																		
	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th><th>DEC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap		X			Action	AS	AS/EC	EC	DEC				X	
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap																
	X																		
Action	AS	AS/EC	EC	DEC															
			X																
CE#331	<p>C503.2. Renames the section title by adding the text "thermal." Revises and clarifies the building thermal envelope U-value requirement for alterations and edits the exceptions. This change requires walls and floors alteration to meet the requirements of Section C402.1 and air barriers to meet the requirements of Section C402.6.1. It may slightly increase the stringency for walls, floors and air barrier alterations.</p> <p>C503.2.1. Renames the Section title and revises the code provisions for clarity of applicability.</p>																		
Related Mods: CEPI- 221, CED1-92-22, CED1- 144-22, CED1- 147-22, CED1- 145-22, CED1- 146-22, CEPI- 225-21, CEPI- 221-21, CEPI- 226-21,	<p>C503.2 Building thermal envelope.</p> <p>New building envelope assemblies that are part of the alteration shall comply with Sections C402.1 through C402.6. Alterations— of existing building thermal envelope— assemblies shall comply with this section. New building thermal envelope assemblies that are part of the alteration shall comply with Section C402.1. An area-weighted average U-factor for new and altered portions of the building thermal envelope shall be permitted to satisfy the U-factor requirements in Table C402.1.4. The existing R-value of insulation shall not be reduced or the U-factor of a building thermal envelope assembly be increased as part of a building thermal envelope alteration except where complying with Section C407.</p> <p>Exception: Where the existing building exceeds the fenestration area limitations of Section C402.5.1 prior to alteration, the building is exempt from Section C402.5.1 provided that there is not an increase in fenestration area:</p> <p>C503.2.1 Roof replacement— ceiling and attic alterations. Roof replacements shall comply with Section C402.1.3, C402.1.2, C402.1.4 or C407 where the existing roof assembly is part of the building thermal envelope and contains insulation entirely above the roof deck. In no case shall the R-value of the roof insulation be reduced or the U-factor of the roof assembly be increased as part of the roof replacement insulation complying with Sections C402.1 and C402.2.1, or an approved design that minimizes deviation from the insulation requirements; shall be provided for the following alterations:</p> <ol style="list-style-type: none">1. An alteration of roof/ceiling construction other than reroofing where existing insulation located below the roof deck or on an attic floor above conditioned space does not comply with Table C402.1.2.2. Roof replacement or a roof alteration that includes removing and replacing the roof covering, where the roof assembly includes insulation entirely above the roof deck.																		
CE2D-69-23	<p>Exceptions: Where compliance with Section C402.1 cannot be met due to limiting conditions on an existing roof, an approved design shall be submitted with the following:</p> <ol style="list-style-type: none">1. Construction documents that include a report by a registered design professional or an approved source documenting details of the limiting conditions affecting compliance with the insulation requirements.2. Construction documents that include a roof design by a registered design professional or an approved source that minimizes deviation from the insulation requirements. <p>insulation requirements.</p> <ol style="list-style-type: none">3. Conversion of unconditioned attic space into conditioned space .4. Replacement of ceiling finishes exposing cavities or surfaces of the roof/ceiling construction.																		
	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td></td><td></td><td>X</td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th><th>DEC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table> <p>Original text of mod is not consistent with that of the 2023 FBC – EC.</p> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap				X	Action	AS	AS/EC	EC	DEC				X	
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap																
			X																
Action	AS	AS/EC	EC	DEC															
			X																
CE#332	<p>Adds new Section C503.2.4. Adds new Section C503.2.5. Adds new Section C503.2.6. Adds new Section C503.2.7.</p>																		
Related Mods: CEPI- 221-21	<p>C503.2.4 Above-grade wall alterations. Above-grade wall alterations shall comply with the following:</p> <ol style="list-style-type: none">1. Where wall cavities are exposed, the cavity shall be filled with cavity insulation complying with Section C303.1.4. New cavities created shall be insulated in accordance with Section C402.1 or an approved design that minimizes deviation from the insulation requirements.2. Where exterior wall coverings and fenestration are added or replaced for the full extent of any exterior wall assembly on one or more elevations of the building , insulation shall be provided where required in accordance with one of the following:<ol style="list-style-type: none">2.1. An R-value of continuous insulation not less than that designated in Table C402.1.3 for the applicable above-grade wall type and existing cavity insulation R-value , if any;2.2. An R-value of not less than that required to bring the above-grade wall into compliance with Table C402.1.2; or,2.3. An approved design that minimizes deviation from the insulation requirements of Section C402.1.3. Where Items 1 and 2 apply, the insulation shall be provided in accordance with Section C402.1. <p>Where any of the above requirements are applicable, the above-grade wall alteration shall comply with Sections 1402.2 and 1404.3 of the International Building Code .</p>																		
	<p>C503.2.5 Floor alterations. Where an alteration to a floor or floor overhang exposes cavities or surfaces to which insulation can be applied, and the floor or floor overhang is part of the building thermal envelope , the floor or floor overhang shall be brought into compliance with Section C402.1 or an approved design that minimizes deviation from the insulation requirements. This requirement applies to floor alterations where the floor cavities or surfaces are exposed and unobstructed prior to construction.</p> <p>C503.2.6 Below-grade wall alterations. Where unconditioned below-grade space is changed to conditioned space , walls enclosing such conditioned space shall be insulated where required in accordance with Section C402.1. Where the below-grade space is conditioned space and where walls enclosing such space are altered, they shall be insulated where required in accordance with Section C402.1.</p> <p>C503.2.7 Air barrier. Altered building thermal envelope assemblies shall be provided with an air barrier in accordance with Section C402.6.1. Such air barrier need not be continuous with unaltered portions of the building thermal envelope . Testing requirements of Section C402.6.1.2 shall not be required.</p>																		
	<table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Modified</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>EC</th><th>DEC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table> <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>	Staff Classification	Correlates Directly	Energy Standard Modified	Over lap		X			Action	AS	AS/EC	EC	DEC				X	
Staff Classification	Correlates Directly	Energy Standard Modified	Over lap																
	X																		
Action	AS	AS/EC	EC	DEC															
			X																
CE#333	<p>Removes reference to Section C408 and moves it to the new subsection C503.3.2 for clarity. Adds new Section C503.3.2. Adds compliance requirement with relevant specific subsections C408.2.2, C408.2.3, and C408.2.5. This section has exceptions based on building size and type. The testing requirement may increase the stringency since it requires testing the unaltered portions of mechanical systems in existing buildings. Adds new Section C503.3.3. It requires existing ductwork serving new equipment, and additions and alterations must be tested. Adds new Section C503.3.4. Requires that thermostatic controls comply with current control requirements when equipment is replaced. This change is cost-effective. Adds new Section C503.3.5. Right-sized equipment, often smaller, generally has lower construction costs and saves operating energy costs.</p>																		

Related Mods: CEPI- 229-21	<p>C503.3 Heating and cooling systems. New heating, cooling and <i>duct systems</i> that are part of the <i>alteration</i> shall comply with Section C403. and C408:</p> <p>C503.3.1 Economizers. New cooling systems that are part of <i>alteration</i> shall comply with Section C403.5.</p> <p>C503.3.2 Mechanical system acceptance testing. Where an <i>alteration</i> requires compliance with Section C403 or any of its subsections, mechanical systems that serve the <i>alteration</i> shall comply with Sections C408.2.2, C408.2.3 and C408.2.5.</p> <p>Exceptions:</p> <ol style="list-style-type: none"><i>Buildings</i> with less than 10,000 square feet (929 m²) and a combined heating, cooling and service water-heating capacity of less than 960,000 Btu/h (281 kW).Systems included in Section C403.5 that serve individual <i>dwelling units</i> and																		
	<p><i>sleeping units</i> .</p> <p>C503.3.3 Duct testing. <i>Ducts</i> and plenums designed to operate at static pressures not less than 3 inches water gauge (747 Pa) that serve an <i>alteration</i> shall be tested in accordance with this section where the <i>alteration</i> includes any of the following:</p> <ol style="list-style-type: none">Twenty-five percent or more of the total length of the <i>ducts</i> in the system are relocated.The total length of all <i>ducts</i> in the system is increased by 25 percent or more. <p><i>Ducts</i> and plenums shall be leak tested in accordance with the SMACNA <i>HVAC Air Duct Leakage Test Manual</i> and shown to have a rate of <i>air leakage</i> (CL) less than or equal to 12.0 as determined in accordance with Equation 4-7 of Section C403.13.2.3. Documentation shall be available demonstrating that representative sections totaling not less than 25 percent of the <i>duct</i> area have been tested and that all tested sections comply with the requirements of this section.</p> <p>C503.3.4 Controls. New heating and cooling equipment that is part of the <i>alteration</i> shall be provided with controls that comply with the control requirements in Sections C403.4 and C403.5 other than the requirements of Sections C403.4.3.3 and C403.4.4.</p> <p>Exceptions:</p> <ol style="list-style-type: none">Systems with <i>direct digital control</i> of individual <i>zones</i> reporting to a central control panel.The replacement of individual components of multiple-zone VAV systems. <p>C503.3.5 System sizing. New heating and cooling equipment that is part of an <i>alteration</i> shall be sized in accordance with Section C403.3.1 based on the existing building features as modified by the <i>alteration</i> .</p> <p>Exceptions:</p> <ol style="list-style-type: none">Where it has been demonstrated to the <i>code official</i> that compliance with this section would result in heating or cooling equipment that is incompatible with the rest of the heating or cooling system.Where it has been demonstrated to the <i>code official</i> that the additional capacity will be needed in the future.																		
	<div><div>FSEC – Anticipated energy impact on FBC-EC – Decrease</div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Applied</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Applied	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Applied	Over lap																
	X																		
Action	AS	AS/EC	D	D/EC															
			X																
CE#334	Adds new Section C503.3.6. Adds new Table C503.3.6.																		
Related Mods:	<p>C503.3.6 Replacement or added roof-mounted mechanical equipment. For roofs with insulation entirely above the roof deck and where existing roof-mounted mechanical equipment is replaced or new equipment is added, and the existing roof does not comply with the insulation requirements for new construction in accordance with Sections C402.1 and C402.2.1 curbs for</p>																		
CED1- 148-22	<p>added or replaced equipment shall be of a height necessary to accommodate the future addition of above-deck roof insulation to be installed in accordance with Section C503.2.1. Item 2. Alternatively, the curb height shall comply with Table C503.3.6. Curb height shall be the distance measured from the top of the curb to the top of the roof deck.</p> <p>TABLE C503.3.6 ROOF-MOUNTED MECHANICAL EQUIPMENT CURB HEIGHTS</p> <table><tr><th>CLIM Category</th><th>CURB HEIGHT, MINIMUM</th></tr><tr><td>0, 1, 2 and 3</td><td>16 inches</td></tr><tr><td>4, 5 and 6</td><td>17 inches</td></tr><tr><td>7 and 8</td><td>18 inches</td></tr></table> <p>For SI: 1 inch = 25.4 mm.</p>	CLIM Category	CURB HEIGHT, MINIMUM	0, 1, 2 and 3	16 inches	4, 5 and 6	17 inches	7 and 8	18 inches										
CLIM Category	CURB HEIGHT, MINIMUM																		
0, 1, 2 and 3	16 inches																		
4, 5 and 6	17 inches																		
7 and 8	18 inches																		
	<div><div></div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Applied</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Applied	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Applied	Over lap																
	X																		
Action	AS	AS/EC	D	D/EC															
			X																
CE#335	<p>Removes reference to Section C408 and moves the requirement to the new subsection C503.4.1.</p> <p>Adds new subsection C503.4.1. Adds compliance requirement with specific subsections C408.2.3 and C408.2.5. This change may increase the stringency of the SHW testing requirements since it requires testing the unaltered portions of hot water systems in existing buildings.</p>																		
Related Mods: CEPI- 229-21	<p>C503.4 Service hot water systems. New service hot water systems that are part of the <i>alteration</i> shall comply with Section C404 and C408:</p> <p>C503.4.1 Service hot water system acceptance testing. Where an <i>alteration</i> requires compliance with Section C404 or any of its subsections, service hot water systems that serve the <i>alteration</i> shall comply with Sections C408.2.3 and C408.2.5.</p> <p>Exceptions:</p> <ol style="list-style-type: none"><i>Buildings</i> with less than 10,000 square feet (929 m²) and a combined heating, cooling and service water-heating capacity of less than 960,000 Btu/h (281 kW).Systems included in Section C403.5 that serve individual <i>dwelling units</i> and <p><i>sleeping units</i> .</p>																		
	<div><div>FSEC – Anticipated energy impact on FBC-EC – Decrease</div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Applied</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><th>Action</th><th>AS</th><th>AS/EC</th><th>D</th><th>D/EC</th></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Applied	Over lap		X			Action	AS	AS/EC	D	D/EC				X	
Staff Classification	Correlates Directly	Energy Standard Applied	Over lap																
	X																		
Action	AS	AS/EC	D	D/EC															
			X																
CE#336	Removes the exception. Improves lighting alteration code clarity and enforceability. No change in stringency. Adds new subsection C503.5.1.																		
	Adds new subsection C503.5.2.																		
Related Mods:	<p>C503.5 Lighting systems. New lighting systems that are part of the <i>alteration</i> shall comply with Sections C503.5.1 and C503.5.2.</p> <p>Exception: Alterations that replace less than 10 percent of the luminaires in a space, provided that such alterations do not increase the installed interior lighting power.</p>																		
CECD1- 2-22, CE2D-70- 23 CECD1- 2-22, CE2D-71- 23, CE2D-71- 23	<p>C503.5.1 Interior lighting and controls. <i>Alterations</i> to interior spaces, lighting or controls shall comply with the following:</p> <ol style="list-style-type: none">Where an <i>alteration</i> of an interior space includes the addition or relocation of full height partitions, the space shall comply with Sections C405.2, C405.3 and C408.3.Where the lighting within interior spaces is altered, those spaces shall comply with Sections C405.2, C405.3 and C408.3.Where the lighting controls within interior spaces are altered, those spaces shall comply with Sections C405.2 and C408.3.																		

		<p>Exception: Compliance with Section C405.2.8 is not required for alterations .</p> <p>C503.5.2 Exterior lighting and controls. Alterations to exterior lighting and controls shall comply with the following:</p> <ol style="list-style-type: none">Where the connected exterior lighting power is increased by more than 400 watts, all exterior lighting, including lighting that is not proposed to be altered, shall comply with Section C405.5.Where the combined power of added and replacement luminaires is more than 400 watts, all lighting that is added or altered shall be controlled in accordance with Sections C405.2 and C408.3. Exception: Individual luminaires less than 50 watts provided they pass functional tests verifying automatic off where daylight is present.Where portions of exterior lighting controls are added or altered, those portions shall comply with Sections C405.2 and C408.3.	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>OLC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over top		X			Action	AS	ALC	D	OLC				X		
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																			
	X																					
Action	AS	ALC	D	OLC																		
			X																			
CE#337	Adds new Section C503.6. Alterations that are substantial improvements must comply with efficiency measures from Sections C406.2, C406.3, or both to achieve the required energy credits specified in Table C406.1.1(1). There are four exceptions to the requirements of this section. This change increases the stringency but is cost-effective.																					
Related Mods: CED1-92-22,	<p>C503.6 Additional energy efficiency credit requirements for alterations. Alterations that are substantial improvements shall comply with measures from Sections C406.2, C406.3 or both to earn the number of required credits specified in Table C406.1.1(1) based on building occupancy group and climate zone . Where a project contains multiple occupancies, credits specified in Table C406.1.1(1) for each building occupancy shall be weighted by the gross conditioned floor area to determine the weighted average credits required. Accessory occupancies other than Group F or H shall be included with the primary occupancy group for the purposes of this section.</p> <p>Exceptions:</p> <ol style="list-style-type: none">Alterations that do not contain conditioned space .Portions of buildings devoted to manufacturing or industrial use.Alterations to buildings where the building after the alteration complies with Section C407.Alterations that are permitted with an addition complying with Section C502.3.7. <p>FSEC – Anticipated energy impact on FBC-EC – Decrease</p>																					
CED1-149-22, CED1-203-22, CEPI-217-21	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>OLC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>				Staff Classification	Correlates Directly	Energy Standard Needed	Over top		X			Action	AS	ALC	D	OLC				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																			
	X																					
Action	AS	ALC	D	OLC																		
			X																			
CE#338	Replaced the text "building envelope" with "building thermal envelope."																					
Related Mods: CED1-92-22	<p>C504.2 Application. For the purposes of this code, the following shall be considered to be repairs :</p> <ol style="list-style-type: none">Glass-only replacements in an existing sash and frame.Roof repairs .Air barriers shall not be required for roof repair where the repairs to the building do not include alterations , renovations or repairs to the remainder of the building thermal envelope .Replacement of existing doors that separate conditioned space from the exterior shall not require the installation of a vestibule or revolving door, provided that an existing vestibule that separates a conditioned space from the exterior shall not be removed.Repairs where only the bulb, the ballast or both within the existing luminaire in a space are replaced, provided that the replacement does not increase the installed interior lighting power.																					
	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>OLC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>				Staff Classification	Correlates Directly	Energy Standard Needed	Over top		X			Action	AS	ALC	D	OLC				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																			
	X																					
Action	AS	ALC	D	OLC																		
			X																			
CE#339	<p>Revises the code language that spaces undergoing a change in occupancy from Group F, H, S, or U occupancy classification group must comply with Section C503 Alterations. Also removes exception item #1, which provides exemptions based on the component performance alternative method, and edits exception item #2 by replacing the text "total" with "simulated."</p> <p>Adds new subsection C505.1.1. Created by moving existing provisions from Section C505.1 for alterations and occupancy changes. No change in stringency.</p> <p>Adds new subsection C505.1.2. Created by moving existing provisions from Section C505.1 for buildings going alterations and occupancy changes for a portions of an existing buildings. No change in stringency.</p>																					
Related Mods:	<p>C505.1 General. Spaces undergoing a change in occupancy from Group F, H, S or U occupancy classification shall comply with Section C503. Buildings or portions of buildings undergoing a change of occupancy without alterations s shall comply with Section C505.2. that would result in an increase in demand for either fossil fuel or electrical energy shall comply with this code. Where the use in a space change</p>																					
CED1-12-22, CEPI-232-21, CEPI-24-21 Part I	<p>C405.3.2(1) or C405.3.2(2), the installed lighting wattage shall comply with Section C405.3. Where the space undergoing a change in occupancy or use is in a building with a fenestration area that exceeds the limitations of Section C402.5.1, the space is exempt from Section C402.5.1 provided that there is not an increase in fenestration area.</p> <p>Exceptions:</p> <ol style="list-style-type: none">Where the component performance alternative in Section C402.1.4 is used to comply with this section, the proposed UA shall not be greater than 110 percent of the target UA.Where the total simulated building performance option in Section C407 is used to comply with this section, the annual energy cost of the proposed design shall be not greater than 110 percent of the annual energy cost otherwise permitted by Section C407.3. <p>C505.1.1 Alterations and change of occupancy. Alterations made concurrently with any change of occupancy shall be in accordance with Section C503.</p> <p>C505.1.2 Portions of buildings. Where changes in occupancy and use are made to portions of an existing building, only those portions of the building shall be required to comply with Section C505.2.</p>																					
	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>D</td><td>OLC</td></tr><tr><td></td><td></td><td></td><td>X</td><td></td></tr></table>				Staff Classification	Correlates Directly	Energy Standard Needed	Over top		X			Action	AS	ALC	D	OLC				X	
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																			
	X																					
Action	AS	ALC	D	OLC																		
			X																			
CE#340	<p>Adds new Section C505.2. Created compliance requirement for thermal envelope, mechanical systems, service water heating system, and lighting under separate new subsections for an existing buildings without alterations. Adds new subsection C505.2.1. Created by moving from Section C505.1. No change in stringency. Adds new subsection C505.2.2. Where a change of occupancy results in the same or increased energy use intensity, the systems serving the building or space undergoing the change must comply with Section C403. No change in stringency. It is not clear what the reference EUI is prior to the change. Adds new Table C505.2.2.</p>																					
Related Mods: CEPI-232-21, CED1-92-22, CED1-110-22	<p>C505.2 Energy use Intensities. Building thermal envelope , space heating, cooling, ventilation , lighting and service water heating shall comply with Sections C505.2.1 through C505.2.4.</p> <p>Exceptions:</p> <ol style="list-style-type: none">Where it is demonstrated by analysis approved by the code official that the change will not increase energy use intensity .Where the occupancy or use change is less than 5,000 square feet (465 m²) in area.																					

	<p>C505.2.1 Building thermal envelope. Where a <i>change of occupancy</i> or use is made to a whole <i>building</i> that results in a fenestration area greater than the maximum fenestration area allowed by Section C402.5.1, the <i>building</i> shall comply with Section C402.1.4, with a proposed UA that shall be not greater than 110 percent of the target UA.</p> <p>Exception: Where the <i>change of occupancy</i> or use is made to a portion of the <i>building</i>, the new occupancy is exempt from Section C402.5.1, provided that there is not an increase in fenestration area.</p> <p>C505.2.2 Building mechanical systems. Where a <i>change of occupancy</i> or use results in the same or increased <i>energy use intensity</i> rank as specified in Table C505.2.2, the systems serving the <i>building</i> or space undergoing the change shall comply with Section C403.</p> <p>TABLE C505.2.2 BUILDING MECHANICAL SYSTEMS</p>																
	<table><tr><th>ENERGY USE INTENSITY</th><th>INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE</th></tr><tr><td>High</td><td>A-2, B (laboratories), I-2</td></tr><tr><td>Medium</td><td>A-1, A-3,^a A-4, A-5, B,^b E, I-1, I-3, I-4, M, R-4</td></tr><tr><td>Low</td><td>A-3 (places of religious worship), R-1, R-2, R-3,^c S-1, S-2</td></tr></table> <p>a. Excluding places of religious worship. b. Excluding laboratories.</p>	ENERGY USE INTENSITY	INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE	High	A-2, B (laboratories), I-2	Medium	A-1, A-3, ^a A-4, A-5, B, ^b E, I-1, I-3, I-4, M, R-4	Low	A-3 (places of religious worship), R-1, R-2, R-3, ^c S-1, S-2								
ENERGY USE INTENSITY	INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE																
High	A-2, B (laboratories), I-2																
Medium	A-1, A-3, ^a A-4, A-5, B, ^b E, I-1, I-3, I-4, M, R-4																
Low	A-3 (places of religious worship), R-1, R-2, R-3, ^c S-1, S-2																
	<p>c. Buildings three stories or less in height above grade plane shall comply with Section R505</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D, DI/EC</td></tr><tr><td></td><td></td><td></td><td>E</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D, DI/EC				E
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
	X																
Action	AS	AS/EC	D, DI/EC														
			E														
CE#341	<p>Adds new subsection C505.2.3.</p> <p>Where a change of occupancy results in the same or increased energy use intensity, the SWH systems serving the building or space undergoing the change must comply with Section C404. No change in stringency.</p> <p>Adds new Table C505.2.3.</p> <p>Adds new subsection C505.2.4. Where a change of occupancy results in the same or increased energy use intensity, the lighting systems serving the building or space undergoing the change must comply with Section C405 with the exception of Sections C405.2.6 and C405.4. No change in stringency.</p>																
Related Mods: CEPI- 232-21	<p>C505.2.3 Service water heating. Where a <i>change of occupancy</i> or use results in the same or increased <i>energy use intensity</i> rank as specified in Table C505.2.3, the <i>service water heating</i> systems serving the <i>building</i> or space undergoing the change shall comply with Section C404.</p> <p>TABLE C505.2.3 SERVICE WATER HEATING</p>																
	<table><tr><th>ENERGY USE INTENSITY RANK</th><th>INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE</th></tr><tr><td>High</td><td>A-2, I-1, I-2, R-1</td></tr><tr><td>Low</td><td>All other occupancies and uses</td></tr></table>	ENERGY USE INTENSITY RANK	INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE	High	A-2, I-1, I-2, R-1	Low	All other occupancies and uses										
ENERGY USE INTENSITY RANK	INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE																
High	A-2, I-1, I-2, R-1																
Low	All other occupancies and uses																
	<p>C505.2.4 Lighting. Where a <i>change of occupancy</i> or use results in the same or increased <i>energy use intensity</i> rank as specified in Table C505.2.4, the lighting systems serving the <i>building</i> or space undergoing the change shall comply with Section C405 except for Sections C405.2.6 and C405.4.</p> <p>TABLE C505.2.4 LIGHTING</p> <p>a. Excluding laboratories and outpatient healthcare. b. Buildings three stories or less in height above grade plane shall comply with Section R505.</p> <p>c. Excluding courtrooms.</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D, DI/EC</td></tr><tr><td></td><td></td><td></td><td>E</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D, DI/EC				E
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
	X																
Action	AS	AS/EC	D, DI/EC														
			E														
CE#342																	
Related Mods:	<p>AERC Attachments Energy Rating Council 355 Lexington Ave 15th Floor New York, NY 10017 AERC 1—2017: Procedures for Determining Energy Performance Properties of Fenestration Attachments</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D, DI/EC</td></tr><tr><td></td><td></td><td></td><td>E</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D, DI/EC				E
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
	X																
Action	AS	AS/EC	D, DI/EC														
			E														
CE#343																	
Related Mods:	<p>AHAM ANSI/AHAM RAC-1—20152020—Room Air-Conditioners—Table C403.3-2(4)</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D, DI/EC</td></tr><tr><td></td><td></td><td></td><td>E</td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D, DI/EC				E
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
	X																
Action	AS	AS/EC	D, DI/EC														
			E														
	<table><tr><th>ENERGY USE INTENSITY RANK</th><th>INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE</th></tr><tr><td>High</td><td>B (laboratories), B (outpatient healthcare), I-2, M</td></tr><tr><td>Medium</td><td>A-2, A-3 (courtrooms), B,^a I-1, I-3, I-4, R-1, R-2, R-3,^b R-4, S-1, S-2</td></tr><tr><td>Low</td><td>A-1, A-3,^c A-4, E</td></tr></table>	ENERGY USE INTENSITY RANK	INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE	High	B (laboratories), B (outpatient healthcare), I-2, M	Medium	A-2, A-3 (courtrooms), B, ^a I-1, I-3, I-4, R-1, R-2, R-3, ^b R-4, S-1, S-2	Low	A-1, A-3, ^c A-4, E								
ENERGY USE INTENSITY RANK	INTERNATIONAL BUILDING CODE OCCUPANCY CLASSIFICATION AND USE																
High	B (laboratories), B (outpatient healthcare), I-2, M																
Medium	A-2, A-3 (courtrooms), B, ^a I-1, I-3, I-4, R-1, R-2, R-3, ^b R-4, S-1, S-2																
Low	A-1, A-3, ^c A-4, E																
CE#344																	

Related Mods:	AHRI
	210/240—2017 and 2023 (2020)—Performance Rating of Unitary Air-conditioning and Air-source Heat Pump Equipment Table C403.3.2(4) Table C403.3.2(2) Table C403.3.2(8) Table C403.3.2(9)
	310/380—2017 (CSA-C744-17): Packaged Terminal Air Conditioners and Heat Pumps
	Table C403.3.2(4)
	340/360—2019 (2022)—Performance Rating of Commercial and Industrial Unitary Air-conditioning and Heat Pump Equipment Table C403.3.2(1) Table C403.3.2(3)
	365 (I-P)—2009: Commercial and Industrial Unitary Air-conditioning Condensing Units
	Table C403.3.2(1)
	390 (I-P)—2003: Performance Rating of Single Package Vertical Air-conditioners and Heat Pumps C403.3.2(4) 400 (I-P)—2015: Performance Rating of Liquid to Liquid Heat Exchangers
	C403.3.2
	440 (I-P)—2008 (2019)—Performance Rating of Room Fan Coils—with Addendum 1
	C403.13.3
	460—2005: Performance Rating of Remote Mechanical-draft Air-cooled Refrigerant Condensers Table C403.3.2(7)
	550/590 (I-P)—2018 (2022)—Performance Rating of Water-chilling and Heat Pump Water-heating Packages Using the Vapor-Compression Cycle Table C403.3.2(3) Table C403.3.2(15)
	560—2018 (2020)—Absorption Water-Chilling and Water-Heating Packages
	Table C403.3.2(3) Table C403.3.2(15)
	640 (I-P)—1998: Performance Rating of Unit Ventilators
	C403.13.3
	910 (I-P)—2014: Performance Rating of Indoor Pool Dehumidifiers
	Table C403.3.2(11)
	920 (I-P)—2020: Performance Rating of Direct Expansion-Dedicated Outdoor Air System Units (with Addendum 1) Table C403.3.2(12) Table C403.3.2(13)
	920—2015 (I-P)—Performance Rating of DX-Dedicated Outdoor Air System Units
	TS
	920—2015 (I-P)—Performance Rating of DX-Dedicated Outdoor Air System Units
	TS
	1200 (I-P)—2013 (2022)—Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets Table C403.12.4
	1230—2014 (2021)—Performance Rating of Variable-Refrigerant-Flow (VRF) Multi-split Air-Conditioning and Heat Pump Equipment (with Addendum 1) 1250 (I-P)—2014 (2020)—Standard for Performance Rating in Walk-in Coolers and Freezers
	Table C403.12.2.1(3)
	1360 (I-P)—2017: Performance Rating of Computer and Data Processing Room Air Conditioners Table C403.3.2(10) Table C403.3.2(16)
	1380 (I-P)—2019: Demand Response through Variable Capacity HVAC Systems in Residential and Small Commercial Applications C403.4.6.1 ANSI/AHRI 1300-2013(R2023)(I-P): Performance Rating of Commercial Heat Pump Water Heaters C406.2.3.1.2
	ASHRAE/ANSI/AHRU/ISO 13256-1 (2012): Water-to-Air and Brine-to-Air Heat Pumps—Testing and Rating for Performance Table C403.3.2(14)
	ASHRAE/ANSI/AHRU/ISO 13256-2 (2012): Water-to-Water and Brine-to-Water Heat Pumps—Testing and Rating for PerformanceTable

CE#345

Related

Mods:

CE#346

AISI

American Iron and Steel Institute
25 Massachusetts Avenue, NW, Suite 800
Washington, DC 20001

AISI S250—22: North American Standard for Thermal Transmittance of Building Envelopes with Cold-Formed Steel Framing, with Supplement 1, dated 2022

Staff Classification	Correlates Directly	Energy Standard	Overlap
	X		

Action	AS	AS/IC	D	D/IC
	x			

Staff Classification	Correlates Directly	Energy Standard Needed	Overlap
	X		

Action	AS	AS/IC	D	D/IC
	x			

Related

Mods:

CE#347

AMCA

208—18: Calculation of the Fan Energy Index

C403.8.3C403.9.1

5000—18: Laboratory Methods for Testing Dampers for Rating C403.7.7

ANSI/AMCA

220—19 (21)—Laboratory Methods of Testing Air Curtain Units for Aerodynamic Performance Rating C403.6.6 ANSI/AMCA 230—15 (22)—Laboratory Methods of Testing Air-Circulating Fans for Rating and Certification C403.9

Staff Classification	Correlates Directly	Energy Standard Needed	Overlap
	X		

Action	AS	AS/IC	D	D/IC
	x			

Related

Mods:

ANSI

American National Standards Institute 25 West 43rd Street, 4th Floor New York, NY 10036

ANSI Z21.47—2016/CSA 2.3—2016 (21)—Gas-Fired Central Furnaces—Table C403.3.2(5)

ANSI Z83.8—2016/CSA 2.6—2016: Gas Unit Heater, Gas Packaged Heaters, Gas Utility Heaters And Gas-Fired Duct Furnaces Table C403.3.2(5) ANSI/CTA-2045-A—2018: Modular Communications Interface for Energy Management

C403.4.6.2C406.3

ANSI/CTA-2045-B—2018: Modular Communications Interface for Energy Management C406.3.7

ANSI/CTA-2045-B—2019: Modular Communications Interface for Energy Management C403.4.6.2

ANSI/CTA-2045-B—2021: Modular Communications Interface for Energy Management Table C404.10

ANSI/NEMA WD 6—2016: Wiring Devices—Dimensional Specifications C405.9.2

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	X		

Action	AS	AS/IC	D	D/I
	X			

Z21.40.3/CSA 4.3—17:—Gas Water Heaters, Volume III—Storage Water Heaters with Input Ratings Above 76,000 Btu per Hour, Circulating Tank and Instantaneous

CE#348																			
Related Mods:	<div>ASABE S640—2017July 2017(R2022):Quantities and Units of Electromagnetic Radiation for Plants (Photosynthetic Organisms) C202</div> <div><table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/IC</td><td>D</td><td>D/C</td></tr><tr><td></td><td>X</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/IC	D	D/C		X			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	X																		
Action	AS	AS/IC	D	D/C															
	X																		
CE#349																			

Related Mods:	<p>ASHRAE</p> <p>55—20172020—Thermal Environmental Conditions for Human Occupancy Table C407.4.1(1)</p> <p>62.1—2019: Ventilation for Acceptable Indoor Air Quality</p> <p>C403.6.1C406.3.3Table C409.6.1.10.2(1)</p> <p>90.1—20192021—Energy Standard for Buildings Except Low-rise Residential Buildings</p> <p>C101.3C401.2.2 C402.1.2Table C402.1.3Table C403.3.2(15)Table C403.3.2(15)C406.2C406.2C406.2.1.1C409.6.1.3.2C409.6.1.5C409.6.1.6Table C409.6.1.10.2(1)Table C409.7(1)C501.2C501.3</p> <p>90.4—20162022—Energy Standard for Data Centers</p> <p>C403.1.2C405.9.1C405.9.2C406.2.2.3</p> <p>140—20142020—Standard Method of Test for the Evaluation of Building Energy Analysis Computer ProgramsMethod of Test for Evaluating Building Performance Simulation Software (with A44enda A and B)</p> <p>C407.5.1.2C409.5.1</p> <p>146—2011n—Testing for Rating Pool Heaters</p> <p>ANSI/ASHRAE/ACCA Standard 183—(RA2017)2007 (RA2020)—Peak Cooling and Heating Load Calculations in Buildings, Except Low-rise Residential Buildings</p> <p>C403.1.1</p> <p>ANSI/ASHRAE/ASHE Standard 170—2021: Ventilation of Health Care Facilities</p> <p>C409.2.1</p> <p>ASHRAE Standard 51—16/ANSI/AMCA Standard 210—16: Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating Table C403.8.5</p> <p>ASHRAE—2020: 2020 ASHRAE Handbook—HVAC Systems and Equipment</p> <p>C403.1.1</p> <p>ISO/AHR/ASHRAE 13256-1 (2012): Water-to-Air and Brine-to-Air Heat Pumps—Testing and Rating for Performance Table C403.3.2(14)</p> <p>ISO/AHR/ASHRAE 13256-2 (2012): Water-to-Water and Brine-to-Water Heat Pumps—Testing and Rating for Performance.....Table C403.3.2(14)</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>SI</td><td>DR</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over top		x			Action	AS	ALC	SI	DR		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																	
	x																			
Action	AS	ALC	SI	DR																
	x																			
CE#350																				
Related Mods:	<p>ASME</p> <p>ASME A17.1—20192022/CSA B44—1922:—Safety Code for Elevators and Escalators</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>SI</td><td>DR</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over top		x			Action	AS	ALC	SI	DR		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																	
	x																			
Action	AS	ALC	SI	DR																
	x																			
CE#351																				
Related Mods:	<p>ASTM</p> <p>C90—2016A21—Specification for Load-bearing Concrete Masonry Units Table C402.1.3</p> <p>C835—06(2020): Standard Test Method for Total Hemispherical Emission of Surfaces up to 1400°C C402.3</p> <p>C1363—1119—Standard Test Method for Thermal Performance of Building Materials and Envelope Assemblies by Means of a Hot Box Apparatus C303.1.4.1Table C402.1.2C402.1.2.1C402.1.2.1Table C402.1.2.1.1C402.3.2</p> <p>C1371—15: Standard Test Method for Determination of Emission of Materials Near Room Temperature Using Portable Emissometers C402.3Table C402.4</p> <p>C1549—16: Standard Test Method for Determination of Solar Reflectance Near Ambient Temperature Using a Portable Solar Reflectometer C402.3Table C402.4</p> <p>D1003—1921—Standard Test Method for Haze and Luminous Transmittance of Transparent Plastics C402.6.2.3.2</p> <p>D8052/D8052M—201722—Standard Test Method for Quantification of Air Leakage in Low-Sloped Membrane Roof Assemblies C402.6.2.3.2</p> <p>E283/E283M—2004(2012)19—Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors Under Specified Pressure Differences Across the Specimen</p> <p>C402.6.1.2.1 C402.6.2.3.2Table C402.6.3</p> <p>E408—13(2019): Standard Test Methods for Total Normal Emission of Surfaces Using Inspection-meter Techniques C402.3Table C402.4</p> <p>E779—10(2018)19—Standard Test Method for Determining Air Leakage Rate by Fan Pressurization C402.6.2.3.1C402.6.2.3</p> <p>E903—2012—Standard Test Method Solar Absorptance, Reflectance and Transmittance of Materials Using Integrating Spheres (Withdrawn 2005) C402.3Table C402.4</p> <p>E1185—22: Standard Practices for Air Leakage Site Detection in Building Envelopes and Air Barrier Systems C402.6.2</p> <p>E1577—1419—Standard Specification for Air Barrier (AB) Material or Systems Assemblies for Low-Rise Framed Building Walls C402.6.2.3.2 E1627—2011(2017)22—Standard Test Methods for Determining Airtightness of Building Using an Orifice Blower Door C402.6.2.3.1C402.6.2.3.2 E1518—06(2016)21—Standard Test Method for Measuring Solar Reflectance of Horizontal or Low-sloped Surfaces in the Field Table C402.4 E1980—11(2019)—Standard Practice for Calculating Solar Reflectance Index of Horizontal and Low-sloped Opaque Surfaces Table C402.4 E2178—1321—Standard Test Method for Determining Air Leakage Rate and Calculation of Air Permeance of Building Materials C402.6.2.3.1</p> <p>E2357—201823—Standard Test Method for Determining Air Leakage of Air Barriers Assemblies C402.6.2.3.2</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>SI</td><td>DR</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over top		x			Action	AS	ALC	SI	DR		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																	
	x																			
Action	AS	ALC	SI	DR																
	x																			
	<p>E3158—18: Standard Test Method for Measuring the Air Leakage Rate of a Large or Multizone Building C402.6.2.1</p> <p>F1281—17(2021): Standard Specification for Cross-linked Polyethylene/Aluminum/Cross-linked Polyethylene (PEX-AL-PEX) Pressure Pipe Table C404.5.2.1</p> <p>F1361—201721—Standard Test Method for Performance of Open-Deep Fat Vat Fryers</p> <p>Table C406.2.6.2(1)</p> <p>F1484—18: Standard Test Method for Performance of Steam Cookers</p> <p>Table C406.2.6.2(2)</p> <p>F1495—2014a20—Standard Specification for Combination Oven Electric or Gas Fired</p> <p>Table C406.2.6.2(4)</p> <p>F1496—201319(2019)—Standard Test Method for Performance of Convection Ovens</p> <p>Table C406.2.6.2(4)</p> <p>F1595—201820—Standard Test Method for Energy Performance of Stationary Rack, Door-Type Commercial Dishwashing Machines Table C406.2.6.2(3)</p> <p>F1920—201520—Standard Test Method for Performance of Rack Conveyor Commercial Dishwashing Machines Table C406.2.6.2(3) F2093—18—Standard Test Method for Performance of Rack Ovens</p> <p>Table C406.2.6.2(4)</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>SI</td><td>DR</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over top		x			Action	AS	ALC	SI	DR		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																	
	x																			
Action	AS	ALC	SI	DR																
	x																			
CE#352																				
Related Mods:	<p>CRRC</p> <p>ANSI/CRRC S100—20202021—Standard Test Methods for Determining Radiative Properties of Materials Table C402.4 C402.4.1</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>SI</td><td>DR</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over top		x			Action	AS	ALC	SI	DR		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																	
	x																			
Action	AS	ALC	SI	DR																
	x																			
CE#353																				
Related Mods:	<p>CSA</p> <p>AAMA/WDMA/CSA</p> <p>101/LS/2/AA40—1922—North American Fenestration Standard/Specification for Windows, Doors and Skylights Table C402.6.3-3/ANSI/CSA C439—18:—Laboratory Methods of Test for Rating the Performance of Heat/Energy Recovery Ventilators C403.7.4.1</p> <p>CSA BEE 1—2012: Test Method for Measuring Efficiency and Recovery of Heat Exchangers Table CSA/TCAC 3.3.5</p> <p>CSA B55.2—2015: Drain Water Heat Recovery Units</p> <p>C404.7</p>	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over top</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table> <table><tr><td>Action</td><td>AS</td><td>ALC</td><td>SI</td><td>DR</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over top		x			Action	AS	ALC	SI	DR		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over top																	
	x																			
Action	AS	ALC	SI	DR																
	x																			
CE#354																				

Related Mods:	<div>CTI</div> <div>ATC-105—2019: Acceptance Test Code for Water Cooling Towers Table C403.3.2(7) ATC-105D5—20152019—Acceptance Test Code for Dry-Fluid Coolers Table C403.3.2(7) ATC-105S—112021—Acceptance Test Code for Closed-Circuit Cooling Towers Table C403.3.2(7) ATC-106—2011: Acceptance Test for Mechanical Draft Evaporative Vapor Condensers Table C403.3.2(7) CTI STD-201 RS(17)2021—Performance Rating of Evaporative-Heat-Rejection Equipment</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
	x																		
CE#355																			
Related Mods:	<div>DASMA</div> <div>ANSI/DASMA 105—20172020—Test Method for Thermal Transmittance and Air Infiltration of Garage Doors and Rolling Doors C303.4.3Table C402.6.3</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
	x																		
CE#356																			
Related Mods:	<div>DOE</div> <div>10 CFR 50: Domestic Licensing of Production and Utilization Facilities C403.17 10 CFR, Part 430—2015: Energy Conservation Program for Consumer Products: Test Procedures and Certification and Enforcement Requirement for Plumbing Products; and Certification and Enforcement Requirements for Residential Appliances; Final Rule Table C403.3.2(1)Table C403.3.2(2)Table C403.3.2(4)Table C403.3.2(5)Table C403.3.2(6)Table C403.3.2(14)C403.15Table C404.2C406.2.3.1.2Table C406.2.3.5 10 CFR, Part 430, Appendix U: Uniform Test Method for Measuring the Energy Consumption of Ceiling Fans C403.8.5Table C403.9 10 CFR, Part 431—2015: Energy Efficiency Program for Certain Commercial and Industrial Equipment: Test Procedures and Efficiency Standards; Final Rules Table C403.3.2(6)C403.8.4 C403.12 C403.12.1Table C403.12.1C403.12.2Table C403.12.2.1(2)C404.2Table C404.2C405.7Table C405.7C405.8Table C405.8(1)Table C405.8(2)Table C405.8(3)Table C405.8(4)</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
	x																		
CE#357																			
Related Mods:	<div>AAMA/FGIA</div> <div>Fenestration & Glazing Industry Alliance (formerly American Architectural Manufacturers Association) 1900 E. Golf Road, Suite 1250 AAMA/WDMA/CSA 101/US-2/A440—1722—North American Fenestration Standard/Specification for Windows, Doors, and Skylights Table C402.6.3</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
	x																		
CE#358																			
Related Mods:	<div>Green-e</div> <div>Green-e c/o Center for Resource Solutions 1012 Torney Ave., 2nd Floor San Francisco, CA 94129 Green-e, Version 1.0, July 7, 2017: Green-e Framework for Renewable Energy Certification</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td></td><td></td><td>x</td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC				x	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
			x																
CE#359																			
Related Mods:	<div>ICC</div> <div>IBC—2124—International Building Code[®] C201.3C202C303.1.1C303.1.2C303.2C402.1.5C402.2.7 C402.6.4C405.2C405.5.1 CG101.2.6C405.15.2.1C501.2C501.2C503.2.4 ICC 500—20: Standard for the Design and Construction of Storm Shelters C402.5.2 IFC—2124—International Fire Code[®] C201.3C405.16.2.1C405.16.2.2C501.2 IFGC—2124—International Fuel-Gas-Code[®] C201.3C501.2 IMC—2124—International Mechanical-Code[®] C201.3C402.1.5C403.2.2C403.6C403.6.1C403.6.6C403.7.1C403.7.2C403.7.4.2C403.7.5C403.7.7C403.8.6.1 C403.13.1C403.13.2 C403.13.2.1 C403.13.2.2C406.2.2.5C406.3.3Table C407.4.1(1)C408.2.2.1C501.2 IPC—2124—International Plumbing-Code[®] C201.3C501.2 IPMC—2124—International Property-Maintenance-Code[®] C501.2 IPSDC—2124—International Private-Sewage-Disposal-Code[®] C501.2</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
	x																		
CE#360																			
Related Mods:	<div>IEC</div> <div>IEC Regional Centre for North America IEC International Electrotechnical Commission 446 Main Street, 16th Floor Worcester, MA 01608 IEC 62746-10-1—2018: Systems interface between customer energy management system and the power management system – Part 10-1: Open automated demand response</div> <div>C403.4.6.2</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td></td><td></td><td></td><td>x</td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC					x
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
				x															
CE#361																			
Related Mods:	<div>IEEE</div> <div>515.1—2012: IEEE Standard for the Testing, Design, Installation, and Maintenance of Electrical Resistance Trace Heating for Commercial Applications C404.6.2 1547—2018a: IEEE Standard for Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces</div> <div>C405.16</div> <div><table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>x</td><td></td><td></td></tr></table><table><tr><td>Action</td><td>AS</td><td>ALRC</td><td>D</td><td>DRC</td></tr><tr><td></td><td>x</td><td></td><td></td><td></td></tr></table></div>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Action	AS	ALRC	D	DRC		x			
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																
	x																		
Action	AS	ALRC	D	DRC															
	x																		
CE#362																			

Related Mods:

IES
ANSI/ASHRAE/IES 90.1—20192022—Energy Standard for Buildings—Except Low-Rise Residential Buildings C301.3C401.2C402.1.21C402.1.3Table C402.1.3Table C403.3.2(5)Table C403.3.2(15)C406.3C406.2.1.1C409.6.1.3.2C409.6.1.3.2C409.6.1.5C409.6.1.6Table C409.6.1.10.2(1)Table C409.7(1)C501.2C501.3
ANSI/IES RP-2—2020: Recommended Practice: Lighting Retail Spaces C406.2.5
ANSI/IES RP-3—2020: Recommended Practice: Lighting Educational Facilities C406.2.5

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#363

Related Mods:

ANSI/IES RP-4—2020: Recommended Practice: Lighting Library Spaces C406.2.5
ANSI/IES RP-6—2020: Recommended Practice: Lighting Sports and Recreational Areas C406.2.5
ANSI/IES RP-7—2020: Recommended Practice: Lighting Industrial Facilities C406.2.5
ANSI/IES RP-8—2021: Recommended Practice: Lighting Roadway and Parking Facilities C406.2.5
ANSI/IES RP-9—2020: Recommended Practice: Lighting Hospitality Spaces C406.2.5
ANSI/IES RP-10—2020: Recommended Practice: Lighting Common Applications C406.2.5
ANSI/IES RP-27—2020: Recommended Practice: Photobiological Safety for Lighting Systems C406.2.5 ANSI/IES RP-29—2020: Recommended Practice: Lighting Hospital and Healthcare Facilities C406.2.5
ANSI/IES RP-30—2020: Recommended Practice: Lighting Museums C406.2.5
ANSI/IES RP-41—2020: Recommended Practice: Lighting Theaters and Worship Spaces C406.2.5
ANSI/IES/ALA RP-11—2020: Recommended Practice: Lighting for Interior and Exterior Residential Environments C406.2.5

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#364

Related Mods:

ISO
ISO 9050—2003: Glass in Building: Determination of Light Transmittance, Solar Direct Transmittance, Total Solar Energy Transmittance, Ultraviolet Transmittance and Related Glazing Factors C402.3
ISO 25745-2—2015: Energy Performance of Lifts, Escalators and Moving Walks—Part 2: Energy calculation and classification for lifts (elevators) C406.2.6.1
ISO 23327-1—2009: Fans—Air Curtain Units—Laboratory Methods of Testing for Aerodynamic Performance Rating C402.6.5
ISO/AHRI/ASHRAE 13256-1—2017: Water-to-Air and Brine-to-Air Heat Pumps—Testing and Rating for Performance Table C403.3.2(14)
ISO/AHRI/ASHRAE 13256-2—2017: Water-to-Water and Brine-to-Water Heat Pumps—Testing and Rating for Performance Table C403.3.2(14)

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#365

Related Mods:

NEMA
ANSI/NEMA MG1—20162021—Motors and Generators C202
OS 4—2016: Requirements for Air-Sealed Boxes for Electrical and Communication Applications C402.6.1.2.2.1

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#366

Related Mods:

NFPA
70—2023—National Electrical Code C405.12.1 C0101.2.6C405.1.6.2.3C501.2

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#367

Related Mods:

NFRC
100—20202023—Procedure for Determining Fenestration Products U-Factors C303.1.3Table C402.1.21Table C402.1.4 C402.2.1.2 C402.5.1.1
200—20202023—Procedure for Determining Fenestration Product Solar Heat Gain Coefficient and Visible Transmittance at Normal Incidence C303.1.3 C402.5.1.1
203—20172023—Procedure for Determining Visible Transmittance of Tubular Daylighting Devices C303.1.3-300—2023—Test Method for Determining the Solar Optical Properties of Glazing Materials and Systems C402.3-400—20202023—Procedure for Determining Fenestration Product Air Leakage

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#368

Related Mods:

OpenADR
OpenADR Alliance
111 Deerwood Road, Suite 200 San Ramon, CA 94583
OpenADR 2.0a and 2.0b—2019: Profile Specification Distributed Energy Resources C403.4.6.2, C406.3

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#369

Related Mods:

RESNET
Residential Energy Services Network, Inc.
P.O. Box 4561
Oceanside, CA 92052-4561
ANSI/RESNET/ICC 380-2022: Standard for Testing Airtightness of Building, Dwelling Unit and Sleeping Unit Enclosures; Airtightness of Heating and Cooling Air Distribution Systems, and Airflow of Mechanical Ventilation Systems

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap
	x		

Action	AS	AS/C	D	D/C
	x			

CE#370																					
Related Mods:	SMACNA ANSI/SMACNA 016, 2nd edition—2012: HVAC Air Duct Leakage Test Manual Second Edition (ANSI/SMACNA 016—2012) C403.13.2.3 C503.3.3																				
	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D		X						
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																		
	X																				
Action	AS	AS/EC	D																		
	X																				
CE#371																					
Related Mods:	UL 710—2012: Exhaust Hoods for Commercial Cooking Equipment—with Revisions through November 2019February 2021 C403-7.5 727—2018: Oil-fired Central Furnaces Table C403.3.2(5) 731—2018: Oil-fired Unit Heaters Table C403.3.2(5) 1741—2021: Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources																				
	<table><tr><td>C405.16 1784—2015: Air Leakage Tests of Door Assemblies—with Revisions through February 2015</td><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td></td><td>X</td><td></td><td></td></tr><tr><td></td><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td></td><td>X</td><td></td><td></td></tr></table>	C405.16 1784—2015: Air Leakage Tests of Door Assemblies—with Revisions through February 2015	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap			X				Action	AS	AS/EC	D			X		
C405.16 1784—2015: Air Leakage Tests of Door Assemblies—with Revisions through February 2015	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																	
		X																			
	Action	AS	AS/EC	D																	
		X																			
CE#372																					
Related Mods:	WDMA AAMA/WDMA/CSA 101/I.S.2/A440—1722: North American Fenestration Standard/Specification for windows, doors and skylights Table C402.6.3																				
	<table><tr><td>Staff Classification</td><td>Correlates Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>X</td><td></td><td></td></tr><tr><td>Action</td><td>AS</td><td>AS/EC</td><td>D</td></tr><tr><td></td><td>X</td><td></td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		X			Action	AS	AS/EC	D		X						
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap																		
	X																				
Action	AS	AS/EC	D																		
	X																				
CE#373	Replaces the "net zero carbon" text with "net zero operational energy." New Definition. Adds new Definition. Deleted existing definition. Adds new Definition. Adds new Definition. Modifies an existing definition. Modifies an existing definition. Adds new Definition. Modifies an existing definition. Deletes an existing definition. Renames the table title and updates the values.																				
Related Mods:	APPENDIX CC ZERO ENERGY COMMERCIAL BUILDING PROVISIONS																				
CECPI-5- 21, CED1- 204-22	CC101.1 Purpose. The purpose of this appendix is to supplement the <i>International Energy Conservation Code</i> and require renewable energy systems of adequate capacity to achieve net zero carbonoperational energy. CC101.2 Scope. This appendix applies to new buildings that are addressed by the <i>International Energy Conservation Code</i> . Exceptions: 1. Detached one- and two-family dwellings and townhouses as well as Group R-2 buildings three stories or less in height above grade plane, manufactured homes (mobile dwellings), and manufactured houses (modular dwellings). 2. Buildings that use neither electricity nor fossil fuel. SECTION CC102 DEFINITIONS CC102.1 Definitions. The definitions contained in this section supplement or modify the definitions in the <i>International Energy Conservation Code</i> . ADJUSTED OFF-SITE RENEWABLE ENERGY.The amount of energy production from off-site renewable energy systems that may be used to offset building energy. BUILDING ENERGY.All energy consumed at the building site as measured at the site boundary. Contributions from on-site or off- site renewable energy systems shall not be considered when determining the building energy.																				
	<p>DIRECT ACCESS TO WHOLESALE MARKET. An agreement by the owner and a renewable energy developer to purchase renewable energy from the wholesale market.</p> <p>DIRECT OWNERSHIP. An off-site renewable energy system under the ownership or control of the building project owner.</p> <p>ENERGY UTILIZATION INTENSITY (EUI). The site energy for either the baseline building or the proposed building divided by the gross conditioned floor area plus any semiheated floor area of the building. For the baseline building, the EUI can be divided between regulated energy use and unregulated energy use.</p> <p>GREEN RETAIL PRICING. A program by the retail electricity provider to provide 100 percent renewable energy to the building project owner.</p> <p>MINIMUM RENEWABLE ENERGY REQUIREMENT. The minimum amount of on-site or adjusted off-site renewable energy needed to comply with this appendix.</p> <p>OFF-SITE RENEWABLE ENERGY SYSTEM. A renewable energy system that serves the building project and is not an on-site renewable energy system, including contracted purchases of renewable energy and renewable energy certificates (RECs) located on the building project.</p> <p>ON-SITE RENEWABLE ENERGY SYSTEM. Renewable energy systems on the building project located on any of the following:</p> <ol style="list-style-type: none">The building.The property on which the building is located.A property that shares a boundary with and is under the same ownership or control as the property on which the building is located.A property that is under the same ownership or control as the property on which the building is located and is separated only by a public right-of-way from the building served by the renewable energy system. <p>RENEWABLE ENERGY INVESTMENT FUND (REIF). A fund established by a jurisdiction to accept payment from building project owners to construct or acquire interests in qualifying renewable energy systems, together with their associated RECS, on the building project owner's behalf.</p> <p>RENEWABLE ENERGY SYSTEM. Photovoltaic, solar thermal, geothermal energy extracted from hot fluid or steam, wind, or other approved and wind systems used to generate renewable energy.</p> <p>SEMIHEATED SPACE. An enclosed space within a building that is heated by a heating system whose output capacity is greater than or equal to 3.4 Btu/h × ft² of floor area but is not a conditioned space.</p> <p>ZERO ENERGY PERFORMANCE INDEX (ZEPI-PB/EE). The ratio of the proposed building EUI without renewables to the baseline building EUI, expressed as a percentage.</p> <p>SECTION CC103 MINIMUM RENEWABLE ENERGY</p> <p>CC103.1 Renewable energy. On-site renewable energy systems shall be installed or off-site renewable energy shall be procured to offset the building energy as calculated in Equation CC-1, or adjusted off-site renewable energy shall be procured to meet the minimum renewable energy requirement in accordance with Equation CC-1.</p>																				

PRESCRIPTIVE RENEWABLE ENERGY REQUIREMENT FOR BUILDING TYPES AND CLIMATES (kWh/ft²-yr)

5B	11	29	16	8	125	14	11	5	21	31	4	14
5C	10	29	17	7	116	13	10	4	18	27	3	13
6A	14	33	20	10	151	20	13	11	26	39	5	17
6B	13	33	19	8	137	17	11	7	22	34	4	16
7	14	37	21	9	164	20	13	10	25	37	5	18
8	15	40	22	11	190	23	16	10	28	43	5	20

CE#374	Modifies the on-site renewable energy calculation software requirement. Adds new Table CC103.2. Adds new subsection CC103.2.1. Revises the code provision for clarity.
--------	--

Related Mods:
CECPI-5- 21,
CED1- 204-22

TABLE CC103.2

PROCUREMENT FACTORS FOR RENEWABLE ENERGY SYSTEM COMPLIANCE ALTERNATIVES

For SI: 1 watt per square foot = $W/0.0929 \text{ m}^2$.

CC103.2.1 Renewable energy certificates. Renewable energy certificates (RECs) associated with the on-site renewable energy system shall be assigned to the initial and subsequent building owner(s) for a cumulative period of not less than 15 years. The building owner(s) are permitted to transfer RECs to building tenants occupying the *building*.

CE#375	<p>Renames the section title and revises the provision for clarity. Revises the code provision for clarity.</p> <p>Edits the off-site renewable calculation equation and updates definition of the variables. Adds new Section CC103.3.3.1.</p> <p>Deletes Table CC103.3.3.</p>
--------	---

Related Mods: CECPI-5- 21, CED1- 204-22	<p>CC103.3 Off-site renewable energy. Off-site energy shall comply with Sections CC103.3.1 and CC103.3.2.</p> <p>CC103.3.1 Qualifying off-site Off-site procurement methods. The following are considered qualifying off-site renewable energy procurement methods: One or more of the following off-site renewable energy procurement methods shall be used to comply with Section CC103.1:</p> <ol style="list-style-type: none">1-Community renewables energy facility: an off-site renewable energy system for which the owner has purchased or leased renewable energy capacity along with other subscribers;2. Renewable energy investment fund : an entity that installs renewable energy capacity on behalf of the owner;3-Virtual power purchase agreement: a power purchase agreement for off-site renewable energy where the owner agrees to purchase renewable energy output at a fixed price schedule. <i>Financial renewable energy power purchase agreement :</i>4. Direct ownership: an off-site renewable energy system owned by the building project owner;5. Direct access to wholesale market: an agreement between the owner and a renewable energy developer to purchase renewable energy;6. Green retail pricing tariffs: a program by the retail electricity provider to provide 100 percent renewable energy to the owner;7. Unbundled Renewable Energy Certificates (RECs): certificates purchased by the owner representing the environmental benefits of renewable energy generation that are sold separately from the electric power;8. <i>Physical renewable energy power purchase agreement .</i>																
	<p>CC103.3.2 Requirements for all procurement methods. The following requirements shall apply to all off-site renewable energy procurement methods: Off-site renewable energy systems and procurement methods used to comply with Section CC103.1 shall comply with all of the following:</p> <ol style="list-style-type: none">1. The building owner shall sign a legally binding contract <i>or other approved agreement</i> to procure qualifying off-site renewable energy.2. The procurement contract shall have duration of not less than 15 years and shall be structured to survive a partial or full transfer of ownership of the property.3. RECs and other environmental attributes associated with the procured off-site renewable energy shall comply with the following requirements: be assigned to the building project for the duration of the contract:<ol style="list-style-type: none">3.1. The RECs shall be retained or retired by or on behalf of the property owner or tenant for a period of not less than 15 years.3.2. The RECs shall be created within a 12-month period of use of the REC.3.3. The RECs shall be from a generating asset constructed not more than 5 years before the issuance of the certificate of occupancy.4. The renewable energy generating source shall include one or more of the following: photovoltaic systems, solar thermal power plants, geothermal power plants and wind turbines. The generating source shall be a renewable energy system.5. The generation source shall be located where the energy can be delivered to the <i>building site</i> by any of the following: the same utility or distribution entity, the same independent system operator (ISO) or regional transmission organization (RTO), or within integrated ISOs (electric coordination entity):<ol style="list-style-type: none">5.1. Direct connection to the off-site renewable energy facility.5.2. The local utility or distribution entity.5.3. An interconnected electrical network where energy delivery capacity between the generator and the <i>building</i> site is available.6. The off-site renewable energy producer shall maintain transparent accounting that clearly assigns production to the building. Records on power sent to or purchased by the building shall be retained by the building owner and made available for inspection by the code official upon request. Records on power sent to or purchased by the building shall be retained by the building owner and made available for inspection by the code official upon request. <p>CC103.3.3 Adjusted off-site renewable energy. The process for calculating the adjusted <i>off-site renewable energy</i> is shown in Equation CC-2.</p> <p>Equation CC-2</p> <p>where:</p> <p>$RE_{off-site}$ = Adjusted off-site renewable energy.</p> <p>$PF_{off-site}$ = Procurement factor for the <i>i</i>-th renewable energy procurement method or class taken from Table CC103.3.3; RE_{method} = The renewable energy procurement factor for off-site renewable energy other than RECs, in accordance with Section</p> <p>CC103.3.3.1.</p>																
	<p>RE_i = Annual energy production for the <i>i</i>-th renewable energy procurement method or class; RE_{method} = Annual energy production for renewable energy procurement methods other than RECs;</p> <p>n = The number of renewable energy procurement options or classes considered; RE_{Renew} = Annual energy production associated with unbundled RECs;</p> <p>CC103.3.3.1 Procurement factors. The procurement factors for renewable energy system compliance alternatives shall be as specified in Table CC103.2.</p> <p>Delete entire Table CC103.3.3 DEFAULT OFF-SITE RENEWABLE ENERGY PROCUREMENT METHODS, CLASSES AND</p> <p>COEFFICIENTS</p> <table><tr><th>Staff Classification</th><th>Correlates Directly</th><th>Energy Standard Needed</th><th>Over lap</th></tr><tr><td></td><td>x</td><td></td><td></td></tr><tr><td>Engineer</td><td>AS</td><td>AS/CE</td><td>AS/CE</td></tr><tr><td></td><td></td><td>x</td><td></td></tr></table>	Staff Classification	Correlates Directly	Energy Standard Needed	Over lap		x			Engineer	AS	AS/CE	AS/CE			x	
Staff Classification	Correlates Directly	Energy Standard Needed	Over lap														
	x																
Engineer	AS	AS/CE	AS/CE														
		x															
CE#376	Adds new Appendix CD.																
Related Mods: CEPI- 257-21	<p>APPENDIX CD THE 2030 GLIDE PATH</p> <p><i>The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.</i></p> <p>User notes:</p> <p><i>About this appendix: This voluntary appendix is suited for adopting authorities that wish to extend beyond the mandatory provisions of this code toward zero net energy goals. Appendix CD is intended to be adopted by jurisdictions that will require new construction to operate at zero net energy by the year 2030. It reduces the net annual energy use of buildings by approximately one-third in comparison with buildings constructed in compliance with the 2021 IECC. It is assumed that the 2027 and 2030 editions will also reduce energy use by one-third each.</i></p> <p>SECTION CD101 COMPLIANCE</p> <p>CD101.1 Reserved.</p> <p>CD101.2 Simulated Building Performance compliance. Where compliance is demonstrated using the Simulated Building Performance option of Section C401.2.1, the percentage of annual energy cost (PAEC), applied to the <i>standard reference design</i> referenced in Equation 4-32, shall be multiplied by 0.97.</p> <p>CD101.3 On-site renewable electricity systems. In addition to any renewable energy generation equipment provided to comply with Section C406.3, buildings shall install equipment for <i>on-site renewable energy</i> generation with a direct current (DC) nameplate capacity rating of not less than that computed using Equation CD-2.</p>																

$$AA = CA + SNA/3$$

AA = Adjusted area, in ft² (m²).
CA = Conditioned area, in ft² (m²).
SNA = Semi-heated and nonconditioned area, in ft² (m²).
Equation CD-2
where:

$$REQ = AA \times CF$$

CF = Capacity factor from Table CD101.3, in watts/ft² (m²).
Exceptions:
1. Any required renewable energy generation capacity in excess of 10 watts per square foot (108 W/m²) of net available roof area is permitted to be provided using an off-site renewable energy system in accordance with Section CD101.4. For the purposes of this section, net available roof area is the gross roof area minus the roof area occupied by any combination of skylights, mechanical equipment, vegetated areas, required access pathways, vehicle parking and occupied roof terrace area.
2. The following buildings are permitted to provide off-site renewable energy generation in accordance with Section CD101.4 in lieu of all or part of the on-site renewable energy generation capacity required by Section CD101.3:
2.1. Any building where more than 50 percent of roof area would be shaded from direct-beam sunlight by existing natural objects or by structures that are not part of the building for more than 2,500 annual hours between 8:00 a.m. and 4:00 p.m.
2.2. Any building with gross conditioned floor area less than 1,000 square feet (93 m²).
2.3. Any building whose primary roof slope is 2 units vertical in 12 units horizontal (17 percent slope) or greater.
3. Alternate forms of renewable energy generation capacity are permitted where the annual energy generation is not less than that produced by the required solar capacity, and where annual energy generation is calculated using an approved methodology.
4. All or part of the required renewable energy generation capacity is permitted to be replaced by other efficiency measures provided that such measures will reduce the annual energy consumption of the building by an amount no less than that which would otherwise be produced annually by the required renewable energy capacity, as calculated using the Simulated Building Performance compliance path in Section C407 and an approved calculation methodology for solar production.

TABLE CD101.3

ON-SITE RENEWABLE ELECTRICITY

CLIMATE ZONE

1A, 2B, 3B, 3C, 4B and 5B
0A, 0B, 1B, 2A, 3A and 6B
4A, 4C, 5A, 5C, 6A, 7 and 8

CAPACITY FACTOR

2.0 W/m²
2.3 W/m²
2.6 W/m²

For SI: 1 watt per square foot = 10.76 W/m²

CD101.4 Off-site renewable energy. Buildings that qualify for one or more of the exceptions to Section CD101.3 and that do not have on-site renewable energy systems sufficiently sized to fully comply with Section CD101.3 shall procure off-site renewable energy in accordance with Sections CD101.4.1 through CD101.4.3. Such procured energy shall provide not less than the total annual required off-site renewable energy determined in accordance with Equation CD-4 and shall be provided in addition to any renewable energy provided to comply with Section C406.3.

Equation CD-3

where:

DEF = Renewable capacity deficit, in DC watts.

REQ = Required on-site capacity in DC watts, from Equation CD-2.

INSTL = Installed on-site capacity, in DC watts

Equation CD-4

where:

OFF = Off-site renewable energy to be procured, in kWh/year.

CD101.4.1 Off-site procurement. The building owner shall procure and be credited for the total amount of off-site renewable energy required by Equation CD-4. Procured off-site renewable energy shall be provided to not less than one of the following:

1. Community renewable energy.
2. Financial renewable energy power purchase agreement.
3. Physical renewable energy power purchase agreement.
4. Direct ownership.

$$OFF = 4.4 \times DEF$$

5. Renewable Energy Investment Fund.
6. Green retail tariff.

CD101.4.2 Off-site contract. The renewable energy shall be delivered or credited to the building site under an energy contract with a duration of not less than 10 years. The contract shall be structured to survive a partial or full transfer of ownership of the building property. The total required off-site renewable energy shall be procured in equal installments over the duration of the off-site contract.

CD101.4.3 Renewable energy certificate (REC) documentation. The property owner or owner's authorized agent shall demonstrate that where RECs are associated with on-site and off-site renewable energy production required by Sections CD101.3 and CD101.4, the following criteria shall be met:

1. The RECs shall be retained and retired by or on behalf of the property owner or tenant for a period of not less than 10 years or the duration of the contract in Section CD101.4.2, whichever is less.
2. The RECs shall be created within a 12-month period of the use of the REC.
3. The RECs represent a generating asset constructed not more than 5 years before the issuance of the certificate of occupancy.

Staff Classification	Correlates Directly	Energy Standard Required	Over-Use
	x		
Action	AS	REC	REC
		x	

CE#377

New Appendix CE. It is not mandatory unless specifically referenced in the adopting ordinance.

Related Mods:
CEPI76- 21

APPENDIX CE REQUIRED HVAC TOTAL SYSTEM PERFORMANCE RATIO (TSPR)

The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

User notes:

About this appendix: Appendix CE can be adopted for stretch codes and utility incentive certification that requires Total System Performance Ratio (TSPR) analysis where it is applicable and requires a higher level of performance, saving 5 percent versus minimum efficiency systems.

SECTION CE101 GENERAL

CE101.1 Required HVAC total system performance ratio (TSPR). For jurisdictions that wish to adopt a stretch code or HVAC incentive system, make the following changes to Section C403.

CE101.2 (Replace Section C403.1 with the following) General. Mechanical systems and equipment serving the building heating, cooling, ventilating or refrigerating needs shall comply with one of the following:

1. Sections C403.1.1 and C403.2 through C403.17 and where applicable, Section C409.

2. Data centers shall comply with Sections C403.1.1, C403.1.2 and C403.6 through C403.17.

CE101.3 HVAC total system performance ratio (TSPR). (Add the following three exceptions to Section C409.2)

Exceptions:

1. Buildings with conditioned floor area less than 5,000 square feet (465 m²).

2. Alterations to existing buildings that do not substantially replace the entire HVAC system and are not serving initial build-out construction.

3. HVAC systems meeting or exceeding all the requirements of the applicable target design HVAC system described in Tables C409.7(1) through C409.7(3).

TABLE CE101.3 MECHANICAL PERFORMANCE FACTORS

OCCUPANCY GROUP		CLIMATE ZONE																	
		0A	0B	1A	1B	2A	2B	3A	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
Office (small and medium) ^a	B	0.68	0.68	0.67	0.67	0.65	0.62	0.67	0.61	0.76	0.67	0.74	0.80	0.73	0.76	0.82	0.79	0.85	0.85
Office (large)	B	0.79	0.79	0.80	0.80	0.75	0.78	0.68	0.73	0.64	0.72	0.60	0.67	0.68	0.60	0.69	0.67	0.67	0.67
Retail	M	0.57	0.54	0.49	0.52	0.44	0.44	0.41	0.38	0.43	0.54	0.65	0.44	0.65	0.64	0.48	0.43	0.42	0.36
H otel	R-1	0.59	0.59	0.60	0.60	0.59	0.65	0.58	0.69	0.43	0.58	0.49	0.38	0.45	0.48	0.33	0.36	0.28	0.25
Multifamily dormitory	R-2	0.61	0.60	0.60	0.60	0.62	0.61	0.56	0.52	0.50	0.48	0.42	0.51	0.45	0.36	0.52	0.48	0.48	0.45
School/education and libraries	E (A-3)	0.78	0.77	0.78	0.75	0.71	0.68	0.67	0.64	0.69	0.68	0.65	0.70	0.69	0.58	0.85	0.76	0.78	0.73

For SI: 1 square foot = 0.0929 m².

a. Large office = gross conditioned floor area greater than 150,000 square feet or greater than 5 floors; all other offices are small or medium.

Staff Classification	Correlates Directly	Energy Standard	Over lap
	A		
Active	AS	ASDC	D
			A

CE#378

Ads new Appendix CF. It is not mandatory unless specifically referenced in the adopting ordinance.

Related Mods:

APPENDIX CF ENERGY CREDITS

CEPI- 193-21

The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

User notes:

About this appendix: Appendix CF can be adopted by authorities having jurisdiction seeking stretch codes building on the methodology of Section C406.

SECTION CF101 GENERAL

CF101.1 Purpose. The purpose of this appendix is to supplement the International Energy Conservation Code and requires projects to comply with Advanced Energy Credit Package requirements.

CF101.2 Scope. This appendix applies to all buildings that, in accordance with Section C406.1, are required to comply with Section C406.1.1 or C406.1.2.

SECTION CF102

ADVANCED ENERGY CREDIT PACKAGE

CF102.1 Advanced Energy Credit Package requirements. The requirements of this section supersede the requirements of Section C406.1.1. Projects shall comply with measures from Section C406.2 to achieve the minimum number of required efficiency credits from Table CF102.1(1) based on building occupancy group and climate zone. Projects with multiple occupancies, unconditioned parking garages and buildings with separate shell-and-core and build-out construction permits shall comply as follows:

Where a project contains multiple occupancies, credits in Table CF102.1(1) from each building occupancy shall be weighted by the gross floor area to determine the weighted average project energy credits required. Accessory occupancies shall be included with the primary occupancy group for purposes of Section C406 and this appendix.

Exceptions:

1. Unconditioned parking garages that achieve 50 percent of the credits required for use groups S-1 and S-2 in Table CF102.1(1).

2. Portions of buildings devoted to manufacturing or industrial use.

3. Where a building achieves more renewable and load management credits in Section C406.3 than are required in Section C406.1.2, surplus credits shall be permitted to reduce required energy efficiency credits as follows:

where:

EEC_{red} = Reduced required energy efficiency credits.

EEC_{tbl} = Required energy efficiency credits from Table C406.1.1(1).

SLRM_{lim} = Surplus renewable and load management credit limit from Table C406.1.1(2). SLRM_{adj} = 1.0 for all-electric or all-renewable buildings (excluding emergency generation); 0.7 for buildings with fossil fuel equipment (excluding emergency generation).

EEC_{red} = EEC_{tbl}

– {the lesser of: [SLRM_{lim}, SLRM_{adj} × (RLM_{ach} – RLM_{req})]}

TABLE CF102.1(1)

ENERGY CREDIT REQUIREMENTS BY BUILDING OCCUPANCY GROUP

BUILDING OCCUPANCY GROUPS	CLIMATE ZONE															
	0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A
R-2, R-4, and I-1	179	174	188	197	200	200	200	200	200	200	200	200	200	200	200	200
I-2	78	75	73	71	80	80	100	85	90	97	83	90	98	90	96	107
R-1	106	100	110	105	109	122	123	125	131	137	129	136	139	147	171	158
B	114	110	112	115	108	107	116	111	114	126	118	123	125	125	152	142
A-2	83	81	82	82	86	86	108	91	97	126	99	111	117	113	160	143
M	113	113	121	118	125	127	116	116	133	136	100	92	98	134	125	171

E	91	95	91	100	96	100	105	104	101	113	110	110	117	122	131	132	126	131
S-1 and S-2	108	106	111	109	108	89	89	108	108	100	100	143	123	200	190	189	148	
All Other	54	53	55	56	57	60	61	60	63	68	60	65	68	69	84	79	84	78

TABLE CF102.1(2)

LIMIT TO ENERGY EFFICIENCY CREDIT CARRYOVER FROM RENEWABLE AND LOAD MANAGEMENT CREDITS

BUILDING OCCUPANCY GROUPS	CLIMATE ZONE																		
	0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4B	4C	5A	5B	5C	6A	6B	7	8
R-2, R-4, AND I-1	100	100	114	110	113	91	95	115	101	73	102	99	54	73	101	45	50	68	62
I-2	30	25	26	20	28	33	38		30	37		32	41	41	50	53	56	75	80
R-1	20	8	20	5	26	22	20		30	19		23	24	28	28	27	30	41	54
B	25	19	18	20	15	15	15		30	31		32	37	40	44	42	40	51	66
A-2	9	5	5	5	5		5	5	5	9	5	5	21	9	5	32	19	41	61
M	5	5	5	5	5		5	5	5	5	5	5	5	5	5	5	5	5	10
E	24	24	31	29	29	28	19		30	31		33	34	37	33	31	33	40	54
S-1 and S-2	5	5	5	5	5		5	5	5	5	5	5	37	19	5	49	41	51	56
All other	5	5	5	5	5		5	5	5	5	6	8	5	11	10	5	5	9	20

SECTION CF103 BUILDINGS WITHOUT HEAT

PUMPS

CF103.1 Buildings without heat pumps. The number of efficiency credits required by Section C406.1.1 shall be multiplied by 1.25 for the following:

- Buildings using *purchased energy* that is not electricity for space heating or *service water heating*.
- Buildings with electric storage water heaters that are not heat pumps.
- Buildings with total heat pump space heating capacity less than the space heating load at heating design conditions calculated in accordance with Section C403.1.1.
Exceptions:
 - Portions of buildings devoted to manufacturing or industrial use.
 - Buildings complying with all of the following:
 - The building's peak heating load calculated in accordance with Section C403.1.1 is greater than the building's peak cooling load calculated in accordance with Section C403.1.1.
 - The building's total heat pump space heating capacity is not less than 50 percent of the building's space heating load at heating design conditions calculated in accordance with Section C403.1.1.
- Any energy source other than electricity or *on-site renewable energy* is used for space heating only where a heat pump cannot provide the necessary heating energy to satisfy the thermostat setting.
 - Electric resistance heat is used only in accordance with Section C403.4.1.1.
 - Low-energy buildings complying with Section C402.1.1.1.
- Portions of buildings in Utility and Miscellaneous Group U, Storage Group S, Factory Group F or High-Hazard Group H.
 - Buildings located in Climate Zones 0A, 0B, 1A, 1B, 2A and 2B.

SECTION CF104 EXISTING BUILDINGS

CF104.1 Additions not served by heat pumps. The number of efficiency credits required by

Section C502.3.7 shall be multiplied by 1.25 for the following:

- Additions using *purchased energy* that is not electricity for space heating or *service water heating*.
- Additions served by electric storage water heaters that are not heat pumps.
- Additions served by total heat pump space heating capacity less than the peak space heating load at heating design conditions calculated in accordance with Section C403.1.1.
Exceptions: Additions complying with all of the following:
 - The addition's peak heating load calculated in accordance with Section C403.1.1 is greater than the addition's peak cooling load calculated in accordance with Section C403.1.1.
 - The addition's total heat pump space heating capacity serving the addition is not less than 50 percent of the addition's space heating load at heating design conditions calculated in accordance with Section C403.1.1.

- Any energy source other than electricity or *on-site renewable energy* is used for space heating serving the addition only where a heat pump cannot provide the necessary heating energy to satisfy the thermostat setting.
- Electric resistance heat serving the addition is used only in accordance with Section C403.4.1.1.

Staff Classification	Correlates Directly	Energy Standard Modified	Overlaps
	x		
Section	0A	0B, 0C	0D, 0E
		x	

CE#379 Adds new Appendix CG. It is not mandatory unless specifically referenced in the adopting ordinance.

Related Mods: APPENDIX CG ELECTRIC VEHICLE CHARGING INFRASTRUCTURE

CED1-15- 22

The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.
User notes:
About this appendix: Appendix CG can be adopted by authorities having jurisdiction seeking electric vehicle charging infrastructure requirements.

SECTION CG101

ELECTRIC VEHICLE POWER TRANSFER

CG101.1 Definitions.

AUTOMOBILE PARKING SPACE. A space within a building or private or public parking lot, exclusive of driveways, ramps, columns, office and work areas, for the parking of an automobile.

ELECTRIC VEHICLE (EV). An automotive-type vehicle for on-road use, such as passenger automobiles, buses, trucks, vans, neighborhood electric vehicles and electric motorcycles, primarily powered by an electric motor that draws current from a building electrical service, electric vehicle supply equipment (EVSE), a rechargeable storage battery, a fuel cell, a photovoltaic array or another source of electric current.

ELECTRIC VEHICLE CAPABLE SPACE (EV CAPABLE SPACE). A designated automobile parking space that is provided with electrical infrastructure such as, but not limited to, raceways, cables, electrical capacity, a panelboard or other electrical distribution equipment space necessary for the future installation of an EVSE.

ELECTRIC VEHICLE READY SPACE (EV READY SPACE). An automobile parking space that is provided with a branch circuit and an outlet, junction box or receptacle that will support an installed EVSE.

ELECTRIC VEHICLE SUPPLY EQUIPMENT (EVSE). Equipment for plug-in power transfer, including: ungrounded, grounded and equipment grounding conductors; electric vehicle connectors; attached plugs; any personal protection system; and all other fittings, devices, power outlets or apparatus installed specifically for the purpose of transferring energy between the premises wiring and

the electric vehicle.

ELECTRIC VEHICLE SUPPLY EQUIPMENT INSTALLED SPACE (EVSE SPACE). An automobile parking space that is provided with a dedicated EVSE connection.

CG101.2 Electric vehicle power transfer infrastructure. Parking facilities shall be provided with electric vehicle power transfer infrastructure in accordance with **Sections CG101.2.1** through **CG101.2.6**.

CG101.2.1 Quantity. The number of required electric vehicle (EV) spaces, *EV capable spaces* and *EV ready spaces* shall be determined in accordance with this section and **Table CG101.2.1** based on the total number of *automobile parking spaces* and shall be rounded up to the nearest whole number. For R-2 buildings, the **Table CG101.2.1** requirements shall be based on the total number of *dwelling units* or the total number of *automobile parking spaces*, whichever is less

- Where more than one parking facility is provided on a *building site*, the number of required *automobile parking spaces* required to have EV power transfer infrastructure shall be calculated separately for each parking facility.
- Where one shared parking facility serves multiple building occupancies, the required number of spaces shall be determined proportionally based on the floor area of each building occupancy.
- Installed electric vehicle supply equipment installed spaces (EVSE spaces) that exceed the minimum requirements of this section may be used to meet the minimum requirements for *EV ready spaces* and *EV capable spaces*.
- Installed *EV ready spaces* that exceed the minimum requirements of this section may be used to meet the minimum requirements for *EV capable spaces*.
- Where the number of *EV ready spaces* allocated for R-2 occupancies is equal to the number of *dwelling units* or to the number of *automobile parking spaces* allocated to R-2 occupancies, whichever is less, requirements for *EVSE spaces* for R-2 occupancies shall not apply.
- Requirements for a Group S-2 parking garage shall be determined by the occupancies served by that parking garage. Where new automobile spaces do not serve specific occupancies, the values for Group S-2 parking garage in **Table CG101.2.1** shall be used.

Exception: Parking facilities serving occupancies other than R2 with fewer than 10 *automobile parking spaces*.

TABLE CG101.2.1

REQUIRED EV POWER TRANSFER INFRASTRUCTURE

OCCUPANCY	EVSE	EV READY	EV CAPABLE SPACES	SPACES	SPACES
Group A	10%	0%	10%		
Group B	15%	0%	30%		
Group E	15%	0%	30%		

Group F	2%	0%	5%
Group H	1%	0%	0%
Group I	15%	0%	30%
Group M	15%	0%	30%
Group R-1	20%	5%	75%
Group R-2	20%	5%	75%
Groups R-3 and R-4	2%	0%	5%
Group S exclusive of parking garages	1%	0%	0%
Group S-2 parking garages	15%	0%	30%

CG101.2.2 EV capable spaces. Each *EV capable space* used to meet the requirements of

Section CG101.2.1 shall comply with the following:

- A continuous raceway or cable assembly shall be installed between an enclosure or outlet located within 3 feet (914 mm) of the *EV capable space* and electrical distribution equipment.
- Installed raceway or cable assembly shall be sized and rated to supply a minimum circuit capacity in accordance with **Section CG101.2.5**.
- The electrical distribution equipment to which the raceway or cable assembly connects shall have dedicated overcurrent protection device space and electrical capacity to supply a calculated load in accordance with **Section CG101.2.5**.
- The enclosure or outlet and the electrical distribution equipment directory shall be marked: "For electric vehicle supply equipment (EVSE)."

CG101.2.3 EV ready spaces. Each branch circuit serving *EV ready spaces* used to meet the requirements of **Section CG101.2.1**

shall comply with the following:

- Terminate at an outlet or enclosure located within 3 feet (914 mm) of each *EV ready space* it serves.
- Have a minimum system and circuit capacity in accordance with **Section CG101.2.5**.
- The electrical distribution equipment directory shall designate the branch circuit as "For electric vehicle supply equipment (EVSE)" and the outlet or enclosure shall be marked "For electric vehicle supply equipment (EVSE)."

CG101.2.4 EVSE spaces. An installed EVSE with multiple output connections shall be permitted to serve multiple *EVSE spaces*.

Each EVSE installed to meet the requirements of **Section CG101.2.1**, serving either a single *EVSE space* or multiple *EVSE spaces*, shall comply with the following:

- Have a minimum system and circuit capacity in accordance with **Section CG101.2.5**.
- Have a nameplate rating not less than 6.2 kW.
- Be located within 3 feet (914 mm) of each *EVSE space* it serves.

4. Be installed in accordance with **Section CG101.2.6**.

CG101.2.5 System and circuit capacity. The system and circuit capacity shall comply with **Sections CG101.2.5.1** and **CG101.2.5.2**.

CG101.2.5.1 System capacity. The electrical distribution equipment supplying the branch circuit(s) serving each *EV capable space*, *EV ready space* and *EVSE space* shall comply with one of the following:

- Have a calculated load of 7.2 kVA or the nameplate rating of the equipment, whichever is larger, for each *EV capable space*, *EV ready space* and *EVSE space*.

2. Meets the requirements of **Section CG101.2.5.3.1**.

CG101.2.5.2 Circuit capacity. The branch circuit serving each *EV capable space*, *EV ready space* and *EVSE space* shall comply with one of the following:

- Have a rated capacity not less than 50 amperes or the nameplate rating of the equipment, whichever is larger.

2. Meets the requirements of **Section CG101.2.5.3.2**.

CG101.2.5.3 System and circuit capacity management. Where system and circuit capacity management is selected in

Section CG101.2.5.1 or **CG101.2.5.2**, the installation shall comply with **Sections CG101.2.5.3.1** and **CG101.2.5.3.2**.

CG101.2.5.3.1 System capacity management. The maximum equipment load on the electrical distribution equipment supplying the branch circuit(s) serving *EV capable spaces*, *EV ready spaces* and *EVSE spaces* controlled by an energy management system shall be the maximum load permitted by the energy management system, but not less than 3.3 kVA per space.

CG101.2.5.3.2 Circuit capacity management. Each branch circuit serving multiple *EVSE spaces*, *EV ready spaces* or *EV capable spaces* controlled by an energy management system shall comply with one of the following:

- Have a minimum capacity of 25 amperes per space.
- Have a minimum capacity of 20 amperes per space for R-2 occupancies where all *automobile parking spaces* are *EV ready spaces* or *EVSE spaces*.

CG101.2.6 EVSE installation. EVSE shall be installed in accordance with **NFPA 70** and shall be *listed and labeled* in accordance with UL 2202 or UL 2594. EVSE shall be accessible in accordance with **Section 1107** of the *International Building Code*.

Staff Classification	Correlates Directly	Energy Standard Needed?	Other Info
	X		
Action	AS	AS/EC	DI
			X

CE#380 Adds new Appendix CH. It is not mandatory unless specifically referenced in the adopting ordinance.

Related Mods: APPENDIX CH ELECTRIC-READY COMMERCIAL BUILDING PROVISIONS

CECD1- 28-22 The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

User notes:

About this appendix: Appendix CH can be adopted where authorities having jurisdiction seek new building to be electric-ready.

SECTION CH101 GENERAL

CH101.1 Intent. The intent of this appendix is to amend the *International Energy Conservation Code* to reduce future retrofit costs by requiring *commercial buildings* with combustion equipment to install the electrical infrastructure for electric equipment.

CH101.2 Scope. The provisions in this appendix are applicable to *commercial buildings*. New construction shall comply with **Section CH103**.

SECTION CH102 DEFINITIONS

APPLIANCE. A device or apparatus that is manufactured and designed to utilize energy and for which this code provides specific requirements.

COMBUSTION EQUIPMENT. Any equipment or appliance used for space heating, service water heating, cooking, clothes drying or lighting that uses a fossil fuel.

COMMERCIAL COOKING APPLIANCES. Commercial cooking appliances used in a commercial food service establishment for heating or cooking food and which produce grease vapors, steam, fumes, smoke or odors that are required to be removed through a local exhaust ventilation system. Such appliances include deep fat fryers, upright broilers, griddles, broilers, steam-jacketed kettles, hot-top ranges, under-fired broilers (charbroilers), ovens, barbecues, rotisseries and similar appliances.

SECTION CH103

NEW COMMERCIAL BUILDING

CH103.1 Additional electric infrastructure. Electric infrastructure in *buildings* that contain combustion equipment shall be installed in accordance with this section.

CH103.1.1 Combustion space heating. Spaces containing combustion equipment for space heating shall comply with **Sections CH103.1.1.1, CH103.1.1.2 and CH103.1.1.3**

TABLE CH103.1.1

99.6% HEATING DESIGN TEMPERATURE

Greater than (°F)	Not greater than	VA/kBtu/h
50	N/A	N/A
45	50	94
40	45	100
35	40	107
30	35	115

25	30	124
20	25	135
15	20	149
10	15	164
5	10	184
0	5	210
-5	0	243
-10	-5	289
-15	-10	293

For SI: °C = [(°F) – 32]/1.8, 1 British thermal unit per hour = 0.2931 kW

CH103.1.1.1 Designated exterior locations for future electric space-heating equipment. Spaces containing combustion equipment for space heating shall be provided with designated exterior location(s) shown on the plans and of sufficient size for outdoor space-heating heat pump equipment, with a chase that is sized to accommodate refrigerant lines between the exterior location and the interior location of the space-heating equipment, and with natural drainage for condensate from heating operation or a condensate drain located within 3 feet (914 mm) of the location of the future exterior space-heating heat pump equipment.

CH103.1.1.2 Dedicated branch circuits for future electric space-heating equipment. Spaces containing combustion space-heating equipment with a capacity not more than 65,000 Btu/h (19 kW) shall be provided with a dedicated 240-volt branch circuit with ampacity of not less than 50. The branch circuit shall terminate within 6 feet (1829 mm) of the space heating equipment and be in a location with ready access. Both ends of the branch circuit shall be labeled with the words “For Future Electric Space Heating Equipment” and be electrically isolated. Spaces containing combustion equipment for space heating with a capacity of not less than 65,000 Btu/h (19 kW) shall be provided with a dedicated branch circuit rated and sized in accordance with **Section CH103.1.1.3**, and terminating in a junction box within 3 feet (914 mm) of the location the space heating equipment in a location with ready access. Both ends of the branch circuit shall be labeled

“For Future Electric Space Heating Equipment.”

Exceptions:

1. Where a branch circuit provides electricity to the space heating combustion equipment and is rated and sized in accordance with **Section CH103.1.1.3**.

2. Where a branch circuit provides electricity to space cooling equipment and is rated and sized in accordance with **Section CH103.1.1.3**.

3. Where future electric space heating equipment would require three-phase power and the space containing combustion equipment for space heating is provided with an electrical panel with a label stating “For Future Electric Space Heating Equipment” and a bus bar rated and sized in accordance with **Section CH103.1.1.3**.

4. Buildings where the 99.6 percent design heating temperature is not less than 50°F (10°C).

CH103.1.1.3 Additional space heating electric infrastructure sizing. Electric infrastructure for future electric space heating equipment shall be sized to accommodate not less than one of the following:

1. An electrical capacity not less than the nameplate space heating combustion equipment heating capacity multiplied by the value in **Table CH103.1.1**, in accordance with **Equation CH-1**.

Equation CH-1

VA_s = The required electrical capacity of the electrical infrastructure in volt-amperes. Q_{com} = The nameplate heating capacity of the combustion equipment in kBtu/h. P_s = The VA per kBtu/h from **Table CH103.1.1** in VA/kBtu/h.

2. An electrical capacity not less than the peak space heating load of the building areas served by the space heating combustion equipment, calculated in accordance with **Section C403.1.1**, multiplied by the value for the 99.6 percent design heating temperature in **Table CH103.1.1**, in accordance with **Equation CH-2**.

Equation CH-2

VA_s = The required electrical capacity of the electrical infrastructure in volt-amperes. $VA_s = Q_{com} \times P_s$ design heating load of the spaces served by the combustion equipment in kBtu/h.

P_s = The VA per kBtu/h from **Table CH103.1.1** in VA/kBtu/h.

3. An *approved* alternate design that uses no energy source other than electricity or on-site renewable energy.

CH103.1.2 Combustion service water heating Spaces containing combustion equipment for service water heating shall comply with **Sections CH103.1.2.1**, **CH103.1.2.2** and **CH103.1.2.3**.

$$VA_s = Q_{design} \times P_s$$

TABLE CH103.1.2

ALTERNATE ELECTRIC WATER HEATING EQUIPMENT CONVERSION FACTORS (VA/kBtu/h)

99.6% HEATING DESIGN TEMPERATURE		P_w
Greater than (°F)	NOT MORE THAN	VA/kBtu/h
55	60	118
50	55	123
45	50	129
40	45	136
35	40	144
30	35	152
25	30	162
20	25	173
15	20	185
10	15	293
5	10	293
0	5	293
Less than 0 °F		293

For SI: °C = [(°F) – 32]/1.8, 1 British thermal unit per hour = 0.2931 kW

CH103.1.2.1 Combustion service water heating electrical infrastructure. For each piece of combustion equipment for water heating with an input capacity of not more than 75,000 Btu/h (22 kW), the following electrical infrastructure is required:

1. An individual 240-volt branch circuit with an ampacity of not less than 30 shall be provided and terminate within 6 feet (1829 mm) of the water heater and shall be in a location with ready access.
2. The branch circuit overcurrent protection device and the termination of the branch circuit shall be labeled "For future electric water heater."
3. The space for containing the future water heater shall include the space occupied by the combustion equipment and shall have a height of not less than 7 feet (2134 mm), a width of not less than 3 feet (914 mm), a depth of not less than 3 feet (914 mm) and with a volume of not less than 700 cubic feet (20 m³).

Exception: Where the space containing the water heater provides for air circulation sufficient for the operation of a heat pump water heater, the minimum room volume shall not be required.

CH103.1.2.2 Designated locations for future electric heat pump water heating equipment. Designated locations for future electric heat pump water heating equipment shall be in accordance with one of the following:

1. Designated exterior location(s) shown on the plans, of sufficient size for outdoor water heating heat pump equipment, and with a chase that is sized to accommodate refrigerant lines between the exterior location and the interior location of the water heating equipment.
2. An interior location with a minimum volume the greater of 700 cubic feet (19 822 L) or 7 cubic feet (198 L) per 1,000 Btu/h (293 W) combustion equipment water heating capacity. The interior location shall include the space occupied by the combustion equipment.
3. An interior location with sufficient airflow to exhaust cool air from future water heating heat pump equipment provided by not fewer than one 16-inch (406 mm) by 24-inch (610 mm) grill to a heated space and one 8-inch (203 mm) duct of not more than 10 feet (3048 mm) in length for cool exhaust air.

CH103.1.2.3 Dedicated branch circuits for future electric heat pump water heating equipment. Spaces containing combustion equipment for water heating with a capacity of greater than 75,000 Btu/h (21 980 W) shall be provided with a

dedicated branch circuit rated and sized in accordance with **Section CH103.1.2.4** and terminating in a junction box within 3 feet (914 mm) of the location the water heating equipment in a location with ready access. Both ends of the branch circuit shall be labeled "For Future Electric Water Heating Equipment."

Exception: Where future electric water heating equipment would require three-phase power and the main electrical service panel has a reserved space for a bus bar rated and sized in accordance with **Section CH103.1.2.4** and labeled "For Future Electric Water Heating Equipment."

CH103.1.2.4 Additional water heating electric infrastructure sizing. Electric infrastructure water heating equipment with a capacity of greater than 75,000 Btu/h (21 980 W) shall be sized to accommodate one of the following:

1. An electrical capacity not less than the combustion equipment water heating capacity multiplied by the value in **Table CH103.1.2** plus electrical capacity to serve recirculating loads as shown in **Equation CH-3**.
2. An alternate design that complies with this code, is *approved* by the authority having jurisdiction and uses no energy source other than electricity or on-site renewable energy.

CH103.1.3 Combustion cooking.

Spaces containing combustion equipment for cooking shall comply with **Section CH103.1.3.1** or **CH103.1.3.2**.

CH103.1.3.1 Commercial cooking. Spaces containing commercial cooking appliances shall be provided with a dedicated branch circuit with a minimum electrical capacity in accordance with **Table CH103.1.3.1** based on the appliance in the space. The branch circuit shall terminate within 3 feet (914 mm) of the appliance in a location with ready access. Both ends of the branch circuit shall be labeled with the words "For Future Electric Cooking Equipment" and be electrically isolated.

$$VA_w = (Q_{capacity} \times P_w) + [Q_{recirc} \times 293(VA/(Btu/h))]$$

TABLE CH103.1.3.1
COMMERCIAL COOKING MINIMUM BRANCH CIRCUIT CAPACITY

COMMERCIAL COOKING APPLIANCE	MINIMUM BRANCH CIRCUIT CAPACITY
Range	469 VA/kBtu/h
Steamer	114 VA/kBtu/h
Fryer	200 VA/kBtu/h
Oven	266 VA/kBtu/h
Griddle	195 VA/kBtu/h
All other commercial cooking appliances	114 VA/kBtu/h

For SI: 1 British thermal unit per hour = 0.2931 kW

CH103.1.3.2 All other cooking. Spaces containing all other cooking equipment not designated as commercial cooking appliances shall be provided with a dedicated branch circuit in compliance with **NFPA 70** Section 422.10. The branch circuit shall terminate within 6 feet (1829 mm) of fossil fuel ranges, cooktops and ovens and be in a location with ready access . Both ends of the branch circuit shall be labeled with the words "For Future Electric Cooking Equipment" and be electrically isolated.

CH103.1.4 Combustion clothes drying. Spaces containing combustion equipment for clothes drying shall comply with **Section CH103.1.4.1** or **CH103.1.4.2**.

CH103.1.4.1 Commercial drying. Spaces containing clothes drying equipment and end uses for commercial laundry applications shall be provided with conduit that is continuous between a junction box located within 3 feet (914 mm) of the equipment and an electrical panel. The junction box, conduit and bus bar in the electrical panel shall be rated and sized to accommodate a branch circuit with sufficient capacity for equivalent electric equipment with equivalent equipment capacity. The electrical junction box and electrical panel shall have labels stating, "For Future Electric Clothes Drying Equipment."

CH103.1.4.2 Residential drying. Spaces containing clothes drying equipment, appliances and end uses serving multiple dwelling units or sleeping areas with a capacity less than or equal to 9.2 cubic feet (0.26 m³) shall be provided with a dedicated 240-volt branch circuit with a minimum capacity of 30 amperes, shall terminate within 6 feet (1829 mm) of fossil fuel clothes dryers and shall be in a location with ready access . Both ends of the branch circuit shall be labeled with the words "For Future Electric Clothes Drying Equipment" and be electrically isolated.

CH103.1.5 On-site transformers. Enclosed spaces and underground vaults containing on-site electric transformers on the building side of the electric utility meter shall have sufficient space to accommodate transformers sized to serve the additional electric loads identified in **Sections CH103.1.1, CH103.1.2, CH103.1.3 and CH103.1.4**.

CH103.2 Hydronic heating design requirements. For all hydronic space heating systems, the design entering water temperature for coils, radiant panels, radiant floor systems, radiators, baseboard heaters and any other device that uses hot water to provide heat to a space shall be not more than 130°F (54°C).

CH103.3 Construction documentation. The construction documents shall provide details for additional electric infrastructure,

including branch circuits, conduit, prewiring, panel capacity and electrical service capacity, as well as designated for future electric equipment.

Staff Classification	Correlates Directly	Energy Standard Number	Sub	Flag
	X			
Adoption	US	ASAC	IN	NDP
			X	

CE#381 Adds new Appendix CI. It is not mandatory unless specifically referenced in the adopting ordinance.

Related Mods:
APPENDIX CI DEMAND RESPONSIVE CONTROLS

CEAPP- 01-24 The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

User notes:

About this appendix: Appendix CI can be adopted by authorities having jurisdiction seeking demand responsive controls to be integrated into heating and cooling systems, water heating systems and lighting systems.

SECTION CI101

DEMAND RESPONSIVE HEATING AND COOLING SYSTEMS

CI101.1 Demand responsive controls. Electric heating and cooling systems shall be provided with demand responsive controls capable of executing the following actions in response to a demand response signal :

1. Automatically increasing the zone operating cooling setpoint by the following values: 1°F (0.5°C), 2°F (1°C), 3°F (1.5°C) and 4°F (2°C).
2. Automatically decreasing the zone operating heating setpoint by the following values: 1°F (0.5°C), 2°F (1°C), 3°F (1.5°C) and 4°F (2°C).

Where a demand response signal is not available, the heating and cooling system controls shall be capable of performing all other functions. Where thermostats are controlled by direct digital control including, but not limited to, an energy management system, the system shall be capable of demand responsive control and capable of adjusting all thermal setpoints to comply. The demand responsive controls shall comply with either **Section CI101.1.1** or **CI101.1.2**.

Exceptions:

1. Group I occupancies.
2. Group H occupancies.
3. Controls serving data center systems .
4. Occupancies or applications requiring precision in indoor temperature control as approved by the code official .
5. Buildings that comply with Load Management measure G02 in **Section C406.3.3**.
6. Buildings with energy storage capacity for not less than a 25 percent load reduction at peak load for a period of not less than 3 hours.

CI101.1.1 Air conditioners and heat pumps with two or more stages of control and cooling capacity of less than 65,000 Btu/h. Thermostats for air conditioners and heat pumps with two or more stages of control and a cooling capacity less than 65,000 Btu/h (19 kW) shall be provided with a demand responsive control that complies with the communication and performance requirements of **AHRI 1380**.

CI101.1.2 All other heating and cooling systems. Thermostats for heating and cooling systems shall be provided with a demand responsive control that complies with one of the following:

1. Certified **OpenADR 2.0a** VEN, as specified under Clause 11, Conformance.
2. Certified **OpenADR 2.0b** VEN, as specified under Clause 11, Conformance.
3. Certified by the manufacturer as being capable of responding to a demand response signal from a certified **OpenADR 2.0b** VEN by automatically implementing the control functions requested by the VEN for the equipment it controls.
4. **IEC 62746-10-1**.
5. The communication protocol required by a controlling entity, such as a utility or service provider, to participate in an automated demand response program.

	<div>6. The physical configuration and communication protocol of <i>ANSI/CTA 2045-A</i> or <i>ANSI/ CTA 2045-B</i>.</div> <div>SECTION C102</div> <div>DEMAND RESPONSIVE WATER HEATING</div> <div>C102.1 Demand responsive water heating. Electric storage water heaters with a rated water storage volume of 40 gallons (151 L) to 120 gallons (454 L) and a nameplate input rating equal to or less than 12 kW shall be provided with demand responsive controls in accordance with Table C102.1.</div> <div>Exceptions:</div> <div><div>1. Water heaters that provide a hot water delivery temperature of 180°F (82°C) or greater.</div><div>2. Water heaters that comply with Section IV, Part HLW or Section X of the ASME Boiler and Pressure Vessel Code.</div><div>3. Water heaters that use three-phase electric power.</div></div> <div>TABLE C102.1</div> <div>DEMAND RESPONSIVE CONTROLS FOR WATER HEATING CONTROLS</div> <div><table><tr><td>EQUIPMENT</td><td>Manufactured</td><td>on or after 7/1/2025</td></tr><tr><td>TYPE</td><td>Manufactured before 7/1/2025</td><td></td></tr><tr><td>Electric storage water heaters</td><td>AHRI Standard 1430 or ANSI/CTA-2045-B Level 1 and also capable of initiating water heating to meet the temperature setpoint in response to a demand response signal</td><td>AHRI Standard 1430</td></tr></table></div> <div>SECTION C103</div> <div>DEMAND RESPONSIVE LIGHTING CONTROLS</div> <div>C103.1 Demand responsive lighting controls. Interior general lighting in Group B, E, M and S occupancies shall have demand responsive controls complying with Section C405.2.8.1 in not less than 75 percent of the interior floor area.</div> <div>Exceptions:</div> <div><div>1. Where the combined interior floor area of Group B, E, M and S occupancies is less than 10,000 square feet (929 m²).</div><div>2. Buildings where a <i>demand response signal</i> is not available from a controlling entity other than the <i>owner</i>.</div><div>3. Parking garages.</div><div>4. Ambulatory care facilities.</div><div>5. Outpatient clinics.</div><div>6. Physician or dental offices.</div></div>	EQUIPMENT	Manufactured	on or after 7/1/2025	TYPE	Manufactured before 7/1/2025		Electric storage water heaters	AHRI Standard 1430 or ANSI/CTA-2045-B Level 1 and also capable of initiating water heating to meet the temperature setpoint in response to a demand response signal	AHRI Standard 1430							
EQUIPMENT	Manufactured	on or after 7/1/2025															
TYPE	Manufactured before 7/1/2025																
Electric storage water heaters	AHRI Standard 1430 or ANSI/CTA-2045-B Level 1 and also capable of initiating water heating to meet the temperature setpoint in response to a demand response signal	AHRI Standard 1430															
	<div>SECTION C104 REFERENCED STANDARDS</div> <div>C104.1 General. See Table C104.1 for standards that are referenced in various sections of this appendix. Standards are listed by the standard identification with the effective date, standard title, and the section or sections of this appendix that reference the standard.</div> <div>TABLE C104.1 REFERENCED STANDARDS</div> <div><table><tr><td>Staff Classification</td><td>Corrosive Directly</td><td>Energy Standard Needed</td><td>Over lap</td></tr><tr><td></td><td>A</td><td>Wetted</td><td></td></tr><tr><td>Notes</td><td>AS</td><td>ALUM</td><td>CP</td></tr><tr><td></td><td></td><td></td><td>CLC</td></tr></table></div>	Staff Classification	Corrosive Directly	Energy Standard Needed	Over lap		A	Wetted		Notes	AS	ALUM	CP				CLC
Staff Classification	Corrosive Directly	Energy Standard Needed	Over lap														
	A	Wetted															
Notes	AS	ALUM	CP														
			CLC														
CE#382	Adds new Appendix CJ. It is not mandatory unless specifically referenced in the adopting ordinance.																
Related Mods: CEPI-7- 21	<div>APPENDIX CJ ELECTRICAL ENERGY STORAGE SYSTEM</div> <div>The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.</div> <div>User notes:</div> <div>About this appendix: This voluntary appendix provides requirements for electric energy storage readiness provisions.</div> <div>SECTION C101 ELECTRICAL ENERGY STORAGE SYSTEM</div> <div>C101.1 Electrical energy storage system. Buildings shall comply with Section C101.1.1 or C101.1.2.</div> <div>C101.1.1 Electrical energy storage system (ESS) capacity. Each building shall have one or more ESS with a total rated energy capacity and rated power capacity as follows:</div> <div><div>1. ESS-rated energy capacity (kWh) ≥ 1.0 × installed on-site renewable electric energy system rated power (kWDC).</div><div>2. ESS-rated power capacity (kW) ≥ 0.25 × installed on-site renewable electric energy system rated power (kWDC).</div></div> <div>Where installed, DC-coupled battery systems shall meet the requirements for rated energy capacity alone.</div> <div>C101.1.2 Electrical energy storage system (ESS) ready. Each building shall have one or more reserved ESS-ready areas to accommodate future electrical storage in accordance with Sections C101.1.2.1 through C101.1.2.4.</div>																
STANDARD ACRONYM	STANDARD NAME	SECTIONS HEREIN REFERENCED															
AHRI 1430 (I-P)—2022	Demand Flexible Electric Storage Water Heaters (with Addendum 1)	Table C102.1															
ASME BPVC	Boiler and Pressure Vessel Code	C102.1															
	<div>C101.1.2.1 ESS-ready location. Each ESS-ready area shall be located in accordance with Section 1207 of the <i>International Fire Code</i>.</div> <div>C101.1.2.2 ESS-ready minimum area requirements. Each ESS-ready area shall be sized in accordance with the spacing requirements of Section 1207 of the <i>International Fire Code</i> and the UL 9540 or UL 9540A designated rating of the planned system. Where rated to UL 9540A, the area shall be sized in accordance with the manufacturer's instructions.</div> <div>C101.1.2.3 Electrical distribution equipment. The on-site electrical distribution equipment shall have sufficient capacity, rating and space to allow the installation of overcurrent devices and circuit wiring in accordance with NFPA 70 for future electrical ESS complying with the capacity criteria of Section C101.1.2.4.</div> <div>C101.1.2.4 ESS-ready minimum system capacity. Compliance with ESS-ready requirements in Sections C101.1.2.1 through C101.1.2.3 shall be based on a minimum total energy capacity and minimum rated power capacity as follows:</div> <div><div>1. ESS-rated energy capacity (kWh) ≥ gross conditioned floor area of the three largest floors (ft²) × 0.0008 kWh/ft².</div><div>2. ESS-rated power capacity (kW) ≥ gross conditioned floor area of the three largest floors (ft²) × 0.0002 kW/ft².</div></div> <div>SECTION C102 REFERENCED STANDARDS</div> <div>CJ102.1 General. See Table CJ102.1 for standards that are referenced in various sections of this appendix. Standards are listed by the standard identification with the effective date, standard title, and the section or sections of this appendix that reference the standard.</div> <div>TABLE CJ102.1 REFERENCED STANDARDS</div>	STANDARD NAME	SECTIONS HEREIN REFERENCED														

Staff Classification	Correlates Directly	Energy Standard Needed	Over lap	
	X			

Action	AS	AS/IC	D	D/IC
			x	

APPLIANCE. A device or apparatus that is manufactured and designed to utilize energy and for which this code provides specific requirements.

COMBUSTION EQUIPMENT. Any equipment or appliance used for space heating, *service water heating*, cooking, clothes drying, humidification or lighting that uses fuel gas or fuel oil.

PURCHASED ENERGY. Energy or power purchased for consumption and delivered to the building site.

SUBSTANTIAL IMPROVEMENT. Any repair, reconstruction, rehabilitation, alteration, *addition* or other improvement of a building or structure, the cost of which is equal to or greater than 50 percent of the market value of the structure before the improvement. Where the structure has sustained substantial damage as defined in the *International Building Code*, any repairs are considered substantial improvement regardless of the actual repair work performed. Substantial improvement does not include the following:

1. Improvement of a building required to correct health, sanitary or safety code violations ordered by the code official.
2. Alteration of a historic building where the alteration will not affect the building's designation as a historic building.

SECTION CRA103

NEW COMMERCIAL BUILDINGS

CRA103.1 Application. New commercial buildings shall be all-electric buildings and comply with Section C401.2.1 or C401.2.2.

1. *Purchased energy* other than electricity shall be permitted where it has been demonstrated to the *code official* that the building is required by an applicable law or regulation to provide space heating with an emergency power system or a standby power system.
2. *Purchased energy* shall be permitted for an emergency power system or a standby power system.

CRA103.2 Electric resistance heating equipment. The sole use of electric resistance equipment and *appliances* for space and water heating shall be prohibited other than for *buildings* or portions of *buildings* that comply with not less than one of **Sections CRA103.2.1 through CRA103.2.8**.

CRA103.2.1 Low space heating capacity. Electric resistance *appliances* or equipment shall be permitted in *buildings* or areas of *buildings* not served by a mechanical cooling system and with a total space heating capacity not greater than 4.0 Btu/h (1.2 watts) per square foot of *conditioned space*.

CRA103.2.2 Small systems. *Buildings* in which electric resistance *appliances* or equipment comprise less than 5 percent of the total system heating capacity or serve less than 5 percent of the *conditioned floor area*.

CRA103.2.3 Specific conditions. Portions of *buildings* or specific equipment and *appliances*, subject to approval, that require electric resistance heating and cannot practically be served by electric heat pumps.

CRA103.2.4 Kitchen makeup air. Makeup air for commercial kitchen exhaust systems required to be tempered by **Section 508.1.1** of the *International Mechanical Code* is permitted to be heated by electric resistance.

CRA103.2.5 Freeze protection. The use of electric resistance heat for freeze protection shall comply with **Sections CRA103.2.5.1 and CRA103.2.5.2**.

CRA103.2.5.1 Low indoor design conditions. Space heating systems sized for spaces with indoor design conditions of not greater than 40°F (4.5°C) and intended for freeze protection, including temporary systems in unfinished spaces, shall be permitted to use electric resistance. The *building thermal envelope* of any such space shall be insulated in accordance with **Section C402.1**.

CRA103.2.5.2 Freeze protection system. Freeze protection systems shall comply with Section C403.13.3.

CRA103.2.6 Preheating of outdoor air. Hydronic systems without energy recovery ventilation and that do not use freeze protection fluids shall be permitted to utilize electric resistance to temper air to not more than 40°F (4.5°C). All systems with energy recovery ventilation shall be permitted to utilize electric resistance to preheat outdoor air to defrost or temper air entering the energy recovery device and shall comply with one of the following:

1. Where the space is mechanically humidified or has a *process application* that will maintain the space above 30 percent relative humidity when the outdoor temperature is not greater than 25°F (-4°C) and the system recovers latent energy, the outdoor air shall not be preheated to greater than 25°F (-4°C).
2. For sensible-only heat recovery exchangers, outdoor air shall not be preheated to greater than 25°F (-4°C).
3. For all other systems, outdoor air shall not be preheated to greater than 5°F (-15°C).

CRA103.2.7 Small buildings. *Buildings* with a *conditioned floor area* of not more than 250 square feet (23.2 m²) and not served by a mechanical space cooling system shall be permitted to use electric resistance *appliances* or equipment for space heating.

CRA103.2.8 Supplemental heat. Electric resistance heat shall be permitted as supplemental heat where installed with heat pumps sized in accordance with **Section CRA103.3** and where operated only when a heat pump cannot provide the necessary heating energy to satisfy the *thermostat* setting.

CRA103.3 Heat pump sizing for space heating. Heat pump space heating systems shall be sized to meet the building heating load at the greater of 0°F (-18°C) or the 99 percent annual heating dry-bulb for the nearest weather station provided in the ASHRAE *Handbook of Fundamentals*. The heat pump space heating system shall not require the use of supplemental electric heat at or above this temperature other than for defrosting. Lower capacity heat pumps that operate in conjunction with thermal storage shall be permitted if the system meets the requirements of this section.

CRA103.4 Heat pump sizing for water heating. Heat pump *service heating systems* shall be sized to meet not less than the *building service water heating* load at the greater of 15°F (-9.5°C) or the 99 percent annual heating dry-bulb for the nearest weather station provided in the latest edition of the ASHRAE *Handbook of Fundamentals*. Supplemental electric heat shall not be required at or above this temperature other than for temperature maintenance in recirculating systems and defrosting.

CRA103.5 Heating outside a building. Systems for heating outside a *building* shall comply with Section C403.13.1.

CRA103.6 Low capacity cooling equipment. Air conditioners with capacities less than 240,000 Btu/h (70 kW) shall be electric heat pump equipment sized and configured to provide both space cooling and space heating.

SECTION CRA104 EXISTING COMMERCIAL BUILDINGS

CRA104.1 Combustion equipment in additions. *Additions* shall use *no purchased energy* other than electricity and new equipment installed to serve additions shall not use *purchased energy* other than electricity. Where existing systems using *purchased energy* other than electricity serve an *addition*, the *existing building* and *addition* together shall not use more *purchased energy* other than electricity than the *existing building* alone.

CRA104.2 Substantial improvement. Buildings undergoing *substantial improvements* shall be all-electric buildings, comply with

Section C402.5 and meet a site EUI by building type in accordance with ASHRAE Standard 100 Table 7-2a.

Exception: Compliance with ASHRAE Standard 100 shall not be required where *Group R* occupancies achieve an ERI score of 80 or below without *on-site renewable energy* included, in accordance with ANSI/RESNET/ICC 301, for each *dwelling unit*.

CRA104.3 Cooling equipment. New and replacement air conditioners shall be electric heat pump equipment sized and configured to provide both space cooling and space heating. Any existing

space heating systems, other than existing heat pump equipment, that serve the same *zone* as the new equipment shall be configured as supplementary heat in accordance with Section CRA104.6.

CRA104.4 Service water heating equipment. Where *water heaters* are added or replaced, they shall not use *purchased energy* other than electricity.

CRA104.5 Furnace replacement. Newly installed warm air furnaces provided for space heating shall be permitted only as supplementary heat controlled in accordance with Section CRA104.6.

CRA104.6 Heat pump supplementary heat. Heat pumps having combustion equipment or electric resistance equipment for supplementary space or *service water heating* shall have controls that limit supplemental heat operation to only those times when one of the following applies:

1. The heat pump is operating in defrost mode.
2. The vapor compression cycle malfunctions.
3. For space heating systems, the *thermostat* malfunctions.
4. For space heating systems, the vapor compression cycle cannot provide the necessary heating energy to satisfy the *thermostat* setting.
5. The outdoor air temperature is less than the design temperature determined in accordance with Section CRA103.3.
6. For *service water heating*, the heat pump *water heater* cannot maintain an output water temperature of 120°F (49°C).
7. For temperature maintenance in *service water heating* systems.

New supplementary space and *service water heating* systems for heat pump equipment shall not be permitted to have a heating output capacity greater than the heating output capacity of the heat pump equipment.

SECTION CRA105 REFERENCED STANDARDS

CRA105.1 General. See Table CRA105.1 for standards that are referenced in various sections of this resource. Standards are listed by the standard identification with the effective date, the standard title, and the section or sections of this resource that reference this standard.

TABLE
CRA105.1
REFERENCED
STANDARDS

STANDARD ACRONYM	STANDARD NAME	SECTION HEREIN REFERENCED
ASHRAE 100—2018	<i>Energy Efficiency in Existing Buildings</i>	CRA104.2
ASHRAE—2017	<i>2017 ASHRAE Handbook of Fundamentals</i>	CRA103.3
ANSI/RESNET/ ICC 301—2022	<i>Standard for the Calculation and Labeling of Energy Performance of Dwelling and Sleeping Units using an Energy Rating Index</i> — includes Addendum A, Approved July 28, 2022, and Addendum B, Approved October 12, 2022	CRA104.2

One
or
less
standards
are
referenced
directly
in this
document
or in a
document
that is
referenced
in this
document

Correlates
Directly
X AS/IC D x

Over lap D/IC

Appendix C

Green Text indicates possible increase in cost of construction Red Text indicates a reduction in construction cost. Blue text indicates no cost change, a clarification was made to the section				
Significant Changes to the 2024 IRC				
Code Section	Code Change	Explanation	Cost	Reasoning Statement - these statements are excerpts from the proposal of the change as submitted to ICC
Section R104	Duties and Powers of Building Official	This section has been reformatted to provide consistency across the I-Codes	\$0	
Section R202	Definitions	Definitions is a very needed section of the code as it is critical that everyone is talking about the same thing. There were several sections that had their own definitions in them and they were moved to this section so all of the definitions of the IRC were in one location	\$0	
Figure R301.2(2)	Ultimate Design Wind Speeds	This is a coordination effort to bring the 2024 IRC up to date with the provisions of the 2022 ASCE/SEI 7 Minimum Design Loads	Will increase the cost of construction	The adjustment to the wind speed map will be an increase for some area of the country. This currently has no effect to buildings in SD, so it will not create an increase to construction in SD
Figure R301.2(3)	Allowable Stress Design Ground Snow Loads	This section was completely revised to address the changes made in ASCE 7-22 Minimum Design Loads and Associated Criteria for Buildings. Previous editions used data for snowfall from 1952 to 1992 and this new document is based on 30 years of additional snow load data	Will increase the cost of construction	This is not a blanket increase. A more address specific approach is used to determine snow loads now that the previous broader map. As an example Sioux Falls will see an increase by going from 40 to 55 lbs. While Pierre stays the same having no effect. Example Sioux Falls increases from 40 to 55 while Pierre stays at 40
R301.2.2.10 & R301.2.2.10.1	Seismic Restraint of Appliances and Equipment	This clarifies what is required when there were sections in the code that stated "seismic forces in accordance with this code", however didn't give any guidance on how to determine what to do.	Will increase the cost of construction	This has no effect to any area to SD
R302.1	Exterior Walls	The intent of this code change is to provide townhouses without lot lines the same protection as those with lot lines by assuming a property line	\$0	
R302.3 & subsections	Two-Family Dwellings	This section has been reorganized and divided into subsections to more clearly delineate current requirements. It also recognizes that two-family homes can be either side by side or stacked units or a combination thereof.	\$0	
R302.3.5	Vertically stacked duplex's	unsprinkler units will require smoke tight construction and interlocking smokealarm between the units	This will increase the cost of construction	This is an increase cost of construction. Vertically stack duplex are at higher risk of life safety in a fire event. So higher standard of construction has been applied to these types of buildings
R303.1.1, R303.1.2 & Table R303.1.2	Spray-applied foam plastic	These sections and table were added to reference the applicable standards that govern foam plastics	\$0	
R303.2	Surface Burning Characteristics of Foam Plastic	This is just an editorial cleanup	\$0	
R306.2.1 & R306.3.2	Elevation Requirements for Flood-Resistant Construction	It will now be allowed to have wet-proofing as an option	\$0	Could lower cost of accessory structures by allowing for wet proofing options over being required to be raised above base flood plain elevation
Section R307	Storm Shelters	This section was revised to be consistent with ICC-500 & IBC Section 423	\$0	
R310.1.2	Installation of Smoke Alarms	This states that smoke alarms must be listed and installed per their listing	\$0	
R310.3.1	Smoke Alarm Installation near Cooking Appliances	This correlates what is required in the IFC and IPMIC	\$0	
R311.1.2	Installation of Carbon Monoxide Alarms	This states that smoke alarms must be listed and installed per their listing	\$0	
R313.1.2	Habitable attics and basements in existing buildings	This section was relocated to coincide with the ceiling height section to make it easier to find	\$0	One may look at this as a cost increase, but the new section allows for more usable area in a home, which previously wasn't allowed. So it could also be seen as a cost decrease by not having to design in more space for extra sleeping areas
Section R316	Sleeping Lifts	This is a new section to the IRC this code cycle. Sleeping lifts are becoming more popular and this gives guidance as to what is acceptable	\$0	
R317.6	Electric Vehicle Charging Systems	If electric vehicle charging systems are installed, this gives guidance	\$0	
R317.7	Automotive Lifts	If an automotive lift is installed, this states that they must be listed and labeled which in turn will give guidance on how said lifts are to be installed	\$0	
R318.7.5.3	Stair Nosings	An additional exception was added for clarification that a nosing projections shall be permitted to exceed 1 1/4 inches where the risers are open	\$0	
R318.7.6	Landings for Stairways	Additional exceptions were added in order to clarify requirements and add additional design options for doors leading into attached garages	\$0	
R318.7.9	Stairways in Existing Buildings	This sections specifically states that alterations to existing stairs shall not be required to comply with the requirement of new stairs where the existing space & construction does not allow a reduction in pitch or slope	\$0 or possibly a decrease	This would be a cost reduction if a jurisdiction previously required steps to be brought up to standard any time they were rebuilt.
R319.5	Replacement Emergency Escape & Rescue Openings	The wording was changed to give options for replacement windows	\$0	
R319.5.1	Window Opening Control Device & Fall Protection Device Height	This clarifies the height the window control device or fall prevention device may be installed under certain conditions	\$0	
Section R320	Handrails	In prior editions of the IRC, handrails requirements were under both the stairway and ramp sections, now it is in a new Handrail section thereby making it easier to find.	\$0	
R320.5	Continuity of Handrails	This now provides clarification for interconnection of handrail terminations	\$0	
R322.3	Accessibility for Care Facilities	This clarifies that when a private home contains a public accommodation the portions of the home used by the public must be accessible	\$0	
Section R323	Elevators and Platform Lifts	This section was added to bring attention to the contractors of the requirements for elevators	\$0	
R325.1.1 & R325.1.2	Natural Light & Natural Ventilation	This code change was purely editorial in nature and the intent was to make this easier to read and understand	\$0	
R329.6.4	Building-integrated Photovoltaic (BIPV) Systems	This section was added so it is in line with the IFC	\$0	
R329.7 and subsections	Elevated Photovoltaic (PV) Support Structures	This provides more options in construction with clear requirements for installation.	\$0	
R330.4	Energy Storage Systems Locations	This fills in the gaps for opening requirements in the envelope of fire resistive walls	Will increase the cost of construction	The cost increase is due to requirements now being applied to ESS systems installed in home. Previously these were rare and now that they are becoming more common the code needs to address the hazard they pose in a home
R330.8.1, 330.8.2 & 330.8.3	Energy Storage Systems in Garages & Impact Protection	These sections align with the requirements of the IFC. The intent is to provide clear methods for providing vehicle impact protection for solar energy systems & energy storage systems when installed	\$0	The energy storage system presents a fire hazard to the occupants of the dwelling. The code already requires a fire protective envelope around ESS but the code has left holes in this envelope, including penetrations and the door. To reduce the chance of fire spread and allow its occupants ample amount of time to evacuate the building the envelope must be sealed. This can easily be done by requiring a fire-rated door or equivalent and to seal any penetrations.
R401.4	Soil Tests in Site Class and Seismic Design Category	This will coincide with IBC Chapter 1613 and ASCE 7. Sites with questionable soils would trigger the requirement for a site-specific site response analysis to identify the applicable Site Class and Seismic Design Category.	Will increase the cost of construction	Will not effect any region of SD
Table R401.4.1(2)	Table for Properties of Soils Classification	A new column was added for USDA Textural Soil Classification, this gives the contractor another option.	\$0	
Table R403.1.2	Continuous Footing Requirements in Seismic Design Categories D _s , D ₁ , and D ₂	This table was added to make it easier for understanding and implementation	\$0	
R403.5 and subsequent Figures and Tables	Crushed Stone Footings for Cast-in Place Concrete Foundations	This allows a less material-intensive, less labor-intensive and therefore less expensive foundation option by allowing the use of crushed stone instead of concrete for footings in some situations.	\$0 or possibly a decrease	Give an option for using crushed stone as your footing when a foundation does not retain any soil. Ex. Slab on grade homes = back fill on each side of foundation wall
Crushed stone footings for wood foundations and precast concrete foundations are currently permitted in IRC Sections R403.2 and R403.4.1 respectively. There is also the well-established geotechnical practice of using crushed stone underlayment for foundations of all types. This proposal simply allows these provisions to also be used for masonry foundations and cast-in-place concrete foundations				

R502.3.3	Floor Cantilevers	This change is editorial by taking Footnotes out and put them in the actual code language. No changes are intended.	\$0		
R502.11 & subsections	Floor Framing Supporting Guards	This section was added to address the installation of guards and their attachments to the floor system.	Will increase the cost of construction	Increased requirement for Guard post floor framing supports. Also not allowing I-joist or engineered truss's to be apart of the direct support. (this was supported by the truss manufacturing industry)	By recommendation of the manufacturers of I-joists and trusses and consensus of the entire task group this proposal prohibits the use of I-joists and trusses as edge framing members supporting guards except where the effects of the guard loads are specifically considered in the design of the edge member. This is based upon the limited embedment of fasteners in the thickness of the joist and truss materials, open areas/voids, and surfaces where fasteners cannot be used that would weaken the component or connections between the truss/I-joist components.
R506.2	Post-Tensioned Slab-on-Ground Floors	This is a new section added for designing post-tensioned slabs on expansive or stable soils.	\$0		
R506.3.3	Vapor Retarder	This takes the 10-mil requirement that was put adopted in the 2021 code and reduces it back to the 6-mil requirement that was used in the previous codes	This will decrease the cost		
R507.2.1	Wood Materials	The changes in this section were brought upon to reference previous sections in the code on decay resistant lumber, creating less confusion.	\$0		
R507.2.3	Fasteners and Connectors	This section was changed to bring the terms in the footnotes to the actual code language.	\$0		
R507.2.4	Flashing	This adds language that self-adhered membranes shall comply with FGIA 711	This will increase the cost of construction	If using a self adhered membrane as flashing it is needs to be manufactured to the FGIA standard. This is a rise in the cost of material used	Self adhering membrane flashing are becoming more common, this new requirements aligns with what is required for self adhering membrane flashings that have been commonly used for window installation for many years
R507.5 & subsequent Tables	Deck Beams	Three more columns have been added which allows the beams to be sized more accurately.	This will decrease the cost in some instances		
R507.5.1, R507.5.2 & subsequent Figures	Deck Beam Bearing and Connection to Supports	This is a clarification of the existing intent of these sections	\$0	The change to the tables make deck beam sizing simpler and more clear. Cost of construction could decrease by reducing the probability of the permitting department requiring larger beams than necessary	
R507.91.3	Ledger to Band Joist Details	This clarifies the intent as the IRC is currently written	\$0		
R507.9.1.5, R507.9.1.6, R507.9.1.7 & R507.9.1.8	Ledger Flashing, Water-Resistive Barrier, Existing Walls and Exterior Wall Coverings	A deck ledger to a house band joist depends on materials that are free from decay. It is critical to ensure the band joist of the house floor system does not decay. The IRC has long required deck ledgers to be flashed to prevent the entry of water, however there was no guidance. This attempts to provide more details on how to be flashed correctly.	Will increase the cost of construction	There will be an increase in material and labor cost. Considering this change is directly related to decks the cost may be minimal as most decks are not large in size	The primary goals of this proposal are: 1)Support the variety of flashing methods currently in use. 2)Recognize the different ledger fastening methods in Section 507. Fastened in contact with the sheathing/water-resistive barrier and fastened with 1/2-inch of stacked washer spacing the ledger off the sheathing/water-resistive barrier. 3)Recognize the different cladding materials and types of installations (drainage plane, back-vented) 4)Recognize the higher risk of cutting into an existing water resistive barrier for a deck attachment. 5)Recognize that many houses do not have a water resistive barrier. 6)Protect the house framing when cladding is replaced with a deck ledger.
R602.10.3.1	Wall Height for Wood Framing	This section was added to clarify how to determine the vertical dimension of the wall height for wood stud framing.	\$0		
R602.10.6	Construction of Methods ABW, PFH, PFG, CSW-PF and BV-WSP	This section was modified to remove confusion by users on where to locate the edge of a single portal frame.	Will increase the cost of construction	With the added note: Headers shall not extend over more than one opening. Cost will increase if multiple opens are close enough together where one header could span multiple openings. By requiring extra studs for the additional long studs and also labor associated with the work	There has been confusion by users on where to locate the edge of a single portal frame when applying the braced wall panel spacing rules in R602.10.2.2. There is disagreement whether the spacing should be measured from the vertical sheathed portal located at one end, or the end of the header. Since the full length of the header is taking shear loads out of the top plate, and the purpose of the braced wall panel spacing requirements is to ensure that excessive load does not accumulate in the top plate, it makes sense that the edge of the portal is the end of the header
Table R702.7(5) & R702.7.2	Continuous Insulation on Walls Without a Vapor Retarder and Vapor Retarder Installation	The purpose of this code change was to coordinate the IRC with the IBC	\$0		
R703.2	Water-Resistive Barrier	There were 3 changes to the section. The first was to line it up with the IBC, the second give the option of foam plastic insulating sheathing to be used and the third clarifies where a water-resistive barrier is not required.	\$0		
R703.3.1	Siding Clearance at Wall and Adjacent Surfaces	This clarifies that a minimum of 6 inches is required between this siding and the ground and 1/2-inch from other surfaces.	\$0	Previously the code addressed wood siding clearances. This change now includes vinyl claddings in that 6" requirement	
R703.3.4	Minimum Fastener Length and Penetration	This is a simple clean-up of the code	\$0		
R703.6.1	Application of Wood Shakes and Shingles	This provides an alternative for horizontal furring installation	\$0	This just adds reference to current code sections ensuring compliance with how horizontal furring strips are installed	
R703.11.1.1 & R703.11.1.2	Starter Strip & Utility Trim	This is a code addition to address the requirements for starter strips and utility trim for insulated vinyl siding, vinyl siding and polynpropylene siding.	\$0		
R703.18	Fiber-mat Reinforced Cementitious Backer Units	This clarifies the this material can be used in an exterior application	\$0	This gives clarity if the manufactures installation instructions doesn't address it	
Section R704	Exterior Soffits and Fascias	This adds language on the installation for Fascias	This will increase the cost of installation	Add additional types of soffit to the list, which could require more blocking if installed on soffits wider than 24"	Over the past few cycles the treatment of exterior wall coverings and soffits has become separated and addressed in different sections of the code. R704 is now an entire section of the code dedicated to soffit and roof fascia. The construction methods for these parts of the exterior of the structure are unique and prior to the last few cycles were not addressed at all. This has been a noticeable area in need of requirements based on wind performance failures due to lack of direction. With this change in definitions and resulting other areas of the code, it will help builders, installers and building officials better understand how R704 applies and how R703 applies. These definitions create clearer understanding of application
R905.1.1 and the subsequent Tables	Underlayment, Types and Application	This adds a new ASTM Standard for synthetic underlayment's and clarifies and reorganizes existing requirements	\$0		
R905.3.6, R905.5.6, R905.6.5, R905.7.5, R905.8.6, R905.9.4, R905.10.5, R905.11.4, R905.12.4, R905.13.4, R905.14.4 & R905.16.7	Wind Resistance of Roof Coverings	This is addresses the wind limitations in the IRC for roof coverings. This is primarily a clarification	\$0		
Section 909	Roof Coatings	This is a new section that clarifies the code's requirements with the use of roof coatings	\$0		
R1001.11	Fireplace Clearance	This change clarifies what the required clearance dimensions. This matches up with Section R1001.10 on Hearth extension dimensions	\$0		
R1005.9	Factory-Built Chimney Offsets	This section was added stating that if the manufacturer's installation instructions do not address factory-built offsets, no chimney shall have an angle greater than 30 degrees and not more than 4 elbows	\$0 or possibly an increase	address' offsetting chimney's when manufactures instructions so not address the issue	
Chapter 11	Energy Efficiency	higher energy performance increases with every code cycle - some has to do with advanced technologies some has to do with upgrade in materials	Will increase the cost of construction	Codified law 11-10-7 states the 2009 IECC as a voluntary standard. Suggest removing voluntary and replacing as a required minimum standard, while also amending chapter 11 out of the IRC in SDCL 11-10-12. It is almost impossible not to build to this minimum with today's industry standards. By making it a required minimum it would give a jurisdiction a base requirement and then build from if they chose to.	
M1411.2, M1411.3, M1411.4, M1411.5, M1411.6 and M1411.7	Refrigeration Listing, Installation, Field-Installed Accessories, Signs & Identification, Charge and Group A2L Refrigerant Piping Testing	This changed emphasizes the requirements currently in the code regarding general listing and installation of mechanical equipment	\$0 because air conditioning is not required per code.		These changes give clear guidance to agencies for the safe use of the new A2L refrigerants being used in appliances
M1502.6 & M1502.6.1	Makeup Air & Closet Installation	This matches the requirements located in the IMC for clothes dryer installations	\$0		

M1504.3	Exhaust Openings	This gives clarification that the openings can be installed per the manufacturer's installation instructions and not necessarily what the code requires. It also added a section of less distance required where the exhaust opening is above a gravity air intake opening, operable windows and doors	\$0 or possibly a decrease
M1505.5 and Table M1505.5	Local Exhaust Rates and subsequent Table	This is a code clarification.	\$0
M1602.2	Return Air Openings	This gives the installer more options for the design of the return air system. Prior to this return air was not allowed to be taken from the mechanical room or closets.	\$0
M2002.4.1	Requirements for Pressure Relief Valve Discharge Piping	This is a new section as there was no guidance on how to install the discharge piping from a pressure relief	\$0 These requirements were in the manufacturer's installation instructions
G2407.1	General	This section was changed by Errata after the first printing as this was a fuel gas standard that was incorrectly updated	\$0
G2407.12	Protection from fumes and gases	This section was revised to give better clarification	\$0
G2414.6	Workmanship & Defects	This section was reformatted only	\$0
G2414.9	Metallic Piping Joints and Fittings	This section was reformatted only	\$0
G2717.7.3.1	Abandoned Fuel Gas Piping	This section was added to give guidance on what needs to be done when an abandoned gas line is brought back into service	\$0
Part VII	Plumbing	The state of SD adopts the UPC and this code is in reference to the IPC, therefore any changes to this part are not consequential.	
Part VIII	Electrical	The state of SD adopts the NEC and all single and two family homes and townhomes must meet the electrical requirements of the NEC as adopted.	
Appendixes		The appendixes are not part of the IRC and must be adopted separately.	



Home Innovation
RESEARCH LABS™

**ESTIMATED COSTS OF THE
2024 IRC CODE CHANGES**

Prepared For
National Association of Home Builders

July 2, 2024

Report No. CR1428-07022024

Disclaimer

Neither Home Innovation Research Labs, Inc., nor any person acting on its behalf, makes any warranty, expressed or implied, with respect to the use of any information, apparatus, method, or process disclosed in this publication or that such use may not infringe privately owned rights, or assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this publication, or is responsible for statements made or opinions expressed by individual authors.

This report may be distributed in its entirety, but excerpted portions shall not be distributed without prior written approval of Home Innovation Research Labs.

TABLE OF CONTENTS

Acronyms, Abbreviations, and Definitions	ii
Background	1
Methodology.....	1
Results.....	3
APPENDIX A: Cost Details of Individual Code Changes	6
APPENDIX B: Location Adjustment Factors.....	24
APPENDIX C: Reference Houses.....	25
<i>Estimated Costs of the 2015 IRC Code Changes</i>	25
Reference House Configurations	25
Reference House Features.....	26
APPENDIX D Reference House 1: One-Story Slab Foundation.....	28
APPENDIX E Reference House 2: Two-Story Slab Foundation	29
APPENDIX F Reference House 3: One-Story Basement Foundation	30
APPENDIX G Reference House 4: Two-Story Basement Foundation	31

ACRONYMS, ABBREVIATIONS, AND DEFINITIONS

ASTM	American Society for Testing and Materials
CY	Cubic yard
EA	Each
FT	Feet
HR	Hour
HVAC	Heating, ventilation, and air conditioning
ICC	International Code Council
IECC	International Energy Conservation Code
IN	Inch
IRC	International Residential Code
LB	Pound
LF	Linear feet
PSF	Pounds per square foot
SF	Square feet

BACKGROUND

The 2024 International Residential Code (IRC) includes several changes which impact construction costs for residential construction.¹ The objective of this analysis was to quantify the incremental construction cost associated with constructing a house compliant with the 2024 IRC relative to a 2021 IRC baseline. Home Innovation Research Labs (Home Innovation) estimated the expected cost impacts of selected code changes provided by the National Association of Home Builders (NAHB) using four single-family, detached reference houses. Cost estimates are aggregated in ranges of high to low based on various methods or components that might be used to comply with the code. Results are relative to the reference house characteristics and configurations; costs may vary substantially for other house designs.

This report does not address any code changes associated with energy efficiency. The energy efficiency requirements in the IRC (Chapter 11) are the same as the residential provisions in the International Energy Conservation Code (IECC). These 2024 IRC Chapter 11 code changes will be assessed separately in an upcoming report by Home Innovation.

METHODOLOGY

The characteristics of the reference houses used for this analysis are summarized below in Table 1. The reference houses and their site locations were initially defined in a report titled *Estimated Costs of the 2015 IRC Code Changes*.² The houses were selected for their similarity to new home offerings in the six metropolitan areas selected as site locations – Miami, FL, Dallas, TX, Los Angeles, CA, Seattle, WA, New York, NY, and Chicago, IL – and their size proximity to a national average of 2,607 SF. Subsequent reports added three site locations for assessing energy use: Helena, MT, Duluth, MN, and Fairbanks, AK. Additional information on the basis for the reference house configurations is provided in Appendix C. Elevations and floor plans for these reference houses are provided in Appendices D through G. These reference houses provided the basis to estimate the incremental costs or savings of the code changes for the 2024 IRC relative to the 2021 IRC.

For this study, construction costs were developed primarily based on RSMeans 2024 Residential Cost Data, using national average costs for labor and materials.³ For specific locations, the national average costs could be modified by applying the appropriate adjustment factor from RSMeans; selected location adjustment factors from RSMeans are provided in Appendix B. In some cases, costs were sourced from material suppliers, online distributor websites, or other relevant sources as applicable to the specific measure. Costs associated with testing or fees provided by an energy rater, engineer, or other third party were estimated based on an internet search of associated web sites. Cost details for individual code changes are provided in Appendix A.

Costs in the results section are reported as cost to consumer. The cost to consumer is calculated by applying a markup to the builder cost to account for builder overhead and profit. For this analysis, the cost to consumer is calculated by applying a markup of 1.182 to the builder cost.⁴

¹ International Code Council, www.iccsafe.org/Pages/default.aspx

² Estimated Costs of the 2015 Code Changes, Home Innovation Research Labs, www.homeinnovation.com/trends_and_reports/featured_reports/estimated_costs_of_the_2015_irc_code_changes

³ RSMeans, <https://www.rsmeans.com/>

⁴ Average Builder gross margin of 18.2% in 2020 as reported by NAHB in The Cost of Doing Business Study, 2022 Edition

The cost to builder represents the cost charged by the subcontractor. RSMeans provides a unit cost which includes materials, labor, installation equipment (if needed to install materials, i.e., not permanently installed equipment), subcontractor overhead (overhead burden is applied to labor cost as a markup of approximately 1.5 although this markup varies by trade) and subcontractor profit (using a 10% markup applied to all costs). For this study, where materials are sourced from national distributor websites (not RSMeans), a 10% subcontractor profit is added for consistency.

The cost details for individual code changes provided in Appendix A are reported as both cost to builder and cost to consumer.

Table 1. Features of the Reference Houses

Feature	Reference House			
	1	2	3	4
Square Feet	2,607	2,607	2,607	2,607
Foundation	Slab	Slab	Basement	Basement
Number of Stories	1	2	1	2
Number of Bedrooms	3	4	3	4
Number of Bathrooms	2	2.5	2	3
Garage, attached	2-car	2-car	2-car	2-car
Heat, Gas Furnace	Yes	Yes	Yes	Yes
Cooling, (Electric) central air	Yes	Yes	Yes	Yes
Hot Water, Gas 50 gallon tank	Yes	Yes	Yes	Yes
9 ft. Ceilings, 1 st	Yes	Yes	Yes	Yes
8 ft. Ceilings, 2 nd	n/a	n/a	Yes	Yes
Energy Star appliances	Yes	Yes	Yes	Yes
Laundry Room	Yes	Yes	Yes	Yes
Walls, 2x4 (Climate Zones 1 & 2)	Yes	Yes	n/a	n/a
Walls, 2x6 (Climate Zones 3 thru 8)	n/a	n/a	Yes	Yes
Basement, Conditioned, Unfinished	n/a	n/a	Yes	Yes
Furnace Location	Attic	Attic	Basement	Basement
Water Heater Location	Interior	Garage	Basement	Basement
Window SF/% gross wall	360/18%	315/12%	360/18%	330/12%
Roof Pitch	12/12	6/12	9/12	4/12

RESULTS

The estimated incremental construction costs of the selected code changes attributed to the reference houses are summarized in Table 2. The costs are aggregated by location and house configuration. The results are reported in ranges of “High” and “Low” based on the code changes that would typically be applicable to the reference houses in those locations. Note that where a code change results in a cost savings, the smallest savings is shown as “high” cost, and the largest savings is shown as “low” cost.

Table 3 summarizes the estimated construction costs of selected code changes that are not attributed to the reference houses and are not included in the aggregated summary. These code changes typically apply only in specific locations (e.g., hurricane-prone areas or flood zones), to items that would be an optional feature for most homes (e.g., decks), or to alternative methods of compliance. Those costs can be added to or subtracted from the aggregated costs in Table 2 as applicable to a particular location or a specific building.

The overwhelming majority of changes in the 2024 IRC not related to energy efficiency or existing buildings, identified by NAHB as significant, and provided to Home Innovation for analysis were deemed to be additional options for compliance with the code, only applicable in specific locations or cases (e.g., if a deck is constructed), or only triggered if a product or system requires the use of alternate means and methods code provisions or a registered design professional. Three significant changes were deemed applicable to most dwellings constructed under the IRC and are shown in Table 2.

Table 3 includes one code change for existing buildings. Other changes for existing buildings will be addressed in an addendum to this report.

This report does not address any code changes associated with energy efficiency. The energy efficiency requirements in the IRC (Chapter 11) are the same as the residential provisions in the International Energy Conservation Code (IECC). These 2024 IRC Chapter 11 code changes will be assessed separately in an upcoming report by Home Innovation.

Cost details for individual code changes are provided in Appendix A.

Table 2. Estimated Incremental Cost of Selected 2024 IRC Changes attributed to the Reference Houses

		Selected Cities	Miami, Dallas		LA, Seattle, New York		Chicago, Helena		Duluth, Fairbanks	
		Climate Zone	1 & 2		3 & 4		5 & 6		7 & 8	
		Reference House	1 & 2		1, 2, 3, & 4		3 & 4		3 & 4	
			Cost Range							
Ref #	Description of Change	2024 IRC Section	High	Low	High	Low	High	Low	High	Low
R-10 (RB173)	Adds requirements for framing at an open floor edge to support a guard assembly & resist rotation.	R502.11	\$459	\$0	\$459	\$0	\$156	\$0	\$156	\$0
R-11 (RB175)	Allows a 6-mil polyethylene vapor retarder under a slab-on-ground floors instead of a 10-mil vapor retarder conforming to ASTM E1745 Class A reqs.	R506.3.3	(\$472)	(\$951)	(\$472)	(\$957)	(\$472)	(\$957)	(\$472)	(\$957)
R-20 (S241.2)	Modifies the water-resistive barrier requirements for stucco in dry climates	R703.7.3	\$0	(\$1,203)	\$0	(\$1,270)	\$0	(\$1,270)	\$0	(\$1,270)
Total			(\$13)	(\$2,154)	(\$13)	(\$2,227)	(\$316)	(\$2,227)	(\$316)	(\$2,227)

Table 3. Estimated Incremental Cost of Selected 2024 IRC Changes not attributed to the Reference Houses

		Selected Cities	Miami, Dallas		LA, Seattle, New York		Chicago, Helena		Duluth, Fairbanks	
		Climate Zone	1 & 2		3 & 4		5 & 6		7 & 8	
		Reference House	1 & 2		1, 2, 3, & 4		3 & 4		3 & 4	
			Cost Range							
Ref #	Description of Change	2024 IRC Section	High	Low	High	Low	High	Low	High	Low
R-1 (ADM 13.2)	Reorganizes and expands the duties and powers of the Building Official.	R104	\$597	\$74	\$597	\$74	\$597	\$74	\$597	\$74
R-2 (RB7)	Reorganizes and updates the appendix for existing buildings; a few items are substantive.	Appendix BO	\$1,304	(\$1,332)	\$1,304	(\$1,720)	\$875	(\$1,720)	\$875	(\$1,720)
R-3 (RB44)	Modifies the table for allowable deflection under live load to exclude guards & handrails.	Table R301.7	\$0	(\$402)	\$0	(\$402)	\$0	(\$402)	\$0	(\$402)
R-4 (RB45)	Requires splices in floor, ceiling, or roof framing members not occurring over a bearing point to be designed by a registered design professional.	R502.3, R802.4.1, R802.5	\$804	\$0	\$891	\$0	\$891	\$0	\$891	\$0

R-5 (RB108)	Provides an exception that exterior stairways to grade with three or fewer risers may have a 36" wide landing provided the stairway is not serving the required egress door.	R318.7.6	\$0	(\$798)	\$0	(\$798)	\$0	(\$798)	\$0	(\$798)
R-6 (RB149)	Requires markings where BIPV systems create hidden electrical hazards.	R329.6.4	\$246	\$190	\$246	\$190	\$246	\$190	\$246	\$190
R-9 (RB165)	Adds a new column with the USDA Textural Soil Classification and indicates which soil types are unsuitable for backfill.	R401.4.1	\$0	(\$946)	\$0	(\$946)	\$0	(\$946)	\$0	(\$946)
R-12 (RB190)	Adds prescriptive requirements for deck ledger flashing and requires the water-resistive barrier to run behind the ledger.	R507.2.4, R507.9, R703.2, R703.4	\$36	\$28	\$36	\$28	\$36	\$28	\$36	\$28
R-13 (RB226)	Provides an additional method to support masonry veneer at a roof-wall intersection.	R703.8.2.2	\$0	(\$328)	\$0	(\$328)	\$0	\$0	\$0	\$0
R-15 (RM13)	Adds a compliance option for location of exhaust openings above windows and doors.	M1504.3	\$0	(\$262)	\$0	(\$262)	\$0	(\$262)	\$0	(\$262)
R-16 (RM18)	Allows taking return air for HVAC systems from bathrooms	M1602.2	\$435	\$198	\$435	\$198	\$435	\$198	\$435	\$198
R-17 (RM19)	Allows taking return air for HVAC systems from closets	M1602.2	\$1,843	\$0	\$1,843	\$0	\$1,843	\$0	\$1,843	\$0
R-18 (RM20)	Allows taking return air for HVAC systems from mechanical rooms.	M1602.2	\$0	\$0	\$244	\$0	\$244	\$0	\$244	\$0
R-19 (S240.2)	Modifies the water-resistive barrier requirements for stucco to apply to all exterior sheathing.	R703.7.3	\$684	\$369	\$750	\$369	\$750	\$394	\$750	\$394

APPENDIX A: COST DETAILS OF INDIVIDUAL CODE CHANGES

R-1: Proposal ADM13.2

IRC R104 Duties and Powers of the Building Official

Summary of Code Change:

The code change replaces the existing Section R104 with a reorganized and expanded set of duties and powers of the building official, especially regarding the alternative materials and methods provisions. While it's difficult to assess the full cost impact, two items stand out: (1) R104.2.1 allows the building official to compel the builder to provide them with a copy of the standard governing a listed product; (2) R104.2.2.6.2 allows the building official to require a signed and sealed engineering report or engineered design for an alternative product where an ICC-ES or other evaluation report is not provided.

Cost Implication of Code Change:

This code change may increase the cost of construction where applicable. Analysis is based on the cost to purchase two example standards and an estimated fee for a structural engineer to provide a report or engineered design. Costs could be higher where additional standards or engineering time are required.

Applicability of Code Change:

This code change is applicable where the building official requires a copy of a standard or an engineering report previously not required.

Table A1-1. Estimated Cost Impact of ADM 13.2: example low cost

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
ASTM E1886-19*	EA	63.00	1	1	1	1	63	63	63	63
Total to builder							63	63	63	63
Total to consumer							74	74	74	74

*ASTM E1886-19 Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems

Table A1-2. Estimated Cost Impact of ADM 13.2: example high cost

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
UL 723*	EA	505.00	1	1	1	1	505	505	505	505
Total to builder							505	505	505	505
Total to consumer							597	597	597	597

*UL 723 Test for surface burning characteristics of building materials

Table A1-3. Estimated Cost Impact of ADM 13.2: example engineer's fee

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
Structural Engineer, fee	HR	170.00	2	2	2	2	340	340	340	340
Total to builder							340	340	340	340
Total to consumer							402	402	402	402

R-2: Proposal RB7

IRC Appendix BO Existing buildings and structures

Summary of Code Change:

This code change reorganizes and updates the appendix for existing buildings. Many portions of the code change update terminology and delete provisions and pointers to requirements that are already found in the body of the code.

Cost Implication of Code Change:

The code change may increase or decrease the cost of construction. A few items in the code change are substantive. Analysis is based on the cost impact of the following items: (1) Adding a requirement to provide CO alarms where required by IRC R315.2.2; (2) Removing the requirement for a preliminary meeting with the building official and permit applicant; (3) Removing the provision allowing a building official to require an evaluation by a registered design professional for a house undergoing reconstruction; (4) Adding requirements to provide stairway illumination as well as code-compliant handrails and guards when stairs are altered; (5) Adding a requirement for a wall-mounted switch controlling lighting outlets when a room is altered; (6) Removing the requirement for wall and ceiling finishes in areas being reconstructed to comply with the flame spread and smoke development requirements of R302.9 and for area separation walls between attached dwelling units to meet R302.

Applicability of Code Change:

Individual items within this code change may be applicable for existing buildings. The total cost would only apply if all aspects of the work are required as part of the project, but in the more likely scenario where all items don't apply, the total provides a range of costs for this code change.

Table A2-1. Estimated Cost Impact of RB7

Component, by item #	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
1. Carbon monoxide detector, hardwired	EA	167.00	3	2	2	2	501	334	334	334
2. Builder/Carpenter*	HR	66.40	(1)	(1)	(1)	(1)	(66)	(66)	(66)	(66)
3. Structural Engineer fee	HR	170.00	(4)	(4)	(4)	(4)	(680)	(680)	(680)	(680)
4. Stairway lighting, handrail, guards (see details in Table A2-2 below)	EA	2,155.16	0	1	0	1	0	2,155	0	2,155
5. Switch assembly for outlet	EA	86.00	1	1	1	1	86	86	86	86
6. Cover existing interior wall paneling with 1/2" drywall (see details in Table A2-3)	SF	2.24	(432)	(324)	(504)	(486)	(968)	(726)	(1,129)	(1,089)
Total to builder							(1,127)	1,103	(1,455)	740
Total to consumer							(1,332)	1,304	(1,720)	875
*Note that a jurisdiction may charge a fee for consultation.										

Table A2-2. Estimated Cost Impact of RB7 item 4

Component	Unit	Unit Cost	Quantity	Cost
Lighting electrical circuit, 3-way switch	EA	104.50	2	209
Lighting outlet	EA	50.00	1	50
Lighting fixture	EA	85.50	1	86
Demo existing stair railing, 2 laborer crew, est.	HR	52.83	2	106
Wood stair railing*	LF	34.90	14	489
Wood stair newels	EA	239.00	2	478
Wood stair balusters	EA	28.40	26	738
Total to builder				2,155

*Based on the top of the guard is the handrail; costs could be higher if installing a handrail as a separate component.

Table A2-3. Estimated Unit Cost of RB7 item 6

Component	Unit	Unit Cost
1/2 gypsum	SF	1.69
Paint, 2 coats	SF	0.55
Total to Builder		2.24

Table A2-4. Estimated area of interior wood wall for item 6, using a Family Room, Study, Library, or Flex Room, by Reference House

Area	Unit	1	2	3	4
Wall area with interior wood paneling	SF	432	324	504	486

R-3: Proposal RB44

IRC Table R301.7 Allowable deflection of structural members

Summary of Code Change:

This code change modifies the table for allowable deflection of any structural member under live load to exclude guards and handrails.

Cost Implication of Code Change:

This code change may decrease the cost of construction where applicable. Analysis is based on a builder no longer needing to hire an engineer to calculate the deflection of wood guards for an outdoor deck and second-story guards for balconies overlooking the first floor for two-story house designs. The high cost is assumed to be zero.

Applicability of Code Change:

This code change may be applicable for houses with an outdoor deck or second-story balcony.

Table A3. Estimated Cost Impact of RB44

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Structural Engineer fee	HR	170.00	(2)	(2)	(2)	(2)	(340)	(340)	(340)	(340)
Total to builder							(340)	(340)	(340)	(340)
Total to consumer							(402)	(402)	(402)	(402)

R-4: Proposal RB45

IRC R502.3 Allowable joist spans, R802.4.1 Rafter size, and R802.5 Ceiling joists

Summary of Code Change:

This proposal requires splices in floor, ceiling, or roof framing members not occurring over a vertical support (bearing point) to be designed by a registered design professional.

Cost Implication of the Code Change:

This proposal may increase the cost of construction where applicable, e.g., because a framer cut one set of joists or rafters too short and field-framed a splice, for which the builder ends up needing to hire an engineer to run numbers and sketch a repair detail. Analysis is based on the estimated fee for a structural engineer to provide an engineered design and detail, plus an additional estimated cost to install a floor joist “sister”. The “low” cost is assumed to be zero.

Applicability of Code Change:

This code change is applicable where there are splices in floor, ceiling, or roof framing that do not occur over vertical supports.

Table A4. Estimated Cost Impact of RB45

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
Structural Engineer, fee	HR	170.00	4	4	4	4	680	680	680	680
2x10 blocking, joist sister	LF	5.89	0	6	6	6	0	35	35	35
Bolt, w/nut, washer, 3/4 dia, 4" long	EA	4.84	0	8	8	8	0	39	39	39
Total to builder							680	754	754	754
Total to consumer							804	891	891	891

R-5: Proposal RB108

IRC R318.7.6 Landings for stairways

Summary of Code Change:

This code change provides an exception that exterior stairways to grade with three or fewer risers serving a deck, porch, or patio shall have a bottom landing of not less than 36 inches, provided that the stairway is not the required access to grade serving the required egress door, i.e., instead of a landing width for the entire stair

Cost Implication of the Code Change:

This code change could decrease the cost of construction where applicable. This change may save the cost to provide concrete, pavers, or other hardscapes across the entire width of the deck, porch, or patio where it steps down to grade. Analysis is based on a 20'x14' deck with steps along one 14' side; the cost savings are estimated using a 3'x3' concrete landing instead of a 14'x3' concrete landing.

Applicability of Code Change:

This code change is applicable to exterior stairways to grade, serving deck, porch or patio, with a maximum of three risers and not serving the required egress door.

Table A5. Estimated Cost Impact of RB108

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Excavate, by hand, heavy soil	CY	99.50	(1.2)	(1.2)	(1.2)	(1.2)	(122)	(122)	(122)	(122)
Forms, slab on grade	LF	5.55	(22)	(22)	(22)	(22)	(122)	(122)	(122)	(122)
Concrete, stair landing, cast on ground	SF	13.07	(33)	(33)	(33)	(33)	(431)	(431)	(431)	(431)
Total to builder							(675)	(675)	(675)	(675)
Total to consumer							(798)	(798)	(798)	(798)

R-6: Proposal RB149

IRC R329.6.4 Building-integrated photovoltaic (BIPV) systems

Summary of Code Change:

This code change requires that markings be provided where BIPV systems (PV systems that also function as a roof covering) are installed in a manner creating areas with electrical hazards that are hidden from view. The markings must identify hazardous areas to avoid ladder placement. The markings must be visible from grade beneath the eaves. There is an exception for BIPV systems listed in accordance with UL 3741 where the removal or cutting away of portions of the BIPV system during firefighting operations have been determined to not expose a firefighter to electrical shock hazards.

Cost Implication of the Code Change:

This code change will increase the cost of construction where applicable. Analysis is based on the cost to install BIPV warning labels every 10 feet along roof eaves and rakes.

Applicability of Code Change:

This code change is applicable where BIPV systems are installed.

Table A6. Estimated Cost Impact of RB149

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
"Caution Solar Circuit" reflective label	EA	1.40	30	20	30	20	42	28	42	28
Labor to install labels	HR	66.40	2.5	2	2.5	2	166	133	166	133
Total to builder							208	161	208	161
Total to consumer							246	190	246	190

R-9: Proposal RB165

IRC R401.4.1 Geotechnical Evaluation

Summary of Code Change:

This code change relocates Table R405.1 to R401.4.1(2), adds a new column with the USDA Textural Soil Classification, and indicates which soil types are unsuitable for backfill.

Cost Implication of the Code Change:

The code change may decrease the cost of construction. This change enables the use of USDA data and textural descriptions to ensure builders select a proper soil classification where geotechnical investigation is not done, so it may save the cost of a soil test report since the USDA information is available at no cost. Analysis is based on the estimated cost savings of not needing a soil test report.

Applicability of Code Change:

This change is applicable where a soil test is no longer required.

Table A9. Estimated Cost Impact of RB165

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
Soil test report	EA	800	(1)	(1)	(1)	(1)	(800)	(800)	(800)	(800)
Total to builder							(800)	(800)	(800)	(800)
Total to consumer							(946)	(946)	(946)	(946)

R-10: Proposal RB173

IRC R502.11 Floor framing supporting guards

Summary of Code Change:

This code change adds requirements for framing at an open floor edge to support a guard assembly and resist rotation where guards are required.

Cost Implication of the Code Change:

This code change may increase the cost of construction where applicable. Analysis is based on installing one additional 2x10 at the floor edge of second floor interior openings that overlook the first floor for the reference houses, additional 2x10 blocking at guard post locations, and additional nailing of the floor sheathing. Quantities are estimates based on a review of the floors plans of the reference houses. The “low” cost will be zero for the one-story reference houses.

Applicability of Code Change:

This code change is applicable where a guard assembly is required to protect an interior opening overlooking the floor below.

Table A10-1. Estimated Cost Impact of RB173: additional 2x10, blocking, and nailing

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
Edge framing, additional 2x10	LF	3.95	0	24	0	6	0	95	0	24
Blocking, 2x10, 6' per post (posts 4' o.c.)	LF	5.27	0	48	0	18	0	253	0	95
Additional nailing of sheathing at roll brace (see details in Table A10-2)	EA	3.54	0	8		3	0	28	0	11
Total to builder							0	376	0	129
Total to consumer							0	445	0	153

Table A10-2. Estimated additional nailing of sheathing per roll brace

Component	Unit	Unit Cost	Quantity	Cost
Additional nails, 10d common bright (12 per roll brace, plus 12 at edge, approx. 58 nails/pound)	LB	5.00	0.5	2.50
Additional labor, 3/4 OSB sheathing	SF	0.52	2.0	1.04
Total to builder				3.54

Table A10-3. Estimated Cost Impact of RB173: double 2x10 vs single composite rim joist for I-joist system

Component	Unit	Unit Cost	Quantity, by Ref House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
Double 2x10 joist	LF	7.90	0	24	0	6	0	190	0	47
Composite rim joist, 1.25 x 9.5	LF	3.43		(24)		(6)		(82)		(21)
Blocking, 2x10, 6' per post (posts 4' o.c.)	LF	5.27	0	48	0	18	0	253	0	95
Additional nailing of sheathing at roll brace (see details in Table A10-2)	EA	3.54	0	8		3	0	28	0	11
Total to builder							0	389	0	132
Total to consumer							0	459	0	156

R-11: Proposal RB175

IRC R506.2.3 Vapor Retarder

Summary of Code Change:

This code change requires a minimum 6-mil polyethylene vapor retarder to be placed under slab-on-ground floors. This change reverses the change from last cycle that required a 10-mil vapor retarder conforming to ASTM E1745 Class A requirements.

Cost Implication of the Code Change:

This code change will decrease the cost of construction for all reference houses. Analysis is based on the cost savings for the reference houses including basements and garages. Note that the vapor barrier is not required for garages, but garages are included as conventional practice.

Applicability of Code Change:

This code change is applicable for all reference houses.

Table A11-1. Estimated Cost Impact of RB175

Component	Unit	Unit Cost	Quantity, by Reference House				Cost, by Reference House			
			1	2	3	4	1	2	3	4
6-mil polyethylene sheeting	SF	0.06	2,980	1,480	3,000	1,480	179	89	180	89
10-mil, ASTM E1745 Class A	SF	0.33	(2,980)	(1,480)	(3,000)	(1,480)	(983)	(488)	(990)	(488)
Total to builder							(805)	(400)	(810)	(400)
Total to consumer							(951)	(472)	(957)	(472)

Table A11-2. Slab-on-ground floor area by Reference House

Area	Unit	1	2	3	4
First floor	SF	2,600	1,080		
Garage	SF	380	400	400	400
Basement	SF			2,600	1,080
Total	SF	2,980	1,480	3,000	1,480

R-12: Proposal RB190

IRC R507.9.1.5 Ledger Flashing, R507.9.1.6 Water-resistive barrier; R703.2 Water-resistive barrier

Summary of Code Change:

This code change adds prescriptive requirements for deck ledger flashing (R507) and requires the water-resistive barrier to run behind the ledger (R507 and R703). For a deck addition, the code change may require portions of the existing siding to be removed.

Cost Implication of the Code Change:

The code change may increase the cost of construction where decks are installed. Analysis is based on the associated cost of providing a seam in the WRB just above the level of the deck ledger that will allow lapping the upper layer of the WRB over the vertical leg of the ledger flashing; the lower layer of the WRB needs to extend up far enough past the ledger to create the proper lap between upper and lower layers of the WRB. The added cost is estimated for the 20-foot long ledger of a 20' x 14' deck. A second cost is developed for an exception that permits the ledger flashing to be placed against the face of the WRB where a self-adhering membrane counterflashing is installed not less than 2 inches over the vertical leg of the flashing and not less than 2 inches onto the WRB. The costs do not address where there is a need to remove and reinstall all types of wall cladding.

Applicability of Code Change:

This code change is applicable to houses with decks.

Table A12-1. Estimated Cost Impact of RB190

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Additional house wrap	SF	0.32	42	42	42	42	13	13	13	13
Additional labor, est.	HR	66.40	0.25	0.25	0.25	0.25	17	17	17	17
Total to builder							30	30	30	30
Total to consumer							36	36	36	36

Table A12-2. Estimated Cost Impact of RB190: counterflashing exception

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Counter flashing, 6" self-adhered, 25-mil HDPE	LF	1.12	21	21	21	21	24	24	24	24
Total to builder							24	24	24	24
Total to consumer							28	28	28	28

R-13: Proposal RB226

IRC R703.8.2.2, Figure R703.8.2.2, Figure R703.8.2.2(2) (New)

Summary of Code Change:

This code change provides an additional method to support exterior masonry veneer at a roof-wall intersection. The change allows a ledger consisting of not fewer than three 2" x 6" sawn lumber members to be installed above the roof sheathing to support the steel angle and brick (formerly the only option was to install the wood ledger below the roof sheathing). This option allows using one continuous piece of flashing installed over the steel angle and ledger instead of multiple pieces of step flashing over the brick that follow the slope of the roof.

Cost Implication of the Code Change:

The code change may decrease the cost of construction where applicable. Analysis is based on the cost savings of installing continuous flashing relative to step flashing, plus some additional savings for the amount of brick veneer displaced by the wood ledger that is now above the roof deck (the size of the wood ledger is the same for either option).

Applicability of Code Change:

This code change is applicable for house designs with masonry brick veneer and any roof-wall intersections.

Table A13. Estimated Cost Impact of RB226

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Flashing, 0.019" aluminum	SF	11.29		47			0	531	0	0
Step Flashing, 0.019" aluminum	SF	14.46		(47)			0	(680)	0	0
Brick veneer, standard	SF	17.95		(16)			0	(281)	0	0
Ledger, 2x6, below roof deck	LF	3.24		47			0	152	0	0
Total to builder							0	(278)	0	0
Total to consumer							0	(328)	0	0

R-15: Proposal RM13

IRC M1504.3

Summary of Code Change:

This code change adds a compliance option for location of exhaust openings above windows and doors. The exhaust opening must be located at least 1 foot above a gravity air intake, operable window, and door (formerly the minimum separation was 3 feet).

Cost Implication of the Code Change:

The code change could decrease construction costs in some cases by reducing exhaust duct length and number of duct bends. Analysis is based on an estimated reduction in the length of kitchen and bathroom exhaust ducts. The high cost is assumed to be zero.

Applicability of Code Change:

This code change is applicable for house designs where exhaust openings no longer need to be located away from windows and doors.

Table A15. Estimated Cost Impact of RM13

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Bathroom exhaust duct, 6" flexible insulated; save 4 LF per bathroom	LF	9.28	(8)	(8)	(8)	(8)	(74)	(74)	(74)	(74)
Kitchen exhaust duct, 3.25" x 10" metal, 22 ga, 3.3 lbs/ft, save 6 LF	LB	7.45	(20)	(20)	(20)	(20)	(148)	(148)	(148)	(148)
Total to builder							(222)	(222)	(222)	(222)
Total to consumer							(262)	(262)	(262)	(262)

R-16: Proposal RM18

IRC M1602.2 Return Air Openings

Summary of Code Change:

This code change allows taking return air for HVAC systems from bathrooms (formerly prohibited).

Cost Implication of the Code Change:

This code change would increase construction costs where this option is implemented. Analysis is based on installing a ducted return in each of two bathrooms to represent the high cost. The low cost is based on installing a transfer grille in each bathroom.

Applicability of Code Change:

This code change is applicable, as an option, to all reference houses.

Table A16-1. Estimated Cost Impact of RM18: High Cost

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Return branch duct, 5" flexible insulated, 15 LF per bathroom (2 bathrooms)	LF	8.77	30	30	30	30	263	263	263	263
Return grille, 10x6	EA	52.50	2	2	2	2	105	105	105	105
Total to builder							368	368	368	368
Total to consumer							435	435	435	435

Table A16-2. Estimated Cost Impact of RM18: Low Cost

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Transfer Grille, 12"x4" Return Air Pathway	EA	83.93	2	2	2	2	168	168	168	168
Total to builder							168	168	168	168
Total to consumer							198	198	198	198

R-17: Proposal RM19

IRC M1602.2 Return Air Openings

Summary of Code Change:

This code change allows taking return air for HVAC systems from closets (formerly prohibited).

Cost Implication of the Code Change:

This code change would increase construction costs where this option is implemented. Analysis is based on installing a ducted return and a transfer grille for each closet, 5 closets per reference house.

Applicability of Code Change:

This code change is applicable, as an option, to all reference houses.

Table A17. Estimated Cost Impact of RM19

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Return branch duct, 5" flexible insulated, 20 LF per closet (5 closets)	LF	8.77	100	100	100	100	877	877	877	877
Return grille, 10x6	EA	52.50	5	5	5	5	263	263	263	263
Transfer Grille, 12"x4" Return Air Pathway	EA	83.93	5	5	5	5	420	420	420	420
Total to builder							1,559	1,559	1,559	1,559
Total to consumer							1,843	1,843	1,843	1,843

R-18: Proposal RM20

IRC M1602.3 Return Air Openings

Summary of Code Change:

This code change allows taking return air for HVAC systems from mechanical rooms (formerly prohibited).

Cost Implication of the Code Change:

This code change could increase construction costs if this option is implemented. Analysis is based on the cost to install a ducted return and a transfer grille for a mechanical room or closet, for reference houses 3 and 4 (the air handler for reference houses 1 and 2 is defined as being located in the vented attic).

Applicability of Code Change:

This code change is applicable, as an option, to houses with mechanical rooms or closets in conditioned space.

Table A18. Estimated Cost Impact of RM20

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Return branch duct, 5" flexible insulated	LF	8.77			8	8			70	70
Return grille, 10x6	EA	52.50			1	1			53	53
Transfer Grille, 12"x4" Return Air Pathway	EA	83.93			1	1			84	84
Total to builder									207	207
Total to consumer									244	244

R-19: Proposal S240.2

IRC R703.7.3 Exterior plaster (stucco)

Summary of Code Change:

This proposal modifies the water-resistive barrier requirements for stucco to apply to all exterior sheathing for stucco (formerly limited to wood-based sheathing for stucco).

Cost Implication of the Code Change:

The code change may increase the cost of construction where applicable. Analysis is based on an example case for a dwelling on a tight lot where a fire-rated wall with gypsum board sheathing is required along one side of the house. The cost is based on one additional WRB layer using drainable housewrap in dry climates (B) and a drainable layer using a drainage mat (rainscreen) in moist climates (A and C).

Applicability of Code Change:

The code change is applicable for dwellings with stucco assemblies containing non-wood-based exterior sheathing.

Table A19-1. Estimated Cost Impact of S240.2 in Dry Climates (B)

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Housewrap, drainable	SF	0.46	675	684	750	722	312	316	346	334
Total to builder							312	316	346	334
Total to consumer							369	374	410	394

Table A19-2. Estimated Cost Impact of S240.2 in Moist Climates (A and C)

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
Drainage Mat (Rainscreen), 3/16"	SF	0.85	675	684	750	722	571	579	635	611
Total to builder							571	579	635	611
Total to consumer							675	684	750	722

R-20: Proposal S241.2

IRC R703.7.3 Water-resistive barriers (Stucco), R703.7.3.1 Dry climates

Summary of Code Change:

This code change modifies the second option for water-resistive barriers for stucco in dry climates. The second option now specifically allows a means of drainage complying with Section R703.7.3.2 Moist or marine climates.

Cost Implication of the Code Change:

The code change may decrease construction costs in some cases. Analysis is based on the case where the water-resistive barrier is separated from the stucco using a drainable house wrap product with a drainage efficiency of not less than 90% (in accordance with R703.7.3.2 option 2) instead of a designed drainage space using $\frac{3}{4}$ " vertical furring.

Applicability of Code Change:

This code change is applicable for houses in dry climates with stucco exterior wall cladding.

Table A20. Estimated Cost Impact of S240.2 in Dry Climates (B)

Component	Unit	Unit Cost	Quantity by Reference House				Cost by Reference House			
			1	2	3	4	1	2	3	4
WRB, second layer, >90% drainage efficiency (e.g., Tyvek StuccoWrap)	SF	0.44	2,070	2,808	2,300	2,964	911	1,236	1,012	1,304
Furring, wood 1" x 2"	SF	0.80	(2,070)	(2,808)	(2,300)	(2,964)	(1,661)	(2,253)	(1,846)	(2,379)
Total to builder							(750)	(1,018)	(834)	(1,074)
Total to consumer							(887)	(1,203)	(985)	(1,270)

APPENDIX B: LOCATION ADJUSTMENT FACTORS

Table B1. Cost Adjustment Factor by Location*

State	City	Factor	State	City	Factor
Alabama	Birmingham	0.892	Montana	Billings	0.919
Alabama	Mobile	0.871	Nebraska	Omaha	0.922
Alaska	Fairbanks	1.163	Nevada	Las Vegas	1.067
Arizona	Phoenix	0.908	New Hampshire	Portsmouth	0.947
Arizona	Tucson	0.883	New Jersey	Jersey City	1.110
Arkansas	Little Rock	0.846	New Mexico	Albuquerque	0.898
California	San Diego	1.096	New York	Long Island City	1.279
California	Los Angeles	1.125	New York	Syracuse	0.993
California	Riverside	1.101	North Carolina	Charlotte	0.886
California	San Francisco	1.260	North Carolina	Hickory	0.853
Colorado	Boulder	0.873	North Carolina	Raleigh	0.850
Colorado	Colorado Springs	0.876	North Dakota	Fargo	0.896
Colorado	Denver	0.918	Ohio	Columbus	0.931
Connecticut	New Haven	1.062	Oklahoma	Oklahoma City	0.881
Delaware	Dover	1.051	Oklahoma	Tulsa	0.852
District of Columbia	Washington, D.C.	0.980	Oregon	Bend	0.984
Florida	Fort Meyers	0.866	Pennsylvania	Norristown	1.038
Florida	Miami	0.887	Pennsylvania	State College	0.959
Florida	Orlando	0.888	Rhode Island	Providence	1.058
Florida	Tampa	0.880	South Carolina	Greenville	0.878
Georgia	Atlanta	0.912	South Dakota	Sioux Falls	0.925
Hawaii	Honolulu	1.220	Tennessee	Memphis	0.896
Idaho	Boise	0.935	Texas	Austin	0.863
Illinois	Chicago	1.172	Texas	Dallas	0.852
Indiana	Indianapolis	0.920	Texas	Houston	0.866
Iowa	Des Moines	0.960	Texas	San Antonio	0.854
Kansas	Wichita	0.874	Utah	Ogden	0.886
Kentucky	Louisville	0.913	Utah	Provo	0.899
Louisiana	Baton Rouge	0.879	Utah	Salt Lake City	0.914
Maine	Portland	0.971	Vermont	Burlington	0.947
Maryland	Baltimore	0.959	Virginia	Fairfax	0.926
Massachusetts	Boston	1.124	Virginia	Winchester	0.883
Michigan	Ann Arbor	0.971	Washington	Tacoma	1.040
Minnesota	Minneapolis	1.067	West Virginia	Charleston	0.949
Mississippi	Biloxi	0.848	Wisconsin	La Crosse	0.950
Missouri	Springfield	0.895	Wyoming	Casper	0.905

*Source: RSMMeans *Residential Cost Data 2024*. Sample cities are listed in this table; check RSMMeans for additional locations.

APPENDIX C: REFERENCE HOUSES

The reference houses used for this analysis and their site locations were initially defined in a report titled *Estimated Costs of the 2015 IRC Code Changes*.⁵ The houses were selected for their similarity to new home offerings in the six metropolitan areas selected as site locations – Miami, FL, Dallas, TX, Los Angeles, CA, Seattle, WA, New York, NY, and Chicago, IL – and their size proximity to a national average of 2,607 SF. Subsequent reports added three site locations for assessing energy use: Helena, MT, Duluth, MN, and Fairbanks, AK. Additional information on the basis for the reference house configurations is provided below. Elevations and floor plans are provided in Appendices D through G.

Estimated Costs of the 2015 IRC Code Changes

Reference House Configurations

The four Reference House designs used in this analysis are based on the data contained in the Census Bureau report, *Characteristics of New Single-Family Construction Completed*.⁶ The report provides information about building foundation type (Table C1) and number of stories for new single-family detached construction over the previous nine-year period. (Table).

Table C1. New Construction Foundation Types

Slab	54%
Crawlspace	17%
Basement	30%

Table C2. New Construction Number of Stories

One-story	53%
Two-story	43%
Three-story	3%

The Census data supports defining the four reference houses as follows to encompass approximately 85% of the last decade's new single-family construction:

- One-story on slab foundation
- Two-story on slab foundation
- One-story on basement foundation
- Two-story on basement foundation

Table C3 covers the locations where each type of Reference House foundation would be pragmatically constructed. All these selected cities, except Chicago, lie within the top ten states for construction starts in 2013.⁷ Chicago was selected to represent a Climate Zone 5 house.

⁵ Estimated Costs of the 2015 Code Changes, Home Innovation Research Labs, www.homeinnovation.com/trends_and_reports/featured_reports/estimated_costs_of_the_2015_irc_code_changes

⁶ Characteristics of New Housing, U.S. Census Bureau, www.census.gov/construction/charts/completed.html

⁷ Housing Construction Starts, www.census.gov/construction/bps/pdf/2013statepiechart.pdf

Table C3. Sites for Reference Houses

Reference House	Climate Zone	1	2	3	4
Foundation		Slab	Slab	Basement	Basement
Miami	1	X	X		
Dallas	2	X	X		
Los Angeles	3	X	X		
Seattle	4	X	X	X	X
New York	4	X	X	X	X
Chicago	5			X	X
Fairbanks	8			X	X

Based on data from Home Innovation's 2013 Annual Builder Practices Survey⁸(ABPS), the typical Heating, Ventilation, and Air Conditioning (HVAC) systems used in new houses are summarized in Table C4. According to the ABPS, 44% of new homes are cooled with a central air conditioner. These results influenced the selection of a gas furnace with a central (electric) air conditioner as the HVAC system in each of the reference houses.

Table C4. Typical HVAC Systems Supplied with New Houses

Feature	% of Stock
Furnace or Boiler, natural gas or propane	48%
Central Air Conditioner, electric	44%
Standard Heat Pump with Backup Heat	41%
Geothermal Heat Pump	4%
Electric furnace, baseboard, or radiant	4%
Furnace or Boiler, oil	2%

The furnace location has been designated as a platform in the attic for both slab reference houses, a practice that is common in Florida and Texas, where the weather is temperate year-round, and thus, the location is practical. A house built on a slab foundation in a cold climate zone would have the HVAC and water heating equipment located within conditioned space.

Reference House Features

The statistics presented in the foregoing tables support Reference House features that are detailed in Table C5.

Table C5. Features of the Reference Houses

Feature	Reference House			
	1	2	3	4
Square Feet	2,607	2,607	2,607	2,607
Foundation	Slab	Slab	Basement	Basement
Number of Stories	1	2	1	2
Number of Bedrooms	3	4	3	4
Number of Bathrooms	2	2.5	2	3
Garage, attached	2-car	2-car	2-car	2-car
Heat, Gas Furnace	Yes	Yes	Yes	Yes
Cooling, (Electric) central air	Yes	Yes	Yes	Yes
Hot Water, Gas 50 gallon tank	Yes	Yes	Yes	Yes
9 ft. Ceilings, 1 st	Yes	Yes	Yes	Yes
8 ft. Ceilings, 2 nd	n/a	n/a	Yes	Yes
Energy Star appliances	Yes	Yes	Yes	Yes

⁸ Annual Builder Practices Survey, www.homeinnovation.com/trends_and_reports/data/new_construction

Laundry Room	Yes	Yes	Yes	Yes
Walls, 2x4 (Climate Zones 1 & 2)	Yes	Yes	n/a	n/a
Walls, 2x6 (Climate Zones 3 thru 8)	n/a	n/a	Yes	Yes
Basement, Conditioned, Unfinished	n/a	n/a	Yes	Yes
Furnace Location	Attic	Attic	Basement	Basement
Water Heater Location	Interior	Garage	Basement	Basement
Window SF/% gross wall	360/18%	315/12%	360/18%	330/12%
Cladding [removed for 2024 study]	Brick, 4 sides	Brick, 4 sides	Brick, 4 sides	Stucco
Roof Pitch	12/12	6/12	9/12	4/12

APPENDIX D REFERENCE HOUSE 1: ONE-STORY SLAB FOUNDATION



Courtesy: LionsGate Homes at The Creekside



APPENDIX E REFERENCE HOUSE 2: TWO-STORY SLAB FOUNDATION





Courtesy: Meritage Homes at Riverstone



APPENDIX F REFERENCE HOUSE 3: ONE-STORY BASEMENT FOUNDATION




Courtesy: K Hovnanian Four Seasons at New Kent Vineyards



APPENDIX G REFERENCE HOUSE 4: TWO-STORY BASEMENT FOUNDATION



Courtesy: Lennar at Sorento Estates





Home Innovation
RESEARCH LABS™