

(12) "**National Electrical Code**" means the code published by the National Fire Protection Association (2020 edition) with the following exceptions:

- (a) Sections 210.8(F) and 230.67;
- (b) Article 100 definitions - remove the new word "machinery" from the definition of "equipment";
- (c) The words "through 250-volt" are changed to ", single-phase, 15- and 20-ampere" in section 210.8(A);
- (d) Eliminate GFCI and AFCI requirement for life support equipment and like or similar equipment as determined by Authority Having Jurisdiction;
- (e) Clarify section 334.10. Uses permitted. Type NM, Type NMC, and Type NMS cables may be used in the following structures:
 - (i) One- and two-family dwellings and accessory structures;
 - (ii) Multifamily dwellings, farmsteads, and accessory structures of Types III, IV, and V construction, except as prohibited in 334.12;
 - (iii) Other structures permitted to be of Types III, IV, and V construction except as prohibited in 334.12. Cables shall be concealed within walls, floors, or ceilings that provide a thermal barrier of material that has at least a 15-minute thermal finish rating as identified in listing of fire-rated assemblies; and
- (f) The words "a zone measured 900 mm (3 ft) horizontally and 2.5 m (8 ft) vertically from the top of the bathtub rim or shower stall threshold. The identified zone is all-encompassing and shall include the space" are changed to "or" and the words "the tub" are changed to "a bathtub" in section 406.9(c);